

JUN 13 1988

In Reply Refer To:
Docket: 50-298/86-28
EA: 88-159

Nebraska Public Power District
ATTN: George A. Trevors
Division Manager - Nuclear Support
P.O. Box 499
Columbus, NE 68601

Gentlemen:

This is to confirm arrangements made with you during telephone conversations with Region IV staff on June 9 and 10, 1988, for an Enforcement Conference in the Region IV office on June 20, 1988, at 11 a.m.

The purpose of the Enforcement Conference is to discuss apparent violations and other matters regarding equipment qualification as documented in NRC Inspection Report 50-298/86-28 and our letter to you regarding this matter dated June 9, 1988. The referenced inspection report and letter were forwarded previously to you. A proposed meeting agenda is enclosed.

Should you have any questions concerning these arrangements, we will be pleased to discuss them with you.

Sincerely,

Original Signed By
A. B. Beach

8806210097 880613
PDR ADDCK 05000298
G PDR

L. J. Callan, Director
Division of Reactor Projects

Enclosure:
Proposed Agenda

cc w/enclosure:
Cooper Nuclear Station
ATTN: Guy Horn, Division Manager
of Nuclear Operations
P.O. Box 98
Brownville, Nebraska 68321

Kansas Radiation Control Program Director

Nebraska Radiation Control Program Director

RIV:DRP/C *gjh*
EHoller/cjg
6/10/88

EO *gjh*
GSA Horn
6/10/88

D:DRS *gjh*
JLM/hoan
6/10/88

DD:DRP *gjh*
ABBeach
6/13/88

~~D:DRP
LJCallan
7/1/88~~

IEAS

bcc to DMB (IE-01) - DRP

bcc distrib. by RIV:

RRI
Section Chief (DRP/C)
RPSB-DRSS
RIV File
RSTS Operator
DRS
G. F. Sanborn, EO
U. Potapovs, NRR
T. Martin, DEDRO
H. Wong, DD/OE

R. D. Martin, RA
Lisa Shea, RM/ALF
MIS System
Project Engineer, DRP/C
W. Long, NRR Project Manager
DRP
J. Lieberman, DOE
J. Taylor, DEDRO
L. Chandler, Asst. GC/OGC

PROPOSED AGENDA

Nebraska Public Power District Enforcement Conference With NRC

June 20, 1988, 11 a.m.

- | | | |
|------|--|--|
| I. | INTRODUCTION AND PURPOSE OF MEETING | A. B. Beach, Deputy Director
Division of Reactor Projects |
| II. | ENVIRONMENTAL QUALIFICATION OF
ELECTRICAL EQUIPMENT | J. L. Milhoan, Director
Division of Reactor Safety |
| | LICENSEE COMMENTS | NPPD Representative |
| | DISCUSSION | |
| | 1. Kerite 600 Volt Cable, Type HTK/FR | |
| | 2. Raychem Coaxial Cable,
Rayolin R and F | |
| | 3. Fenwal/Patel Temperature Switch
Model 01-170020-090; Thomas &
Betts Sta-kon Cable Splices | |
| | 4. Limitorque Motor Operators,
Okonite Motor Lead Splices | |
| | 5. BIW Coaxial Cable, RG59B/4 | |
| | 6. Limitorque Motor Operators,
Scotch tape and T&B sta-kon
splices | |
| | 7. Electrical Penetrations,
General Electric Co.
Model 238X600NSGI | |
| III. | ENVIRONMENTAL QUALIFICATION OF ELECTRICAL
EQUIPMENT (RESOLUTION COMPLETED OR IN
PROCESS) | J. L. Milhoan, Director
Division of Reactor Safety |
| | LICENSEE COMMENTS | NPPD Representative |
| | DISCUSSION | |
| | 1. BIW Bostrad 7E Cable | |
| | 2. Various Pressure/Level Switches
and Transmitters; mounting,
orientation, and interfaces | |

3. Microswitch Limit Switches
Models OP-N and DTE 6-2RQ62
4. ASCO Temperature Switch,
Model SA11AR and OJ 11A4R
5. ASCO Solenoid Valves, Type
HVA-90-405-2A, WPHT-8316E-36,
and NP-1
6. Barksdale Pressure Switch,
Model B2TM1255 and B2T-A1SS
7. Rosemount Transmitters
Model 1153 Series B;
1153D B/1159DP,
with Remote Seal System
8. Static-O-Ring Pressure
Switches, TA Series
9. GE Motor, Model 5X6346XC74A
and 5X6346XC84A

IV. LICENSEE CLOSING COMMENTS

NPPD Representative

V. NRC CLOSING COMMENTS

A. B. Beach/J. L. Milhoan