

TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

May 16, 1986

WILLIAM G. COUNCIL
EXECUTIVE VICE PRESIDENT

Mr. Eric H. Johnson, Director
Division of Reactor Safety and Projects
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76012

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
DIESEL GENERATOR CONTROLS
SDAR: CP-86-15 (INTERIM REPORT)

Dear Mr. Johnson:

On March 14, 1986, we verbally notified your Mr. T. F. Westerman of a deficiency involving the field flash and K1 relays which are required to operate during the starting process of the diesel generators. This is an interim report of a potentially reportable item under the provisions of 10CFR50.55(e). We have submitted an interim report logged TXX-4764, dated April 14, 1986.

We are continuing our evaluation and anticipate submitting our next report by June 18, 1986.

Very truly yours,

W.G. Council
W. G. Council

JCH/anh

c - NRC Region IV (0 + 1 Copy)

Director, Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8605280019 860516
PDR ADOCK 05000445
S PDR

*IE27
1/0*