



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 8, 2020

LICENSEE: Exelon Generation Company, LLC

FACILITY: Nine Mile Point Nuclear Station, Unit 1

SUBJECT: SUMMARY OF MAY 8, 2020, MEETING WITH EXELON GENERATION COMPANY, LLC REGARDING PROPOSED EMERGENCY LICENSE AMENDMENT REQUEST INVOLVING CONTROL ROOM AIR TREATMENT SYSTEM (EPID L-2020-LLA-0103)

On May 8, 2020, a telephone conference was held between the U.S. Nuclear Regulatory Commission (NRC) and representatives of Exelon Generation Company, LLC (Exelon, the licensee). The purpose of the meeting was to discuss Exelon's plan to submit a license amendment request (LAR) involving the control room air treatment system at Nine Mile Point Nuclear Station (Nine Mile Point), Unit 1, under emergency circumstances per Section 50.91(a)(5) of Title 10 of the *Code of Federal Regulations*. Because of emergency circumstances, the telephone conference was not noticed as a public meeting. A list of attendees is enclosed.

During the telephone conference, the licensee described (1) the circumstances causing the need for the proposed emergency LAR, (2) the proposed change to the technical specifications (TSs), (3) the compensatory measures the licensee planned to implement, and (4) the date the proposed LAR would be submitted and requested date for the NRC staff to complete the review of the LAR.

According to Exelon, on May 3, 2020, a fan motor in the control room air treatment system failed. Because of the failed fan motor, the licensee is required by Nine Mile Point, Unit 1, TS Limiting Condition for Operation (LCO) 3.4.5.e to restore the system to operable within 7 days. Exelon stated that the failure was unpredictable and there were no indications of degraded performance prior to the failure. Because efforts to restore the system to operable could exceed the required time in LCO 3.4.5.e, the licensee planned to request an extension to that time. The licensee described several compensatory measures that it would include in the proposed LAR. The licensee requested that the NRC staff complete the review of the proposed LAR by the morning of May 10, 2020. Because the failure was unpredictable and the proposed change was needed within 2 days, the licensee believed that it met the criteria for emergency circumstances.

Subsequent to the telephone conference, the licensee informed the NRC staff that it was able to restore the system to operable within the time required by Nine Mile Point, Unit 1, TS LCO 3.4.5.e. Thus, Exelon no longer needed to request a change to the Nine Mile Point, Unit 1, TSs and did not submit the proposed LAR to the NRC.

No members of the public were in attendance except for representatives from the State of New York. No public meeting feedback forms were received.

Please direct any inquiries to me at 301-415-2871 or Michael.Marshall@nrc.gov.

/RA/

Michael L. Marshall, Jr., Senior Project Manager
Plant Licensing Branch I
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-220

Enclosure:
List of Attendees

cc: Listserv

LIST OF ATTENDEES

MAY 8, 2020, MEETING WITH EXELON GENERATION COMPANY, LLC

NINE MILE POINT NUCLEAR STATION, UNIT 1

PROPOSED EMERGENCY LICENSE AMENDMENT REQUEST

INVOLVING CONTROL

ROOM AIR TREATMENT SYSTEM

Name	Organization
Campbell, Tison	U.S. Nuclear Regulatory Commission (NRC)
Carfang, Erin	NRC
Danna, James	NRC
Gamin, Kayla	NRC
Hsueh, Kevin	NRC
Jones, Steve	NRC
Karipineni, Nageswara	NRC
Marshall, Michael	NRC
Parillo, John	NRC
Sienel, Beth	NRC
Stock, Gregory	NRC
Frymire, Bridget	State of New York
Peterson, Alyse	State of New York
Bartolini, Pat	Exelon Generation Company, LLC (Exelon)
Gardner, Shane	Exelon
Geiss, Ben	Exelon
Gudger, David	Exelon
Massari, John	Exelon
Mattessich, Kevin	Exelon
Rafferty-Czincila, Shannon	Exelon
Shultz, Brandon	Exelon
Tryt, Nick	Exelon
Villar, Rick	Exelon
Williams, Christian	Exelon
Wolniak, Denise	Exelon

Enclosure

SUBJECT: SUMMARY OF MAY 8, 2020, MEETING WITH EXELON GENERATION COMPANY, LLC REGARDING PROPOSED EMERGENCY LICENSE AMENDMENT REQUEST INVOLVING CONTROL ROOM AIR TREATMENT SYSTEM (EPID L-2020-LLA-0103) DATED JUNE 8, 2020

DISTRIBUTION:

PUBLIC
PM File Copy
RidsNrrDorlLpl1
RidsRgn1MailCenter
RidsACRS_MailCTR
RidsNrrLALRonewicz
RidsNrrPMNineMilePoint
RidsNrrDssScpb
RidsNrrDraArcb
JParillo, NRR
NKaripineni, NRR
TCampbell, OGC
KGamin, OGC
MMcCoppin, OEDO
OLopez-Santiago, OEDO
CdeMessieres, NRR
LBetancourt, NRR
ECarfang, R-I
SJones, NRR
BSienel, R-I
GStock, R-I

ADAMS Accession No.: ML20157A182

OFFICE	DORL/LPL1/PM	DORL/LPL1/LA	DORL/LPL1/BC	DORL/LPL1/PM
NAME	MMarshall	LRonewicz	JDanna (JPoole for)	MMarshall
DATE	06/08/2020	06/08/2020	06/08/2020	06/08/2020

OFFICIAL RECORD COPY