



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
REGION I
2100 RENAISSANCE BLVD., SUITE 100
KING OF PRUSSIA, PENNSYLVANIA 19406-2713

July 1, 2020

Mr. Bryan C. Hanson
Senior Vice President
Exelon Generation Company, LLC
President and Chief Nuclear Officer
Exelon Nuclear
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: LIMERICK GENERATING STATION, UNITS 1 AND 2 – INFORMATION
REQUEST TO SUPPORT TRIENNIAL BASELINE DESIGN-BASIS CAPABILITY
OF POWER-OPERATED VALVES INSPECTION; INSPECTION REPORT
05000352/2020014 AND 05000353/2020014

Dear Mr. Hanson:

The purpose of this letter is to notify you that the U.S. Nuclear Regulatory Commission (NRC) Region I staff will conduct a team inspection at your Limerick Generating Station, Units 1 and 2. Amar Patel, a Senior Reactor Inspector from the NRC's Region I Office, will lead the inspection team. The inspection will be conducted in accordance with Inspection Procedure 71111.21N.02, "Design-Basis Capability of Power-Operated Valves Under 10 CFR 50.55a Requirements," dated July 26, 2019 (ADAMS Accession No. ML19067A240).

The inspection will assess the reliability, functional capability, and design bases of risk-important power-operated valves (POVs) as required by Title 10 of the *Code of Federal Regulations* (10 CFR) 50.55a, and Appendix A and B requirements. The inspectors will select a sample of POVs based on risk insights, safety significance, and operating margin.

During a telephone conversation on June 30, 2020, with Mr. Charles Wheeler, a member of your Limerick staff, we confirmed arrangements for an information gathering site visit and the two-week onsite inspection. The schedule is as follows:

- Information gathering visit: Week of August 17, 2020
- Onsite weeks: Weeks of September 14 and September 28, 2020

The purpose of the information gathering visit is to meet with members of your staff and to become familiar with your programs and procedures intended to ensure compliance with 10 CFR 50.55a for POVs. The lead inspector will discuss aspects of the programs including any specific applicable regulatory commitments made by your facility and your use of NRC Regulatory Guides or industry standards. Frank Arner, a Region I Senior Risk Analyst, will support Amar Patel during the information-gathering visit to review probabilistic risk assessment data and identify the final POV samples to be examined during the inspection.

Experience with previous design basis team inspections of similar depth and length has shown this type of inspection is resource intensive, both for NRC inspectors and licensee staff. In

order to minimize the inspection impact on the site and to ensure a productive inspection for both parties, we have enclosed a request for information needed for the inspection.

Insofar as possible, this information should be provided electronically to the lead inspector at the NRC Region I office by August 10, 2020. Additional documents may be requested during the information gathering visit and/or during team preparation week (the week prior to the first onsite inspection week). The inspectors will minimize your administrative burden by specifically identifying only those documents required for the inspection.

If there are any questions about the inspection or the material requested in the enclosure, please contact the lead inspector at 610-337-5220 or via e-mail at amar.patel@nrc.gov.

This letter does not contain new or amended information collection requirements subject to the Paperwork Reduction Act of 1995 (44 U.S.C. 3501 et seq.). Existing information collection requirements were approved by the Office of Management and Budget, Control Number 3150-0011. The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a currently valid Office of Management and Budget Control Number.

This letter and its enclosure will be made available for public inspection and copying at <http://www.nrc.gov/reading-rm/adams.html> and at the NRC Public Document Room in accordance with 10CFR Part 2.390, "Public Inspections, Exemptions, Requests for Withholding."

Thank you in advance for supporting this resource intensive but important engineering inspection.

Sincerely,

X /RA/

Signed by: Melvin K. Gray

Mel Gray, Chief
Engineering Branch 1
Division of Reactor Safety

Docket Nos. 05000352 and 05000353
License Nos. NPF-39 and NPF-85

Enclosure:
Document Request for Power-Operated
Valves Inspection

cc: Distribution via ListServ®

SUBJECT: LIMERICK GENERATING STATION, UNITS 1 AND 2 – INFORMATION
REQUEST TO SUPPORT TRIENNIAL BASELINE DESIGN-BASIS CAPABILITY
OF POWER-OPERATED VALVES INSPECTION; INSPECTION REPORT
05000352/2020014 AND 05000353/2020014 DATED JULY 1, 2020

DISTRIBUTION:

DLew, RA (R1ORAMAIL Resource)
RLorson, DRA (R1ORAMAIL Resource)
DCollins, DRP (R1DRPMAIL Resource)
BWellington, DRP (R1DRPMAIL Resource)
JYerokun, DRS (R1DRSMAIL Resource)
PKrohn, DRS (R1DRSMAIL Resource)
JGrieves, DRP
LCasey, DRP
JPatel, DRP, SRI
SHaney, DRP, RI
NEsch, DRP, AA
OLopez-Santiago, RI OEDO
RidsNrrPMLimerick Resource
RidsNrrDorlLpl1 Resource

DOCUMENT NAME: G:\DRS\Engineering Branch 2\Patel A\Limerick POV\Limerick DBAI - POV Request for Information Letter.docx
ADAMS ACCESSION NUMBER: ML20183A319

<input checked="" type="checkbox"/> SUNSI Review		<input checked="" type="checkbox"/> Non-Sensitive <input type="checkbox"/> Sensitive		<input checked="" type="checkbox"/> Publicly Available <input type="checkbox"/> Non-Publicly Available	
OFFICE	RI/DRS	RI/DRS			
NAME	APatel	MGray			
DATE	6/30/20	7/1/20			

OFFICIAL RECORD COPY

DOCUMENT REQUEST FOR POWER-OPERATED VALVES INSPECTION

Inspection Report: 05000352/2020014 and 05000353/2020014

Onsite Inspection Dates: September 14 through September 18, 2020; and
September 28 through October 2, 2020

Inspection Procedure: Inspection Procedure 71111.21N.02, Design-Basis Capability of
Power-Operated Valves Under 10 CFR 50.55a Requirements

Lead Inspector: Amar Patel, Senior Reactor Inspector
610-337-5220
amar.patel@nrc.gov

I. Information Gathering Visit

During this visit, we plan to obtain sufficient insights to finalize POV samples for this inspection. We would like to meet with POV specialists to discuss the upcoming inspection and our sample selection process. The primary valve types to be reviewed for this inspection include motor-operated valves (MOVs) and air-operated valves (AOVs); and additional valve types include hydraulic-operated valves (HOVs), solenoid-operated valves (SOVs), and pyrotechnic-actuated (squib) valves. During this visit, the lead inspector will (a) discuss the scope of the planned inspection; (b) identify additional information needed to review in preparation for the inspection; (c) ensure that the information to be reviewed is available at the beginning of the inspection; and (d) verify that logistical issues will be identified and addressed prior to the team's arrival. Please reserve a room during the site visit with a telephone, wireless internet access, and a licensee computer with access to procedures, corrective action program documents, and a printer.

II. Information Requested for Selection of Power-Operated Valves

The following information is requested by August 10, 2020, to facilitate inspection preparation. Feel free to contact the lead inspector if you have any questions regarding this information request. Please provide the information electronically in "pdf" files, Excel, or other searchable formats, preferably on some portable electronic media (e.g., CD-ROM, DVD). The files should contain descriptive names, and be indexed and hyperlinked to facilitate ease of use. Information in "lists" should contain enough information to be easily understood by someone who has knowledge of light water reactor technology and POVs.

1. A word-searchable Update Final Safety Analysis Report. If not available in a single file per unit, please ensure a collective table of contents is provided.
2. Site (and corporate if applicable) procedures associated with implementation of the MOV program required by 10 CFR 50.55a(b)(3)(ii) and/or ASME OM Code Mandatory Appendix III; and site (corporate) procedure for AOV program.
3. Site response(s) to NRC Generic Letter (GL) 95-07, Pressure Locking and Thermal Binding of Safety-Related Power-Operated Gate Valves.

Enclosure

DOCUMENT REQUEST FOR POWER-OPERATED VALVES INSPECTION

4. Site evaluation of NRC Information Notice 2012-14, MOV Inoperable due to Stem-Disc Separation.
5. List of corrective action documents related to the MOV and AOV programs since 9/2015 (include document No., title/short description, date).
6. List of corrective action documents related to each of the 30 POVs listed below since 9/2015 (include document No., title/short description, date).
7. List of significant modifications, repairs, or replacement of safety related POVs completed since 9/2015, including date completed (include document No., title, date completed).
8. Any self-assessments or quality assurance type assessments of the MOV/AOV programs (performed since 9/2015).
9. Most recent POV (e.g., MOV, AOV, SOV) program health report, if available.
10. List and electronic copy of all Emergency Operating Procedures.
11. List of Abnormal Operating Procedures.
12. Identify the edition of the ASME Operation and Maintenance of Nuclear Power Plants (OM Code) that is the Code of Record for the current 10-year Inservice Test Program interval, as well as any standards to which the station has committed with respect to POV capability and testing.
13. For each of the following MOVs, provide the information listed in the table below (further information on what/how to provide was discussed during the June 30th phone call with Mr. Charles Wheeler).

Containment Atmospheric Control, FV-DO-101A
Containment Atmospheric Control, HV-57-163
High Pressure Coolant Injection, HV-55-1F002
High Pressure Coolant Injection, HV-55-1F003
High Pressure Coolant Injection, HV-55-2F001
High Pressure Coolant Injection, HV-55-2F004
Reactor Core Isolation Cooling, HV-49-2F008
Reactor Core Isolation Cooling, HV-49-1F013
Reactor Core Isolation Cooling, HV-50-2F045
Reactor Water Clean-Up, HV-44-1F004
Residual Heat Removal, HV-51-1F014B
Residual Heat Removal, HV-51-1F017B
Residual Heat Removal, HV-51-1F068B
Residual Heat Removal Service Water, HV-12-032A
Residual Heat Removal Service Water, HV-12-032C
Residual Heat Removal, HV-51-2F014A
Residual Heat Removal, HV-51-2F015A
Residual Heat Removal, HV-C-51-2F048A

DOCUMENT REQUEST FOR POWER-OPERATED VALVES INSPECTION

Item	Parameter/Information*
1	MOV Identification
2	Safety Function
3	Valve manufacturer, type, and size
4	Actuator manufacturer, type, and size
5	Motor manufacturer, type (AC/DC), and size
6	Valve ASME Class
7	Risk Significance
8	Control Switch Trip (CST) Application (Close/Open)
9	Design-Basis Differential Pressure (DBDP) and Flow (Close/Open)
10	Rising-Stem Valve: Assumed Valve Factor (VF)
11	Quarter-Turn Valve: Assumed bearing torque coefficient
12	Assumed Stem Friction Coefficient (SFC)
13	Assumed Load Sensitive Behavior (LSB) (%)
14	% Uncertainties (e.g., diagnostic equipment, CST repeatability, etc.)
15	Calculated Required Thrust/Torque (Close/Open)
16	Least Available Output (e.g., actuator, CST, rating, spring pack, weak link)
17	Test Conditions (e.g., fluid differential pressure (DP), system pressure, flow, and temperature; ambient temperature; and motor voltage) (Close/Open)
18	Thrust and torque required to overcome dynamic conditions (Close/Open)
19	Rising-Stem Valve: Measured VF (Close/Open)
20	Rising-Stem Valve: Available VF (Close/Open)
21	Measured SFC (Close/Open)
22	Measured LSB (%)
23	Quarter-Turn Valve: Measured bearing torque coefficient (Close/Open)
24	Determined % Margin (Close/Open)
25	<i>Basis for Design-Basis Capability:</i>
25.a	Dynamic test performed at design-basis DP/flow conditions
25.b	Extrapolation of dynamic test data
25.c	Justification from normal operation at or above design-basis conditions
25.d	Industry dynamic test methodology (such as EPRI MOV PPM)
25.e	Grouped with similar valves dynamically tested at plant
25.f	Grouped with similar valves dynamically tested at other plants
25.g	Valve qualification testing (such as ASME QME-1-2007)
25.h	Other (such as large calculated margin)
<i>*Specify Not Applicable (NA) as appropriate</i>	

14. For each of the following AOVs, provide the information listed in the table below.

Emergency Service Water, HV-11-041
 Emergency Service Water, HV-11-047
 Emergency Service Water, HV-11-123
 Nuclear Boiler, HV-41-1F022C
 Nuclear Boiler, HV-41-1F028D
 Reactor Core Isolation Cooling, FV-50-113
 Containment Atmospheric Control, HV-57-204
 Containment Atmospheric Control, HV-57-221
 Control Rod Drive Hydraulic, XV-47-2F181
 Emergency Service Water, HV-11-201H

DOCUMENT REQUEST FOR POWER-OPERATED VALVES INSPECTION

Item	Parameter/Information*
1	AOV Identification
2	Safety Function
3	Fail safe position (open/close)
4	Valve manufacturer, type, and size
5	Actuator manufacturer, type, and size
6	Valve ASME Class
7	Risk Significance
8	Design-Basis Differential Pressure (DBDP) and Flow (Close/Open)
9	Rising-Stem Valve: Assumed Valve Factor (VF)
10	Quarter-Turn Valve: Assumed bearing torque coefficient
11	% Uncertainties (e.g., diagnostic equipment, CST repeatability, etc.)
12	Calculated Required Thrust/Torque (Close/Open)
13	Minimum allowable air pressure (Beginning/End Stroke)
14	Maximum allowable air pressure (Beginning/End Stroke)
15	Minimum allowable spring preload (Beginning/End Stroke)
16	Maximum allowable spring preload (Beginning/End Stroke)
17	Least Available Actuator Output (e.g., actuator capability, actuator limit, valve weak link limitation)
18	Test Conditions (e.g., fluid differential pressure (DP), system pressure, flow, and temperature; and ambient temperature) (Close/Open)
19	Thrust and torque required to overcome dynamic conditions (Close/Open)
20	Rising-Stem Valve: Measured VF (Close/Open)
21	Quarter-Turn Valve: Measured bearing torque coefficient (Close/Open)
22	Determined Margin (%) (Least margin for air stroke operation, spring stroke operation, maximum spring load, and structural capability)
23	<i>Basis for Design-Basis Capability:</i>
24.a	Dynamic test performed at design-basis DP/flow conditions
24.b	Extrapolation of dynamic test data
24.c	Justification from normal operation at or above design-basis conditions
24.d	Industry dynamic test methodology
24.e	Grouped with similar valves dynamically tested at plant
24.f	Grouped with similar valves dynamically tested at other plants
24.g	Valve qualification testing (such as ASME QME-1-2007)
24.h	Other (such as large calculated margin)
<i>*Specify Not Applicable (NA) as appropriate</i>	

15. For each of the following miscellaneous POVs, provide the information listed in the table below.

Core Spray SV-52-239
Standby Liquid Control XV-48-2F004C

Item	Parameter/Information*
1	Safety Function
2	Fail safe position (open/close/as-is)
3	Valve manufacturer, type, and size
4	Actuator manufacturer, type, and size
5	Valve ASME Class
6	Risk significance

DOCUMENT REQUEST FOR POWER-OPERATED VALVES INSPECTION

7	Design-basis differential pressure and flow (close/open)
8	Minimum required Voltage at the POV
9	Available voltage at the POV
10	Environmental Qualification harsh environment (Y/N)
11	Normally energized (Y/N)
12	Time in service
<i>*Specify Not Applicable (NA) as appropriate</i>	