June 8, 1988

Docket No.: 50-344

Mr. David W. Cockfield Vice President, Nuclear Portland General Electric Company 121 S.W. Salmon Street Portland, Oregon 97204

Dear Mr. Cockfield:

SUBJECT: GENERIC LETTER 88-03, "STEAM BINDING OF AUXILIARY FEEDWATER PUMPS" (TAC NO. 67284)

On February 17, 1988, Generic Letter 88-03 was issued and requested all licensees of operating PWRs and holders of construction permits for PWRs to confirm that appropriate procedures are in place, and will be maintained, to minimize the occurrence of steam binding of the auxiliary feedwater (AFW) system each shift during times when the system is required to be operable, and recognizing steam binding and restoring the AFW to operable status should steam binding occur.

Your response dated May 24, 1988 confirmed that you have in place, and will maintain, the necessary procedures. Thus, your response to Generic Letter 88-03 is satisfactory and no further action is necessary.

Sincerely,

original signed by

Terence L. Chan, Project Manager Project Directorate V Division of Reactor Projects - III, IV, V and Special Projects Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION		
Docket File	TChan	
NRC & Local PDRs	OGC-White	Flint
PD5 Reading	EJordan	
DCrutchfield	JPartlow	
GHoluhan	ACRS (10)	
JLee	LOIshan	
DRSP/PDV ORSP/D:PD TChan:dr Gyknighto 6/7/88 6/9/88		
OFFICIAL RECORD COPY		
PDR ADICK 05	30608 2000344 PDR	

June 8, 1988

Docket No.: 50-344

Mr. David W. Cockfield Vice President, Nuclear Portland Genera! Electric Company 121 S.W. Salmon Street Portland, Oregon 97204

Dear Mr. Cockfield:

SUBJECT: GENERIC LETTER 88-03, "STEAM BINDING OF AUXILIARY FREDWATER PUMPS" (TAC NO. 67284)

On February 17, 1988, Generic Letter 88-03 was issued and requested all licensees of operating PWRs and holders of construction permits for PWRs to confirm that appropriate procedures are in place, and will be maintained, to minimize the occurrence of steam binding of the auxiliary feedwater (AFW) system each shift during times when the system is required to be operable, and recognizing steam binding and restoring the AFW to operable status should steam binding occur.

Your response dated May 24, 1988 contirmed that you have in place, and will maintain, the necessary procedures. Thus, your response to Generic Letter 88-03 is satisfactory and no further action is necessary.

Sincerely,

original signed by

Terence L. Chan, Project Manager Project Directorate V Division of Reactor Projects - III, IV, V and Special Projects Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION Docket File NRC & Local PDRs PD5 Reading DCrutchfield GHolahan	TChan OGC-White Flint EJordan JPartlow ACRS (10)
JLee	LOIshan
fle 1	

DRSP/PDV TChan:dr 6/ 7/88 GVKnighton 6/ g /88

OFFICIAL RECORD COPY



## UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

June 8, 1988

Docket No.: 50-344

Mr. David W. Cockfield Vice President, Nuclear Portland General Electric Company 121 S.W. Salmon Street Portland, Oregon 97204

Dear Mr. Cockfield:

SUBJECT: GENERIC LETTER 88-03, "STEAM BINDING OF AUXILIARY FEEDWATER PUMPS" (TAC NO. 67284)

On February 17, 1988, Generic Letter 88-03 was issued and requested all licensees of operating PWRs and holders of construction permits for PWRs to confirm that appropriate procedures are in place, and will be maintained, to minimize the occurrence of steam binding of the auxiliary feedwater (AFW) system each shift during times when the system is required to be operable, and recognizing steam binding and restoring the AFW to operable status should steam binding occur.

Your response dated May 24, 1988 confirmed that you have in place, and will maintain, the necessary procedures. Thus, your response to Generic Letter 88-03 is satisfactory and no further action is necessary.

Sinceret

Terence L. Chan, Project Manager Project Directorate V Division of Reactor Projects - 111, IV, V and Special Projects Office of Nuclear Reactor Regulation

cc: See next page

Mr. David W. Cockfield Portland General Electric Company

## cc:

.

. .

Senior Resident Inspector U.S. Nuclear Regulatory Commission Trojan Nuclear Plant Post Office Box O Rainier, Oregon 97048

Mr. Michael J. Sykes, Chairman Board of County Commissioners Columbia County St. Helens, Oregon 97501

Mr. William T. Dixon Oregon Department of Energy Salem, Oregon 97310

Regional Administrator, Region V U.S. Nuclear Regulatory Commission 1450 Maria Lane, Suite 210 Walnut Creek, California 94596 Trojan Nuclear Plant