



# PECO NUCLEAR

A Unit of PECO Energy

**Michael P. Gallagher, P.E.**  
Plant Manager  
Limerick Generating Station

PECO Energy Company  
Limerick Generating Station  
PO Box 2300  
Sanatoga, PA 19464-0920  
610 718 2000

10CFR50.73  
Tech Spec 6.9.2

May 19, 1999  
Docket No. 50-352  
License No. NPF-39

U.S. Nuclear Regulatory Commission  
Attn.: Document Control Desk  
Washington, DC 20555

SUBJECT: Licensee Event Report  
Limerick Generating Station - Unit 1

This LER reports Reactor Protection System (RPS) and Primary Containment and Reactor Vessel Isolation Control System (PCRVICES) actuations that resulted from a loss of feedwater flow due to the spurious tripping of a breaker that supplies power to position indication to the inlet valves to the deep bed condensate demineralizer system.

This LER also contains Special Report information for the High Pressure Coolant Injection and Reactor Core Isolation Cooling system injections into the reactor vessel in response to the loss of feedwater event described above.

Reference: Docket No. 50-352  
Report Number: 1-99-003  
Revision Number: 00  
Event Date: April 20, 1999  
Report Date: May 19, 1999  
Facility: Limerick Generating Station  
P.O. Box 2300, Sanatoga, PA 19464

This LER is being submitted pursuant to the requirements of 10CFR50.73(a)(2)(iv). The Special Report information is being submitted pursuant to Technical Specifications Reporting Requirement 6.9.2, as required by Technical Specifications Actions 3.7.3.b and 3.5.1.f.

Very truly yours,

cc: H. J. Miller, Administrator Region I, USNRC  
A. L. Burritt, USNRC Senior Resident Inspector, LGS

11  
IE22

9905280180 990519  
PDR ADOCK 05000352  
S PDR