

May 27, 1986

Docket No. 50-309

Mr. J. B. Randazza  
Executive Vice President  
Maine Yankee Atomic Power Company  
83 Edison Drive  
Augusta, Maine 04336

Distribution:	<b>Docket File</b>
NRC & L PDRs	PBD-8 Files
PSears	PKreutzer
TBarnhart 4	OELD
FMiraglia	ACRS 10
WJones	JPartlow
BGrimes	LFMB
OPA	LHarmon
EJordan	WRegan
EButcher	

Dear Mr. Randazza:

The Commission has issued the enclosed Amendment No. 89 to Facility Operating License No. DPR-36 for the Maine Yankee Atomic Power Station. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated April 23, 1985 as supplemented October 7, 1985.

This amendment adds additional manual containment isolation valves and blowdown and body vent valves on instrument lines to the list of manual containment isolation valves that may be repositioned under administrative control without taking specific compensatory measures. This will permit flow testing of post accident hydrogen purge and analysis systems, as well as obtaining containment atmospheric samples of analysis.

A copy of the Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's next regular bi-weekly Federal Register notice.

Sincerely,

/s/

Patrick M. Sears, Project Manager  
PWR Project Directorate #8  
Division of PWR Licensing-B

Enclosures:

1. Amendment No. 89 to DPR-36
2. Safety Evaluation

cc w/enclosures:  
See next page

PBD#8:DL  
PKreutzer  
5/7/86

PSears  
5/19/86

AT  
PBD#8:DL  
ATHadani  
5/20/86

OELD  
5/12/86