

APPENDIX A

NOTICE OF VIOLATION

Portland General Electric Company  
Trojan Nuclear Plant

Docket No. 50-344  
License No. NPF-1

As a result of the inspection conducted on August 22-26, 1988, and in accordance with the "General Policy and Procedures for NRC Enforcement Actions," 10 CFR 50, Part 2, Appendix C (1985), the following violation was identified:

10 CFR 50.48 required the licensee to install emergency lighting units with at least an 8 hour battery power supply in all areas needed for operation of safe shutdown equipment, and in access and egress routes thereto, in accordance with section III.J of Appendix R to 10 CFR 50. According to the licensee's May 20, 1987 letter to the NRC, the licensee completed implementation of required emergency lighting modifications prior to startup from the last refueling outage.

Contrary to the above, as of August 23, 1988, there were no 8 hour battery power supply emergency lighting units installed in the following areas needed for operation of safe shutdown equipment and in access and egress routes thereto:


- A. On the south wall and west of the Intake Structure in support of manual actions.
- B. At the designated fire hydrant east of the Circulating Water Pump Pit in support of manual actions.
- C. In the Circulating Water Pump Pit at the pump discharge and suction valves in support of manual actions.

This is considered a severity level IV violation (Supplement No. 1.0).

Pursuant to the provisions of 10 CFR 2.201, Portland General Electric Company is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Regional Administrator, Region V, within 30 days of the date of the letter transmitting this Notice. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation if admitted, (2) the corrective steps that have been taken, and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause why

the license should not be modified, suspended or revoked or why such other action as may be proper should not be taken. Consideration may be given to extending the response time for good cause shown.

FOR THE NUCLEAR REGULATORY COMMISSION

 FOR  
Robert J. Pate, Chief  
Reactor Safety Branch

Dated this 20<sup>TH</sup> day of October, 1988  
at Walnut Creek, California.