NUREG-0020 Vol. 12, No. 5 May 1988

LICENSED OPERATING REACTORS

STATUS SUMMARY REPORT

DATA AS OF 04-30-88

UNITED STATES NUCLEAR REGULATORY COMMISSION



8806230155 880630 PDR NUREG 0020 R PDR

Available from

· 2.52

NRC/GPO Sales Program

Superintendent of Documents Government Printing Office Washington, D. C. 20402

A year's subscription consists of 12 issues for this publication.

Single copies of this publication are available from National Technical Information Service, Springfield, VA 22161

Microfiche of single copies are available from NRC/GPO Sales Program Washington, D. C. 20555

÷

NUREG-0020 Vol. 12, No. 5 May 1988

LICENSED OPERATING REACTORS

STATUS SUMMARY REPORT

DATA AS OF 04-30-88

Manuscript Completed: June 1988 Date Published: June 1988

OFFICE OF ADMINISTRATION AND RESOURCES MANAGEMENT U.S. NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555



STATEMENT OF PURPOSE

The U.S. Nuclear Regulatory Commission's monthly LICENSED OPERATING REACIORS Status Summary Report provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Information Resources Management, from the Headquarters Staff of NRC's Office of Inspection and Enforcement, from NRC's Regional Offices, and from utilities. Since all of the data concerning operation of the units is provided by the utility operators less than two weeks after the end of the month, necessary corrections to published information are shown on the ERRATA page.

This report is divided into three sections: the first contains monthly highlights and statistics for commercial operating units, and errata from previously reported data; the second is a compilation of detailed information on each unit, provided by NRC Regional Offices, IE Headquarters and the Utilities; and the third section is an appendix for miscellaneous information such as spent fuel storage capability, reactor years of experience and non-power reactors in the United States.

The percentage computations, Items 20 through 24 in Section 2, the verdor capacity factors on page 1-7, and <u>actual</u> vs. <u>potential</u> energy production on Page 1-2 are computed using actual data for the period of consideration. The percentages listed in power generation on Page 1-2 are computed as an arithmetic average. The factors for the life-span of each unit (the "Cumulative" column) are reported by the utility and are not entirely re-computed by NRC. Utility power production data is checked for consistency with previously submitted statistics.

It is hoped this status report proves informative and helpful to all agencies and individuals interested in analyzing trends in the nuclear industry which might have safety implications, or in maintaining an awareness of the U.S. energy situation as a whole.

TABLE OF CONTENTS

	PAGE
GLOSSARY INDEX TO LICENSED UNITS	ii vii

SECTION 1 - CURRENT DATA SUMMARIES

MONTHLY HIGHLIGHTS OF COMMERCIAL NUCLEAR POWER UNITS	1-2
Licensed Power Reactors	1-2
Power Generation	1-2
Actual vs. Potential Energy Production	1-2
Dutage Data	1-2
Reasons for Shutdown	1-3
Derated Units	1-3
Shutdowns Greater Than 72 Hours Each	1-3
UNIT AVAILABILITY, CAPACITY, AND FORCED OUTAGE RATE PLOT	1-4
AVERAGE DAILY PONER LEVEL FOR ALL COMMERCIAL OPERATING UNITS	1-5
AVERAGE CAPACITY FACTORS BY VENDOR	
Vendor Plot	1-6
Statistics	1-7
MEMORANDA - SPECIAL INFORMATION	1-8
ERRATA - CORRECTIONS TO PPEVIOUSLY REPORTED DATA	1-9

SECTION 2 - OPERATING POWER REACTORS

ARKANSAS	1	THROUGH	ZION	2		
For each		eactor:				

2-002 through 2-477

or each reactor: Operating Status Average Daily Power Level (MWe) Plot

Unit Shutdowns/Reductions Summary

Facility Data Inspection Status Licensee Reports

SECTION 3 - APPENDIX

STATUS OF SPENT FUEL STORAGE CAPABILITY	3-2
REACTOR-YEARS OF OPERATION	3-6
NON-POWER REACTORS IN THE U.S.	3-7

GLOSSARY

AVERAGE DAILY POWER LEVEL (MWg)	The net electrical energy generated during the day (measured from 0001 to 2400 hours inclusive) in megawatts hours, divided by 24 jours.
LICENSED THERMAL POWER (MWt)	The maximum thermal power of the reactor authorized by the NRC, expressed in megawatts.
DATE OF COMMERCIAL OPERATION	Date unit was declared by utility owner to be available for the regular production of electricity; usually related to satisfactory completion of qualification tests as specified in the purchase contract and to accounting policies and practices of utility.
DESIGN ELECTRICAL RATING (DER) (NET MWe)	The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.
FORCED OUTAGE	An outage required to be initiated no later than the weekend following discovery of an offnormal condition.
FORCED OUTAGE HOURS	The clock hours during the report period that a unit is unavailable due to forced outages.
GROSS ELECTRICAL ENERGY GENERATED (MWH)	Electrical output of the unit during the report period as measured at the output terminals of the turbine generator, in megawatts hours.
GROSS HOURS	The clock hours from the beginning of a specified situation until its end. For outage durations, the clock hours during which the unit is not in power production.
GROSS THERMAL ENERGY GENERATED	The thermal energy produced by the unit during the report period as measured or computed by the licensee in megawatt hours.
HOURS GENERATOR ON-LINE	Also, "Unit Service Hours." The total clock hours in the report period during which the unit operated with breakers closed to the station bus. These hours added to the total outage hours experienced by the unit during the report period, shall equal the hours in the report period.
HOURS IN REPORTING PERIOD	For units in power ascension at the end of the period, the gross hours from the beginning of the period or the first electrical production, whichever comes last, to the end of the period.
	For units in commercial operation at the end of the period, the gross hours from the beginning of the period or of commercial operation; whichever comes last, to the end of the period or decommissioning, whichever comes first.

PAGE II

GLOSSARY (continued)

HOURS REACTOR CRITICAL	The total clock hours in the report period during which the reactor sustained a controlled chain reaction.
MAXIMUM DEPENDABLE CAPACITY (GROS5) (MDC Gross) (Gross MWe)	Dependable main-unit gross capacity, winter or summer, whichever is smaller. The dependable capacity varies because the unit efficiency varies during the year due to cooling water temperature variations. It is the gross electrical output as measured at the output terminals of the turbine generator during the most restrictive seasonal conditions (usually summer).
MAXIMUM DEPENDABLE CAPACITY (NET) (MDC Net) (Net MWe)	Maximum Dependable Capacity (Gross) less the normal station service loads.
NAMEPLATE RATING (Gross MWe)	The nameplate power designation of the generator in megavolt amperes (MVA) times the nameplate power factor of the generator. NOTE: The nameplate rating of the generator may not be indicative of the maximum or dependable capacity, since some other item of equipment of a lesser rating (e.g., turbine) may limit unit output.
NET ELECTRICAL ENERGY GENERATED	Gross electrical output of the unit measured at the output terminals of the turbine generator during the reporting period, minus the normal station service electrical energy utilization. If this quantity is less than zero, a negative number should be recorded.
OUTAGE	A situation in which no electrical production takes place.
OUTAGE DATE	As reported on Appendix D of Reg. Guide 1.16, the date of the start of the outage. If continued from a previous minth, report the same outage date but change "Method of Shutting Down Reactor" to "4 (continuations)" and add a note: "Continued from previous month."
OUTAGE DURATION	The Total clock hours of the outage measured from the beginning of the report period or the outage, whichever comes last, to the end of the report period or the outage, whichever comes first.
OUTAGE NUMBER	A number unique to the outage assigned by the licensee. The same number is reported each month in which the outage is in progress. One format is "76-05" for the fifth outage to occur in 1976.
PERIOD HOURS	See "Hours in Reporting Period."
POWER REDUCTION	A reduction in the Average Daily Power Level of more than 20% from the previous day. All power reductions are defined as outage of zero hours durations for the purpose of computing unit service and availability factors, and forced outage rate.

GLOSSARY (continued)

REACTOR AVAILABLE HOURS	The Total clock hours in the report period during which the reactor was critical or was capable of being made critical. (Reactor Reserve Shutdown Hours + Hours Reactor Critical.)
REACTOR AVAILABILITY FACTOR	Reactor Available Hours x 100 Period Hours
REACTOR RESERVE SHUTDOWN	The cessation of criticality in the reactor for administrative or other similar reasons when operation could have been continued.
REACTOR RESERVE SHUTDOWN HOURS	The total clock hours in the report period that the reactor is in reserve shutdown mode. NOTE: No credit is given for NRC imposed shutdowns.
REACTOR SERVICE FACTOR	Hours Reactor Critical x 100 Period Hours
REPORT PERIOD	Usually, the preceding calender month. Can also be the preceding calendar year, (Year-to-Date), or the life-span of a unit (cumulative).
RESTRICTED POWER LEVEL	Maximum net electrical generation to which the unit is restricted during the report period due to the state of equipment, external conditions, administrative reasons, or a direction by NRC.
SCHEDULED OUTAGE	Planned removal of a unit from service for refueling, inspection, training, or maintenance. Those outages which do not fit the definition of "Forced Outage" perforce are "Scheduled Outages."
STARTUP AND POWER ASCENSION TEST PHASE	Period following initial criticality during which the unit is tested at successively higher levels, culmin- ating with operation at full power for a sustained period and completion of warranty runs. Following this phase, the utility generally considers the unit to be available for commercial operation.
UNIT	The set of equipment uniquely associated with the reactor, including turbine generators, and ancillary equipment, considered as a single electrical energy production facility.
UNIT AVAILABLE HOURS	The total clock hours in the report period during which the unit operated on-line or was capable of such operation. (Unit Reserve Shutdown Hours + Hours Generator On-Line.)

GLOSSARY (continued)

UNIT AVAILABILITY FACTOR

Unit Available Hours x 100 Period Hours

UNIT CAPACITY FACTORS

*	Using L	licensed Thermal Power	Gross Thermal Energy Generated x 100 Period Hours x LIC. Thermal Power
-	Using M	Nameplate Rating	Gross Electrical Energy Generated x 100 Period Hours x Nameplate Rating
-	Using [DER	Net Electrical Energy Generated x 100 Period Hours x DER
-	Using M	MDC Gross	Gross Electrical Energy Generated x 100 Period Hours x MDC Gross
-	Using M	MDC Net	Net Electrical Energy Generated x 100 Period Hours x MDC Net

NOTE: if MDC GROSS and/or MDC NET have not been determined, the DER is substituted for this quantity for Unit Capacity Factor calculations.

UNIT FORCED OUTAGE RATE	Forced Outage Hours × 100 Unit Service Hours * Forced Outage Hours
UNIT RESERVE SHUTDOWN	The removal of the unit from on-line operation for economic or other similar reasons when operation could have been continued.
UNIT RESERVE SHUTDOWN HOURS	The total clock hours in the report period during which the unit was in reserve shutdown mode.
UNIT SERVICE FACTOR	Unit Service Hours x 100 Period Hours
UNIT SERVICE HOURS	See "Hours Generator On-Line."

NOTE:

At the end of each statement in the Enforcement Summary for any given facility may be found numbers in parentheses. These numbers are related to the inspection, e.g., 8111 (the 11th inspection of the plant in 1981); and the severity level, e.g., 4 (severity level IV). Violations are ranked by severity levels from I through V with level I being the most serious. The severity level is used in the determination of any resulting enforcement action. Gray Book lists severity level by Arabic numbers corresponding to the Roman numerals. Details on the various severity levels and enforcement actions can be found in Appendix C to 10 CFR Part 2 published in the Federal Register of March 9, 1982 pages 9987 through 9995, and as corrected April 14, 1982.



INDEX TO OPERATING POWER REACTORS

PAGE

PAGE

ADVANCES A	0.000	HOUTTOFLLO	a a//
AKKANSAS I	2-002	MUNIICELLO	2-246
ARKANSAS 2	2-006	NINE MILE POINT 1	2-252
BEAVED VALLEY 4	2-010	NTHE MILE DOTHE 2	2-256
DEAVER VALLET I	2 010	NINE DILL FUINT &	2 230
BEAVER VALLEY Z	2-014	NORTH ANNA 1	2-260
BIG ROCK PCINT 1	2-018	NORTH ANNA 2	2-264
REATDWOOD 1	2-022	OCONFE 1	2-268
BRAIDHOOD I	2 022	OCONCE I	2 200
BROWNS FERRY 1	2-028	OCONEE Z	2-212
BROWNS FERRY 2	2-034	OCONEE 3	2-276
REDUNS FERRY 3	2-060	OYSTER CREEK 1	2-280
POINCHTCK 4	2-064	DALTCADEC	2 200
DRUNDWICK 1	2-040	PALIJADES	2-204
BRUNSWICK 2	2-050	PALO VERDE 1	2-288
BYRON 1	2-054	PALO VERDE 2	2-292
BYRON 2	2-058	PALO VERDE 3	2-206
DIRON &	2 0 0 0	PALO VERDE J	2 270
CALLAWAY 1	2-062	PLACH BUITUM Z	2-200
CALVERT CLIFFS 1	2-066	PEACH BOTTOM 3	2-304
CALVERT CLIEFS 2	2-070	PERRY 1	2-308
CATALIRA	2-076	DTLODTM 4	2-212
CATANDA 1	2-074	FILGKIN I	6-316
CATAWBA 2	2-078	POINT BEACH 1	2-316
CLINTON 1	2-082	POINT BEACH 2	2-320
COOK 1	2-086	PRATRIE ISLAND 1	2-326
COOK 1	2 000	PRATRIC ISCHID I	2 729
LUOK Z	2-090	FRAIRIE ISLAND Z	2-328
CCOPER STATION	2-094	QUAD CITIES 1	2-332
CRYSTAL RIVER 3	2-100	QUAD CITIES 2	2-336
DAVIC-RESSE 1	2-106	PANCHO SECO 1	2-360
DIADLO CANYON A	2 104	DIVED DEND 4	2 340
DIADLU CANTUN I	2-110	KIVEK BEND I	2-240
DIABLO CANYON 2	2-116	ROBINSON 2	2-350
DRESDEN 2	2-122	SALEM 1	2-354
DDECDEN Z	2-128	CALEM 2	2.758
DREDDEN D	2-120	SALEM C	2-330
DUANE ARNOLD	2-154	SAN UNOFRE 1	2-362
FARLEY 1	2-138	SAN ONOFRE 2	2-368
FARLEY 2	2~144	SAN ONDERE 3	2-374
CEDMI 2	2-150	SEDUDYAL 1	2-278
FERMI C	2-150	SEQUUTAR 1	2-310
FITZPATRICK	2-156	SEQUOYAH Z	2-384
FORT CALHOUN 1	2-160	SOUTH TEXAS 1	2-390
FORT ST VRAIN	2-164	ST LUCIE 1	2-396
CTHUR	2-1/2	ST LUCIE 2	2-708
GINNA	2-100	ST LUCIE E	2-390
GRAND GULF 1	2-172	SUMMER 1	2-402
HADDAM NECK	2-176	SURRY 1	2-406
HARRIS 1	2-180	SURRY 2	2-410
HATCH A	2.100	CUCOUCASUNA 4	3 646
HAICH 1	2-104	SUSAUEHANNA I	2-010
HATCH Z	2-188	SUSQUEHANNA Z	2-420
HOPE CREEK 1	2-192	THREE MILE ISLAND 1	2-424
INDIAN POINT 2	2-196	TROIAN	2-628
THOTAN DOTHE 7	2-200	THOREY DOTHE T	2-676
INDIAN FUINT 5	2-200	TURKET FUINT 5	2-434
KENAUNEE	2-204	TURKEY POINT 4	2-440
LASALLE 1	2-208	VERMONT YANKEE 1	2-446
145 11 F 2	2-212	VOGTLE 1	2-450
I THEOTOP 4	2 214	UACHTHOTON MUCIEAD 2	2 154
LINCKICK	2 210	MASHINGTON NUCLEAR 2	2-434
MAINE YANKEE	2-220	WATERFORD 3	2-458
MCGUIRE 1	2-224	WOLF CREEK 1	2-462
MCGUIRE 2	2-230	YANKEE-ROWE 1	2-466
MILLSTONE 1	2-236	7108 1	2-670
MILLSTONE 1	2 234	2101 1	2-470
MILLSTONE Z	2-238	210N 2	2-414
MILLSTONE 3	2-242		



MONTHLY HIGHLIGHTS

XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX	105 IN COMMER (a) 2 IN POWER (b)107 LICENSED (c) 2 LICENSED AND LOW	CIAL OPERATION	91,45 2,37 	3 CAPACITY MWe (Ne 0 - 3 TOTAL	Based upon maximum dependable capacity; design elec. rating used if MDC not determined
(a)BRAIDWOOD SOUTH TEX	MDC NET 1 1120 (b) AS 1 1250	Excludes these plants licensed for operation which are shut down indefinitely or permanently	1. DRESDEN 1 2. HUMBOLDT BAY 3. TMI 2 4. LACROSSE	DER 200 (c) BRAID 65 SHORE 50	DATE DER WOOD 2 12/18/87 1120 HAM 07/03/85 820
*********** * POWER * * GENERATION * ****	1. GROSS ELECTR 2. NET ELECTRIC 3. AVG. UNIT SE 4. AVG. UNIT AV 5. AVG. UNIT CA 6. AVG. UNIT CA 7. FORCED OUTAG	ICAL (MWHE) AL (MWHE). RVICE FACTOR (%). AILABILITY FACTOR (%). PACITY FACTOR (MDC) (%) PACITY FACTOR (DER) (%) E RATE (%).	REPORT MONT 41,969,866 39,859,342 65.1 65.1 65.1 61.6 60.3 9.5	H PREVIOUS MONTH 46,072,264 43,781,511 69.4 69.4 65.5 63.9 10.3	YEAR-TO-DATE 179,152,154 170,319,709 69.7 69.7 66.0 64.5 11.6
************* * ACTUAL VS. * * POTENTIAL * * ENERGY * * PRODUCTION *	 ENERGY ACTUA ENERGY NOT P ENERGY NOT P ENERGY NOT P 	LLY PRODUCED DURING THIS RODUCED DUE TO SCHEDULED RODUCED DUE TO FORCED OU RODUCED FOR OTHER REASON	S REPORT PERIOD D OUTAGES (NET) UTAGES (NET)	39,859,342 NET .16,983,094 MWHe . 6,680,446 MWHe . 2,235,488 MWHe	25.8 10.2 3.4
POTENTIAL ENERGY	PRODUCTION 'N T 5. ENERCY NOT P 6. ENERGY NOT P	HIS PERIOD BY UNITS IN C (Using Maximum Depen RODUCED DUE TO NRC-REQUI RODUCED DUE TO NRC RESTR	COMMERCIAL OPERATION Idable Capacity Net IRED OUTAGES RICTED POWER LEVELS	65,758,370 МИНе МИНе МИНе	100.02 TOTAL 3 UNIT(S) WITH NRC RESTRICTION
************* * OUTAGE * * DATA *	1. FORCES OUTAG 2. SCHEDULED OU	ES DURING REPORT PERIOD TAGES DURING REPORT PERI	NUMBER HO 6,8 0D. 44 6,8 0D. 47 19,4 TOTAL 91 26,3	PERCENT OF URS CLOCK TIME 49.7 9.1 78.3 25.8 	MWHE LOST PRODUCTION 6,680,446 16,983,094 23,663,540

MWHE LOST PRODUCTION = Down time X maximum dependable capacity net

Report Period APR 1988

PAGE 1-2

MONTHLY HIGHLIGHTS

************ * REASONS * * FOR * * SHUTDOWNS * ****	A - Equipment Fa B - Maintenance C - Refueling . D - Regulatory R E - Operator Ira F - Administrati G - Operational H - Other	ilure or Test . estriction ining & Li ve Error	cense Examinati	on	TOTAL	MBER HOURS LOST 28 1,959.3 15 3,128.4 28 15,513.4 0 0.0 1 260.8 8 3,607.5 3 120.8 8 1,757.8 91 26,328.0			
*********** * DERATED * * UNITS * *****	BYRON 1 BYRON 2 COOK 1 COOK 2 FORT ST VRAIN PEACH BOTTOM 2 PEACH BOTTOM 3 ROBINSOM 2 SAN ONOFRE 1	MDC (MWe Net) POW 1120 1 1120 1 1020 1060 330 1051 1055 665 436	ER 097 055 920 864 271 0 420 390	LIMIT (MH	e Net) TYP Self-imp Self-imp Self-imp Self-imp NRC Rest NRC Rest Self-imp Self-imp	E osed osed osed riction riction riction osed osed		
************* * SHUTDOWNS * * GREATER * * THAN 72 HRS * * EACH * ****	UNIT ARKANSAS 2 BROWNS FERRY 3 CALVERT CLIFFS 1 COOK 2 DRESDEN 3 HATCH 1 LASALLE 1 NINE MILE POINT 1 PALO VERDE 2 POINT BEACH 1 SAN ONOFRE 1 SURRY 1 TURKEY POINT 4	REASON C C C C B,H C C C H C C A	UNIT BIG ROCK POINT BRUNSWICK 2 CALVERT CLIFFS COOPER STATION FARLEY 1 HATCH 2 LIMERICK 1 OCONEE 2 PEACH BOTTOM 2 QUAD CITIES 2 SAN ONOFRE 2 SURRY 2 VOGTLE 1	1 2	REASON C C C C H B C C C C B A A	UNIT BROWNS FERRY 1 BYRON 1 CATAWBA 2 DAVIS-BESSE 1 FERMI 2 HOPE CREEK 1 MILLSTONE 2 OCONEE 3 PEACH BOTTOM 3 RANCHO SECO 1 SEQUOYAH 1 SUSQUEHANNA 2 WATERFORD 3	REASON F A B C B C B C E F C C	UNIT BROWNS FERRY 2 CALLAWAY 1 CLINTON 1 DIABLO CANYON 1 FORT ST VRAIN KEWAUNEE MILLSTONE 3 PALISADES PILGRIM 1 SALEM 1 SEQUOYAH 2 TROJAN ZION 1	REASON F A B C A C H A C B F, F C C

Report Period APR 1988

PAGE 1-3

٠,

Unit Availability, Capacity, Forced Outage

Avg Unit Percentage as of April 1988



Legend

- × Availability Factor
- Capacity Factor (MDC)
- G Capacity Factor (DER)
- A Forced Outage Rate

Report Feriod APR 1988

AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIALLY OPERATING UNITS

This chart depicts the average daily power level for the units in commercial operation during the month.

The straight line on the graph labelled "SUM OF MDC" is plotted at the value shown by summing the separate maximum dependable capacities of the commercially operating units (in Net MWe). The plot shown below the line is calculated by summing the separate average daily power levels of the same units for each day of the month.

The scale on the left vertical axis runs in 1,000 MWe increments from 0 to 55,000 MWe (Net). The right vertical axis shows the percentage in 10% increments, up to 100% of the "SUM OF MDC".

It should be recognized that the 100% line would be obtainable only if all of the commercially operating units operated at 100% capacity, 24 hours per day, for the entire month. In other words, since any power generator must occasionally shui down to refuel and/or perform needed maintenance, and also since 100% capacity production is not always required by power demands, the 100% line is a theoretical goal and not a practical one. THE AVERAGE POWER LEVEL CHART IS NOT AVAILABLE THIS REPORT PERIOD DUE TO SOFTWARE PROBLEMS

Vendor Average Capacity Factors 4/30/88



Legend

- × General Electric
- o Westinghouse
- Combustion Engineering
- Babcock & Wilcox

NOTE: This display of average capacity factors provides a general performance comparison of plants supplied by the four nuclear steam supply system vendors. One must be careful when drawing conclusions regarding the reasons for the performance levels indicated, since plant performance may be affected by unspecified factors such as: (1) various plant designs and models are included for each vendor; (2) turbine/generators and (3) different architect/engineers are also involved.

AVERAGE CAPACITY FACTORS BY VENDORS

*************** * GENERAL * * ELECTRIC *	CFMDC 0.0 BROWNS FERRY 1 0.2 BRUNSWICK 2 0.0 DRESDEN 3 105.6 GRAND GULF 1 0.0 LASALLE 1 100.9 MONTICELLO 0.0 PEACH BOTTOM 2 88.1 QUAD CITIES 1 0.0 SUSQUEHANNA 2	CFMDC 0.0 B 0.0 C 89.5 D 29.9 H 89.8 L 0.0 N 0.0 P 27.9 Q 100.9 V	ROWNS FERRY 2 LINTON 1 UANE ARNOLD ATCH 1 ASALLE 2 INE MILE POINT 1 EACH BOTTOM 3 UAD CITIES 2 ERMONT YANKEE 1	CFMDC 0.0 0.0 52.6 40.8 95.7 87.3 99.0 91.6	BRCHNS FERRY 3 COOPER STATION FERMI 2 HATCH 2 LIMERICK 1 NINE MILE POINT 2 PERRY 1 RIVER BEND 1 WASHINGTON NUCLEAR 2	CFMDC 94.6 86.4 103.1 45.3 97.5 100.4 0.0 101.2	BRUNSWICK 1 DRESDEN 2 FITZPATRICK HOPE CREEK 1 MILLSTONE 1 OYSTER CREEK 1 PILGRIM 1 SUSQUEHANNA 1
*************** * BABCOCK & * * WILCOX *	CFMDC 80.2 ARKANSAS 1 49.7 OCONEE 2	CFMDC 101.7 C 50.7 D	RYSTAL RIVER 3 CONEE 3	CFMDC 0.0 13.7	DAVIS-BESSE 1 RANCHO SECO 1	CFMDC 100.0 105.9	OCONEE 1 THREE MILE ISLAND 1
************** * COMBUSTION * * ENGINEERING *	CFMDC 0.0 ARKANSAS 2 98.4 MAINE YANKEE 0.0 PALO VERDE 2 102.7 ST LUCIE 1	CFMDC 25.6 C 76.8 M 95.9 P 100.3 S	ALVERT CLIFFS 1 ILLSTONE 2 ALO VERDE 3 T LUCIE 2	CFMDC 89.4 88.5 82.9 2.3	CALVERT CLIFFS 2 PALISADES SAN ONOFRE 2 WATERFORD 3	CFMDC 97.2 86.3 97.5	FORT CALHOUN 1 PALO VERDE 1 SAN ONGFRE 3
************** * WESTINGHOUSE* ****	CFMDC 99.9 BEAVER VALLEY 1 54.8 CALLAHAY 1 58.3 COOK 2 101.5 FARLEY 2 103.6 INDIAM POINT 2 101.5 MCGUIRE 2 24.7 POINT BEACH 1 58.7 ROBINSON 2 0.0 SEQUOYAH 1 78.7 SURRY 2 77.1 VOGILE 1 89.9 ZION 2	CFMDC 93.5 B 100.6 C 0.0 D 103.3 G 92.3 I 7.5 M .3 P 50.1 S 0.0 S 39.0 T 102.0 W	EAVER VALLEY 2 ATAMBA 1 IABLO CANYON 1 INNA NDIAN POINT 3 ILLSTONE 3 OINT BEACH 2 ALEM 1 EQUOYAH 2 ROJAN DLF CREEK 1	CFMDC 35.3 60.5 97.2 94.6 41.6 100.1 100.4 90.5 100.6 101.5 95.7	BYRON 1 CATAWBA 2 DIABLO CANYON 2 HADDAM NECK KEWAUNEE NORTH ANNA 1 PRAIRIE ISLAND 1 SALEM 2 SUMMER 1 TURKEY POINT 3 YANKEE-ROWE 1	CFMDC 89.8 89.3 0.0 101.9 95.9 100.0 99.7 0.0 20.1 86.0 0.0	BYRON 2 CODK 1 FARLEY 1 HARRIS 1 MCGUIRE 1 NORTH ANNA 2 PRAIRIE ISLAND 2 SAN ONOFRE 1 SURRY 1 TURKEY POINT 4 ZION 1
************** * OTHER INFO * *****	Units excluded are: BIG ROCK POINT DRESDEN 1 FORT ST VRAIN HUMBOLDT BAY LACROSSE THREE MILE ISLAND 2	Capacit deper vendo	ty factor in thi dable capacity. Ar averages are	s page, deno See the cor computed by Net	ted as CFMDC, is a fu responding definition the formula: Electrical Energy Pr	nction in the oduced	of the net maximum glossary. The by Vendor x 100%
	LINE THE EVENTS			Potential El	ectrical Production b	by Vende	or in this Month
	NET ELECTRICAL	GE BWRs	West PWRs	Comb PW	Rs B&W PWRs		ALL PWRs
	PRODUCTION MDC NET CFMDC.	10,500,561 30,908 47.3	19,555,395 39,493 68.9	6,762,2 13,9 67	46 2,978,567 49 6,704 .4 61.8	25	296,208 60,146 67.7

Report Period APR 1988

.

6

PAGE 1-7

MEMORANDA

THE FOLLOWING UNITS USE WEIGHTED AVERAGES TO CALCULATE CAPACITY FACTORS:

ITEM 22

۲,-

ITEM 22 & 23

BIG ROCK POINT 1 CALVERT CLIFFS 1 FARLEY 1 FIIZPATRICK FORT CALHOUN 1 INDIAN POINT 2* KEWAUNEE OYSTER CREEK 1 POINT BEACH 1 & 2 THREE MILE ISLAND 1 TURKEY POINT 3 & 4 GINNA HADDAM NECK (CONNECTICUT YANKEE) MAINE YANKEE MILLSTONE 2 OCONEE 1. 2. & 3 YANKEE-ROWE 1

*COMPUTED SINCE 7/1/74, THE DATE OF COMPLETION OF A 100 DAY - 100% P' . OPERATION TEST.

THE FOLLOWING UNITS USE THE DATE OF FIRST ELECTRICAL GENERATION INSTEAT OF COMMERCIAL OPERATION, FOR THEIR CUMULATIVE DATA:

ITEMS 20 THROUGH 24

ITEM 24 ONLY

COOK 1 & 2 RIVER BEND SAN ONOFRE 1 BIG ROCK POINT 1

Report Period APR 1988

PAGE 1-8

.

.

. PAGE 1-9 ÷ ٢ CORRECTIONS TO PREVIOUSLY REPORTED DAIA NOTE: THESE CHANGES ARE REFLECTED IN THE DATA CONTAINED IN THE CURRENT REPORT . REVISED MONTHLY HIGHLIGHTS ш u 2 Ľ Z 4 ERRATA 2 0 . 2 0 0 z z 0 z z -.. Report Period APR 1988

SECTION 2 SECTION 2 OPERATING POWER POWER REACTORS

1. Docket: <u>50-313</u>	OPERAT	ING S	TATUS								
2. Reporting Period:	88 Outage	+ On-line	Hrs: 719.0								
3. Utility Contact: J. N. G	OBELL (561)	964-3251									
4. Licensed Thermal Power (M	Licensed Thermal Power (MWt):										
5. Nameplate Rating (Gross M	Nameplate Rating (Gross MWe): 1003)										
6. Design Electrical Rating	(Net MWe):		850								
7. Maximum Dependable Capaci	ty (Gross M	We):	883								
8. Maximum Dependable Capaci	ty (Net MWe):	836								
 If Changes Occur Above Si NONE 	nce Last Re	port, Give	Reasons:								
10. Power Level To Which Rest	ricted, If	Any (Net M	le):								
11. Reasons for Restrictions,	If Any:										
NONE		<u> </u>									
12. Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE								
13. Hours Reactor Critical	719.0	2,871.2	81,926.5								
14. Rx Reserve Shtdwn Hrs		. 0	5,044.0								
15. Hrs Generator On-Line	719.0	2,865.6	80,294.5								
16. Unit Reserve Shtdwn Hrs		.0	817.5								
17. Gross Therm Ener (MWH)	1,489,778	5,869,035	184,704,042								
18. Gross Elec Ener (MWH)	507,575	2,003,425	61,270,555								
19. Net Elec Ener (MWH)	482,094	1,900,693	58,290,070								
20. Unit Service Factor	100.0	98.7	68.5								
21. Unit Avail Factor	100.0	98.7	69.3								
22. Unit Cap Factor (MDC Net)	80.2	78.3	59.5								
23. Unit Cap Factor (DER Net)	78.9	77.0	58.5								
24. Unit Forced Outage Rate		1.3	13.4								
25. Forced Outage Hours	. 0		12,435.0								
26. Shutdowns Sched Over Next	t 6 Months (Type,Date,	Duration):								
REFUELING - 9/2/88 - 72 I	Limated Star	tun Date:	NZA								

*****	*******	*****	*****	*****	*****
×	A	RKANSA:	5 1		×
*****	*******	******	******	******	*****
AVERA	GE DAILY	POWER	LEVEL	(MWe)	PLOT

ARKANSAS 1



APRIL 1980

Report Period APR 1988

The start of the s	No. Date	Type Hours	Reason Method	LER Number	System Component	Cause &	Corrective	Action	to Prevent	Recurrence
--	----------	------------	---------------	------------	------------------	---------	------------	--------	------------	------------

NONE

Iype	Reason		Method	System & Component		
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3 Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)		

FACILITY DESCRIPTION

LOCATION STATE.....ARKANSAS

COUNTY......POPE

DIST AND DIRECTION FROM NEAREST POPULATION CTR...6 MI WNW OF RUSSELLVILLE, AR

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...AUGUST 6, 1974

DATE ELEC ENER 1ST GENER... AUGUST 17, 1974

DATE COMMERCIAL OPERATE.... DECEMBER 19, 1974

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER....DARDANELLE RESERVOIR

ELECTRIC RELIABILITY COUNCIL.....SOUTHWEST POWER POOL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE..... ARKANSAS POWER & LIGHT

CORPORATE ADDRESS......NINTH & LOUISIANA STREETS LITTLE ROCK, ARKANSAS 72203

CONTRACTOR

ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER... BABCOCK & WILCOX

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....WESTINCHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV

IF RESIDENT INSPECTOR......B. JOHNSON

LICENSING PROJ MANAGER....G. DICK DOCKET NUMBER.....50-313

LICENSE & DATE ISSUANCE.... DPR-51, MAY 21, 1974

PUBLIC DOCUMENT ROOM.....ARKANSAS TECH UNIVERSITY RUSSELLVILLE, ARKANSAS 72801

INSPECTION SUMMARY

INSPECTION CONDUCTED FEB.21-26, 1988 (88-02) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEL'S RADIATION PROTECTION ACTIVITIES DURING THE UNIT 2 REFUELING OUTAGE (2R6). WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED. NO DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED FEB. 29 - MARCH 10, 1988 (88-04) ROUTINE, UNANNOUNCED INSPECTION OF SUPPLIMENTAL DESIGN CONTROL, ALLEGATION ASSESSMENT, AND 10 CFR PART 21 INSPECTION. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED AND TWO UNRESOLVED ITEMS WERE IDENTIFIED.

INSPECTION CONDUCTED FEB. 22 - MARCH 27, 1988 (88-06) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, ALLEGATION FOLLOWUP, AND GENERIC LETTER FOLLOWUP. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED MARCH 22-24, 1988 (88-09) ROUTINE, ANNOUNCED INSPECTION OF THE LICENSEE'S IMPLEMENTATION OF THE EMERGENCY PLAN AND PROCEDURES DURING THE 1988 ANNUAL EMERGENCY EXERCISE. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. TWO DEFICIENCIES WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

***** × ARKANSAS 1 ********************************

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

ONE REACTOR COOLANT PUMP OUT OF SERVICE

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

POWER OPERATION

LAST IE SITE INSPECTION DATE:H 27, 1988

INSPECTION REPORT NO: 88-06

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-01	04/29/85	03/28/88	PLANT MODIFICATION DESIGN DEFICIENCIES RESULTING IN INCORRECT INSTALLATION OF SOLENOID OPERATED VALVES AND DEGRADATION OF CONTAINMENT ISOLATION CAPACITY.
88-03	02/17/88	04/05/88	REACTOR TRIP
88-04	02/10/88	04/05/88	REACTOR BUILDING HYDROGEN CONCENTRATION INSTRUMENT INOPERABLE DUE TO INADEQUATE POST-MODIFICATION TESTING.

١.	Docket: <u>50-368</u> 0	PERAT	INGS	TATUS							
2.	Reporting Period:	_ Outage	+ On-line	Hrs: 719.0							
3.	Utility Contact: D. F. HAR	RISON (50	1) 964-3743								
4.	Licensed Thermal Power (MWt):										
5.	Nameplate Rating (Gross MWG	;);		943							
6.	Design Electrical Rating ()	let MWe):	1.	912							
7.	Maximum Dependable Capacity	Gross M	We):	897							
8.	Maximum Dependable Capacity (Net MWe): 858										
9.	. If Changes Occur Above Since Last Report, Give Reasons:										
	NONE										
10.	Power Level To Which Restri	icted, If	Any (Net M	le):							
11.	Reasons for Restrictions,	If Any:		<u></u>							
	NONE										
		MONTH	YEAR	CUMULATIVE							
12.	Report Period Hrs	/19.0	2,903.0								
13.	Hours Reactor Critical	. 0									
14.	Rx Reserve Shtdwn Hrs		.0	1,430.1							
15.	Hrs Generator On-Line	.0	1,027.5	49,420.9							
16.	Unit Reserve Shtdwn Hrs	. ?	. 0	75.0							
17.	Gross Therm Ener (MWH)	0	2,816,266	127,673,823							
18.	Gross Elec Ener (MWH)	0	939,120	41,938,531							
19.	Net Elec Ener (MWH)	-4,377	889,498	39,908,995							
20.	Unit Service Factor	. 0	35.4	69,6							
21.	Unit Avail Factor	. 0	35.4	69.7							
_22.	Unit Cap Factor (MDC Net)	. 0	35.7	65.5							
23.	Unit Cap Factor (DER Net)	. 0	33.6	61.6							
24.	Unit Forced Outage Rate	. 0	. 0	14.4							
25.	Forced Outage Hours	. 0	. 0	8,336.0							
_26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):							
-	NONE										





APRIL 1988

PAGE 2-006

112

Report	Period A	PR 19	88		UN	IT	SHU	тром	N S	/ R	ED	U	ст	I O	N	**************************************
No.	Date	Type	Hours	Reason	Method	LER	Number	System	Comp	onent		-	Cau	58	8 C	Corrective Action to Prevent Recurrence
88-01	02/12/88	S	719.0	С	4			ZZ	ZZZ	ZZZ	UNI	T SI	нитр	OWN	FO	R REFUELING AND MAINTENANCE.

*********** ARKANSAS UNIT 2 REMAINED SHUTDOWN DURING APRIL FOR SCHEDULED * SUMMARY * REFUELING AND MAINTENANCE DUTAGE.

Ivpe	Reason		Method	System & Component		
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)		

PAGE 2-007

.

0

FACILITY DESCRIPTION

LOCATION

STATE.....ARKANSAS

COUNTY.....POPE

DIST AND DIRECTION FROM NEAREST POPULATION CTR...6 MI WNW OF RUSSELLVILLE, AR

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY...DECEMBER 5, 1978

DATE ELEC ENER 1ST GENER... DECEMBER 26, 1978

DATE COMMERCIAL OPERATE.... MARCH 26, 1980

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER..., DARDANELLE RESERVOIR

ELECTRIC RELIABILITY

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE..... ARKANSAS POWER & LIGHT

CORPORATE ADDRESS......NINTH & LOUISIANA STREETS LITTLE ROCK, ARKANSAS 72203

CONTRACTOR

ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE....IV

IE RESIDENT INSPECTOR.....W. JOHNSON

LICENSING PROJ MANAGER....C. HARBUCK DOCKET NUMBER.....50-368

LICENSE & DATE ISSUANCE....NPF-6, SEPTEMBER 1, 1978

PUBLIC DOCUMENT ROOM.....ARKANSAS TECH UNIVERSITY RUSSELLVILLE, ARKANSAS 72801 I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED FEB.21-26, 1988 (88-02) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S RADIATION PROTECTION ACTIVITIES DURING THE UNIT 2 REFUELING OUTAGE (2R6). WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED. NO DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED FEB. 29 - MARCH 10, 1988 (88-04) ROUTINE, UNANNOUNCED INSPECTION OF INSERVICE INSPECTION, DESIGN CHANGES AND MODIFICATIONS, SUPPLEMENTAL DESIGN CONTROL INSPECTION, USE OF E-BRITE 26-1 TUBING IN SHUTDOWN COOLING HEAT EXCHANGERS, ALLEGA(ION ASSESSMENT, AND 10 CFR PART 21 INSPECTION. WITHIN THE AREAS INSPECTED, TWO VIOLATIONS WERE IDENTIFIED AND TWO UNRESOLVED ITEMS WERE IDENTIFIED.

INSPECTION CONDUCTED FEB. 22 - MARCH 27, 1988 (88-06) ROUTINE, UNANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, ALLEGATION FOLLOWUP, REFUELING ACTIVITIES, PRESSURIZER REPAIR, EVENT FOLLOWUP, AND GENERIC LETTER FOLLOWUP. WITHIN THE AREAS INSPECTED, VIOLATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED MARCH 7-11, 1988 (88-07) ROUTINE, UNANNOUNCED INSPECTION OF THE INSERVICE TESTING PROGRAM FOR PUMPS AND VALVES. SUBJECT ACTIVITIES REVIEWED IN THIS AREA OF INSPECTION INCLUDED TRACKING METHODOLOGY FOR INSERVICE TESTING, TEST PROCEDURES AND RESULTS, INSERVICE TESTING TREND REPORTS, QUALITY ASSURANCE AUDITS, AND WITNESSING OF AN INSERVICE TEST. WITHIN THE ONE AREA INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED MARCH 22-24, 1988 (88-09) ROUTINE, ANNOUNCED INSPECTION OF THE LICENSEE'S IMPLEMENTATION OF THE EMERGENCY PLAN AND PROCEDURES DURING THE 1988 ANNUAL EMERGENCY EXERCISE. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE PAGE 2-008 Report Period APR 1988

INSPECTION SUMMARY

IDENTIFIED. TWO DEFICIENCIES WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TECH. SPEC. 6.8.1 THE LICENSEE FAILEDTO PROPERLY CONTROL COMBUSTIBLES IN THE NORTH EMERGENCY DIESEL GENERATOR ROOM. (8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

POWER OPERATION

LAST IE S TINSPECTION DATE: MARCH 27, 1988

INSPECTION REPORT NO: 50-368/88-06

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-04	02/11/88	04/11/88	VIBRATION INDUCED CLOSURE OF AIR VOLUME SYSTEM.
88-05	03/19/88	04/07/88	CONTINUOUS FIRE WATCH PERSONNEL FOUND ASLEEP.

1.	Docket: 50-334	PERAT	ING S	TATUS							
2	orting Period: 04/01/8	0utage	+ On-line	Hrs: 719.0							
з.	Utility Contact: P.A.SMIT	TH (412) 39	3-7621								
÷.	Licensed Thermal Power (MWt):2652										
5.	Nameplate Rating (Gross MWe): <u>1026 X 0.9 = 923</u>										
6.	Design Electrical Rating	(Net MWe):	<u> </u>	835							
7.	Maximum Dependable Capacity (Gross MMe):860										
8.	Maximum Dependable Capacity (Net MWe):810										
9.	If Changes Occur Above Since Last Report, Give Reasons:										
	NONE			<u> </u>							
10.	Power Level To Which Rest	ricted, If	Any (Net M	de):							
11.	Reasons for Restrictions,	If Any:									
	NONE			<u></u>							
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 105,191.0							
13.	Hours Reactor Critical	719.0	1,489.6	60,677.7							
14.	Rx Reserve Shtdwn Hrs	. 0		4,482.7							
15.	Hrs Generator On-Line	719.0	1,429.0	59,083.3							
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	2.2							
17.	Gross Therm Ener (MWH)	1,884,007	3,561,633	140,478,943							
18.	Gross Elec Ener (MWH)	616,790	1,164,149	45,029,909							
19.	Net Elec Ener (MWH)	581,970	1,085,627	42,021,230							
20.	Unit Service Factor	100.0	49.2	58.5							
21.	Unit Avail Factor	100.0	49.2	58.5							
22.	Unit Cap Factor (MDC Net)	99.9	46.2	52.5							
23.	Unit Cap Factor (DER Net)	96.9	44.8	51.0							
24.	Unit Forced Outage Rate	. 0	. 6	19.3							
25.	Forced Outage Hours	. 0	8.1	19,049.5							
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):							
27	Té Concentiu Shutdem Est	instad Star	tuo Dato:	NZA							



APRIL 1988

×

UNIT SHUTDOWNS / REDUCTIONS

Report Period APR 1988

BEAVER VALLEY 1 *********

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
10	04/01/88	F	0.0	В	5		HC	HTEXCH	THE UNIT ENTERED THE MONTH AT 80% POWER TO PERMIT CLEANING CONDENSER TUBES IN THE "B" W ATERBOX OF THE UNIT'S MAIN CONDENSER.
11	04/01/88	F	0.0	В	5		HC	HTEXCH	THENIT'S OUTPUT WAS REDUCED TO 80% TO PERMIT CLEANING THE CONDENSER TUBES IN THE 'C' WATERBOX OF THE UNIT'S MAIN CONDENSER.
12	04/04/88	F	0.0	A	5		нн	VALVEX	THE UNIT'S OUTPUT WAS REDUCED TO 80% TO STABILIZE THE STEAM GENERATOR FEEDWATER SYSTEM WHILE CONDENSATE PUMP DISCHARGE PRESSURE WAS BELOW ITS NORMAL VALUE.

******* * SUMMARY * *********

BEAVER VALLEY 1 INCURRED 3 POWER REDUCTIONS IN APRIL AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component	
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual Error 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)	

PAGE 2-011

.

FACILITY DESCRIPTION

LOCATION STATE.....PENNSYLVANIA

COUNTY BEAVER

DIST AND DIRECTION FROM NEAREST POPULATION CTR...SHIPPINGPORT, PENNSYLVANIA

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... MAY 10, 1976

DATE ELEC ENER 1ST GENER...JUNE 14, 1976

DATE COMMERCIAL OPERATE....OCTOBER 1, 1976

CONDENSER COOLING METHOD. .. COOLING TOWER

CONDENSER COOLING WATER.... OHIO RIVER

ELECTRIC RELIABILITY

COUNCIL.....FAST CENTRAL AREA RELIABILITY COORDINATION AGREEMENT

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....DUQUESNE LIGHT

CORPORATE ADDRESS.....ONE OXFORD CENTRE, 301 GRANT STREET PITTSBURGH, PENNSYLVANIA 15279

CONTRACTOR ARCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....STONE & WEBSTER

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....J. BEALL

LICENSE & DATE ISSUANCE.... DPR-66, JULY 2, 1976

PUBLIC DOCUMENT ROOM.....B.F. JONES MEMORIAL LIBRARY 633 FRANKLIN AVENUE ALIQUIPPA, PA 15001

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS: NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

PAGE 2-012

Report Period APR 1988

OTHER ITEMS

MANAGERIAL	L ITEMS:										
NO INPUT P	PROVIDED.										
PLANT STAT	rus:										
NO INPUT P	PROVIDED.										
LAST IE SI	TE INSPECTI	ON DATE: N	INPUT PR	OVIDED.							
INSPECTION	REPORT NO:	NO INPUT	PROVIDED.								
				REPO	RTS	FROM	1 LI	ENSE	E		
				=======	======					 	
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT								
	PROVIDED									 	

1.	Docket: 50-412 0	PERAT	ING S	TATUS						
2.	Reporting Period: 04/01/88 Outage + On-line Hrs: 719.0									
3.	Utility Contact: P. A. SM	ITH (412)	643-1825							
4.	Licensed Thermal Power (MWt):2652									
5.	Nameplate Rating (Gross MWe): 923									
6.	Design Electrical Rating (Net MWe): 836									
7.	Maximum Dependable Capacit	885								
8.	Maximum Dependable Capacit	833								
9.	If Changes Occur Above Since Last Report, Give Reasons:									
0.	Power Level To Which Restr	icted, If	Any (Net MW	le):						
1.	Reasons for Restrictions,	If Any:								
	NONE									
2.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE						
3.	Hours Reactor Critical	698.5	2,483.0	3,448.5						
4.	Rx Reserve Shtdwn Hrs	. 0	.0							
5.	Hrs Generator On-Line	692.7	2,464.4	3,414.2						
6.	Unit Reserve Shtdwn Hrs	. 0	. 0	. 0						
7.	Gross Therm Ener (MWH)	1,816,453	6,373,823	8,759,460						
8.	Gross Elec Ener (MWH)	589,700	2,073,000	2,855,200						
9.	Net Elec Ener (MWH)	558,678	1,958,071	2,696,175						
20.	Unit Service Factor	96.3	84.9	58.5						
21 -	Unit Avail Factor	96.3	84.9	58.5						
22.	Unit Cap Factor (MDC Net)	93.3	81.0	52.5						
23.	Unit Cap Factor (DER Net)	92.9	80.7	51.0						
24.	Unit Forced Outage Rate	3.7	3.6	19.3						
25.	Forced Outage Hours	26.3	91.6	212.8						
26.	Shutdowns Sched Over Next	6 Months (Type,Date,I	Duration):						
	to constitute Shutdawa Est	imstod Star	tun Data:	NZA						



APRIL 1986

Report	Period Af	PR 19	88		UN	IT SHU	TDOW	NS / R	E D U C T I O N S * BEAVER VALLEY 2 * *********************************
No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
8	04/04/88	F	26.3	А	3	88-007	EB	RELAYX	THE UNIT TRIPPED FROM 100% POWER WHEN THE 'A' REACTOR COOLANT PUMP TRIPPED AFTER THE UNIT'S '2A' 4 KV BUS BECAME DE-ENERGIZED BY A FAULTY RELAY.

)

**********	BEAVER VALLEY 2	INCURRED 1 OUTAGE IN APRIL
* SUMMARY *	DUE TO A FAULTY	RELAY WHICH CAUSED 'A'
**********	REACTOR COOLANT	PUMP TO TRIP.

Type	Reason	and the second second	Method	System & Component		
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161		

FACILITY DESCRIPTION

LOCATION

STATE.....PENNSYLVANIA

COUNTY.....BEAVER

DIST AND DIRECTION FROM NEAREST POPULATION CTR...SHIPPINGPORT, PENNSYLVANIA

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY...AUGUST 4, 1987

DATE ELEC ENER 1ST GENER...AUGUST 17, 1987

DATE COMMERCIAL OPERATE....NOVEMBER 17, 1987

CONDENSER COOLING METHOD... HNDCT

CONDENSER COOLING WATER.... OHIO RIVER

ELECTRIC RELIABILITY

COUNCIL......EAST CENTRAL AREA RELIABILITY COORDINATION AGREEMENT

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....DUQUESNE LIGHT

CORPORATE ADDRESS.......435 SIXTH AVENUE PITTSBURGH, PENNSYLVANIA 15219

CONTRACTOR ARCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....STONE & WEBSTER

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....J. BEALL

LICENSING PROJ MANAGER.....P. TAM DOCKET NUMBER......50-412

LICENSE & DATE ISSUANCE....NPF-73, AUGUST 14, 1987

PUBLIC DOCUMENT ROOM......B.F. JONES MEMORIAL LIBRARY 633 FRANKLIN AVENUE ALIQUIPPA, PA 15001

INSPECTION STATUS

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

Report Period APR 1988
******* BEAVER VALLEY 2 * ******************************

PLANT STATUS:

INFO, NOT SUPPLIED BY REGION LAST IE SITE INSPECTION DATE: INFO. NOT SUPPLIED BY REGION INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION REPORTS FROM LICENSEE NUMBER DATE OF DATE OF SUBJECT EVENT REPORT INFO. NOT SUPPLIED BY REGION

1.	Docket: <u>50-155</u> 0	PERAT	ING S	TATUS					
2.	Reporting Period: 04/01/8	8_ Outage	+ On-line	Hrs: 719.0					
3.	Utility Contact: J. R. JO	HNSTON (616) 547-6537						
4.	Licensed Thermal Power (MWt): 240								
5.	Nameplate Rating (Gross MWe): 70.6 X 0.85 = 60								
6.	Design Electrical Rating (Net MWe): 72								
7.	Maximum Dependable Capacity (Gross MWe): 73								
8.	Maximum Dependable Capacit	y (Net MWe)	a	69					
9.	If Changes Occur Above Since Last Report, Give Reasons:								
1	NONE								
10.	Power Level To Which Restr	icted, If A	iny (Net Mk	le):					
11.	Reasons for Restrictions,	If Any:							
	NONE								
		MONTH	YEAR	CUMULATIVE					
12.	Report Period Hrs	719.0	2,903.0	219,954.0					
13.	Hours Reactor Critical	190.6	2,187.6	158,021.3					
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	. 0					
15.	Hrs Generator On-Line	187.2	2,141.0	155,275.9					
16.	Unit Reserve Shtdwn Hrs	. 0		. 0					
17.	Gross Therm Ener (MWH)	32,664	401,610	29,335,133					
18.	Gross Elec Ener (MWH)	10,830	130,951	9,302,785					
19.	Net Elec Ener (MWH)	10,205	123,730	8,796,972					
20.	Unit Service Factor	26.0	73.8	70.6					
21.	Unit Avail Factor	26.0	73.8	70.6					
22.	Unit Cap Factor (MDC Net)	20.6	61.8	<u>59.4</u> ×					
23.	Unit Cap Factor (DER Net)	19.7	59.2	55.5					
24.	Unit Forced Outage Rate	. 0	7.1	13.5					
25.	Forced Outage Hours	.0	163.3	12,270.0					
26.	Shutdowns Sched Over Next	6 Months ()	Type, Date, D)uration):					
	NONE								
				Contraction of the second					

CANCE DALL'I TOREN CETEL TIMOT I LO

BIG ROCK POINT 1





* Item calculated with a Weighted Average

UNIT SHUTDOWNS / REDUCTIONS * BIG ROCK POINT 1

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-09	04/08/88	S	531.8	с	1				A CONTROLLED POWER REDUCTION IN PREPARATION FOR THE 1988 REFUELING OUTAGE. THE REFUELING OUTAGE IS EXPECTED TO CON- TINUE UNTIL APPROX. JUNE 6, 1988.

YPe	Reason	Method	System & Component			
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueiing H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)			

FACILITY DESCRIPTION

LOCATION STATE.....MICHIGAN COUNTY.....CHARLEVOIX DIST AND DIRECTION FROM NEAREST POPULATION CTR...4 MI NE OF CHARLEVOIX, MICH TYPE OF REACTOR.....BWR DATE INITIAL CRITICALITY...SEPTEMBER 27, 1962 DATE ELEC ENER 1ST GENER...DECEMBER 8, 1962 DATE COMMERCIAL OPERATE....MARCH 29, 1963 CONDENSER COOLING METHOD...ONCE THRU CONDENSER COOLING WATER....LAKE MICHIGAN ELECTRIC RELIABILITY COUNCIL.......EAST CENTRAL AREA

.....EAST CENTRAL AREA RELIABILITY COORDINATION AGREEMENT

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE.....CONSUMERS POWER

CORPORATE ADDRESS......212 WEST MICHIGAN AVENUE JACKSON, MICHIGAN 49201

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....S. GUTHRIE

LICENSE & DATE ISSUANCE.... DPR-6, AUGUST 30, 1962

PUBLIC DOCUMENT ROOM.....NORTH CENTRAL MICHIGAN COLLEGE 1515 HOWARD STREET PETOSKEY, MICHIGAN 49770 INSPECTION STATUS

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

RDS VALVES CORROSION PROBLEM

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

PAGE 2-020

Report Period APR 1988

Report Period APR 1988 INSPECTION STATUS - (CONTINUED)

******************************** * BIG ROCK POINT 1 **********************************

OTHER ITEMS

NONE

PLANT STATUS:

REFUELING OUTAGE 4/7 TO 6/6

LAST IE SITE INSPECTION DATE: 04/19/88

INSPECTION REPORT NO: 88005

REPORTS FROM LICENSEE

NUMBER DATE OF DATE OF SUBJECT EVENT REPORT

PAGE 2-021

1.	Docket: _50-456	OPERAT	INGS	TATUS						
2.	Reporting Period: 04/01/1	88_ Outage	+ On-line	Hrs: 719.0						
3.	Utility Contact:B, M, Pl	EACOCK (815) 458-2801	EXT. 2480						
4.	4. Licensed Thermal Power (MWt): 3411									
5.	5. Nameplate Rating (Gross MWe):									
6.	. Design Electrical Rating (Net MNe): 1120									
7.	Maximum Dependable Capacity (Gross MWo):1175									
8.	Maximum Dependable Capacit	ty (Net MWe):	1120						
9.	If Changes Occur Above Sir	nce Last Re	port, Give	Reasons:						
10.	Power Level To Which Restr Reasons for Restrictions,	icted, If If Any:	Any (Net MW	le):						
	NONE									
12.	Report Period Hrs	MONTH 719,0	YEAR 2,903.0	CUMULATIVE 7,056.0						
13.	Hours Reactor Critical	163.1	249.0	3,308.7						
4.	Rx Reserve Shtdwn Hrs	. 0		. 0						
15.	Hrs Generator On-Line	140.6	213.2	2,823.9						
16.	Unit Reserve Shtdwn Hrs	0		. 0						
7.	Gross Therm Ener (MWH)	154,593	250,909	5,266,581						
8.	Gross Elec Ener (MWH)	49,032	79,586	1,684,190						
9.	Net Elec Ener (MWH)	42,025	58,136	1,514,787						
20.	Unit Service Factor									
:t.,	Unit Avail Factor		NOT IN							
22.	Unit Cap Factor (MDC Net)		COMMERCIA	L						
	Unit Cap Factor (DER Net)		OPERATION							
3.	The second									
23.	Unit Forced Outage Rate									
23. 24. 25.	Unit Forced Outage Rate Forced Outage Hours	578.4	783.4	1,655.6						





APRIL 1988

*********	BRAIDWOOD 1 ENTERED APRIL IN MODE 5. UNIT
* SUMMARY *	CAME ON LINE ON APRIL 25 AT 50% POWER.
********	POWER REDUCED TO 25% ON APRIL 28 AND REMAINED AT THIS LEVEL FOR REMAINDER OF THE MONTH.

Туре	Reason		Method	System & Component				
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exam	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)				

FACILITY DESCRIPTION

LOCATION

STATE.....ILLINOIS

COUNTY.....WILL

DIST AND DIRECTION FROM NEAREST POPULATION CTR...24 MI SSW OF JOLIET, ILL

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... MAY 29, 1987

DATE ELEC ENER 1ST GENER...JULY 12, 1987

DATE COMMERCIAL OPERATE.....

CONDENSER COOLING METHOD...CC ART

CONDENSER COOLING WATER....KANKAKEE RIVER

ELECTRIC RELIABILITY

COUNCIL......MID-AMERICA INTERPOOL NETWORK

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....COMMONWEALTH EDISON

CORPORATE ADDRESS......P.O. BOX 767 CHICAGO, ILLINOIS 60699

CONTRACTOR ARCHITECT/ENGINEER......SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR......COMMONWEALTH EDISON

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....L. MCGREGOR

LICENSING PROJ MANAGER.....S. SANDS DOCKET NUMBER......50-456

LICENSE & DATE ISSUANCE....NPF-72, JULY 2, 1987

PUBLIC DOCUMENT ROOM.....HEAD LIBRARIAN GOVERNMENT DOCUMENTS COLLECTION WILMINGTON PUBLIC LIBRARY 201 SOUTH KANKAKEE STREET WILMINGTON, ILLINOIS, 60481

INSPECTION SUMMARY

Inspection on October 5 through December 22, 1987, January 19 and February 18 and 26, 1988 (87038; 87036): Routine, unannounced safety inspection of licensee action on previous inspection findings; review of electrical and instrumentation components including systems design and completed installations; examination of Remote Shutdown Panel; inspection of Main Steam Line and Main Feedwater Isolation Valve components; observation of ongoing field activities; review of selected systems and components; review of Critical Drawings in the control room; review of OAD construction activities; and training (92701, 99020, 41400, 51053, 51054, 51055, 51056, 510663, 510664, 51065, 510665, 52053, 52054, 52055, 52056, 52063, 52064, 520664, and 52066). Of the nine areas inspected, no violations or deviations were identified in three areas; one violation with three examples - failure to follow procedure or inadequate procedures; one violation with five examples.

STATUS

INSPECTION

Inspection on March 14 through March 30, 1988 (88010; 88011): Routine announced inspection conducted to review the status of fire protection license conditions and open items. The following inspection modules were employed by the inspector: 64704 and 92701. Of the areas inspected, no violations or deviations were identified.

Inspection from March 14 through March 25, 1988 (88012): Special safety inspection conducted by the resident inspectors concerning an event in which the 2B Safety Injection pump was found incapable of performing its intended function when its manual discharge valve (25I8921B) was found locked shut. One violation (failure to meet a Technical Specification requirement) was identified.

PAGE 2-024

Report Period APR 1988

INSPECTION SUMMARY

Inspection from February 14 through April 9, 1988 (88008; 88009): Routine, unannounced safety inspection by the resident inspector of licensee action on previously identified items; confirmatory action letters; regional requests; followup on IMI action items; operators' use of measuring and test equipment (M&TE); control room log entries; startup test observation; initial criticality witnessing; operational safety verification; radiological protection; engineered safety feature systems; sustained control room and plant observations; physical security; monthly maintenance observation monthly surveillance observation; training effectiveness; report review; and meetings and other activities. Of the nineteen areas inspected, no violations were identified in seventeen. In the remaining areas is violations were identified regarding operators' use of M&TE and control room log entries.

Inspection on February 16 through March 7, 1988 (88007): Special announced team inspection by Region III, NRC Headquarters, and senior resident based inspectors to perform an operational readiness inspection prior to full power licensing of the Braidwood Unit 2 plant. Areas reviewed included: operations, surveillance and testing, maintenance, radiation controls, chemistry controls, nuclear engineer activities, and training. Of the seven functional areas inspected, no violations or deviations were identified in six of the seven areas. However, one Open Item was identified in one functional area (maintenance) to track resolution of a perceived problem with the licensee's scheduling of periodic lubrications, and one Unresolved Item was identified in another functional area (radiation controls) to track resolution of a potential noncompliance with Technical Specification requirements for control of Radiation Control Technicians overtime. Within the remaining functional area (operations) two violations were identified. One violation was identified for failure to write a deviation report, as required, after the Boric Acid Transfer Pumps recirculation line was identified as having become plugged. The second violation involved multiple examples of a weak and ineffective Out-of-Service program. After retuning to the Braidwood station to followup on corrective actions instituted by the licensee as a result of the initial inspection, the ORI was bale to make a recommendation to Region II management for issuance of a full power license for Braidwood Unit 2.

Meeting On March 28, 1988 (880012): An enforcement conference conducted to discuss licensee errors associated with a design change to the electrical heaters in the Control Room Ventilation Systems.

Inspection from March 14 through March 25, 1988 (88011; 88013): Special safety inspection conducted by resident inspector to evaluate circumstances and significance of events surrounding the inoperability of non-accessible are exhaust filter plenums on December 18, 1987, and on March 13, 1988, for Units 1 and 2. One violation of NRC requirements was identified: two events involving two inoperable non-accessible area exhaust filter plenums with the subsequent failure to place units in the applicable operating modes as specified in Technical specification 3.0.3.

Inspection on March 3-7, 1988 (88009; 88010): Special safety inspection to follow-up allegation RIII 88-A-0009. No violations or deviations were identified.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

× BRAIDWOOD 1 ******

OTHER ITEMS

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

BRAIDWOOD 1 OPERATING IN THE STARTUP TEST PROGRAM UP TO 1002 RATED POWER

LAST IE SITE INSPECTION DATE: 04/27/88

INSPECTION REPORT NO: 88014

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-08	032588	042588	REACTOR COOLANT SYSTEM LEAKAGE DUE TO BROKEN RELIEF VALVE DISC PIN
88-09	040788	042688	LOSS OF OB CONTROL ROON CHILLER DUE TO DETERMINATION OF TEMPERA TURE CONTROLLER
88-10	041088	042888	CONTROL ROOM VENTIALTION TO MAKEUP MODE OF OPERATION FROM A HIGH RADIATION ALARM DUE TO

ł PAGE 2-027 THIS FAGE INTENTIONALLY LEFT BLANK ß

1. Docket: <u>50-259</u> 0	PERAT	INGS	TATUS					
2. Reporting Period: 04/01/8	8_ Outage	+ On-line	Hrs: 719.0					
3. Utility Contact: D. CR	AWFORD (205) 729-2507						
. Licensed Thermal Power (MWt): 3293								
. Nameplate Rating (Gross MWe): <u>1280 X 0.9 = 1152</u>								
. Design Electrical Rating (Net MWe): 1065								
7. Maximum Dependable Capacit	Maximum Dependable Capacity (Gross MWe): 1098							
8. Maximum Dependable Capacit	Maximum Dependable Capacity (Net MWe): 1065							
9. If Charges Occur Above Sin	ice Last Rep	ort, Give	Reasons:					
10 Deve Level To Uhish Deste	icted If A	ny (Not M	(a):					
10. Power Level to Which Kestr	icted, if A	ny thet m						
11. Reasons for Restrictions,	If Any:							
NONE								
12. Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 120,529.0					
13. Hours Reactor Critical	. 0	. 0	59,520.9					
14. Rx Reserve Shtdwn Hrs	. 0	. 0	6,996.8					
15. Hrs Generator Gn-Line	. 0	. 0	58,276.4					
16. Unit Reserve Shtdun Hrs		. 0						
17. Gross Therm Ener (MWH)	0	0	167,963,338					
18. Gross Elec Ener (MWH)	0	0	55, 398, 130					
19. Net Elec iner (MWH)	-4,606	-9,415	53,658,502					
20. Unit Service Factor	. 0	. 0	48.4					
21. Unit Avail Factor	.0	. 0	48.4					
22. Unit Cap Factor (MDC Net)	. 0	. 0	41.8					
23. Unit Cap Factor (DER Net)		. 0	41.8					
24. Unit Forced Outage Rate	100.0	100.0	42.8					
25. Forced Outage Hours	719.0	2,903.0	43,601.1					
26. Shutdowns Sched Over Next	6 Months (1	ype,Date,	Duration):					
	united Stand	up Data:	NZA					





PAGE 2-028

Report	Period Al	PR 19	88		UN	ţт	S Н Ц	T	D	0 W	N	s	/	RE	D	U	с	7	1 (N	s	**************************************
No.	Date	Type	Hours	Reason	Nethod	TER	Number	-	Sys	tem	Ē	ompo	nen	5 2			C	au	SE.	8	Co	rrective Action to Prevent Recurrence
315	06/01/85	F	719.0	F	4									A	DM		ST	RA		E ON	HO	LD TO RESOLVE VARIOUS RNS.

....

....

0

14

.

Туре	Reason		Method	System & Component				
F-Forced S-Sched	 Equip Failure Maint or Test C-Refueling D-Regulatory Rest E-Operator Traini & License Exam 	F-Admin G-Oper Error H-Other riction ng ination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)				

PAGE 2-029

a

4

8

BROWNS FERRY 1 * FAC	CILITY DATA Report
ACILITY DESCRIPTION	UTILITY & CONTRACTOR INFORMATION
LOCATION STATEALABAMA	UTILITY LICENSEETENNESSEE VALLEY AUTHORITY
COUNTYLIMESTONE	CORPORATE ADDRESS
DIST AND DIRECTION FROM NEAREST POPULATION CTR10 MI NW OF DECATUR, ALA	CONTRACTOR ARCHITECT/ENGINEERTENNESSEE VALLEY AUTHORITY
TYPE OF REACTOR BWR	NUC STEAM SYS SUPPLIERGENERAL ELECTRIC
DATE INITIAL CRITICALITY AUGUST 17, 1973	CONSTRUCTOR TENNESSEE VALLEY AUTHORITY
DATE ELEC ENER 1ST GENER OCTOBER 15, 1973	TURBINE SUPPLIERGENERAL ELECTRIC
DATE COMMERCIAL OPERATEAUGUST 1, 1974	REGULATORY INFORMATION
CONDENSER COOLING METHODONCE THRU	IE REGION RESPONSIBLEII
CONDENSER COOLING WATERTENNESSEE RIVER	IE RESIDENT INSPECTORJ. PAULK
	LICENSING PROLIMANACER I GEARS

INSPECTION

ELECTRIC RELIABILITY RELIABILITY COUNCIL

ort Period APR 1988

WER II E 374C1 ITY ITY LICENSING PROJ MANAGER..... DOCKET NUMBER 50-259 LICENSE & DATE ISSUANCE.... DPR-33, DECEMBER 20, 1973 PUBLIC DOCUMENT ROOM ATHENS PUBLIC LIBRARY SOUTH AND FORREST

ATHENS, ALABAMA 35611

INSPECTION SUMMARY

+ INSPECTION JANUARY 6-13 (88-01): THIS ANNOUNCED SPECIAL INSPECTION WAS CONDUCTED IN THE CORPORATE OFFICES IN CHATTANOOGA TO REVIEW THE LICENSEE'S CORRECTIVE MEASURES IN RESPONSE TO UNRESOLVED ITEM NO. 50-259,260 AND 296/86-37-01 AND 50-327 AND 328/86-58-01. THE UNRESOLVED ITEM IS CLOSED.

STATUS

INSPECTION MARCH 14-21 (88-06): THIS ROUTINE, ANNOUNCED INSPECTION WAS IN THE AREAS OF ULTRASONIC EXAMINATION OF UNIT 2 REACTOR VESSEL SHROUD ACCESS COVER AS REFERENCED IN NRC INFORMATION NOTICE NO. 88-03 AND GENERAL ELECTRIC (GE) SURVEILLANCE INSTRUCTION LETTER (SIL) NO. 462 AND INSERVICE INSPECTION STATUS FOR UNITS 1 AND 3. ONE VIOLATION WAS IDENTIFIED - FAILURE TO FOLLOW PROCEDURE FOR PREVENTION OF FOREIGN MATERIAL IN REACTOR VESSEL CAVITY.

INSPECTION MARCH 22-24 (88-08): THIS SPECIAL, ANNOUNCED INSPECTION WAS CONDUCTED TO ENSURE THAT OPERATORS IN GROUP 4 DF YOUR ACCELERATED REQUALIFICATION TRAINING COURSE HAD SATISFACTORILY COMPLETED THE COURSE AND ARE READY TO PERFORM LICENSED DUTIES IN THE SHUTDOWN AND REFUELING MODES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN THIS REPORT.

INSPECTION APRIL 4-8 (88-09): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED REVIEW AND EVALUATION OF THE LICENSEE'S EMERGENCY PREPAREDNESS PROGRAM. NO VIOLATIONS UR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

FAILURE TO MAINTAIN AND FOLLOW CONTROL AND ACCOUNTABILITY FOR NON FUEL SNM. FAILURE TO UPDATE INTERNAL RECORDS IN A TIMELY MANNER.

(8702 4)

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION II, CRITERION V, CRITERION XVII, QA TOPICAL REPORT TABLE 17E-1, NUCLEAR QUALITY ASSURANCE MANUAL (NQAM), PART 1, SECTION 2.17, AND NUCLEAR ENGINEERING PROCEDURE 1.2, REV. 1, AS OF OCTOBER 1987, DNE TRAINING AND DOCUMENTATION FAILED TO MEET THE FOLLOWING REQUIREMENTS OF NEP-1.2: (1) THE ASSISTANT CHIEF MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 30 OF 40 REQUIRED TRAINING SUBJECTS. A LEAD MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 35 OF 40 REQUIRED TRAINING SUBJECTS. (2) WATTS BAR SITE-SPECIFIED TRAINING REQUIREMENTS WERE LESS THAN THE TRAIN.NG PROGRAM SPECIFIED BY NEP-1.2. A TYPICAL EXAMPLE CONCERNS A WATTS BAR ASSISTANT PROJECT ENGINEER (APE), WHOSE SITE-SPECIFIED TRAINING REQUIREMENTS DID NOT INCLUDE SEVEN AREAS REQUIRED BY NEP-1.2. (3) THE LICENSEE WAS UNABLE TO CONFIRM THAT REQUIREMENTS OF THE TRAINING MATRIX HAD BEEN ACCOMPLISHED FOR FIVE MECHANICAL ENGINEERING BRANGH (MEB) PERSONNEL AND TWO WATTS BAR APES. SINCE AN ADDITIONAL OPPORTUNITY TO CONFIRM THE ABOVE TRAINING WAS AFFORDED SUBSEQUENT TO THE EXIT INTERVIEW AND THE TRAINING WAS NOT CONFIRMED, THE TRAINING WAS NOT CONDUCTED.

CONTRARY TO 10 CFR PART 50, APPFNDIX B, CRITIRION XVIII, CRITERION XVI, AND NQAM, PART 1, SECTION 2.18, REV. 0, 10 AUDITS FROM 1985 TO JANUARY 1987 IDENTIFIED TRAINING DEFICIENCIES WHICH, AT THE TIME OF THE INSPECTION, HAD NOT BEEN CORRECTED. (8703 4)

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION V, AND NEP 1.3, REV. 0, CORRECTIONS WERE MADE TO NUMEROUS DOCUMENTS IN A MANNER NOT IN CONFORMANCE WITH THE ONE LINE, INITIAL, AND DATE METHOD. (8703 5)

CONTRARY TO TECHNICAL SPECIFICATION (TS) 4.7.8.2.A, THE TEST PERFORMED ON SGTS TRAIN B NOVEMBER 25, 1987, TO SATISFY THIS REQUIREMENT FOLLOWING A FIRE IN THE UNIT 2 DRYMELL DID NOT COMPLY WITH ANSI N510-1975 IN THE FOLLOWING EXAMPLES: (1) THE FREON GAS GENERATOR OUTPUT WAS NOT HELD TO PLUS OR MINUS 20% OF THE PRE-SET VALUE AS SPECIFIED IN STEP 12.4.3 OF ANSI N510-1975. (2) THE UPSIREAM CONCENTRATION OF FREON TRACER GAS WAS NOT LIMITED TO 20 PPM AS SPECIFIED IN STEP 12.4.3 OF ANSI N510-1975. (2) (8704 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

ENVIRONMENTAL QUALIFICATION WORK.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

TVA APPOINTED MR. JOHN WALKER TO PLANT MANAGER POSITION.

PLANT STATUS:

SHUTDOWN FOR REPAIRS ON 03/19.

Report Period APR 1988 INSPECTION STATUS - (CONTINUED)

****** BROWNS FERRY 1 ×

OTHER ITEMS

LAST IE SITE INSPECTION DATE: APRIL 4-8, 1988 *

INSPECTION REPORT NO: 50-259/88-09 +

REPORTS FROM LICENSEE

*********	**********		
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-013	03/28/88	04/26/88	RADIATION MONITOR SPIKE INITIATES CONTROL ROOM EMERGENCY VENTILATION
*********			***************************************

PAGE 2-033 ١] THIS PAGE INTENTIONALLY LEFT BLANK

1.1	Docket: <u>50-260</u> 0	PERAT	INGS	TATUS					
2. 1	Reporting Period:04/01/8	0utage	+ On-line	Hrs: 719.0					
3.4	Utility Contact: D. CRAWFORD (205) 729-2507								
4. 1	Licensed Thermal Power (MWt): 3293								
5.1	Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152								
6.1	Design Electrical Rating (let MHe):		1065					
7.1	Maximum Dependable Capacity	Gross MW	le):	1098					
8.1	Maximum Dependable Capacity	(Net MWe)	:	1065					
9.1	If Changes Occur Above Sin	ce Last Rep	ort, Give	Reasons:					
	NONE								
10. 1	Power Level To Which Restr	icted, If A	ny (Net Mi	le):					
11. 8	Reasons for Restrictions,	If Any:							
	NONE								
12.1	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 115,440.0					
13. 1	Hours Reactor Critical	. 0	.0	55,859.6					
14. 1	Rx Reserve Shtdwn Prs	. 0		14,200.4					
15. 1	Hrs Generator On-Line	. 0		54,338.5					
16.1	Unit Reserve Shtdwn Hrs	. 0	. 0	.0					
17. 1	Gross Therm Ener (MWH)	0	0	153,245,167					
18. 1	Gross Elec Ener (MWH)	0	0	50,771,798					
19.1	Net Elec Ener (MWH)	-1,924	-7,666	49,176,167					
20. 1	Unit Service Factor	. 0	.0	47.1					
21.	Unit Avail Factor	. 0		47.1					
22.	Unit Cap Factor (MDC Net)	. 0	0	40.0					
23.	Unit Cap Factor (DER Net)	. 0	.0	40.0					
24.	Unit Forced Outage Rate	100.0	100.0	42.1					
25.	Forced Outage Hours	719.0	2,903.0	39,656.4					
26.	Shutdowns Sched Over Next	6 Months (1	ype,Date,	Duration):					
27	16 Currently Shutdown Esti	mated Start	un Date:	NZA					



Report Period APR 1988	UNIT SHUTDOWNS / R	E D U C T I O N S ***********************************
No. Date Type Hours Reason M	Method LER Number System Component	Cause & Corrective Action to Prevent Recurrence
305 09/15/84 F 719.0 F	4	ADMINISTRATIVE HOLD TO RESOLVE VARIOUS TVA AND NRC CONCERNS.

Type	Reason	Method	System & Component		
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)		

*********** BROWNS FERRY 2 ********

FACILITY DESCRIPTION

LOCATION STATE.....ALABAMA

COUNTY LIMESTONE

DIST AND DIRECTION FROM NEAREST POPULATION CTR...10 MI NW OF DECATUR, ALA

TYPE OF REACTOR BWR

DATE INITIAL CRITICALITY ... JULY 20, 1974

DATE ELEC ENER 1ST GENER. . . AUGUST 23, 1974

DATE COMMERCIAL OPERATE ... MARCH 1, 1975

CONDENSER COOLING METHOD ... ONCE THRU

CONDENSER COOLING WATER....TENNESSEE RIVER

ELECTRIC RELIABILITY

RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

CHATTANOOGA, TENNESSEE 37401

CONTRACTOR ARCHITECT/ENGINEER..... TENNESSEE VALLEY AUTHORITY

NUC STEAM SYS SUPPLIER ... GENERAL ELECTRIC

CONSTRUCTOR......TENNESSEE VALLEY AUTHORITY

REGULATORY INFORMATION

IE REGION RESPONSIBLE......II

IE RESIDENT INSPECTOR.....J. PAULK

LICENSING PROJ MANAGER.....J. GEARS

LICENSE & DATE ISSUANCE.... DPR-52, AUGUST 2, 1974

PUBLIC DOCUMENT ROOM......ATHENS PUBLIC LIBRARY SOUTH AND FORREST ATHENS, ALABAMA 35611

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION JANUARY 6-13 (88-01): THIS ANNOUNCED SPECIAL INSPECTION WAS CONDUCTED IN THE CORPORATE OFFICES IN CHATTANOOGA TO REVIEW THE LICENSEE'S CORRECTIVE MEASURES IN RESPONSE TO UNRESOLVED ITEM NO. 50-259,260 AND 296/86-37-01 AND 50-327 AND 328/86-58-01. THE UNRESOLVED ITEM IS CLOSED.

INSPECTION MARCH 14-21 (88-06): THIS ROUTINE, ANNOUNCED INSPECTION WAS IN THE AREAS OF ULTRASONIC EXAMINATION OF UNIT 2 REACTOR VESSEL SHROUD ACCESS COVER AS REFERENCED IN NRC INFORMATION NOTICE NO. 88-03 AND GENERAL ELECTRIC (GE) SURVEILLANCE INSTRUCTION LETTER (SIL) NO. 462 AND INSERVICE INSPECTION STATUS FOR UNITS 1 AND 3. ONE VIOLATION WAS IDENTIFIED - FAILURE TO FOLLOW PROCEDURE FOR PREVENTION OF FOREIGN MATERIAL IN REACTOR VESSEL CAVITY.

IN SPECTION MARCH 22-24 (88-08): THIS SPECIAL, ANNOUNCED INSPECTION WAS CONDUCTED TO ENSURE THAT OPERATORS IN GROUP 4 OF YOUR ACCELERATED REQUALIFICATION TRAINING COURSE HAD SATISFACTORILY COMPLETED THE COURSE AND ARE READY TO PERFORM LICENSED DUTIES IN THE SHUTDOWN AND REFUELING MODES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN THIS REPORT.

INSPECTION APRIL 4-8 (88-09): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED REVIEW AND EVALUATION OF THE LICENSEE'S EMERGENCY PREPAREDNESS PROGRAM. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

PAGE 2-036

Report Period APR 1988

INSPECTION STATUS - (CONTINUED)

ENFORCEMENT SUMMARY

FAILURE TO MAINTAIN AND FOLLOW CONTROL AND ACCOUNTABILITY FOR NON FUEL SNM. FAILURE TO UPDATE INTERNAL RECORDS IN A TIMELY MANNER.

(8702 4)

CONTRARY TC 10 CFR 50, APPENDIX B, CRITERION II, CRITERION V, CRITERION XVII, QA TOPICAL REPORT TABLE 17E-1, NUCLEAR QUALITY ASSURANCE MANUAL (NQAM), PART 1, SECTION 2.17, AND NUCLEAR ENGINEERING PROCEDURE 1.2, REV. 1, AS OF OCTOBER 1987, DNE TRAINING AND DOCUMENTATION FAILED TO MEET THE FOLLOWING REQUIREMENTS OF NEP-1.2: (1) THE ASSISTANT CHIEF MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 30 OF 40 REQUIRED TRAINING SUBJECTS. A LEAD MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 30 OF 40 REQUIRED TRAINING SUBJECTS. A LEAD MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 55 OF 40 REQUIRED TRAINING SUBJECTS. (2) WATTS BAR SITE-SPECIFIED TRAINING REQUIREMENTS WERE LESS THAN THE TRAINING PROGRAM SPECIFIED BY NEP-1.2. A TYPICAL EXAMPLE CONCERNS A WATTS BAR ASSISTANT PROJECT ENGINEER (APE), WHOSE SITE-SPECIFIED TRAINING REQUIREMENTS DID NOT INCLUDE SEVEN AREAS REQUIRED BY NEP-1.2. (3) THE LICENSEE WAS UNABLE TO CONFIRM THAT REQUIREMENTS OF THE TRAINING MATRIX HAD BEEN ACCOMPLISHED FOR FIVE MECHANICAL ENGINEERING BRANCH (MEB) PERSONNEL AND TWO WATTS BAR APES. SINCE AN ADDITIONAL OPPORTUNITY TO CONFIRM THE ABOVE TRAINING WAS AFFORDED SUBSEQUENT TO THE EXIT INTERVIEW AND THE TRAINING WAS NOT CONFIRMED, THE NRC CONCLUDES THAT THE TRAINING WAS NOT CONDUCTED.

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION XVIII, CRITERION XVI, AND NQAM, PART 1, SECTION 2.18, REV. 0, 10 AUDITS FROM 1985 TO JANUARY 1987 IDENTIFIED TRAINING DEFICIENCIES WHICH, AT THE TIME OF THE INSPECTION, HAD NOT BEEN CORRECTED. (8703 4)

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION V, AND NEP 1.3, REV. 0, CORRECTIONS WERE MADE TO NUMEROUS DOCUMENTS IN A MANNER NOT IN CONFORMANCE WITH THE ONE LINE, INITIAL, AND DATE METHOD. (8703 5)

CONTRARY TO TECHNICAL SPECIFICATION (TS) 4.7.8.2.A, THE TEST PERFORMED ON SGTS TRAIN B NOVEMBER 25, 1987, TO SATISFY THIS REQUIREMENT FOLLOWING A FIRE IN THE UNIT 2 DRYWELL DID NOT COMPLY WITH ANSI N510-1975 IN THE FOLLOWING EXAMPLES: (1) THE FREON GAS GENERATOR OUTPUT WAS NOT HELD TO PLUS OR MINUS 20% OF THE PRE-SET VALUE AS SPECIFIED IN STEP 12.4.3 OF ANSI N510-1975. (2) THE UPSTREAM CONCENTRATION OF FREON TRACER GAS WAS NOT LIMITED TO 20 PPM AS SPECIFIED IN STEP 12.4.3 OF ANSI N510-1975.

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

TVA APPOINTED MR. JOHN WALKER TO PLANT MANAGER POSITION.

PLANT STATUS:

SHUTDOWN ON SEPTEMBER 15, 1984 FOR REFUELING OUTAGE.

0.7			 C 14 C
	н	- HC	 PPD-
~ .		- Th	 Sector Sector
_			

LAST IE SITE INSPECTION DATE: APRIL 4-8, 1988 +

INSPECTION REPORT NO: 50-260/88-09 +

REPORTS FROM LICENSEE

	*********		***********	************	***********	***********	************	 ********************
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT					
NONE.								
				*************		*************	***********	 ****************

PAGE 2-039 . ,ei 1 1 1 THIS PAGE INTENTIONALLY LEFT BLANK --• .

10

1. D	ocket: <u>50-296</u> 0	PERAT	ING S	TATUS					
2. R	eporting Period:	0utage	+ Jn-line	Hrs: 719.0					
3. U	tility Contact: J. D. CR	WFORD (205) 729-2507						
4. L	Licensed Thermal Power (MWt): 3293								
5. N	ameplate Rating (Gross MW	2):	1280 X	0.9 = 1152					
6. D	esign Electrical Rating (Net MWe):	a Real and Color	1065					
7. M	aximum Dependable Capacity	Gross MW	e):	1098					
8. M	aximum Dependable Capacity	(Net MWe)	s	1065					
9. I	f Changes Occur Above Sind	ce Last Rep	ort, Give	Reasons:					
N	ONE								
10. P	ower Level To Which Restr	icted, If A	ny (Net M	le):					
11. R	easons for Restrictions,	If Any:							
N	ONE								
12. R	eport Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE					
13. H	ours Reactor Critical	. 0	. 0	45,306.8					
14. R	× Reserve Shtdwn Hrs	.0	.0	5,149.4					
15. H	rs Generator On-Line	. 0	. 0	44,195.6					
16. U	nit Reserve Shtdwn Hrs	.0	. 0						
17. G	ross Therm Ener (MWH)	0	0	131,846,076					
18. G	ross Elec Ener (MWH)	0	0	43, 473, 760					
19. N	et Elec Ener (MWH)	-1,763	-10,530	42,031,538					
20. U	nit Service Factor	. 0	. 0	45,1					
21. U	nit Avail Factor	. 0	.0	45.1					
22. U	nit Cap Factor (MDC Net)	. 0	.0	40.3					
23. U	nit Cap Factor (DER Net)	. 0		40.3					
24. U	nit Forced Outage Rate	100.0	100.0	43.2					
25. F	orced Outage Hours	719.0	2,903.0	33,640.4					
26. S	hutdowns Sched Over Next	6 Months (1	ype,Date,	Duration):					
27 7	f Currently Shutdown Feti	mated Start	up Date:	N/A					





UNIT SHUTDOWNS / REDUCTIONS * BROWNS FERRY 3

1

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
157	03/03/85	F	719.0	F	4				ADMINISTRATIVE HOLD TO RESOLVE VARIOUS

****** BROWN'S FERRY 3 REMAINED ON ADMINISTRATIVE * SUMMARY * HOLD IN MARCH IN ORDER TO RESOLVE VARIOUS ************ TVA AND NRC CONCERNS.

Type	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE.....ALABAMA

COUNTY.....LIMESTONE

DIST AND DIRECTION FROM NEAREST POPULATION CTR...10 MI NW OF DECATUR, ALA

TYPE OF REACTOR BWR

DATE INITIAL CRITICALITY... AUGUST 8, 1976

DATE ELEC ENER 1ST GENER...SEPTEMBER 12, 1976

DATE COMMERCIAL OPERATE....MARCH 1, 1977

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....TENNESSEE RIVER

ELECTRIC RELIABILITY

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

CONTRACTOR ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR......TENNESSEE VALLEY AUTHORITY

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....J. PAULK

LICENSING PROJ MANAGER....J. GEARS DOCKET NUMBER.....50-296

LICENSE & DATE ISSUANCE.... DPR-68, AUGUST 18, 1976

PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY SOUTH AND FORREST ATHENS, ALABAMA 35611

INSPECTION STATUS

SPECTION SUMMARY

+ INSPECTION JANUARY 6-13 (88-01): THIS ANNOUNCED SPECIAL INSPECTION WAS CONDUCTED IN THE CORPORATE OFFICES IN CHATTANOOGA TO REVIEW THE LICENSEE'S CORRECTIVE MEASURES IN RESPONST TO UNRESOLVED ITEM NO. 50-259,260 AND 296/86-37-01 AND 50-327 AND 328/86-58-01. THE UNRESOLVED ITEM IS CLOSED.

INSPECTION MARCH 14-21 (88-06): THIS ROUTINE, ANNOUNCED INSPECTION WAS IN THE AREAS OF ULTRASONIC EXAMINATION OF UNIT 2 REACTOR VESSEL SHROUD ACCESS COVER AS REFERENCED IN NRC INFORMATION NOTICE NO. 88-03 AND GENERAL ELECTRIC (GE) SURVEILLANCE INSTRUCTION LETTER (SIL) NO. 462 AND INSERVICE INSPECTION STATUS FOR UNITS 1 AND 3. ONE VIOLATION WAS IDENTIFIED - FAILURE TO FOLLOW PROCEDURE FOR PREVENTION OF FOREIGN MATERIAL IN REACTOR VESSEL CAVITY.

INSPECTION MARCH 22-24 (88-08): THIS SPECIAL, ANNOUNCED INSPECTION WAS CONDUCTED TO ENSURE THAT OPERATORS IN GROUP 4 OF YOUR ACCELERATED REQUALIFICATION TRAINING COURSE HAD SATISFACTORILY COMPLETED THE COURSE AND ARE READY TO PERFORM LICENSED DUTIES IN THE SHUTDOWN AND REFUELING MODES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN THIS REPORT.

INSPECTION APRIL 4-8 (88-09): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED REVIEW AND EVALUATION OF THE LICENSEE'S EMERGENCY PREPAREDNESS PROGRAM. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION STATUS - (CONTINUED)

ENFORCEMENT SUMMARY

FAILURE TO MAINTAIN AND FOLLOW CONTROL AND ACCOUNTABILITY FOR NON FUEL SNM. FAILURE TO UPDATE INTERNAL RECORDS IN A TIMELY MANNER.

(8702 4)

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION II, CRITERION V, CRITERION XVII, QA TOPICAL REPORT TABLE 17E-1, NUCLEAR QUALITY ASSURANCE MANUAL (NQAM), PART 1, SECTION 2.17, AND NUCLEAR ENGINEERING PROCEDURE 1.2, REV. 1, AS OF OCTOBER 1987, DNE TRAINING AND DOCUMENTATION FAILED TO MEET THE FOLLOWING REQUIREMENTS OF NEP-1.2: (1) THE ASSISTANT CHIEF MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 30 OF 40 REQUIRED TRAINING SUBJECTS. A LEAD MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 30 OF 40 REQUIRED TRAINING SUBJECTS. (2) WATTS BAR SITE-SPECIFIED TRAINING REQUIREMENTS WERE LESS THAN THE TRAINING PROGRAM SPECIFIED BY NEP-1.2. A TYPICAL EXAMPLE CONCERNS A WATTS BAR ASSISTANT PROJECT ENGINEER (APE), WHOSE SITE-SPECIFIED TRAINING REQUIREMENTS DID NOT INCLUDE SEVEN AREAS REQUIRED BY NEP-1.2. (3) THE LICENSEE WAS UNABLE TO CONFIRM THAT REQUIREMENTS OF THE TRAINING MATRIX HAD BEEN ACCOMPLISHED FOR FIVE MECHANICAL ENGINEFRING BRANCH (MEB) PERSONNEL AND TWO WATTS BAR APES. SINCE AN CONFIRMED, THE NRC CONCLUDES THAT THE TRAINING WAS NOT CONDUCTED.

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION XVIII, CRITERION XVI, AND NQAM, PART 1, SECTION 2.18, REV. 0, 10 AUDITS FROM 1985 TO JANUARY 1987 IDENTIFIED TRAINING DEFICIENCIES WHICH, AT THE TIME OF THE INSPECTION, HAD NOT BEEN CORRECTED. (8703 4)

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION V, AND NEP 1.3, REV. 0, CORRECTIONS WERE MADE TO NUMEROUS DOCUMENTS IN A MANNER NOT IN CONFORMANCE WITH THE ONE LINE, INITIAL, AND DATE METHOD. (8703 5)

CONTRARY TO TECHNICAL SPECIFICATION (TS) 4.7.8.2.A, THE TEST PERFORMED ON SGTS TRAIN B NOVEMBER 25, 1987, TO SATISFY THIS REQUIREMENT FOLLOWING A FIRE IN THE UNIT 2 DRYWELL DID NOT COMPLY WITH ANSI N510-1975 IN THE FOLLOWING EXAMPLES: (1) THE FREON GAS GENERATOR OUTPUT WAS NOT HELD TO PLUS OR MINUS 20% OF THE PRE-SET VALUE AS SPECIFIED IN STEP 12.4.3 OF ANSI N510-1975. (2) THE UPSTREAM CONCENTRATION OF FREON TRACER GAS WAS NOT LIMITED TO 20 PPM AS SPECIFIED IN STEP 12.4.3 OF ANSI N510-1975. (8704 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

LICENSEE EVALUATING CAUSE OF REACTOR VESSEL WATER LEVEL INDICATION PROBLEMS.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

TVA APPOINTED MR. JOHN WALKER TO PLANT MANAGER POSITION.

PLANT STATUS:

SHUTDOWN ON MARCH 9, 1985.

OTHER ITEMS

LAST IE SITE INSPECTIO	N DATE: APRIL 4-8,	1988 +		
INSPECTION REPORT NO:	50-296/88-09 +			
		REPORTS	FROM LICENSEE	
*****************	**********************	**************		
NUMBER DATE OF	DATE OF SUBJECT			

EVENT REPORT

THIS PAGE INTENTIONALLY LEFT BLANK

1.1	Docket: 50-325	DPERAT	INGS	TATUS					
2.	Reporting Period: 04/01/1	88_ Outage	+ On-line	Hrs: 719.0					
3.	Utility Contact: FRANCES HARRISON (919) 457-2756								
G .	Licensed Thermal Power (MWt):2436								
5.	Nameplate Rating (Gross MWe): 963 X 0.9 = 867								
6.	Design Electrical Rating	(Net MWe):		821					
7.	Maximum Dependable Capaci	ty (Gross M	Wo):	815					
8.	Maximum Dependable Capacit	ty (Net MWe		790					
9.	If Changes Occur Above Sin	nce Last Re	port, Give	Reasons:					
	NONE								
10.	Power Level To Which Rest	ricted, If	Any (Net M	le):					
11.	Reasons for Restrictions,	If Any:							
	NONE								
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 97,488.0					
13.	Hours Reactor Critical	719.0	2,249.8	63,187.5					
14.	Rx Reserve Shtdwn Hrs	. 0		1,647.1					
5.	Hrs Generator On-Line	719.0	2,180.6	60,041.3					
16.	Unit Reserve Shtdwn Hrs			. 0					
17.	Gross Therm Ener (MMH)	1,669,936	5,108,689	127,088,225					
18.	Gross Elec Ener (MWH)	553,025	1,684,420	41,793,967					
9.	Net Elec Ener (MWH)	537,142	1,631,013	40,210,145					
20.	Unit Service Factor	100.0	75.1	61.6					
21.	Unit Avail Factor	100.0	75.1	61.6					
22.	Unit Cap Factor (MDC Net)	94.6	71.1	52.2					
23.	Unit Cap Factor (DER Net)	91.0	68.4	50.2					
24	Unit Forced Outage Rate	.0		15.1					
64.		0	.0	10,619.7					
25.	Forced Outage Hours								





APRIL 1988

********************************** BRUNSWICK 1

Report Period APR 1988

UNIT CHUTDOWNS / REDUCTIONS *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88020	04/08/88	s	0.0	Α	5				REDUCE POWER TO MAKE DRYWELL ENTRY TO ADD OIL TO RECIRC PUMP
88022	04/10/88	s	0.0	В	5				REDUCE POWER FOR CONTROL ROD PATTERN CHANGE.
88023	04/13/88	5	0.0	В	5				REDUCE POWER FOR CONTROL ROD PATTERN CHANGE.
88021	04/23/88	5	0.0	В	5				REDUCE POWER FOR CONTROL ROD PATTERN CHANGE.
88026	04/26/88	F	0.0	Α	5				18 REACTOR RECIRCULATION PUMP MG SET FIELD BREAKER TRIP.
88027	04/26/88	F	0.0	A	5				18 REACTOR FEED PUMP BECAME STEAM BOUND FOLLOWING REACTOR RECIRCULATION PUMP TRIP (EVENT NO. 88026)
88628	04/27/88	S	0.0	В	5				REDUCE POWER FOR CONTROL ROD PATTERN CHANGE.
88029	04/28/88	s	0.0	Α	5				1C CIRCULATING WATER JATAKE PUMP TRAVELING SCREEN CHAIN DRIVE HAD A CRACKED SIDEBAR. POWER REDUCED TO CHANGE DUT SIDEBAR.

********* BRUNSWICK 1 INCURRED 8 POWER REDUCTIONS

* SUMMARY * ********

IN APRIL FOR REASONS STATED ABOVE.

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161

FACILITY DESCRIPTION

LOCATION STATE.....NORTH CAROLINA

COUNTY.....BRUNSWICK

DIST AND DIRECTION FROM NEAREST POPULATION CTR...3 MI N OF SGUTHPORT, NC

TYPE OF REACTOR......BWR

DATE INITIAL CRITICALITY... OCTOBER 8, 1976

DATE ELEC ENER 1ST GENER... DECEMBER 4, 1976

DATE COMMERCIAL OPERATE.... MARCH 18, 1977

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER....CAPE FEAR RIVER

ELECTRIC RELIABILITY

COUNCIL......SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....CAROLINA POWER & LIGHT

CORPORATE ADDRESS......P. 0. BOX 1551 RALEIGH, NORTH CAROLINA 27602

CONTRACTOR ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR......BROWN & ROOT

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....W. RULAND

LICENSING PROJ MANAGER.....E. SYLVESTER DOCKET NUMBER......50-325

LICENSE & DATE ISSUANCE.... DPR-71, NOVEMBER 12, 1976

PUBLIC DOCUMENT ROOM......RANDALL LIBRARY UNIV OF N.C. AT WILMINGTON 601 S. COLLEGE ROAD WILMINGTON, N. C. 28403

INSPECTION SUMMARY

INSPECTION STATUS

+ INSPECTION MARCH 7-11 (88-13): THIS ROUTINE, ANNOUNCED INSPECTION WAS IN THE AREAS OF THE PREVIOUS OPEN ITEMS AND MARK I CONTAINMENT LONG TERM PROGRAM MODIFICATION. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TS 4.0.5.4.2 AND 6.8.1, ASME SECTION XI, REQUIREMENTS FOR STROKE TIMING POWER OPERATED VALVES WERE NOT PROPERLY IMPLEMENTED. CONTRARY TO TS 6.12.2, ON NOVEMBER 12, 1987, AN AUXILIARY EQUIPMENT OPERATOR (AEO) WHILE PERFORMING DAILY ROUNDS OF PLANT SYSTEMS UNLOCKED THE ENTRANCE TO THE UNIT 2, 80 FOOT EAST FUEL POOL HEAT EXCHANGER ROOM, A HIGH RADIATION AREA, AND LEFT THE AREA UNATTENDED. CONTRARY TO TS 6.11.1, TS 6.8.1, RG 1.33, APPENDIX A, SECTION I.3, PLANT PROCEDURE ENP-46, RADIATION CONTROL AND PROTECTION PROCEDURE, VOLUME VIII, SECTION 6.6.2 AND SECTION 6.6.3, THE LICENSEE FAILED TO ESTABLISH ADEQUATE RADIATION PROTECTION PROCEDURES CONCERNING HANDLING OF IRRADIATED DRY TUBES AND USING PERSONNEL MONITORING DEVICES, AND TO ADHERE TO A RADIATION (8800 4)

CONTRARY TS 3.8.1.1.B, REQUIREMENTS WERE NOT MET IN THAT, WITH TWO DIESEL GENERATORS INOPERABLE ON JANUARY 5, 1988, AT 3:52 P.M., THE REMAINING OPERABLE DIESEL GENERATORS WERE NOT OPERATED AT LEAST AT 1750 KW FOR 15 MINUTES WITHIN 2 HOURS. DIESEL GENERATOR

PAGE 2-048

Report Period APR 1988

INSPECTION STATUS - (CONTINUED)

ENFORCEMENT SUMMARY

ND. 4 COMPLETED ITS 15 MINUTE RUN AT 6:00 P.M., ON JANGARY 5, 1988. (8800 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ GE CR305 SERIES AUXILIARY CONTACTS (REPLACED GE CR205) USED IN SAFETY RELATED SYSTEMS WERE FOUND TO BE SICKING, AND CONSEQUENITY CAUSING VALVE FAILURE. GE HAS CORRECTED RELATED MANUFACTURING PROBLEM, AND IS PRESENTLY TESTING THE CR305 REPLACEMENT BEFORE INSTALLATION INTO BOTH UNITS.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

+ PLANT OPERATION AT 100% POWER.

LAST IE SITE INSPECTION DATE: MARCH 7-11, 1988 +

INSPECTION REPORT NO: 50-325/88-13 +

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-009	03/09/88	04/05/88	ACCIDENTIAL DEENERGIZATION OF UNIT 2 PROCESS OFF-GAS RAD MONITOR AND REACTOR BLD3 VENTILATION EXHAUST RAD M ONI DURING MAINT.

	Docket: 50-324 0	PERAT	INGS	TATUS					
2.	Reporting Period: 04/01/88 Outage + On-line Hrs: 719.0								
3.	Utility Contact: FRANCES HARRISON (919) 457-2756								
4.	Licensed Thermal Power (MWt):2436								
5.	Nameplate Rating (Gross MWe): 963 X 0.9 = 867								
6.	Design Electrical Rating (Net MWe): 821								
7.	Maximum Dependable Capacity (Gross MWe): 815								
8.	Maximum Dependable Capacit	y (Net MWe)	1	790					
9.	If Changes Occur Above Since Last Report, Give Reasons: NGME								
10.	Power Level To Which Restr	icted, If A	ny (Net M	le):					
11.	Reasons for Restrictions,	If Any:							
	NONE								
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 109,512.0					
13.	Hours Reactor Critical	124.2	148.5	67,221.5					
14.	Rx Reserve Shtdwn Hrs	.0	. 0	. 0					
15.	Hrs Generator On-Line	44.9	69.2	63,315.7					
16.	Unit Reserve Shtdwn Frs	. 0	. 0						
17.	Gross Therm Ener (MWH)	29,407	67,122	126,654,601					
18.	Gross Elec Ener (MWH)	10,140	22,050	41,763,582					
19.	Net Elec Ener (MWH)	928	-554	40,042,275					
	Unit Service Factor	6.2	2.4	57.8					
20.				57.8					
20. 21.	Unit Avail Factor	6.2	2.4						
20. 21. 22.	Unit Avail Factor Unit Cap Factor (MDC Net)	<u> </u>	.0	46.3					
20. 21. 22. 23.	Unit Avail Factor Unit Cap Factor (MDC Net) Unit Cap Factor (DER Net)	<u> 6.2</u> .2 .2	.0	46.3					
20. 21. 22. 23. 24.	Unit Avail Factor Unit Cap Factor (MDC Net) Unit Cap Factor (DER Net) Unit Forced Outage Rate	<u> </u>		46.3					
20. 21. 22. 23. 24. 25.	Unit Avail Factor Unit Cap Factor (MDC Net) Unit Cap Factor (DER Net) Unit Forced Outage Rate Forced Outage Hours	<u> 6.2</u> <u> .2</u> <u> 18.2</u> <u> 10.0</u>	0 0 12.7 10.1	46.3 44.5 14.9 11,469.9					



APRIL 1988

Report	Period A	PR 19	88		UN	ІТ ЅНИ	TDOW	NS / R	EDUCTIONS ************************************
No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88002	01/02/88	s	663.2	с	4		RC	FUELXX	COMPLETE REFUELING AND APPENDIX R MODIFICATIONS.
88003	04/28/88	F	10.0	A	3				TURBINE TRIP CAUSED BY LP TURBINE NO. 5 BEARING VIBRATION. TURBINE SHOT PERFORMED.
88005	04/29/88	s	0.9	в	2				PERFORM TURBINE OVERSPEED TESTING.

* SUMMARY	BRUNSWICK 2 OUTAGE IN A OUTAGES FOR	DMPLETED SCHEDULED REFUELD IL. SUBSEQUENTLY INCURRED EASONS STATED ABOVE.	NG 2	
Туре	Reason	Method	System & Componen	t

E-Forced	A-Fauin Failure F-Advin	1-Manual	Exhibit E & H
S-Sched	B-Maint or Test G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

PAGE 2-051

•

FACILITY DESCRIPTION

LOCATION STATE.....NORTH CAROLINA

COUNTY.....BRUNSWICK

DIST AND DIRECTION FROM NEAREST POPULATION CTR...3 MI N OF SOUTHPORT, NC

DATE INITIAL CRITICALITY...MARCH 20, 1975

DATE ELEC ENER 1ST GENER... APRIL 29, 1975

DATE COMMERCIAL OPERATE....NOVEMBER 3, 1975

CONDENSER COOLING METHOD ... ONCE THEU

CONDENSER COOLING WATER....CAPE FEAR RIVER

ELECTRIC RELIABILITY

COUNCIL.....SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE.....CAROLINA POWER & LIGHT

CORPORATE ADDRESS......411 FAYETTEVILLE STREET RALEIGH, NORTH CAROLINA 27602

CONTRACTOR ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS

NUC STEAM SYS SUPPLIER. ...GENERAL ELECTS C

CONSTRUCTOR BROWN & ROOT

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....W. RULAND

LICENSE & DATE ISSUANCE.... DPR-62, DECEMBER 27, 1974

PUBLIC DOCUMENT ROOM......RANDALL LIBRARY UNIV OF N.C. AT WILMINGTON 601 S. COLLEGE ROAD WILMINGTON, N. C. 28403

INSPECTION SUMMARY

+ INSPECTION MARCH 7-11 (88-13): THIS ROUTINE, ANNOUNCED INSPECTION WAS IN THE AREAS OF THE PREVIOUS OPEN ITEMS AND MARK I CONTAINMENT LONG TERM PROGRAM MODIFICATION. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TS 4.0.5.A.2 AND 6.8.1, ASME SECTION XI, REQUIREMENTS FOR STROKE TIMING POWER OPERATED VALVES WERE NOT PROPERLY IMPLEMENTED. CONTRARY TO TS 6.12.2, ON NOVEMBER 12, 1987, AN AUXILIARY EQUIPMENT OPERATOR (AEO) WHILE PERFORMING DAILY ROUNDS OF PLANT SYSTEMS UNLOCKED THE ENTRANCE TO THE UNIT 2, 80 FOOT EAST FUEL POOL HEAT EXCHANGER ROOM, A HIGH RADIATION AREA, AND LEFT THE AREA UNATTENDED. CONTRARY TO TS 6.11.1, TS 6.8.1, RG 1.33, APPENDIX 4, SECTION I.3, PLANT PROCEDURE EMP-46, RADIATION CONTROL AND PROTECTION PROCEDURE, VOLUME VIII, SECTION 6.6.2 AND SECTION 6.6.3, TO LICENSEE FAILED TO ESTABLISH ADEQUATE RADIATION PROTECTION PROCEDURES CONCERNING HANDLING OF IRRADIATED DRY TUBES AND USING PEPJONNEL MONITORING DEVICES, AND TO ADHERE TO A RADIATION CONTROL PROCEDURE. (8800 4)

CONTRARY TS 3.8.1.1.8, REQUIREMENTS WERE NOT MET IN THAT, WITH TWO DIESEL GENERATORS INOPERABLE ON JANUARY 5, 1988, AT 3:52 P.M., THE REMAINING OPERABLE DIESEL GENERATORS WERE NOT OPERATED AT LEAST AT 1750 KW FOR 15 MINUTES WITHIN 2 HOURS. DIESEL GENERATOR
Report Period APR 1988

ENFORCEMENT SUMMARY

NO. 4 COMPLETED ITS 15 MINUTE RUN AT 6:00 P.M., ON JANUARY 5, 1988. (8800 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ GE CR305 SERIES AUXILIARY CONTACTS (REPLACED GE CR205) USED IN SAFETY RELATED SYSTEMS WERE FOUND TO BE SICKING, AND CONSEQUENITY CAUSING VALVE FAILURE. GE HAS CORRECTED RELATED MANUFACTURING PROBLEM, AND IS PRESENTLY TESTING THE CR305 REPLACEMENT BEFORE INSTALLATION INTO BOTH UNITS.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

+ UNIT IS SHUTDOWN TO FACILITATE SILICON-BRONZE BOLT REPLACEMENT IN DC & MOTOR CON'ROL CABINETS.

LAST IE SITE INSPECTION DATE: MARCH 7-11, 1988 +

INSPECTION REPORT NO: 50-324/88-13 +

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT	
88-006	03/08/88	04/06/88	CONTROL ROD 10-39 UNKNOWINGLY WITHDRAWN WITH REACTOR PROTECTION SYSTEM SHORTING LINKS INS	TALLED
68-000	03/19/88	04/18/88	PINHOLE LEAKS AND LINEAR INDICATIONS IN THE INSERT AND WITHDRAW LINES OF UNIT 2 CONTROL R DRIVES	OD

1. Docket: _50-45	40	PERAT	ING S	TATUS							
2. Reporting Peri	od: 04/01/8	8_ Outage	+ On-line	Hrs: 719.0							
3. Utility Contac	. Utility Contact: D. J. SPIIZER (815) 234-5441 X2023										
4. Licensed Therm	3411										
5. Nameplate Rati	ng (Gross MW	le):		1175							
6. Design Electri	cal Rating (Net MWe):		1120							
7. Maximum Depend	able Capacit	y (Gross M	lile) :	1120							
8. Maximum Depend	able Capacit	y (Net MNe):	1120							
9. If Changes Occ	ur Above Sin	ice Last Re	port, Give	Reasons:							
10. Power Level To	Which Restr	icted, If	Any (Net Mk	le): 1097							
11. Reasons for Re	strictions,	If iny:									
STEAM GENERATO	R SPLIT FLOW										
12. Report Period	Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE							
13. Hours Reactor	Critical	368.7	2,552.7	17,864.9							
4. Rx Reserve Sht	dwn Hrs	. 0	. 0	37.8							
5. Hrs Generator	On-Line	359.1	2,543.1	17,504.1							
6. Unit Reserve S	htdwn Hrs	. 0	. 0								
7. Gross Therm En	er (MWH)	934,505	7,826,762	51,422,613							
8. Gross Elec Ene	r (MWH)	310,196	2,592,971	17,218,748							
9. Net Elec Ener	(MWH)	283,917	2,443,456	16,182,933							
0. Unit Service F	actor	49.9	87.5	76.1							
1. Unit Avail Fac	tor	49.9	87.6	76.1							
2. Unit Cap Facto	r (MDC Net)	35.3	75.2	62.8							
5. Unit Cap Factor	r (DER Net)	35.3	75.2	62.8							
4. Unit Forced Ou	tage Rate	15.4	2.5	5.3							
5. Forced Outage	Hours	65.3	65.3	977.4							
6. Shutdowns Sche	d Over Next	6 Months (Type,Date,D	Ouration):							
REFUELING 9/3/	88.		in the second is								





Report	Period Al	PR 19	88		UN	IT SHU	TDOWNS /	REDUCTIONS * CYRON 1 *
No.	Date	Type	Hours	Reason	Method	LER Number	System Componen	t Cause & Corrective Action to Prevent Recurrence
4	04/00/88	5	294.6	Α	1		SG	OUTAGE FOR SNUBBER INSPECTION AND 1D STEAM GENERATOR LEAK REPAIR.
5	04/18/88	F	65.3	Α	3	6-88-002-00		RX TRIP ON POWER RANGE FLUX RATE HIGH.
6	04/23/88	5	0.0	в	5			RE-ADJUST POWER RANGE N.I. "HIGH FLUX RX TRIP" SETPOINTS.

.

.

ņ

Type	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Costinued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161

****** BYRON 1 ****** FACILITY DESCRIPTION LOCATION STATE.....ILLINOIS DIST AND DIRECTION FROM NEAREST POPULATION CTR...17 MI SW OF ROCKFORD, ILL TYPE OF REACTOR PWR DATE INITIAL CRITICALITY... FEBRUARY 2, 1985 DATE ELEC ENER 1ST GENER...MARCH 1, 1985 DATE COMMERCIAL OPERATE SEPTEMBER 16, 1985 CONDENSER COOLING METHOD...CC HNDCT CONDENSER COOLING WATER ROCK RIVER ELECTRIC RELIABILITY INTERPOOL NETWORK

FACILITY DATA

HITILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE......COMMONWEALTH EDISON

CHICAGO, ILLINOIS 60690

CONTRACTOR ARCHITECT/ENGINEER...... SARGENT & LUNDY

NUC STEAM SYS SUPPLIER. .. WESTINGHOUSE

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....J. HINDS

LICENSING PROJ MANAGER.....L. OLSHAN

LICENSE & DATE ISSUANCE....NPF-37, FEBRUARY 14, 1985

PUBLIC DOCUMENT ROOM LIBRARIAN BUSINESS SCIENCE & TECHNOLOGY DEPT. ROCKFORD PUBLIC LIBRARY 215 NORTH WYMAN STREET ROCKFORD, ILLINOIS 61101

INSPECTION SUMMARY

Inspection from January 13 through March 17, 1988 (88005; 88004): Routine, unannounced safety inspection of licensee actions on previous inspection findings (92701, 92702) startup test results evaluation (72301, 72400, 72596, 72600, 72608, 72616, 72624); and startup test results verification (72301, 72596, 72600, 72608, 72616, 72624). No violations or deviations were identified. The licensee's review of the startup test results were adequate to address the results and any concerns identified during testing.

Inspection from February 12 - March 31, 1988 (88006; 20006): Routine, unannounced safety inspection by the resident inspectors of licensee action on previous inspection findings; licensee event reports; bulletins; generic letters; operations summary; training; surveillance; maintenance; operational safety and engineered safety features system walkdowns; event followup; followup of Region III requests; licensee action reports; engineering and technical support; and management changes. Of the 12 areas inspected, no violations or deviations were identified. One potential issue affecting the public's health and safety was identified (environmentally unqualified pressure switches).

ENFORCEMENT SUMMARY

NONE

INSPECTION STATUS

PAGE 2-056

Report Period APK 1988

******* × EYRON 1 ****

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

CHANGE NRC RESIDENT TO P. BROCHMAN NEW PLANT MANAGER, FRODUCTION SEPT.

PLANT STATUS:

UNIT 1 OPERATED AT POWER UP TO 98% ON LINE THE ENTIRE MONTH

LAST IE SITE INSPECTION DATE: \$3/31/88

INSPECTION REPORT NO: 88006

REPORTS FROM LICENSEE

	**********	**********		
NUMBER	DATE OF EVENT	DATE OF REPORT	UBJECT	

1.	Decket: <u>50-455</u> OPERATING	STATUS
2.	Reporting Period: 04/01/88 Outage + On-li	ine Hrs: 719.1
3.	Utility Contact: D. J. SPITZER (815)234-544	1 X2623
4.	Licensed Thermal Power (MWt):	3411
5.	Nameplate Rating (Gross MWe):	1175
6.	Design Electrical Rating (Net MWe):	1120
7.	Maximum Dependable Capacity (Gross MWe):	1120
8.	Maximum Dependable Capacity (Net MWe):	1120
9.	If Changes Occur Above Since Last Report, Gi	ve Reasons:
10.	Power Level To Which Restricted, If Any (Net	MWe): 1055

11. Reasons for Restrictions, If Any:___ STEAM GENERATOR SPLIT FLOW.

12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 6,096.0
13.	Hours Reactor Critical	719.0	2,888.6	5,215.8
14.	R× Reserve Shtdwn Hrs			. 0
15.	Hrs Generator On-Line	719.0	2,690.2	4,970.6
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	. 0
17.	Gross Therm Ener (MWH)	2,215,387	7,660,533	14,132,696
18.	Gross Elec Ener (MWH)	765,010	2,561,438	4,665,749
19.	Net Elec Ener (MWH)	723,376	2,410,588	4,381,489
20.	Unit Service Factor	100.0	92.7	81.5
21.	Unit Avail Factor	100.0	92.7	81.5
22.	Unit Cap Factor (MDC Net)	89.8	74.1	64.2
23.	Unit Cap Factor (DER Net)	89.8	74.1	64.2
24.	Unit Forced Outage Rate			5.9
25.	Forced Outage Hours	. 0	25.2	313.2
26.	Shutdowns Sched Over Next NONE	6 Months (Type,Date,D	Juration):





APRIL 1',88

Report	Period Al	PR 19	88		UN	II	S H U	TD	0 W	N	S / R	E	DU	CT	I	0	NS	**************************************
No.	Date	Type	Hours	Reason	Method	TER	Number	Sys	tem	Co	mponent	-		Ca	us:	8	Corre	ctive Action to Prevent Recurrence
7	04/08/88	S	0.0	А	5			F	W	2	CFWPP	20	FE	EDWA	TER	P	UMP LO	W PRESSURE GOVERNOR VALVE.

Туре	Reason		Method	System & Component		
F-Forced	A-Equip Failure	F-Admin G-Oper Farer	1-Manual	Exhibit F & H		
3-3ched	C-Refueling	H-Other	3-Auto Scram	Preparation of		
	D-Regulatory Res E-Operator Train	itriction	4-Continued 5-Reduced Load	Data Entry Sheet Licensee Event Report		
	& License Exa	mination	9-0ther	(LER) File (NUREG-0161		

FACILITY DESCRIPTION

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS......P.O. BOX 767 CHICAGO, ILLINOIS 60690

CONTRACTOR ARCHITECT/ENGINEER......SARGENT & LUNDY

NUC STEAM SYS SUPPLIER ... WESTINGHOUSE

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....J. HINDS

LICENSE & DATE ISSUANCE....NPF-66, JANUARY 30, 1987

PUBLIC DOCUMENT ROOM.....LIBRARIAN

BUSINESS SCIENCE & TECHNOLOGY DEPT. ROCKFORD PUBLIC LIBRARY 215 NORTH WYMAN STREET ROCKFORD, ILLINOIS 61101

INSPECTION SUMMARY

Inspection from January 13 through March 17, 1988 (88005; 88004): Routine, unannounced safety inspection of licensee actions on previous inspection findings (92701, 92702) startup test results evaluation (72301, 72400, 72596, 72600, 72608, 72616, 72624); and startup test results verification (72301, 72596, 72500, 72608, 72616, 72624). No violations or deviations were identified. The licensee's review of the startup test results were adequate to address the results and any concerns identified during testing.

STATUS

INSPECTION

Inspection from February 12 March 31, 1988 (88006; 88006): Routine, unannounced safety inspection by the resident inspectors of licensee action on previous inspection findings; licensee event reports; bulletins; generic letters; operations summary; training; surveillance; maintenance; operational safety and engineered safety features system walkdowns; event followup; followup of Region III requests; licensee action reports; engineering and technical support; and management changes. Of the 12 areas inspected, no violations or deviations were identified. One potential issue affecting the public's health and safety was identified (environmentally ungualified pressure switches).

ENFORCEMENT SUMMARY

NONE

PAGE 2-060

Report Period APR 1988

*********	*************	******
×	BYRON 2	*
**********	*************	******

OTHER .

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

CHANGE NRC RESIDENT TO P BROCHMAN

PLANT STATUS:

U-2 SHUTDOWN UNTIL SEPTEMBER 4, FOR FORCED OUTAGE. ONLINE FOR REST OF MONTH U-2 PLACED IN COMMERCIAL SERVICE EFFECTIVE 8/21/87.

LAST IE SITE INSPECTION DATE: 03/31/88

INSPECTION REPORT NO: 88006

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-02	032988	042888	COMPONENT COOLING MATER SURGE TANK LEVEL INSTRUMENTATION DIS CREPANCIES DUE TO A DESIGN ERROR
88-03	032988	042688	TECHNICAL SPECIFICATION ACTION STATEMENT NOT SATISFIED DURING UNINTENDED 28 DIESEL GENERATOR

1.	Docket: 50-483 OPERATING STATUS											
2.	Reporting Period: <u>04/01/88</u> Outage + On-line Hrs: <u>719.0</u>											
3.	Utility Contact: MARY DALY (314) 676-8460											
4.	Licensed Thermal Power (M		3565									
5.	Nameplate Rating (Gross MWe): <u>1373 X .9 =</u>											
6.	Design Electrical Rating		1171									
7.	Maximum Dependable Capaci	lWe):	1174									
8.	Maximum Dependable Capaci	ty (Net MWe):	1120								
9.	If Changes Occur Above Since Last Report, Give Reasons:											
10	Power Level To Which Rest	ricted. If	Any (Not MW	le):								
11	Reasons for Restrictions.	If Any:	any choice in									
	NONE											
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE								
13.	Hours Reactor Critical	440.9	2,518.6	24,516.4								
14.	R× Reserve Shtdwn Hrs	. 0	.0	.0								
15.	Hrs Generator On-Line	424.3	2,471.9	23:927.7								
16.	Unit Reserve Shtdwn Hrs		0	.0								
17.	Gross Therm Ener (MWH)	1,401,495	8,201,120	76,570,906								
18.	Gross Elec Ener (MWH)	472,075	2,819,443	25,861,163								
19.	Net Elec Ener (MWH)	441,600	2,678,320	24,567,996								
20.	Unit Service Factor	59.0	85.1									
21.	Unit Avail Factor	59.0	85.1	81.2								
22.	Unit Cap Factor (MDC Net)	54.8	82.4	74.4								
23.	Unit Cap Factor (DER Net)	52.4	78.8	71.2								
24.	Unit Forced Outage Rate	15.1	7.9	4.5								
25.	Forced Outage Hours	75.3	211.7	1,115.2								
26.	Shutdowns Sched Over Next	6 Months (Type,Date,D)uration):								
27	TE Consertion Shotdawn Ent	instad Star	tur Data:	NZA								

******	*****	*****	*****	*****	****
κ.	CI	ALLAWAY	Y 1		×
******	*****	*****	******	******	*****
AVERAGE	DAILY	POWER	LEVEL	(MWe)	PLOT



APRIL 1988

Report Period APR 1988

UNIT SHUTDOWNS / REDUCTIONS * CALLAWAY 1

* CALLAWAY 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
4	04/11/88	F	0.0	Α	5				REDUCE POWER TO 94% DUE TO TUBE LEAK IN THE 1C FEEDWATER HEATER.
5	04/16/88	S	39.1	Α	1				SHUTDOWN TO REPAIR TUBE LEAK IN 1C FEEDWATER HEATER.
6	04/17/88	F	18.6	Α	5				TURBINE/REACTOR TRIP DUE TO STEAM GENERATOR LEVEL OSCILLATIONS DURING PLANT STARTUP. LER 88-005-0.
7	1/88	F	56.7	A	2				TURBINE/REACTOR TRIP DUE TO FAILURE OF 'C' FEED REG VALVE. LER 88-006-0.
8	04/23/88	s	180.3	Α	1				COOLDOWN TO MODE 5 TO REPAIR LEAKING CONOSEAL.

*********** CALLAWAY 1 HAD 4 OUTAGES AND 1 POWER * SUMMARY * REDUCTION IN APRIL FOR REASONS STATED ************ ABOVE.

Туре	Reason	Method	System & Component		
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling G-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scraw 4-Continued 5-Reduced Load 9-Other	Exhibit F & H instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)		

FACILITY DESCRIPTION

LOCATION STATE	MISSOURI
COUNTY	CALLAWAY
DIST AND DIRECTION FROM NEAREST POPULATION CTR	10 MI SE OF FULTON, MO
TYPE OF REACTOR	. PWR
DATE INTTIAL CRITICALITY	OCTOBER 2, 1984
DATE ELEC ENER 1ST GENER	OCTOBER 24, 1984
DATE COMMERCIAL OPERATE	DECEMBER 19, 1984
CONDENSER COOLING METHOD	COOLING TOKER
CONDENSER COOLING WATER	MISSOURT RIVER
ELECTRIC RELIABILITY COUNCIL	MID-AMERICA INTERPOOL NETHURA

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....UNION ELECTRIC

CORPURATE ADDRESS......P.O. BOX 149 ST LOUIS, MISSOURI 63166

ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR......DANIEL INTERNATIONAL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

CONTRACTOR

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....B. LITTLE

LICENSING PROJ MANAGER.....T. ALEXION DOCKET NUMBER.....50-483

LICENSE & DATE ISSUANCE....NPF-30, OCTOBER 18, 1984

PUBLIC DOCUMENT ROOM......WASHINGTON UNIVERSITY JOHN M. OLIN LIBRAKY SKINKER & LINDELL BLVD. ST. LOUIS MO. 63130

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

FAGE 2-064

Report Feriod APR 1988

OTHER ITEMS

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

LAST IE SITE INSPECTION DATE: 03/03/88

INSPECTION REPORT NO: 88005

REPORTS FROM LICENSEE

NUMBER DATE OF DATE OF SUBJECT EVENT REPORT

1.	Docket: 50-317 0	PERAT	ING S	TATUS						
2.	Reporting Period: _04/01/8	8_ Outage	+ On-lice	Hrs: 719.0						
3.	Utility Contact: C. BEHNK	E (301) 26	0-4871							
4.	Licensed Thermal Power (MWt): 2700									
5.	. Nameplate Rating (Gross MWe): 1020 X 0.9									
6.	Design Electrical Rating (Net MWe):		845						
7.	Maximum Dependable Capacit	y (Gross M	We):	860						
8.	Maximum Dependable Capacit	y (Net MWe):	825						
9.	If Changes Occur Above Sin	ce Last Pe	port, Give	Reasons:						
	NONE									
10.	Power Level To Which Restr	icted, If	Any (Net M)	ve):						
11.	Reasons for Restrictions,	If Any:								
	NONE									
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	LUMULATIVE 113,796.0						
13.	Hours Reactor Critical	194.3	2,378.3	88,765.5						
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	2,299.2						
15.	Hrs Generator On-Line	192.9	2,351.3	86,804.2						
16.	Unit Reserve Shtdwn Hrs	. 0	.0	. 0						
17.	Gross Therm Ener (MWH)	470,945	6,099,545	218,174,263						
18.	Gross Elec Ener (MWH)	158,913	2,051,480	72,267,081						
19.	Net Elec Ener (MWH)	151.894	1,967,731	68,983,248						
20.	Unit Service Factor	26.8	31.0	76.3						
21.	Unit Avail Factor	26.8	81.0	76.3						
22.	Unit Cap Factor (MDC Net)	25.6	82.2	73.5						
23.	Unit Cap Factor (DER Net)	25.0	80.2	71.7						
24.	Unit Forced Outage Rate	. 0	1.1	9.1						
25.	Forced Outage Hours	. 0	25.6	8,607.8						
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):						
27	If Currently Shutdown Feti	mated Star	tup Date:	05/29/88						

CALVERT CLIFFS 1





* Item calculated with a Weighted Average

Report	Period Al	PR 19	88		UN	ΙŢ	SHU	T	DO	W	N	s /	R	E	D	U C	т	I	0	N	S * CALVERT CLIFFS 1 * ********************************	
No.	Date	Type	Hours	Reason	Method	LER	Number	<u> </u>	yst	em	Co	ompon	ent			_	Ca	usi	el	\$ (Corrective Action to Prevent Recurrence	-
88-02	04/09/88	S	526.1	С	1									SI	HUT	DOF	IN	FOR	RI	REP	UELING OPERATIONS.	

*********** CALVERT CLIFFS 1 SHUTDOWN FOR SCHEDULED * SUMMARY * REFUELING OUTAGE IN APRIL.

Type	Reason		Method	5. stem & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exam	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE	MÀRYLAND
COUNTY	CALVERT
DIST AND DIRECTION FROM NEAREST POPULATION CTR	40 MI S OF ANNAPOLIS, MD
TYPE OF REACTOR	PWR
DATE INITIAL CRITICALITY	OCTOBER 7, 1974
DATE ELEC ENER 1ST GENER	DECEMBER 30, 1974
DATE COMMERCIAL OPERATE	MAY 8, 1975
CONDENSER COOLING METHOD	ONCE THRU
CONDENSER COOLING WATER	CHESAPEAKE BAY
ELECTRIC RELIABILITY COUNCIL	MID-ATLANTIC AREA COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE......BALTIMORE GAS & ELEC

CORPORATE ADDRESS......P.O. BOX 1475 BALTIMORE, MARYLAND 21203

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER......GENERAL ELECTRIC

REGULATORY IN ORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....T. FOLEY

LICFNSE & DATE ISSUANCE.... DPR-53, JULY 31, 1974

PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY FOURTH STREET PRINCE FREDERICK, MARYLAND 206.8

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

PAGE 2-068

Report Period APR 1988

Report Period APR 1988

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

*********	**********		************	
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT	
		and and the own the last the task of the set	and , is not but on the set of an and an and an and an an	
NO INPUT	PROVIDED.			
===========	***********			

1.	Docket: 50-318	OPERAT	INGS	TATUS						
2.	Reporting Period: 04/01/1	88_ Outage	+ On-line	Hrs: 719.8						
3.	Utility Contact: C. BEHN	(E (301) 26	0-4871							
4.	Licensed Thermal Power (MWt):2700									
5.	Nameplate Rating (Gross MWe): <u>1012 X 0.9 = 911</u>									
6.	Design Electrical Rating	(Net MWe):		845						
7.	Maximum Dependable Capacit	ty (Gross M	We):	860						
8.	Maximum Dependable Capacit	ty (Net MWe):	825						
9.	If Changes Occur Above Since Last Report, Give Reasons: NONE									
10.	Power Level To Which Restr	ricted, If	Any (Net M	4e):						
11.	Reasons for Restrictions,	If Any:								
	NONE	<u> </u>								
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 97,151.0						
13.	Hours Reactor Critical	618.0	1,975.7	79,818,7						
14.	Rx Reserve Shtdwn Hrs	. 0	.0	1,296.0						
15.	Hrs Generator On-Line	613.4	.,96: 3	78,647.0						
16.	Unit Reserve Shtdwn Hrs		.0	. 0						
17.	Gross Therm Ener (MWH)	1,638,533	5,194,779	198,535,442						
18.	Gross Elec Ener (MWH)	551,496	1,762,169	65,650,305						
19.	Net Elec Ener (MWH)	530,227	1,691,405	62,680,302						
20.	Unit Service Factor	85.3	67.7	81.0						
21.	Unit Avail Factor	85.3	67.7	81.0						
22.	Unit Cap Factor (MDC Net)	89.4	70.6	78.2						
23.	Unit Cap Factor (DER Net)	87.3	69.0	76.4						
24.	Unit Forced Outage Rate	12.4	5.0	5.6						
25.	Forced Outage Hours	87.2	103.0	4,675.5						
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):						
	Te Conception Shoutdawn East	imstad Star	tur Data:	05/02/88						



APRIL 1988

Report	Period Al	PR 19	88		UN	IT	SHU	тром	NS / R	E D U C T I O N S *********************************
No.	Date	Type	Hours	Reason	Method	LER	Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-06	02/27/88	S	18.4	В	4					CONTINUED SHUTDOWN FOR PRE-SUMMER GENERAL MAINTENANCE MINI-OUTAGE.
88-07	04/27/88	F	87.2	A	2	88-04		HB	PUMPXX	TRIP ON LOW STEAM GENERATOR WATER LEVEL BE AUSE 21 SGFP TRIPPED FOR NO APPARENT REA JON. THERE WERE NO PRIOR (OR SUB. "QUENT) SYMPTOMS. 1. NONITOR TRIP CIRCUITRY TO FIND ROOT CAUSE.

2. EVALUATE POSSIBLE REPLACEMENT OF INSTALLED THRUST BEARING WEAR MONITOR.

********* * SUMMARY * ********** CALVERT CLIFFS 2 COMPLETED PRE-SUMMER GENERAL MAINTENANCE MINI-OUTAGE. SUBSEQUENTLY INCURRED 1 FORCED OUTAGE FO? REASONS STATED ABOVE.

Туре	Reason		Method	System & Component		
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Rest E-Operator Traini & License Exam	F-Admin G-Oper Error H-Other riction ng mation	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)		

FACILITY DESCRIPTION

LOCATION STATE.....MARYLAND

COUNTY......CALVERT

DIST AND DIRECTION FROM NEAREST POPULATION CTR...40 MI S OF ANNAPOLIS, MD

TYPE OF REACTOR.....PWR DATE INITIAL CRITICALITY...NOVEMBER 30, 1976 DATE ELEC ENER 1ST GENER...DECEMBER 7, 1976 DATE COMMERCIAL OPERATE....APRIL 1, 1977

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....CHESAPEAKE BAY

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS......P.O. BOX 1475 BALTIMORE, MARYLAND 21203

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....T. FOLEY

LICENSE & DATE ISSUANCE.... DPR-69, NOVEMBER 30, 1976

PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY FOURTH STREET PRINCE FREDERICK, MARYLAND 20678

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

PAGE 2-072

Report Period APR 1988

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

	***********			 	**********	***********	***********	**********	 ======
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT						
NO INPUT	PROVIDED.			 					

1.	Docket: _50-413	DPERAT	ING S	TATUS							
2.	Reporting Period:	88 Outage	+ On-line	Hrs: 719.0							
3.	Utility Contact: J. A. R	EAVIS (704)	373-7567								
4.	Licensed Thermal Power (M	Wt):		3411							
5.	Nameplate Rating (Gross M	We):	1305								
6.	Design Electrical Rating	(Net MWe):		1145							
7.	Maximum Dependable Capacity (Gross MWe):										
8.	Maximum Dependable Capaci):	1129								
9.	If Changes Occur Above Since Last Report, Give Reasons:										
10.	Power Level To Which Rest	ricted, If	Any (Net MW	e) 1							
11.	Reasons for Restrictions,	If Any:									
	NONE										
12.	Report Period Hrs	MONTH 719.0	YEAR	CUMULATIVE							
13.	Hours Reactor Critical	719.0	2,616.8	17,730.8							
4.	Rx Reserve Shtdwn Hrs	. 0	0								
15.	Hrs Generator On-Line	719.0	2,573.6	17,172.9							
16.	Unit Reserve Shtdwn Hrs			0							
17.	Gross Therm Ener (MWH)	2,413,567	8,292,891	54, 347, 755							
18.	Gross Elec Ener (MWH)	860,692	2,945,762	19,036,884							
19.	Net Elec Ener (MWH)	816,617	2,776,677	17,777,522							
20.	Unit Service Factor	100.0	88.7	69.0							
21.	Unit Avail Factor	100.0		69.0							
22.	Unit Cap Factor (MDC Net)	100.6	84.7	63.3							
23.	Unit Cap Factor (DER Net)	99.2	83.5	62.4							
24.	Unit Forced Outage Rate	. 0	11.3	17.3							
25.	Forced Outage Hours	. C		3,588.0							
26.	Shutdowns Sched Over Next	6 Months (Type,Date,I	Duration):							
	nonc										





Report	Ceriod Af	PR 19	88		UN	IT	S Н IJ	трим	NS / R	E D U C T I O N S ***********************************
No.	Date	Type	Hours	Reason	Method	LER	Number	System	Component	Cause & Corrective Action to Prevent Recurrence
31-P	04/14/88	F	0.0	A	5			нн	PIPEXX	POWER REDUCTION DUE TO MAIN STEAM LINE WELD LEAKING, CAUSING LOSS OF VACUUM.
32-P	04/16/88	S	0.0	В	5			HB	VALVEX	REDUCTION DUE TO CONTROL VALVE MOVE-

********** * SUMMARY * APRIL FOR REASONS STATED ABOVE.

Туре	Reason		Method	System & Component			
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)			

FACILITY DESCRIPTION

- LOCATION
 - STATE.....SOUTH CAROLINA

DIST AND DIRECTION FROM NEAREST POPULATION CTR...6 MI NNN OF ROCK HILL, SC

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... JANUARY 7, 1985

DATE ELEC ENER 1ST GENER... JANUARY 22, 1985

DATE COMMERCIAL OPERATE....JUNE 29, 1985

CONDENSER COOLING METHOD...MDCT

CONDENSER COOLING WATER....LAKE WYLIE

ELECTRIC RELIABILITY

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....DUKE POWER

CONTRACTOR ARCHITECT/ENGINEER.....DUKE POWER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR DUKE POWER

TURBINE SUPPLIER......GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....P. SKINNER

LICENSE & DATE ISSUANCE....NPF-35, JANUARY 17, 1985

PUBLIC DOCUMENT ROOM......YORK COUNTY LIBRARY 138 E. BLACK STREET ROCK HILL, SOUTH CAROLINA 29730

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 22-26 (88-12): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF THE RADIATION PROTECTION ASPECTS OF THE UNIT 2 OUTAGE INCLUDING: AUDITS AND SURVEILLANCES; PLANNING AND PREPARATION; TRAINING AND QUALIFICATION; EXTERNAL EXPOSURE CONTROL; INTERNAL EXPOSURE CONTROL; CONTROL OF RADIGACTIVE MATERIALS AND CONTAMINATION, SURVEYS AND MONITORING; THE PROGRAM TO MAINTAIN EXPOSURES AS LOW AS REASONABLY ACHIEVABLE (ALARA) AND FOLLOWUP ON PREVIOUS ENFORCEMENT ITEMS AND IE NOTICES. ONE LICENSEE IDENTIFIED VIOLATION WAS IDENTIFIED: FAILURE OF AN INDIVIDUAL TO WEAR AN INTEGRATING, ALARMING DOSIMETER IN A HIGH RADIATION AREA (HRA).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

PAGE 2-076

Report Period APR 1988

***** * CATAWBA 1 ********************************

OTHER ITEMS

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NONE.

LAST IE SITE INSPECTION DATE: FEBRUARY 22-26, 1988 +

INSPECTION REPORT NO: 50-413/88-12 +

REPORTS FROM LICENSFE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-012	02/08/88	03/31/88	INADVERTENT RELEASE DUE TO LEAKAGE FOLLOWING SYSTEM MAINTENANCE
88-014	01/13/88	04/01/88	INOPERABLE FIRE BARRIER IN VIOLATION OF TS DUE TO THE INSTALLATION OF TELEPHONE WIRE BECAUSE OF A MGT DEFICIENCY
88-015	03/09/88	04/08/88	DEGRADED PERFORMANCE OF UNIT 1 AUXILIARY FEEDWATER SYSTEM AND REQUIREMENT SHUTDOWN OF BOTH UNITS DUE TO A SYATIC CLAM INFEST NSWS
88-017	03/17/88	04/15/88	INADVERTENT ACTUATION OF A REACTOR TRIP BREAKER DUE TO A PERSONNEL ERROR

1.	Docket: _50-414_	DPERAT	INGS	TATUS
2.	Reporting Period: _04/01/8	<u>88</u> Outage	+ On-line	Hrs: 719.0
3.	Utility Contact: J. A. R	EAVIS (704)	373-7567	
4.	Licensed Thermal Power (MM	lt):		3411
5.	Nameplate Rating (Gross M	Ne):		1305
6.	Design Electrical Rating	(Net MWe):		1145
7.	Maximum Dependable Capacit	We):	1145	
8.	Maximum Dependable Capacit):	1129	
9.	If Changes Occur Above Sin	nce Last Re	port, Give	Reasons:
0.	Power Level To Which Restr	ricted, If	Any (Net MW	le):
1.	Reasons for Restrictions, NONE	If Any:		
2.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIV
3.	Hours Reactor Critical	566.4	944.1	9,549.1
4.	Rx Reserve Shtdwn Hrs		. 0	
5.	Hrs Generator On-Line	556.6	871.6	9,216.
6.	Unit Reserve Shtdwn Hrs	. 0	0	لعسبين
7.	Gross Therm Ener (MWH)	1,523,048	2,363,133	28,090,620
8.	Gross Elec Ener (MWH)	530,403	821,698	9,898,71
9.	Net Elec Ener (MWH)	491,127	726,799	9,193,49
0.	Unit Service Factor	77.4		61.8
1.	Unit Avail Factor	77.4	30.0	61,
2.	Unit Cap Factor (MDC Net)	60.5	22.2	54.0
3.	Unit Cap Factor (DER Net)	59.7	21.9	53.
4.	Unit Forced Outage Rate			29.
25.	Forced Outage Hours	.0	463.5	3,857.
26.	Shutdowns Sched Over Next	6 Months (Type,Date,I	Duration):
	Té Conservation Shutdarm Fet	imstod Star	tun Date:	05/03/8





APRIL 1988

Report Period APR 1988

UNIT SHUTDOWNS / REDUCTIONS *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
18-P	04/01/88	F	0.0	В	5		КH	VALVEX	POWER DECREASE TO REPAIR STEAM GENERATOR '2A' FEEDWATER CONTROL VALVE.
20-P	04/04/88	s	0.0	В	5		CB	INSTRU	HOLDING POWER FOR REACTOR COOLANT SYSTEM LEAKAGE CALCULATION
23-P	04/05/88	F	0.0	н	5		CB	XXXXXX	POWER DECREASE DUE TO LOW SUBCOOLING ON TRAIN A INADEQUATE CORE COOLING SYSTEM MONITOR
29-P	04/23/88	F	0.0	Α	5		НА	XXXXXX	POWER REDUCTION DUE TO GROUND FAULT ON EXCITER FIELD
8	04/24/88	s	162.4	В	1		НА	XXXXXX	UNIT REMOVED FROM SERVICE TO REPAIR EXCITER GROUND FAULT

Туре	Reason	Method	System & Component			
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)			

FACILITY DESCRIPTION

LOCATION

STATE......SOUTH CAROLINA

DIST AND DIRECTION FROM NEAREST POPULATION CTR...6 MI NNW OF ROCK HILL, SC

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... MAY 8, 1986

DATE ELEC ENER 1ST GENER...MAY 18, 1986

DATE COMMERCIAL OPERATE.... AUGUST 19, 1986

CONDENSER COOLING METHOD. .. HNDCT

CONDENSER COOLING WATER....LAKE WYLIE

ELECTRIC RELIABILITY COUNCIL.....SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

ACILITY DATA

UT)LITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....DUKE POWER

CORPORATE ADDRESS......POWER BLDG., BOX 2178 CHARLOTTE, NORTH CAROLINA 28201

CONTRACTOR ARCHITECT/ENGINEER.....DUKE POWER

NUC STEAM SYS SUPPLIER ... WESTINGHOUSE

CONSTRUCTOR DUKE POWER

TURBINE SUFPLIER......GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....P. SKINNER

LICENSE & DATE ISSUANCE....NPF-52, MAY 15, 1986

PUBLIC DOCUMENT ROOM......YORK COUNTY LIBRARY 138 E. BLACK STREET ROCK HILL, SOUTH CAROLINA 29730

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 22-26 (88-12): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF THE RADIATION PROTECTION ASPECTS OF THE UNIT 2 OUTAGE INCLUDING: AUDITS AND SURVEILLANCES; PLANNING AND PREPARATION; TRAINING AND QUALIFICATION; EXTERNAL EXPOSURE CONTROL; INTERNAL EXPOSURE CONTROL; CONTROL OF RADIGACTIVE MATERIALS AND CONTAMINATION, SURVEYS AND MONITORING; THE PROGRAM TO MAINTAIN EXPOSURES AS LOW AS REASONABLY ACTIEVABLE (ALARA) AND FOLLOWUP ON PREVIOUS ENFORCEMENT ITEMS AND IE NOTICES. ONE LICENSEE IDENTIFIED VIOLATION WAS IDENTIFIED: FAILURE OF AN INDIVIDUAL TO WEAR AN INTEGRATING, ALARMING DOSIMETER IN A HIGH RADIATION AREA (HRA).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

PAGE 2-080

Report Period APR 1988

****** CATAWBA 2 26. *****

OTHER ITEMS

NONE .

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NONE.

LAST IE SITE INSPECTION DATE: FEBRUARY 22-26, 1988 +

INSPECTION REPORT NO: 50-414/88-12 +

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-011	12/29/87	04/01/88	ESSENTIAL SWITCHGEAR INCOMING BREAKER FAILS TO TRIP DURING TESTING DUE TO OPEN SLIDING LINK IN CONTROL CIRCUIT
88-012	03/09/88	04/08/88	REACTOR TRIP FOLLOWED BY AN AUXILIARY FEEDWATER SUCTION SWAP TO THE NUCLEAR SERVICE WATER SYSTEM DUE TO EQUIPMENT FAILURES
88-013	03/14/88	04/13/88	FEEDWATER ISOLATION CAUSED BY STEAM GENERATOR HIGH LEVEL DUE TO A VALVE FAILURE AND A PERSONNEL ERROR
88-014	03/17/88	04/15/88	AUXILIARY FEEDWATER AUTO START FOLLOWED BY AUX FEEDWATER SUCTION SWAP TO THE NUCLEAR SERVICE WATER SYSTEM DUE TO DELAMINATED COAT MAT.

1.	Docket: <u>50-461</u> 0	PERAT	ING S	TATUS							
2.	Reporting Period: _04/01/88	8_ Outage	+ On-line	Hes: 719.0							
3.,	Utility Contact: F.A. SPAN	GENBERG (217)935-888	1 X3400							
4 .	Licensed Thermal Power (MW	D:		2894							
5.	Nameplate Rating (Gross MWe):										
6.	Design Electrical Rating (i	Net MWe):		933							
7.1	Maximum Dependable Capacity	We):	933								
8.1	Maximum Dependable Capacity	; (Net MWe):	930							
9.	If Changes Occur Above Sind	ce Last Re	port, Give	Reasons:							
10.	Power Level To Which Restr	icted, If	Any (Net MW	le):							
11.1	Reasons for Restrictions,	If Any:									
	NONE										
		MONTH	YEAR	CUMULATIVE							
12.1	Report Period Mrs	719.0	2,903.0	3,801.3							
13.	Hours Reactor Critical	. 0	1,875.3	2,773.6							
4.	Rx Reserve Shtdwn Hrs	. 0	. 0								
15.	Hrs Generator On-Line	. 0	1,870.5	2,768.8							
16.	Unit Reserve Shtdwn Hrs	. 0									
17.	Gross Therm Ener (MWH)	0	5,085.874	7,231,374							
18.	Gross Elec Ener (MWH)	0	1,703,040	2,419,690							
19.	Net Elec Ener (MWH)	0	1,628,016	2, 312, 119							
20.	Unit Service Factor	. 0	64.4								
21.	Unit Avail Factor	. 0	64.4	72.8							
22.	Unit Cap Factor (MDC Net)	. 0	60.3	65.0							
23.	Unit Cap Factor (DER Net)	, 0	60.1	65.3							
24.	Unit Forced Outage Rate	, 0	0								
25.	Forced Outage Hours	. 0	<u>c</u>								
26.	Shutdowns Sched Over Next) NONE	6 Months (Type, Sote, I	Uration):							
27	If Currently Shutdown Feti	nated Star	tun Data:	05/05/8							



DAYS

APR:L 1988

PAGE 2-082

Report	Period Al	PR 19	88		UN	ΙT	รหง	л	D	ы	N	s	/ 1	R E	D	U C	т :	1	O N	1 5	xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx
No.	Date	Type	Hours	Reason	Method	LER	Number	=	ys	tem	Co	mpo	nen	E I			Cau	ise	8	Cor	rective Action to Prevent Recurrence
8	03/19/88	S	719.0	В	4									P	LAN	TS		DO	WN SCH	TO	PERFORM SURVEILLANCE JLED MAINTENANCE.

黄美英兰英英英英英英英	CLINTON 1 REMAINED SHUTDOWN IN APRIL TU
* SUMMARY *	PERFORM SURVEILLANCE TESTING AND
*********	SCHEDULED MAINTENANCE.

Type	Reason		Method	System 3 Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other striction ming mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licenses Event Report (LER, File (NUREG-0161

xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx	FΑ
FACILITY DESCRIPTION	
LOCATION STATEILLINOIS	
COUNTYDE WITT	
DIST AND DIRECTION FROM NEAREST POPULATION CTR6 MI E OF CLINTON, ILL	
TYPE OF REACTOR BWR	
DATE INITIAL CRITICALITYFEBRUARY 27, 1987	
DATE ELEC ENER 1ST GENERAPRIL 24, 1987	
DATE COMMERCIAL OPERATENOVEMBER 24, 1987	
CONDENSER COOLING METHODONCE THRU	
CONDENSER COOLING WATERSALT CREEK	
ELECTRIC RELIABILITY COUNCILMID-AMERICA INTERPOOL NETWORK	6

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS..... 500 SOUTH 27TH STREET DECATUR, ILLINOIS 62525

CONTRACTOR

ARCHITECT/ENGINEER.....SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR BALDWIN ASSOCIATES

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

STATUS

IE RESIDENT INSPECTOR.....P. HILAND

LICENSE & DATE ISSUANCE....NPF-62, APRIL 17, 1987

PUBLIC DOCUMENT ROOM......VESPASIAN WARNER PUBLIC LIBRARY 120 WEST JOHNSON ST. CLINTON, IL. 61727

INSPECTION SUMMARY

Inspection on February 24-26, 1988 (83005): Routine, unannounced inspection of the solid radwaste program, including: organization and management controls (IP 83722), qualifications and training (IP 83725), solid radwaste (IP 84721), and transportation activities (IP 66721). Also reviewed were an apparent resin intrusion into the liquid radwaste stream, a licensee investigation of a former employee's concerns (IP 99024), and previous inspection findings (IP 92701). The licensee's solid radwaste and transportation programs appear to satisfy NRC, DDT, and burial site requirements for processing, packaging, and disposal of solid radwaste. Waste appears to be solidified in accordance with the licensee's approved Process Control Program to meat applicable federal and state regulations. No violations or deviations were identified.

Inspection on January 15 through April 6, 1988 (88002): Routine, unannounced safety inspection of actions on a previously identified item (92701), and review of startup test results (72532, 92301). Of the two areas inspected, no violations or deviations were identified. Overall, the licensee appeared to have well documented test packages that included all required data/information to establish proper validation of test results against approved acceptance criteria.

INSPECTION

Inspection on April 5-8, 1988 (88011): Included a review of a licensee reported security event on April 14, 1988. The licensee was found to be in apparent noncompliance with NRC requirements as noted below: Access Control - Personnel: The licensee failed to adequately control access to a vital area because of the ineffectiveness of compensatory measures.

Inspection on March 14-18, March 28-31, and April 6, 1988 (88006): Routine, unannounced inspection by two region based inspectors of the modification process and as ociated quality verification process, and followup of previous inspector identified problems. PAGE 2-084

INSPECTION SUMMARY

The inspection was conducted utilizing portions of Inspection Procedure 37702. No violations were identified.

ENFORCEMENT SUMMARY

NONE

. .

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

.

0

1

PLANT STATUS:

THE LICENSEE HAS COMPLETED THE POWER ASCENSION TEST PROGRAM. THE LICENSEE IS CURRENTLY OPERATING AT 100% POWER.

LAST IE SITE INSPECTION DATE: 04/08/88

INSPECTION REPORT NO: 88011

REPORTS FROM LICENSEE

= :		2002220222		
	NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
	88-07	031488	041388	FAI'URE TO UNDERSTAND DIESEL GENERATOR (DG) VENTILATION OFF-NORMAL OPERATION RESULTS IN IMPAIRED FIRE PROTECTION AND TEMPERATURE CONTROL IN THE DG ROOMS
	88-10	046188	042188	OVERSIGHT BY UTILITY-LICENSED OPERATORS RESULTS IN FAILURE TO PERFORM SHIFT CONTROL ROOM OPERATOR SURVEILLANCE LOG

1. Docket: 50-315	OPERA	TINGS	TATUS					
2. Reporting Period: 04/01/	188 Outage	e + On-line	Hes: 719.0					
3. Utility Contact: HIRSCH	(616) 465-	5901						
Licensed Thermal Power (MWt): 3250								
5. Nameplate ?ating (Gross M	. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152							
6. Design Electrical Rating	(Net MWe):		1030					
7. Maximum Dependable Capaci	. Maximum Dependable Capacity (Gross MWe): 1056							
8. Maximum Dependable Capaci	ty (Net MW	.):	1020					
9. If Changes Occur Above Si	nce Last Re	port, Give	Reasons:					
NONE								
10. Power Level To Which Rest	ricted, If	Any (Net M	Ne): 920					
11. Reasons for Restrictions,	If Any:							
ADMINISTRATIVE								
12. Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE					
13. Hours Reactor Critical	719.0		84,687.0					
14. R× Reserve Shtdwn Hrs		. 0	463.0					
15. Hrs Cenerator On-Line	719.0	2,838.0	83,075.4					
t6. Unit Reserve Shtdwn Hrs		0	321.0					
17. Gross Therm Ener (MWH)	2,089,788	8,171,533	241,162,903					
18. Gross Elec Ener (MWH)	681,160	2,663,920	78,808,590					
19. Net Elec Ener (MWH)	655,125	2,560,859	75,791,857					
20. Unit Service Factor	100.0	97.8	72.3					
21. Unit Avail Factor	100.0	97.8	72.3					
22. Unit Cap Factor (MDC Net)	89.3	86.5	64.7					
S. Unit Cap Factor (DER Net)	88.5	85.6	62.6					
4. Unit Forced Outage Rate	. 0	.9	8.1					
25. Forced Outage Hours	. 0	26.5	6,644.7					
26. Shutdowns Sched Over Next NONE	6 Months (Type,Date,D	wration):					
27. If Currently Shutdown Est	imated Star	tup Bate:	N/A					





Report	Period Al	PR 19	88		UN	IT	SHU	тром	NS / R	E D U C T I O N S XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
No.	Date	Type	Hours	Reason	Method	LER	Numter	System	Component	Cause & Corrective Action to Prevent Recurrence
269	04/30/88	s	0.0	В	5			HF	HTEXCH	UNIT POWER WAS REDUCED TO 58% TO CLEAN THE MAIN FEED PUMP TURBINE CONDENSER WATERBOXES. POWER WAS RESTORED TO 90% (ADMINISTRATIVE LIMIT) ON 5-1-88.

********** * SUMMARY * COOK 1 INCURRED 1 POWER REDUCTION IN APRIL FOR REASONS STATED ABOVE WHILE OPERATING AT AN ADMINISTRATIVE IMPOSED LEVEL OF 90%

POWER.

Туре	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

K COOK 1 K FAC	ILITY DATA Report Period APR 1988					
FACILITY DESCRIPTION	UTILITY & CONTRACTOR INFORMATION					
LOCATION STATEMICHIGAN	UTILITY LICENSEEINDIANA MICHIGAN POWER CO.					
COUNTYBERRIEN	CORPORATE ADDRESS 1 RIVERSIDE PLAZA					
DIST AND DIRECTION FROM NEAREST POPULATION CTR11 MI S OF BENTON HARBOR, MI	CONTRACTOR ARCHITECT/ENGINEERAMERICAN ELEC. POWER SERVICE CORP.					
TYPE OF REACTORPWR	NUC STEAM SYS SUPPLIERWESTINGHOUSE					
DATE INITIAL CRITICALITYJANUARY 18, 1975	CONSTRUCTOR AMERICAN ELEC. POWER SERVICE CORP.					
DATE ELEC ENER 1ST GENERFEBRUARY 10, 1975	TURBINE SUPPLIERGENERAL ELECTRIC					
DATE COMMERCIAL OPERATEAUGUST 27, 1975	REGULATORY INFORMATION					
CONDENSER COOLING METHODONCE THRU	IE REGION RESPONSIBLEIII					
CONDENSER COOLING WATERLAKE MICHIGAN	IE RESIDENT INSPECTORB. JORGENSEN					
ELECTRIC RELIABILITY COUNCILEAST CENTRAL AREA	LICENSING PROJ MANAGERJ. STANG DOCKET NUMBER					
AGREEMENT	IICENSE & DATE ISSUANCEDPR-58, OCTOBER 25, 1974					
TNSPE	PUBLIC DOCUMENT ROOMMAUDE PRESTON PALENSKE MEMORIAL LIBRARY 500 MARKET STREET ST. JOSEPH, MICHIGAN 49085					

INSPECTION SUMMARY

Inspection on February 8-26, 1988 (88007; 88008): This special safety inspection was conducted to determine the adequacy of the licensee's 10 CFR 50.59 safety evaluations. This was an announced inspection conducted under IE Module 92702. The licensee's safety evaluations were judged to be adequate. The use of a dedicated group to perform these evaluations was considered a major strength. This resulted in generally comprehensive safety evaluations. One weakness noted was the failure to directly address the three criteria defining an unreviewed safety question in the safety evaluation documentation. This led to some doubts in certain instances as to whether or not these criteria had been thoroughly addressed. No violations or deviations were identified.

INSPECTION ON JANUARY 27 THROUGH MARCH 14, 1988 (88008; 88009): ROUTINE, UNAN NOUNCED INSPECTION BY THE RESIDENT INSPECTOR OF : ACTIONS ON PREVIOUSLY IDENTI FIED ITEMS; PLANT OPERATIONS; RADIOLOGICAL CONTROLS; MAINTENANCE; SURVEILLANCE FIRE PROTECTION; SECURITY; QUALITY PROGRAPH ACTIVITIES; AND NRC INFORMATION NOTICES. OF THE NINE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN ANY AREAS.

INSPECTION ON MARCH 15-31, 1988 (88013; 88015): ROUTINE ANNOUNCED INSPECTION OF THE LICENSEE'S IMPLEMENTATION OF GENERIC LETTER 83-28 IN THE AREAS OF EQUIP MENT CLASSIFICATION, VENDOR INTERFACE, POST MAINTENANCE TESTING AND REACTOR TRIP SYSTEM RELIABILITY. CLOSED TI2513/64RI AND TI2515/91. NO VIOLATIONS OR DEVIA TIONS WERE IDENTIFIED.
×××	×××	×××)	****	[关关关关关	******	*****
×			(COOK 1		*
***	***	***	*****	*****	******	*******

ENFORCEMENT SUMMARY

FAILURE TO ADEQUATELY IMPLEMENT A COMPENSATORY MEASURE.

(8800 4)

10 CFR 50, APPENDIX B, CRITERION V, AS IMPLEMENTED BY THE D. C. COOK OPERATIONS QUALITY ASSURANCS PROGRAM, REQUIRES THAT ACTIVITIES AFFECTING QUALITY BE PRESCRIBED BY AND PERFORMED IN ACCORDANCE WITH DOCUMENTED PROCEDURES. CONTRARY TO THE ABOVE, ON MAY L9, L985, THE MAINTENANCE DEPARTMENT REPLACED A UNIT 1 CONTAINMENT ISOLATION BUTTERFLY VALVE, NUMBER CCM-451, MANUFACTURED BY CENTERLINE, WITH A SIMILAR VALVE MANUFACTURED BY PRATT, WITHOUT FIRST PROCESSING A REQUEST FOR CHANGE REQUIRED BY SECTION 5.2 OF PMI 5040.

(8800 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

THE ASSISTANT PLANT MANAGER, ENGINEERING IS ACTING FOR THE TECHNICAL SUPERINTENDENT, PHYSICAL SCIENCE RADIATION PROTECTION MANAGER

PLANT STATUS:

THE UNIT OPERATED NORMALLY THROUGHOUT THE MONTH EXCEPT FOR ICE CONDENSER SURVEILLANCE OUTAGE DURING MARCH 26-27, 1988.

LAST IE SITE INSPECTION DATE: 03/31/88

INSPECTION REPORT NO: 88013

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-02	040488	040488	SECURITY SAFEGUARDS EVENT
88-02	032688	042588	ICE BUILDUP IN ICE CONDENSER FLOW PASSAGES DUE TO SUBLIMATION

5.	Docket: _50-316_	OPERAT	TING S	TATUS
2,	Reporting Period:	88 Outage	e + On-line	Hrs: 719.0
3.	Utility Contact: <u>HIRSCH</u>	(616) 465-	5901	
4.	Licensed Thermal Power (M	Wt):	and the second	3411
5.	Nameplate Rating (Gross M	lWe):	<u>1333 X</u>	0.85 = 1133
6.	Design Electrical Rating	(Net MWe):		1100
7.	Maximum Dependable Capaci	ty (Gross a	1We):	1100
8.	Maximum Dependable Capaci	ty (Net MWa	»):	1060
9.	If Changes Occur Above Si	nce Last Re	eport, Give	Reasons:
	NONE			
10.	Power Level To Which Rest	ricted, If	Any (Net M	We): 864
11.	Reasons for Restrictions,	If Any:		
	ADMINISTRATIVE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 90,551.0
13.	Hours Reactor Critical	531.5	2,715.5	63,587.9
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	
15.	Hrs Generator On-Line	531.1	2,715.1	62,210.3
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	2.2
17.	Gross Therm Ener (MWH)	1,432,639	7,410,979	191,990,217
18.	Gross Elec Ener (MWH)	463,950	2,419,600	61,896,040
19.	Net Elec Ener (MWH)	444,578	2,323,265	59,586,746
20.	Unit Service Factor	73.9	93.5	70.6
21.	Unit Avail Factor	73.9	93.5	70.6
22.	Unit Cap Factor (MDC Net)	58.3	75.5	63.8
23.	Unit Cap Factor (DER Net)	56.2	72.8	62.2
24.	Unit Forced Outage Rate	. 0		14.5
25.	Forced Outage Hours	. 0		10,497.2
26.	Shutdowns Sched Over Next NONE	5 Months (Type,Date,I	Duration):
27	If Currently Shutdown Est	imated Star	tup Date:	02/01/89

*	*****	*****	COOK	2 ******	*****	¥ *****
A	VERAGE	DAILY	POWER	LEVEL	(MWe)	PLOT
			COOK	2		



APRIL 1988

****** Report Period APR 1988 UNIT SHUTDOWNS / REDUCTIONS * COOK 2 ****** No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence ZZZZZZ A POWER COASTDOWN WAS BEGUN ON 4-18-88 04/23/88 S 187.9 C 1 ZZ 189 IN PREPARATION FOR THE STEAM GENERATOR REPLACEMENT/REFUELING OUTAGE. ON 4-23-88 THE UNIT WAS REMOVED FROM SERVICE. THE REPORTING PERIOD ENDED WITH THE RCS IN MODE 5 DRAINING TO HALF-LOOP. THE EXPECTED RETURN TO SERVICE DATE IS FEB. 1989.

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161

FACILITY DESCRIPTION

LOCATION STATE.....MICHIGAN

COUNTY.....BERRIEN

DIST AND DIRECTION FROM NEAREST POPULATION CTR...11 MI S OF BENTON HARBOR, MI

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY. .. MARCH 10, 1978

DATE ELEC ENER 1ST GENER. . . MARCH 22, 1978

DATE COMMERCIAL OPERATE....JULY 1, 1978

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER....LAKE MICHIGAN

ELECTRIC RELIABILITY

COUNCIL.....EAST CENTRAL AREA RELIABILITY COORDINATION AGREEMENT

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS..... 1 RIVERSIDE PLAZA COLUMBUS, 0HIO 43216

CONTRACTOR

ARCHITECT/ENGINEER..... AMERICAN ELEC. POWER SERVICE CORP.

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....J. A. JONES CONSTRUCTION

TURBINE CUPPLIER BROWN BOVERI

REGULAIORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR......B. JORGENSEN

LICENSE & DATE ISSUANCE.... DPR-74, DECEMBER 23, 1977

PUBLIC DOCUMENT ROOM......MAUDE PRESTON PALENSKE MEMORIAL LIBRARY SOO MARKET STREET ST. JOSEPH, MICHIGAN 49085 IN SPECTICN STATUS

INSPECTION SUMMARY

Inspection on February 8-26, 1988 (88007; 88008): This special safety inspection was conducted to determine the adequacy of the licensee's 10 CFR 50.59 safety evaluations. This was an unnounced inspection conducted under IE Module 92702. The licensee's safety evaluations were judged to be adequate. The use of a dedicated group to perform these evaluations was considered a major strength. This resulted in generally comprehensive safety evaluations. One weakness noted was the failure to directly address the three criteria defining an unreviewed safety question in the safety evaluation documentation. This led to some doubts in certain instances as to whether or not these criteria had been thoroughly addressed. No violations or deviations were identified.

INSPECTION ON JANUARY 27 THROUGH MARCH 14, 1988 (88008; 88009): ROUTINE, UNAN NOUNCED INSPECTION BY THE RESIDENT INSPECTOR OF : ACTIONS ON PREVIOUSLY IDENTI FIED ITEMS; PLANT OPERATIONS; RADIOLOGICAL CONTROLS; MAINTENANCE; SURVEILLANCE FIRE PROTECTION; SECURITY; QUALITY PROGRAM ACTIVITIES; AND NRC INFORMATION NOTICES. OF THE NINE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN ANY AREAS.

INSPECTION ON MARCH 15-31, 1983 (88013; 88015): ROUTINE ANNOUNCED INSPECTION OF THE LICENSEE'S IMPLEMENTATION OF GENERIC LETTER 83-28 IN THE AREAS OF EQUIP MENT CLASSIFICATION, VENDOR INTERFACE, POST MAINTENANCE TESTING AND REACTOR TRIP SYSTEM RELIABILITY. CLOSED TI2515/64RI AND TI2515/91. NO VIOLATIONS OR DEVIA TIONS WERE IDENTIFIED.

****	(××)	exe	ĸж	¥	×	¥	×	×	×	ж	×	×	¥	¥	×	×	¥	×	×	×	×	×	×	×	ж	×	¥3	×
×							C	0	0	K		2															3	×
****	1441	e ar i	**	¥	¥	¥	¥	¥	¥	×	×	×	¥	¥	×	×	×	×	¥	×	×	×	×	×	×	×	×	ĸ

ENFORCEMENT SUMMARY

FAILURE TO ADEQUATELY IMPLEMENT A COMPENSATORY MEASURE.

(8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

LONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT OPERATED NORMALLY THROUGHOUT THE MONTH.

LAST IE SITE INSPECTION DATE: 03/31/88

INSPECTION REPORT NO: 88015

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-03	031188	041188	REPETITIVE VIOLATION OF ESF INSTRUMENTATION LIMITING CONDITIONS FOR OPERATION TOLERANCES DUE TO HIGHLY RESTRICTIVE ALLOWABLE VALUES

1.	Docket: <u>50-298</u> 0	PERAT	ING S	TATUS
2.	Reporting Period: 04/01/8	8 Outage	+ On-line	Hrs: 719.0
3.	Utility Contact: J. T. SC	HEUERMAN (402) 825-38	311
G .	Licensed Thermal Power (MM	lt):		2381
5.	Nameplate Rating (Gross MW	le):	983 X (0,85 = 836
6.	Design Electrical Rating (Net MWe):		778
7.	Maximum Dependable Capacit	y (Gross M	We):	787
8.	Maximum Dependable Capacit	y (Net MWe):	764
9.	If Changes Occur Above Sin NONE	ice Last Re	port, Give	Reasons:
10.	Power Level To Which Restr	icted, If	Any (Net M	Ne):
11.	Reasons for Restrictions,	If Any:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 121,272.0
13.	Hours Reactor Critical	.0	1,297.0	91,304.4
14.	ax Reserve Shtdwn Hrs	.0	. 0	. 0
15.	Hrs Generator On-Line		_1,281.2	
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	. 0
17.	Gross Therm Ener (MWH)	0	2,629,440	177,260,147
18.	Gross Elec Ener (MWH)	0	872,027	56,931,108
19.	Net Elec Ener (MWH)	6	840,096	54,868,720
20.	Unit Service Factor	.0	44.1	74.1
21.	Unit Avail Factor	. 0	44.1	74.1
22.	Unit Cap Factor (MDC Net)	. 0		59.2
23.	Unit Cap Factor (DER Net)	. 0	37.2	58.2
24.	Unit Forced Outage Rate	. 0	16.8	4.9
25.	Forced Outage Hours	0	259.3	3,953.6
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Dura on):
27	If Currently Shutdown Feti	mated Star	tup Date:	05/19/88





Report	Period A	PR 19	88		UN	ΙT	SHU	TDO	N N	s /	R	EDU	C 1	r I	0 1	N S	**************************************
No.	Date	Type	Hours	Reason	Method	LER	Number	Syste	m C	ompone	ent		5	VSQ	8	Corr	ective Action to Prevent Recurrence
88-02	03/05/88	s	719.0	С	4							REACTO	OR S	HUT	DON	AN FO	DR 1988 (EDC11)

Type	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION

STATE.....NEBRASKA

COUNTY.....NEMAHA

DIST AND DIRECTION FROM NEAREST POPULATION CTR...23 MI S OF NEBRASKA CITY, NEB

TYPE OF REACTOR......BWR

DATE INITIAL CRITICALITY...FEBRUARY 21, 1974

DATE ELEC ENER 1ST GENER... MAY 10, 1974

DATE COMMERCIAL OPERATE....JULY 1, 1974

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER....MISSOURI RIVER

ELECTRIC RELIABILITY

COUNCIL.....MID-CONTINENT AREA RELIABILITY COORDINATION AGREEMENT

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE......NEBRASKA PUBLIC POWER DISTRICT

CORPORATE ADDRESS.....P.O. BOX 499 COLUMBUS, NEBRASKA 68601

CONTRACTOR ARCHITECT/ENGINEER.....BURNS & ROE

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR......BURNS & ROE

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV

IE RESIDENT INSPECTOR.....D. DUBOIS

LICENSE & DATE ISSUANCE.... DPR-46, JANUARY 18. 1974

PUBLIC DOCUMENT ROOM.....AUBURN PUBLIC LIBRARY 1118 15TH STREET AUBURN, NEBRASKA 68305 INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION CONDUCTED FEB. 29 - MARCH 2, 1988 (88-03) ROUTINE, UNANNOUNCED INSPECTION OF SELECTED AREAS OF THE RADIATION PROTECTION PROGRAM. WITHIN THE AREA INSPECTED, ONE DEVIATION WAS IDENTIFIED.

INSPECTION CONDUCTED FEB. 8-12, FEB. 29 - MARCH 4, 1988 (88-04) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S QUALITY ASSURANCE PROGRAM IMPLEMENTATION INCLUDING THE AREAS OF RECORDS MANAGEMENT, DOCUMENT CONTROL, RECEIVING INSPECTION OF MATERIALS AND COMPONENTS; AND IMPLEMENTATION OF 10 CFR PART 21 REQUIREMENTS. WITHIN THE AREAS INSPECTED, TWO VIOLATIONS WERE IDENTFIED.

INSPECTION CONDUCTED MARCH 14 - 18, 1988 (88-05) ROUTINE, UNANNOUNCED INSPECTION OF RECORDS AND REPORTS, ACCESS CONTROL, VEHICLES, PHYSICAL PROTECTION SAFEGUARDS INFORMATION, MANAGEMENT EFFECTIVENESS, PHYSICAL BARRIERS - PROTECTED AREA, PHYSICAL BARRIERS -VITAL AREA, SECURITY SYSTEM POWER SUPPLY, LIGHTING, COMPENSATORY MEASURES, ASSESSMENT AIDS, ACCESS CONTROL - PACKAGES, DETECTION AIDS - PA, DETECTION AIDS - VA, AND TRAINING AND QUALIFICATIONS. WITHIN THE AREAS INSPECTED, THREE VIOLATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED MARCH 21-25, 1988 (88-09) ROUTINE, UNANNOUNCED INSPECTION OF SITE TOURS, NONLICENSED STAFF TRAINING, AND LICENSED OPERATOR TRAINING. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED APRIL 4-7, 1988 (88-10) ROUTINE, UNANNOUNCED INSPECTION OF LICENSEE ACTION ON PREVIOUSLY IDENTIFIED IDENTIFIED INSPECTION FINDINGS, WELDING ACTIVITIES, AND ALLEGATION ASSESSMENT. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRABAND MATERIALS WERE FOUND INSIDE THE PROTECTED AREA IN VIOLATION OF REGULATIONS. (8703 3)

10 CFR 50.54(Q) REQUIRES THAT A LICENSEE SHALL FOLLOW AND MAINTAIN IN EFFECT EMERGENCY PLANS WHICHMEET THE STANDARDS IN 50.47(B) AND THE REQUIREMENTS IN APP.E. SEC. 8.1.1 OF THE EMERGENCY PLAN STATES THAT FORMAL CLASSROOM TRAINING IS PROVIDED TO EACH CNS EMPLOYEE ON AN ANNUAL BASIS. INITIAL TRAINING WILL BE CONDUCTED AND REFRESHER TRAINING WILL BE CONDUCTED ON AN ANNUAL BASIS. CONTRARY TO THE ABOVE, A REVIEW OF RANDOMLY SELECTED EMERGENCY RESPONSE PERSONNEL TRAINING RECORDS INDICATED THAT NINE INDIVIDUALS HAD NOT RECEIVED APPROPRIATE REQUIRED EMERGENCY RESPONSE TRAINING, IN THAT 8 STATION OPERATORS HAD NOT RECEIVED REQUIRED ANNUAL FORMAL CLASSROOM RETRAINING DURING CALENDAR YEAR 1987 AND ONE STATION OPERATOR HAD NOT RECEIVED THE REQUIRED INITIAL TRAINING OR RETRAINING. 10 CFR 50.56(T) REQUIRES THAT PART OF THE REVIEW INVOLVING EVALUATION FOR ADEQUACY OF LICENSEE INTERFACE WITH STATE AND LOCAL GOVERNMENTS SHALL BE AVAILABLE TO THE APPROPRIATE STATE AND LOCAL GOVERMENTS. SEC.8.3 OF THE PLAN STATES, "AUDITS...INCLUDES QUALITY ASSURANCE AUDITS PER 10 CFR 50.54(T) AND NRC INSPECTION REPORT RESPONSE SUBMITTAL." A QA EVALUATION/AUDIT WAS CONDUCTED DURING MARCH, APRIL, AND MAY 1987. THE EVALUATION AUDIT REPORT TRANSMITTAL MEMO STATED, "AS SPECIFICALLY POINTED OUT IN PREVIOUS EMERGENCY PREAREDNESS EVALUATION/AUDIT REPORT TRANSMITTAL MEMO STATED, "AS SPECIFICALLY POINTED OUT IN PREVIOUS EMERGENCY PREAREDNESS EVALUATION/AUDIT REPORT REGRONG INTERFACES TO CONTIGUOUS STATE AND LOCAL AUTHORITIES IN COMPLIANCE WITH 13 CFR 50.54(T)." CONTRARY TO THE ABOVE, THE LICENSEE COULD NOT PRODUCE RECURDS INDICATING HAT THE STATE OR LOCAL GOVERMENT HAD BEEN NOTIFIED OF THE RESULTS OF THE ATTACHED REPORT REGARDING INTERFACES TO CONTIGUOUS STATE AND LOCAL AUTHORITIES IN COMPLIANCE WITH 13 CFR 50.54(T)." CONTRARY TO THE ABOVE, THE LICENSEE COULD NOT PRODUCE RECURDS INDICATING THAT THE STATE OR LOCAL GOVERMENT HAD BEEN NOTIFIED OF THE EVALUATION/AUDIT REPORT.

```
OTHER ITEMS
```

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

CYCLE 12 REFUELING OUTAGE

LAST IE SITE INSPECTION DATE:

INSPECTION REPORT NO: 50-298/88-06

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-004	03/05/88	04/04/88	INADVERTENT ISOLATION OF THE REACTOR WATER CLEANUP SYSTEM AT REDUCED PRESSURE DURING A PLANT COOLDOWN DUE TO LOW PUMP NET POSITIVE SUCTION HEAD
88-005	03/05/88	04/04/88	ACTUATION OF ESF GROUP ISOLATIONS SUBSEQUENT TO A PLANNED MANUAL SCRAM DUE TO MOMENTARY LOW REACTOR VESSEL WATER LEVEL
88-006	03/16/88	04/12/88	UNPLANNED AUTOMATIC ACTUATION OF DIESEL GENERATOR NO. 1 STARTING LOGIC DUE TO 4160V AC BREAKER DURING RELAY COVER REPLACEMENT

PAGE 2-099 THIS PACK INTENTIONALLY LEFT BLANK

2. Reporting Period: <u>04/01/88</u> Outage + On-line Hrs: <u>71</u> 3. Utility Contact: <u>D. GRAHAM (904) 795-3802</u> 4. Licensed Thermal Power (MWt): <u>2544</u> 5. Nameplate Rating (Gross MWe): <u>989 X 0.9 = 890</u> 6. Design Electrical Rating (Net MWe): <u>825</u> 7. Maximum Dependable Capacity (Gross MWe): <u>860</u> 8. Maximum Dependable Capacity (Net MWe): <u>821</u> 9. If Changes Occur Above Since Last Report, Give Reasons: <u>NONE</u> 10. Power Level To Which Restricted, If Any (Net MWe):	9.0
 3. Utility Contact: <u>D. GRAHAM (904) 795-3802</u> 4. Licensed Thermal Power (MWt): <u>2544</u> 5. Nameplate Rating (Gross MWe): <u>989 X 0.9 = 890</u> 6. Design Electrical Rating (Net MWe): <u>825</u> 7. Maximum Dependable Capacity (Gross MWe): <u>821</u> 9. If Changes Occur Above Since Last Report, Give Reasons: <u>NONE</u> 10. Power Level To Which Restricted, If Any (Net MWe):	
4. Licensed Thermal Power (MWt): 2544 5. Nameplate Rating (Gross MWe): 989 X 0.9 = 890 6. Design Electrical Rating (Net MWe): 825 7. Maximum Dependable Capacity (Gross MWe): 860 8. Maximum Dependable Capacity (Net MWe): 821 9. If Changes Occur Above Since Last Report, Give Reasons: NONE 10. Power Level To Which Restricted, If Any (Net MWe): NONE 12. Report Feriod Hrs 719.0 2,903.0 97,60 13. Hours Reactor Critical 719.0 2,632.0 61,95 14. Rx Reserve Shtdwn Hrs .0 .0 1,27	
5. Nameplate Rating (Gross MWe): 989 X 0.9 = 890 6. Design Electrical Rating (Net MWe): 825 7. Maximum Dependable Capacity (Gross MWe): 860 8. Maximum Dependable Capacity (Net MWe): 821 9. If Changes Occur Above Since Last Report, Give Reasons: NONE 10. Power Level To Which Restricted, If Any (Net MWe): 11. Reasons for Restrictions, If Any: NONE 12. Report Feriod Hrs MONTH 719.0 2,903.0 97,60 13. Hours Reactor Critical 719.0 2,632.0 61,95 14. Rx Reserve Shtdwn Hrs .0 .0 1,27	1.11
6. Design Electrical Rating (Net MWe): 825 7. Maximum Dependable Capacity (Gross MWe): 860 8. Maximum Dependable Capacity (Net MWe): 821 9. If Changes Occur Above Since Last Report, Give Reasons: NONE 10. Power Level To Which Restricted, If Any (Net MWe): 11. Reasons for Restrictions, If Any: NONE 12. Report Feriod Hrs MONTH YEAR CUMULAT 719.0 2,903.0 97,60 13. Hours Reactor Critical 719.0 2,632.0 61. Rx Reserve Shtdwn Hrs .0 .0 1,27	
7. Maximum Dependable Capacity (Gross MWe):	
8. Maximum Dependable Capacity (Net MWe): <u>821</u> 9. If Changes Occur Above Since Last Report, Give Reasons: NONE 10. Power Level To Which Restricted, If Any (Net MWe):	
9. If Changes Occur Above Since Last Report, Give Reasons: NONE 10. Power Level To Which Restricted, If Any (Net MWe):	
10. Power Level To Which Restricted, If Any (Net MWe):	
MIL Reasons for Restrictions, If Any:	
NONE MONTH YEAR CUMULAT 12. Report Feriod Hrs 719.0 2,903.0 97,60 13. Hours Reactor Critical 719.0 2,632.0 61,95 14. Rx Reserve Shtdwn Hrs .0 .0 1,27	
MONTH YEAR CUMULAT 12. Report Feriod Hrs 719.0 2,903.0 97,60 13. Hours Reactor Critical 719.0 2,632.0 61,95 14. Rx Reserve Shtdwn Hrs .0 .0 1,27	
13. Hours Reactor Critical 719.0 2,632.0 61,95 14. Rx Reserve Shtdwn Hrs .0 .0 1,27	IVE 7.0
4. Rx Reserve Shtdwn Hrs00	8.8
	5.5
5. Mrs Generator Un-Line	2.6
6. Unit Reserve Shtdwn Hrs0	. 0
7. Gross Therm Ener (MWH) 1,823,486 6,182,835 135,930,	023
8. Gross Elec Ener (MWH) <u>629,176</u> 2,130,936 46,505,	051
9. Net Eloc Ener (MWH)	612
0. Unit Service Factor 100.0 88.4 6	2.1
1. Unit Avail Factor 88.46	2.1
2. Unit Cap Factor (MDC Net) 101.7 85.1 5	5.1
23. Unit Cap Factor (DER Net) 101.2 84.7 5	4.8
4. Unit Forced Outage Rate0	2.6
25. Forced Outage Hours 93.9 17,72	8.9
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration) NONE	\$
27. If Currently Shutdown Estimated Startup Date:	

******	*****	*****	******	*******
×	CRYS	TAL RI	VER 3	×
******	****	*****	******	*******
AVERAGE	DAILY	POWER	LEVEL	(MWe) FLOT
	CRYS	TAL	IVER 3	



UNIT SHUTDOWNS / REDUCTIONS * CRYSTAL RIVER 3

RENERAL RENERAL RENERAL RENERAL RENERAL RENERAL RENER RENER

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause	8	Corrective	Action	to	Prevent	Recurrence

NONE

Type	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE.....FLORIDA

COUNTY.....CITRUS

DIST AND DIRECTION FROM NEAREST POPULATION CTR...7 MI NW OF CRYSTAL RIVER, FLA

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... JANUARY 14, 1977

DATE ELEC ENER 1ST GENER... JANUARY 30, 1977

DATE COMMERCIAL OPERATE.... MARCH 13, 1977

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER.... GULF OF MEXICO

ELECTRIC RELIABILITY

COUNCIL.....SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE......FLORIDA POWER CORPORATION

CONTRACTOR ARCHITECT/ENGINEER.....GILBERT ASSOCIATES

NUC STEAM SYS SUPPLIER... BABCOCK & WILCOX

CONSTRUCTOR.....J. A. JONES CONSTRUCTION

TURBINE SUPPLIER.....WESTINGHOUSE

FEGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....T. STETKA

LICENSE & DATE ISSUANCE.... DPR-72, JANUARY 28, 1977

PUBLIC DOCUMENT ROOM.....CRYSTAL RIVER PUBLIC LIBRARY 668 N.H. FIRST CRYSTAL RIVER, FLORIDA 32629 IN SPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 12 - MARCH 11 (88-06): THIS ROUTINE INSPECTION WAS CONDUCTED BY THREE RESIDENT INSPECTORS IN THE AREAS OF PLANT OPERATIONS, SECURITY, RADIOLOGICAL CONTROLS, LICENSEE EVENT REPORTS AND NONCONFORMING OPERATIONS REPORTS, FACILITY MODIFICATIONS, AND LICENSEE ACTION ON PREVIOUS INSPECTION ITEMS. NUMEROUS FACILITY TOURS WERE CONDUCTED AND FACILITY OPERATIONS OBSERVED. SOME OF THESE TOURS AND OBSERVATIONS WERE CONDUCTED ON BACKSHIFTS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MARCH 7-11 (88-07): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF LIQUID AND GASEOUS RADWASTE SYSTEMS, EFFLUENT MONITORING SYSTEMS, AND ENVIRONMENTAL MONITORING. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MARCH 8-11 (88-08): THIS ROUTINE, ANNOUNCED INSPECTION WAS IN THE AREAS OF LICENSE ACTIONS ASSOCIATED WITH LER 88-006 (REACTOR TRIP DUE TO FAILURE OF FEEDWATER BLOCK VALVE FWV-29). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MARCH 21-25 (88-10): THIS ROUTINE, UNANNOUNCED INSIGCTION WAS IN THE AREAS OF REVIEW OF POST-REFUELING STARTUP TESTING, REACTOR COOLANT SYSTEM LEAKAGE DETERMINATION, REVIEW OF LOCAL LEAK RATE TESTING, AND VERIFICATION OF CONTAINMENT INTEGRITY. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

INSPECTION STATUS - (CONTINUED)

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.8.1.A, PROCEDURES CP-115 AND OP-703 WERE N// ADHERED TO IN THAT REQUIRED CLEARANCE CERTIFICATIONS AND PROPER PROCEDURE STEPS TO DEENERGIZE A 4160V ES BUS WERE NOT FOLL0/4ED. (8704 4)

CONTRARY TO TS 6.8.1, PLANT PROCEDURES OP-703, PT-110, AKD AI 2205 WERE NOT PROPERLY IMPLEMENTED. CONTRARY TO TS 3.3.3.3, TABLE 3.7-7, THE TRIAXIAL PEAK ACCELOGRAPHS DID NOT HAVE THE REQUIRED PLUS OR MINUS 2.06 MEASUREMENT RANGE. (8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: DECEMBER 16 - FEBRUARY 11, 1988 +

INSPECTION REPORT NO: 50-302/88-01 +

REPORTS FROM LICENSEE

DATE OF EVENT	DATE OF REPORT	SUBJECT
01/27/88	04/06/88	UNKNOWN CAUSE RESULTS IN REACTOR BUILDING SPRAY PUMP OPERATING BELOW ITS DESIGN FLOW
01/04/88	04/14/88	UNKNOWN CAUSE OF INSTRUMENT DRIFT LEADS TO LOSS OF REQUIRED SAFETY FUNCTION
03/03/88	04/14/88	VIOLATION OF APP. RIII.O DUE TO INSUFFICIENT RESERVE VOL IN RC PUMP LUBE OIL COLL. SYSTEM CAUSED BY LACK OF AWARENESS
03/25/88	04/25/88	RELEASE MONITOR TRIP SETPOINT ABOVE T.S. LIMIT DUE TO INADEQUATE PROCEDURE
	DATE OF EVENT 01/27/88 01/04/88 03/03/88 03/25/88	DATE OF EVENT DATE OF REPORT 01/27/88 04/06/88 01/04/88 04/14/88 03/03/88 04/14/88 03/25/88 04/25/88

1.	Docket: <u>50-346</u> 0	PERAT	INGS	TATUS
2.	Reporting Period: 04/01/8	8_ Outage	+ On-line	Hrs: 719.0
3.	Utility Contact: MORTEZA	KHARZRAI (419) 249-50	000 X7290
4.	Licensed Thermal Power (MW	t):	-	2772
5.	Nameplate Rating (Gross MW	e):	1069 X	0.9 = 962
6.	Design Electrical Rating (Net MWe):	-	906
7.	Maximum Dependable Capacit	y (Gross M	We):	904
8.	Maximum Dependable Capacit	y (Net MWe):	860
9.	If Changes Occur Above Sin NONE	ce Last Re	port, Give	Reasons:
10.	Power Level To Which Restr	icted, If	Any (Net M	4e):
11.	Reasons for Restrictions,	If Any:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE
13.	Hours Reactor Critical	. 0	1,661.3	45,143.0
4.	Rx Reserve Shtdwn Hrs	. 0	. 0	5,050.1
5.	Hrs Generator On-Lina	. 0	1,580.0	43,380.8
6.	Unit Reserve Shtdwn Hrs	. 0	. 0	1,732.7
7.	Gross Therm Ener (MWH)	0	3,306,442	101,268,640
8.	Gross Elec Ener (MWH)	0	1,072,485	33,448,288
9.	Net Elec Ener (MWH)	0	998,787	31,299,434
20.	Unit Service Factor	J	54.4	50.7
21.	Unit Avail Factor	. 0	54.4	52.7
22.	Unit Cap Factor (MDC Net)	. 0	40.0	42.5
23.	Unit Cap Factor (DER Net)	. 0	38.0	40.4
26.	Unit Forced Outage Rate	. 0		32.5
25.	Forced Ourage Hours	. 0		21,470.0
26.	Shutdowns Sched Over Next	6 Months (Type,Date,I	Ouration):
27	16 Commentally Should form Fail	anted St.	tun Datas	00/12/88

*******	*****	*****	*****	*****	****
×	DAV	IS-BESS	SE 1		*
******	*****	*****	*****	******	****
AVERAGE	DAILY	POWER	LEVEL	(MWe)	PLOT
	DEV	IS-BES	SE 1		



APRIL 1988

Report Period APR 1988			UN	IT	SHU	TDOW	NS / R	E D U C T I O N S × DAVIS-BESSE 1 × xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx		
No.	Date	Type	Hours	Reason	Method	LER	Number	System	Component	Cause & Corrective Action to Prevent Recurrence
2	03/10/88	s	719.0	с	4					THE UNIT OUTAGE WHICH BEGAN ON MARCH 10, 1988 WAS STILL IN PROGRESS THROUGH THE END OF APRIL, 1988.

Type	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exam	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE.....OHIO

COUNTY.....OTTAWA

DIST AND DIRECTION FROM NEAREST POPULATION CTR...21 MI E OF TOLEDO, OH

TYPE OF REACTOR......PWR

DATE INITIAL CRITICALITY...AUGUST 12, 1977

DATE ELEC ENER 1ST GENER...AUGUST 28, 1977

DATE COMMERCIAL OPERATE....JULY 31, 1978

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER....LAKE ERIE

ELECTRIC RELIABILITY

COUNCIL.....EAST CENTRAL AREA RELIABILITY COORDINATION AGREEMENT

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....TOLEDO EDISON

CONTRACTOR ARCHITECT/ENGINEER......BECHTEL

NUC STEAM SYS SUPPLIER... BABCOCK & WILCOX

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....P. BYRON

LICENSING PROJ MANAGER....A. DEAGAZIO DOCKET NUMBER......50-346

LICENSE & DATE ISSUANCE....NPF-3, APRIL 22, 1977

PUBLIC DOCUMENT ROOM.....UNIVERSITY OF TOLEDO LIBRARY GOVERNMENT DOCUMENTS COLLECTION 2801 WEST BANCROFT AVENUE TOLEDO, OHIO 43606

INSPECTION SUMMARY

INSPECTION ON FEBRUARY 23-26 AND MARCH 7-11, 1988 (88008): SPECIAL, ANNOUNCED team inspection of the operational radiation protection, solid radwaste management, and nonradiological chemistry programs including: radiological control organization, management controls, and qualifications (IP 83522); chemistry organization, management controls, and training (IP 83522, 83523); general orientation training (IP 83523); internal exposure controls (IP 83525); external exposure controls (IP 83522); control of radioactive materials and contamination (IP 83526); ALARA (IP 83728); solid radwaste (IP 84522); water quality (IP 79701); implementation of the chemistry program (IP 79701); chemistry QA/QC program (IP 79701); and nonradiological chemistry confirmatory measurements. Also reviewed were past open items, audits, and allegation, and planning and preparation for the extended scheduled outage. Extensive organizational and procedural changes resulting in increased program formality to accommodate significant staff increases are in various stages of completion. The changes have the potential to improve long-term licensee performance in the radiological controls area. Station internal and external doses and radwaste volumes remain very low. No violations or deviations were identified. One unresolved item was identified pertaining to the absorber thickness used in personal dosimetry devices.

INSPECTION ON JANUARY 1 THROUGH FEBRUARY 15, 1988 (88002): ROUTINE, unannounced inspection by resident inspectors of licensee action on previous inspection findings; operational safety; maintenance; surveillance; performance enhancement program; licensee event reports followup; security; onsite followup of events; fuel receipt; management meetings; and independent safety engineering. Of the 11 areas inspected, no violations or deviations were identified in 10 areas; two violations were identified in the followup of licensee event reports (failure to submit a Special Report in a timely manner and failure to comply with

PAGE 2-106

Report Period APR 1988

INSPECTION STATUS - (CONTINUED)

INSPECTION SUMMARY

Technical specification 3.8.2.3., Paragraph 7.b); however, in accordance with 10 CFR 2, Appandix C, Section V.A., a Notice of Violation was not issued for the failure to comply with Technical Specification 3.8.2.3.

INSPECTION ON FEBRUARY 22-26 AND 7-11, 1988 (88006): SPECIAL SAFETY inspection of activities with regard to review of allegations and resultant review of QA implementing procedures (510618) and quality records (510658); design changes and modifications (37700, 37701, 37702); Licensee action on previously identified items (92701); and training (41400). Of the four areas inspected, no violations or deviations were identified in two areas; two violations were identified in the remaining areas (failure to install oil sightglass in accordance with approved procedures and failure to apply design control measures to a spectication change).

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 3.7.9.3.A REQUIRES THAT WITH ONE OR MORE FIRE HOSE STATIONS IN TABLE 3.7-4 INOPERABLE, AN ADDITIONAL EQUIVALENT FIRE HOSE SHALL BE ROUTED TO THE UNPROTECTED AREA FROM AN OPERABLE HOSE STATION WITHIN ONE HOUR. FIRE HOSE STATION HCS-30 IS LISTED IN TABLE 3.7-4. CONTRARY TO THE ABOVE, ON OCTOBER 26, 1987. THE LICENSEE REPLACED A 75 FOOT HOSE SECTION WITH A 50 FT. HOSE SECTION ON FIRE HOSE STATION HCS-30. THE SHOPTER HOSE RENDERED FIRE HOSE STATION HCS-30 INOPERABLE BECAUSE IT HAS UNABLE TO REACH ALL OF THE EQUIPMENT IMPORTANT TO SAFETY IN ROOM 515. THE SGIFT SUPERVISOR WAS NOTIFIED OF THIS CONDITION AT 9:57 A.M. ON OCTOBER 26, 1987. THE SHIFT SUPERVISOR DIRECTED THAT AN ADDITIONAL LENGTH OF HOSE BE ADDED TO FIRE HOSE STATION HCS-30, WHICH MADE IT OPERABLE. FIRE HOSE STATION HCS-30 WAS INOPERABLE FOR APPROXIMATELY FOUR DAYS.

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

TWO MAIN STEAM SAFETY VALVES (MSSV) WERE REPLACED WITH BLANK FLANGES. ONE FAILED AFTER THE PLANT TRIP ON SEPTEMBER 6, 1987, THE SECOND WAS REMOVED DUE TO INDICATIONS OF WEAR WHICH MAY BE A PRECURSOR TO FAILURE. A THIRD MSSV WAS GAGGED SHUT ON OCTOBER 9, 1987, AFTER ADDITIONAL ENGINEERING EVALUATIONS AND INSPECTIONS REVEALED SIGNS OF ANOTHER POSSIBLE FAILURE PRECURSOR.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

SALP MEETING WITH THE LICENSEE A: THE SITE ON MARCH 30, 1988

PLANT STATUS:

SHUT DOWN FOR A 6 MONTH MAINTENANCE/MODIFICATION/REFUELING OUTAGE. RESTART ABOUT MID- SEPTEMBER, 1988.

LAST IE SITE INSPECTION DATE: 04/14/88

INSPECTION REPORT MO: 88013

Report Period	I APR 1988		REPORTS FROM LICENSEE **********************************	

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT	
88-08	031288	040888	NUCLEAR SAFETY RELATED EQUIPMENT POTENTIALLY IMPACTED BY NON -SEISMIC EQUIPMENT	
				==

THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docket: _50-275_ 0	PERAT	ING S	TATUS
2.	Reporting Period: _04/01/88	Outage	+ On-line	Hrs: 719.0
3.	Utility Contact: P. BEDASA	M (805) 5	95-4097	
<i>4</i> .,	Licensed Thermal Power (MWH	t) :		3338
5.	Nameplate Rating (Gross MWG	»):		1137
6.	Design Electrical Rating ()		1086	
7.	Maximum Dependable Capacity	Gross M	We):	1124
8.	Maximum Dependable Capacity	(Net MWe):	1073
9.	If Changes Occur Above Sind NONE	ce Last Re	port, Give	Reasons:
0.	Power Level To Which Restri	icted, If	Any (Net MW	le):
	Reasons for Restrictions,	If Any:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE
3.	Hours Reactor Critical	. 0	1,531.6	
4.	Rx Reserve Shtdwn Hrs	. 0	. 0	
5.	Hrs Generator On-Line	. 0	1,523.3	20,831.
6.	Unit Reserve Shtdwn Hrs	, 0		
17.	Gross Therm Ener (MWH)	0	4,020,604	62,985,06
8.	Gross Elec Ener (MWH)	0	1,355,000	21,205,83
19.	Net Elec Ener (MWH)	-2,730	1,270,956	20,082,65
20.	Unit Service Factor	. 0	52.5	79.
21.	Unit Avail Factor	. 0	52.5	79,
żz.	Unit Cap Factor (MDC Net)	. 0	40.8	71.
23.	Unit Cap Factor (DER Net)	. 0	40.3	70.
24.	Unit Forced Dutage Rate	. 0	3.8	3.
25.	Forced Outage Hours	. 0	59.9	840.
26.	Shutdowns Sched Over Next	6 Months (Type,Date,I	Duration):



APRIL 1988

Report Period APR 1988	UNIT	SH	υT	DO	ы 1	N S	/	R	E	DU) C	T	1 (N	s	XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
	in the second					_		-	-		1.1					

NO	Date	TAbe	Hours	Reason	Method	LER Number	System Compon	nentCause & Corrective Action to Prevent Recurrence	
1 .	03/06/88	S	719.0	C C	4			SCHEDINED REFUELING OUTAGE	

03/06/88 S 719.0 C 4

SCHEDULED REFUELING OUTAGE.

DIABLO CANYON 1 REMAINED SHOTDOWN IN APRIL FOR SCHEDULED REFUELING OUTAGE. 我州关关大王关大王关 * SUMMARY * ********

Ispe	Reason	Method	System & Component		
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161		

FACILITY DESCRIPTION

- LOCATION STATE.....CALIFORNIA

COUNTY......SAN LUIS OBISPO

DIST AND DIRECTION FROM NEAREST POPULATION CTR...12 MI WSW OF SAM LUIS OBISPO

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... APRIL 29, 1984

DATE ELEC ENER 1ST GENER. .. NOVEMBER 11, 1984

DATE COMMERCIAL OPERATE.... MAY 7, 1985

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER.... PACIFIC OCEAN

ELECTRIC RELIABILITY

COUNCIL......WESTERN SYSTEMS COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

CORPORATE ADDRESS......77 BEALE STREET SAN FRANCISCO, CALIFORNIA 94106

CONTRACTOR ARCHITECT/ENGINEER.....PACIFIC GAS & ELECTRIC

NUC STEAM SYS SUPPLIER. .. WESTINGHOUSE

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V

IE RESIDENT INSPECTOR.....J. BURDOIN

LICENSING PROJ MANAGER....H. ROOD DOCKET NUMBER.....50-275

LICENSE & DATE ISSUANCE.... DPR-80, NOVEMBER 2, 1984

PUBLIC DOCUMENT ROOM.....ROBERT F. KENNEDY LIBRARY CALIFORNIA POLYTECHNIC STATE UNIVERSITY SAN LUIS OBISPO, CA. 93407

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION ON TEBRUARY 29 - MARCH 4, 1988 (REPORT NO. 50-275/88-02) AREAS INSPECTED: A SPECIAL ANNOUNCED INSPECTION OF REPRESENTATIVE SUBSYSTEMS OF THE POST-ACCIDENT MONITORING SYSTEM AT THE DIATLO CANYON POWER PLANT UNIT 1.

RESULTS: OF THE AREAS INSPECTED, ONE VIOLATION AND ONE DEVIATION WERE IDENTIFIED.

+ INSPECTION ON MARCH 14-30, 1988 (REPORT NO. 50-275/88-05) AREAS INSPECTED: SECURITY PLAN AND IMPLEMENTING PROCEDURES; MANAGEMENT EFFECTIVENESS; SECURITY ORGANIZATION, RECORDS AND REPORTS; TESTING AND MAINTENANCE; LOCKS, KEYS AND COMBINATIONS; PHYSICAL BARRIERS-PROTECTED AREA; PHYSICAL BARRIERS-VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; LIGHTING; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL- PERSONNEL; ACCESS CONTROL-PACKAGES; ACCESS CONTROL-VEHICLES; DETECTION AIDS-PROTECTED AREA; DETECTION AIDS-VITAL AREAS; ALARM STATIONS; COMMUNICATIONS; PERSONNEL TRAINING AND QUALIFICATION PLAN; CONTINGENCY PLAN IMPLEMENTING PROCEDURES; PHYSICAL PROTECTION SAFEGUARDS INFORMATION; SECURITY EVENT FOLLOWUP; FOLLOWUP ITEMS FROM PREVIOUS SECURITY INSPECTIONS; FOLLOWUP ON INFORMATION NOTICE 87-64; AND INDEPENDENT INSPECTION EFFORT. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: THE LICENSEE WAS FUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THIS INSPECTION EXCEPT FOR THE FOLLOWING ITEMS: PHYLICAL BARRIERS-PROTECTED AREA AND FAILURE TO PROVIDE A CLEAR ZONE FOR SURVEILLANCE AT THE PROTECTED AREA PERIMETER.

+ INSPECTION ON MARCH 21 - APRIL 1, 1988 (REPORT NO. 50-275/88-06) AREAS INSPECTED: AN ANNOUNCED INSPECTION BY TWO REGIONALLY

PAGE 2-112

Report Period APR 1988

INSPECTION SUMMARY

BASED INSPECTORS OF VARIOUS VITAL AREAS AND EQUIPMENT IN THE PLANT, AND FOLLOWUP OF ENFORCEMENT AND OPEN ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MARCH 6 - APRIL 9, 1988 (REPORT NO. 50-275/88-07) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 4 - 8, 1988 (REPORT NO. 50-275/88-08) REPORT BEING FREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 3 - 8, 1988 (REPORT NO. 50-275/88-09) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON MARCH 5 - APRIL 1, 1988 (REPORT NO. 50-275/88-10) '.EPORT, BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 10 - MAY 14, 1988 (REPORT NO. 50-275/38-11) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 18 - 22, 1988 (REPORT NO. 50-275/88-12) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NOME

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ THE PLANT IS IN A REFUELING OUTAGE.

LAST IE SITE INSPECTION DATE: 04/10 - 05/14/88+

INSPECTION REPORT NO: 50-275/88-11+

REPORTS FROM LICENSEE

	NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
	88-02-L0	01-08-88	02-08-88	MODE 1 100% REACT/16 TRIP/TURB TRIP LOW RX COOLANT SYSTEM FLOW SIGNAL INADEQUATE PROCEDURAL GUIDANCE
	88-02-50	03-18-88	04-88-88	10 CFR 73.71 (C) RPT. RE: UNLOCKED HATCH COVER PROVIDING UNDETECTED PA ACCESS (SAFEGUARDS EVENT)
	88-03-10	01-09-88	02-08-88	SPUR ACTUATION CONTAINMENT VENT - NOISE ON POWER BUS TO RAD MONITORS
	88-06-10	02-09-88	03-08-88	MODE 1 FHBVS AND C RM VENT SYSTEMS MODE CHANGE INITIATED DUE TO REDUCED OUTPUT VOLT - INVERTER IY13
	88-07-L0	02-17-88	03-17-88	MODE 1 75% POWER ESF ACTUATION VENT SYSTEMS MODE CHANGE
=				= 2011년 1월 2012년 1월 2

THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docket: _50-323_	OPERAT	ING S	TATUS						
2.	Reporting Period: 04/01/88 Outage + On-line Hrs: 719.0									
3.	Utility Contact: P. BEOE	SEM (805) 5	595-4097							
4.	Licensed Thermal Power (M	3411								
5.	Nameplate Rating (Gross M	-	1164							
6.	Design Electrical Rating		1119							
7.	Maximum Dependable Capaci	1We):	1137							
8.	Maximum Dependable Capaci	ty (Net MWe	:	1087						
9.	If Changes Occur Above Since Last Report, Give Reasons: NONE									
10.	Power Level To Which Rest	ricted, If	Any (Net Mk	le):						
11.	Reasons for Restrictions,	If Any:								
	NONE									
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 18,716.0						
13.	Hours Reactor Critical	719.0	2,836.2	15,752,0						
14.	Rx Reserve Shtdwn Hrs	. 0	.0	.0						
15.	Hrs Generator On-Line	719.0	2,835.6	15,320.6						
16.	Unit Reserve Shtdwn Hrs	. 0	.0	.0						
17.	Gross Therm Ener (MWH)	2,401,972	9,472,541	48,734,528						
18.	Gross Elec Ener (MWH)	797,900	3,159,200	16,146,899						
19.	Net Elec Ener (MWH)	759,409	3,005,037	15,268,429						
20.	Unit Service Factor	100.0	97.7	81.9						
21.	Unit Avail Factor	100.0	97.7	81.9						
22.	Unit Cap Factor (MDC Net)		95.2	75.1						
23.	Unit Cap Factor (DER Net)	94.4	92.5	72.9						
24.	Unit Forced Outage Rate	. 0	2.3	9.3						
25.	Forced Outage Hours		67.4	1,572.8						
26.	Shutdowns Sched Over Next	6 Months (Type, Date, D)uration):						
	REFUELING - SEPT. 15 - 70	DAY DURATI	ON .							
27.	If Currently Shutdown Est	imated Star	i Jp Date:	N/A						



0+0

5

10

20

15

DAYS

APRIL 1988

25

PAGE 2-116

- 0

30

Report	Period Al	PR 19	88		UN	ΙT	SHU	TD	0	WN	1 5	/	R	ED	U	с	T	10	A 6	N S	**************************************
No.	Date	Туре	Hours	Reason	Method	LER	Number	Sy	ste	mī	omp	oner	<u>it</u>			C	au	se	8	Cor	rective Action to Prevent Recurrence
02	04/22/88	F	0.0	В	5									POW	ER	RE	DU	CEI M I	DEM	TO 5 MUSS	0% TO BACKFLUSH CONDENSER WATERBOXES ELING OPERATIONS.

DIABLO CANYON 2 INCURRED 1 POWER REDUCTION IN APRIL AS DISCUSSED ABOVE. *********

* SUMMARY *

Туре	Reason		Method	System & Component		
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)		

**** DIABLO CANYON 2 16 ******

FACILITY DESCRIPTION

LOCATION STATE.....CALIFORNIA DIST AND DIRECTION FROM NEAREST POPULATION CTR...12 MI WSW OF SAN LUIS OBISPO TYPE OF REACTOR PWR DATE INITIAL CRITICALITY... AUGUST 19, 1985 DATE ELEC ENER 1ST GENER...OCTOBER 20, 1985 DATE COMMERCIAL OPERATE....MARCH 13, 1986 CONDENSER COOLING METHOD... ONCE THRU CONDENSER COOLING WATER.... PACIFIC OCEAN ELECTRIC RELIABILITY COUNCIL......WESTERN SYSTEMS

COORDINATING COUNCIL

FACILITY DATA

UTILITY & COMTRACTOR INFORMATION

UTILITY

LICENSEE......PACIFIC GAS & ELECTRIC

SAN FRANCISCO, CALIFORNIA 94106

COMRACTOR ARCHITECT/ENGINEER.....PACIFIC GAS & ELECTRIC

NUC STEAM SYS SUPPLIER. .. WESTINGHOUSE

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V

IE RESIDENT INSPECTOR.....J. BURDOIN

LICENSING PROJ MANAGER..... H. ROOD

LICENSE & DATE ISSUANCE..., DPR-82, AUGUST 26, 1985

PUBLIC DOCUMENT ROOM......ROBERT F. KENNEDY LIBRARY CALIFORNIA POLYTECHNIC STATE UNIVERSITY SAN LUIS OBISPO, CA. 93407 INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION ON FEBRUARY 29 - MARCH 4, 1988 (REPORT NO. 50-323/88-02) AREAS INSPECTED: A SPECIAL ANNOUNCED INSPECTION OF REPRESENTATIVE SUBSYSTEMS OF THE POST-ACCIDENT MONITORING SYSTEM AT THE DIABLO CANYON POWER PLANT UNIT 2.

RESULTS OF THE AREAS INSPECTED, ONE VIOLATION AND ONE DEVIATION WERE IDENTIFIED.

* I'SPECTION ON MARCH 14 - 30, 1988 (REPORT NO. 50-323/88-05) AREAS INSPECTED: SECURITY PLAN AND IMPLEMENTING PROCEDURES; MANAGEMENT EFFECTIVENESS; SECURITY ORGANIZATION; RECORDS AND REPORTS; TESTING AND MAINTENANCE; LOCKS; KEYS AND COMBINATIONS; "HYSICAL BARRIERS-PROTECTED AREA; PHYSICAL BARRIERS-VITAL AREAS; SECURITY SYSTEM SUPPLY; LIGHTING; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL-PERSONNEL; ACCESS CONTROL PACKAGES; ACCESS CONTROL-VEHICLES; DETECTION AIDS-PROTECTED AREA; DETECTION AIDS-VITAL AREAS; ALARM STATIONS; COMMUNICATIONS; PERSONNEL TRAINING AND QUALIFICATION PLAN; CONTINGENCY PLAN IMPLEMENTING PROCEDURES; PHYSICAL PROTECTION SAFEGUARDS INFORMATION; SECURITY EVENT FOLLOWUP; FOLLOWUP ITEMS FROM PREVIOUS SECURITY INSPECTIONS; FOLLOWUP ON INFORMATION NOTICE 87-64; AND INDEPENDENT INSPECTION EFFORT. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MARCH 28 - APRIL 1, 1988 (REPORT NO. 50-323/88-06) AREAS INSPECTED: AN ANNOUNCED INSPECTION BY TWO REGIONALLY BASED INSPECTORS OF VARIOUS VITAL AREAS AND EQUIPMENT IN THE PLANT, AND FOLLOWUP OF ENFORCEMENT AND OPEN ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

PAGE 2-118

Report Period APR 1988

INSPECTION STATUS - (CONTINUED)

INSPECTION SUMMARY

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MARCH 6 - APRIL 9, 1988 (REPORT NO. 50-323/88-07) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 3 - 8, 1988 (REPORT NO. 50-323/88-08) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON MARCH 28 - APRIL 1, 1988 (REPORT NO. 50-323/88-09) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 10 - MAY 14, 1988 (REPORT NO. 50-323/88-10) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 18 -22, 1988 (REPORT NO. 50-323/88-11) REPORT BEING FREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS: NONE FACILITY ITEMS (PLANS AND PROCEDURES): NONE MANAGERIAL ITEMS: NONE PLANT STATUS: THE PLANT IS IN COMMERCIAL OPERATION, AT APPROXIMATELY 100% POWER. LAST IE SITE INSPECTION DATE: 04/10 - 05/14/88+ INSPECTION REPORT ND: 50-323/88-10+

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-01-LO	02-25-88	03-24-88	SPURIOUS ACTUATION FUEL HANDLING BLDG VENT SYSTEMS IODINE REMOVAL MODE DUE TO ELETRONIC NOISE
	==========		12

THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docket: _50-237	OPERAT	INGS	TATUS								
2.	. Reporting Period: <u>04/01/88</u> Outage + On-line Hrs: <u>719.0</u>											
3.	Utility Contact: D.C. MAXWELL (815) 942-2920 X 489											
4.	Licensed Thermal Power (MWt):											
5.	Nameplate Rating (Gross MWe): 920 X 0.9 = 828											
6.	Design Electrical Rating (Net MWe):794											
7.	Maximum Dependable Capacity (Gross MWe):812											
8.	Maximum Dependable Capaci	ty (Net MWe):	772								
9.	If Changes Occur Above Since Last Report, Give Reasons: NONE											
10.	Power Level To Which Rest	ricted, If	Any (Net M	Ne):								
11.	Reasons for Restrictions,	If Any:										
	NONE											
12.	Report Period Mrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 157,487.0								
13.	Hours Reactor Critical	719.0	2,903.0	119,475.3								
14.	Rx Reserve Shtdwn Hrs	. 0		. 0								
15.	Hrs Generator On-Line	719.0	2,903.0	113,996.8								
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	. 0								
17.	Gross Therm Ener (MWH)	1,582,076	6,561,536	234,580,359								
18.	Gross Elec Ener (MWH)	502,653	2,097,836	75,037,806								
19.	Net Elec Ener (MWH)	479,709	2,002,750	70,938,928								
20.	Unit Service Factor	100.0	100.0	72.4								
21.	Unit Avail Factor	100.0	100.0	72.4								
22.	Unit Cap Factor (MDC Net)	86.4	89.4	58.3								
23.	Unit Cap Factor (DER Net)	84.0	86.9	56.7								
24.	Unit Forced Outage Rate	. 0	. 0	11.4								
25.	Forced Outage Hours	. 0	. 0	1.157.0								
26.	Shutdowns Sched Over Next	6 Months (Type, Date, 1	Duration):								
	BATTERY DISCH. TEST 5/88, 1	DURA. 1 WK.	REFUEL 9/1	38								
27.	If Currently Shutdown Est	imated Star	tup Date:	N/A								





APRIL 1988

***** UNIT SHUTDOWNS / REDUCTIONS * DRESDEN 2 Report Period APR 1988 ************************************ Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence No. THE 24 RECIRC M.G. TRIPPED AND LOAD WAS REDUCED TO 5 04/07/88 S 0.0 A 1 INVESTIGATE PROBLEM. LOAD WAS REDUCED TO FACILITATE A DRYWELL ENTRY. 3 0.0 H 04/13/88 S 2 LOAD WAS REDUCED TO ENTER DRYWELL AND REPAIR AIR 5 H 3 04/27/88 S 0.0 LINE ON 1B MSIV.

4

Туре	Reason	Method	System & Component		
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Err C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual ror 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)		

FACILITY DESCRIPTION

INTERPOOL NETWORK

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE......COMMONWEALTH EDISON

CORPORATE ADDRESS......P.O. BOX 767 CHICAGO, ILLINOIS 60690

CONTRACTOR

ARCHITECT/ENGINEER.....SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR......UNITED ENG. & CONSTRUCTORS

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....S. DUPONT

LICENSE & DATE ISSUANCE.... DPR-19, DECEMBER 22, 1969

PUBLIC DOCUMENT ROOM......MORRIS PUBLIC LIBRARY 604 LIBERTY STREET MORRIS, ILLINOIS 60450 INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON FEBRUARY 29 THROUGH MARCH 2, 1988 (88004; 88004): ROUTINE, ANNOUNCED INSPECTION OF THE DRESDEN STATION'S ANNUAL EMERGENCY PREPAREDNESS EXERCISE, INVOLVING OBSERVATIONS BY FOUR NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE. NO VIOLATIONS OF NRC REQUIREMENTS WERE IDENTIFIED.

INSPECTION DURING THE PERIOD OF JANUARY 30 THROUGH MARCH 17, 1982 (88005; 88005): ROUTINE UNANNOUNCED SAFETY INSPECTION BY THE RESIDENT INSPECTOR SON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY VERIFICATION; FOLLOWUP OF EVENTS; LICENSEE EVENT REPORTS FOLLOWUP; NRC INFORMATION NOTICE FOLLOWUP; IT-2515/90; MANAGEMENT MEETINGS; CHAIRMAN ZECH VISIT; AND REPORT REVIEW. OF THE 9 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN 7 AREAS; ON VIOLATION WAS IDENTIFIED IN THE AREA OF THE OPERATIONAL SAFETY VERIFICATION (FAILURE TO ENSURE COMPLIANCE WITH A TECHNICAL SPECIFICATION). ADDITIONALLY, ONE VIOLATION WAS ALSO IDENTIFIED IN THE AREA OF LICENSEE EVENT REPORTS; HONEVER IN ACCORDANCE WITH 10 CFR* 2, APPENDIX C, SECTION V.A., A NOTICE OF VIOLATION WAS NOT ISSUED (FAILURE TO VERIFY THE APRM INOPERATIVE FUNCTION WHILE IN THE STARTUP MODE).

INSPECTION FROM SEPTEMBER 3, 1987 THROUGH MARCH 16, 1988 (87030; 87029): SPECIAL SAFETY INSPEC TION OF PREVIOUSLY IDENTIFIED ITEMS OF NONCOMPLIANCE AND UNRESOLVED ITEMS, AND ONSITE FOLLOWUP OF EVENTS AT OPERATING REACTORS (92701, 92702 AND 93702). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

Report Period APR 1988
ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION (TS) 3.7.A.5.A, "LIMITING CONDITION FOR OPERATION (LCO)," REQUIRES THAT THE PRIMARY CONTAINMENT ATMOSPHERE BE REDUCED TO LESS THAN FOUR PERCENT DXYGEN WITH NITROGEN GAS DURING REACTOR POWER OPERATION WITH REACTOR COOLANT PRESSURE ABOVE 90 PSIG, EXCEPT AS SPECIFIED IN TS 3.7.A.5.B. WHICH rROVIDES THAT DEINERTING MAY COMMENCE 24 HOURS PRIOR TO A SHUTDOWN. DRESDEN 00 PERATING PROCEDURE 1600-9, REVISION 4, "NITROGEN MAKE-UP TO PRIMARY CONTAINMENT," STATES THAT "THE CONTAINMENT ATMOSPHERE SHALL BE REDUCED TO LESS THAN FOUR X OXYGEN WITH NITROGEN GAS . . . AND UP TO 24 HOURS BEFORE TAKING THE REACTOR OUT OF THE RUN MODE." CONTRARY TO THE ABOVE, AT 1220 HOURS ON NOVEMBER 28, 1986, DURING POWER OPERATION AND WITH REACTOR COOLANT PRESSURE ABOVE 90 PSIG, THE LICENSEE COMMENCED DEINERTING PROCEDURES. ALTHOUGH THE OXYGEN CONCENTRATION MAS GREATER THAN FOUR PERCENT, THE REACTOR CONTINUED OPERATING UNTIL IT WAS MANUALLY SCRAMMED AT 1703 HOURS ON 11/29/86 A DEINERTING PERIOD OF 28 HOURS & 43 MINUTES. (B) TECHNICAL SPEC. LIMITING CONDITION FOR OPERATION 3.7.A.7.A. REQ. THAT DIFFERENTIAL PRESSURE BETWEEN THE DRYWELL & SUPPRESSION CHAMBER BE MAINTAINED AT = TO OR < THAN 1.00 PSID, EXCEPT AS SPECIFIED IN TS 3.7.A.(1), WHICH PROVIDES THAT THE DIFFERENTIAL MAY BE RELAXED 24 HOURS PRIOR TO A REACTOR SHUTDOWN, AND TS 3.7.A.7.A.(2) IS NOT APPLICABLE HERE. CONTRARY TO THE ABOVE, AT 1220 HOURS ON NOVEMBER 28, 1986, A TWO INCH EQUALIZING LINE BETWEEN THE DRYWELL AND THE TORUS WAS OPENED, THEREBY REDUCING THE DIFFERENTIAL PRESSURE TO LESS THAN 1.00 PSID. THE REACTOR CONTINUED TO OPERATE IN THIS CONFIGURATION UMTIL 1703 HOURS ON NOVEMBER 29, 1986, A PERIOD OF 28 HOURS AND 43 MINUTES, WHEN THE REACTOR WAS MANUALLY SCRAMMED. (8700 3)

10 CFR 50, APPENDIX B, CRITERION XVI, AS IMPLEMENTED BY CECO TOPICAL REPORT CE-1-A, "QUALITY ASSURANCE PROGRAM FOR NUCLEAR GENERATING STATIONS", AND CECO CORPORATE QUALITY ASSURANCE MANUAL, NUCLEAR GENERATING STATIONS, "QUALITY REQUIREMENT SECTION 16.0", REQUIRES THAT CORRECTIVE ACTIONS IDENTIFIED FROM NONCONFORMANCES, INCIDENTS AND DEVIATIONS ARE VERIFIED FOR SATISFACTORY COMPLETION TO PRECLUDE REPETITION. CONTRARY TO THE ABOVE, THE CORRECTIVE ACTIONS TAKEN TO RESOLVE AN AUGUST 18, 1987, VIOLATION OF TECHNICAL SPECIFICATION TABLE 3.1.1, WHICH REQUIRES A MINIMUM OF TWO OPERABLE APRM DOWNSCALE/IRM HIGH HIGH OR INOPERABLE TRIP FUNCTIONS PER REACTOR PROTECTION SYSTEM CHANNEL WERE NOT EFFECTIVE IN PREVENTING A SECOND IDENTICAL VIOLATION OF THIS TECHNICAL SPECIFICATION REQUIREMENT WHICH OCCURRED FOUR MONTHS LATER ON DECEMBER 18, 1987. (8704 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT OPERATING ROUTINELY AT APPROXIMATELY FULL POWER.

LAST IE SITE INSPECTION DATE: 03/14/88

INSPECTION REPORT NO: 88005

Repo	rt Perio	d APR 1988		REPORTS FROM LICENSEE * DRESDEN 2 * **********************************
==	NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
	88-01	032988	042588	DIESEL GENERATOR AIR START PIPING OUTSIDE FSAR STRESS ALLOWABLES DUE TO APPARENT ORIGINAL DESIGN DEFICIENCY

THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docket: 50-249 0	PERAT	INGS	TATUS									
2.	Reporting Period: _04/01/8	8 Outage	+ On-line	Nrs: 719.0									
3.	Utility Contact: D.C. MAX	WELL (815)	942-2920	X 489									
4.	Licensed Thermal Power (MW	(t):		2527									
5.	Nameplate Rating (Gross MWe): 920 X 0.9 = 828												
6.	Design Electrical Rating (Design Electrical Rating (Net MWe):											
7.	Maximum Dependable Capacit	y (Gross M	We):	812									
8.	Maximum Dependable Capacit	y (Net MWe):	773									
9.	If Changes Occur Above Since Last Report, Give Reasons:												
10	Power Level To Which Restr	icted. If	Any (Net M	ie):									
11.	Reasons for Restrictions.	If Any:											
	NONE												
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE									
13.	Hours Reactor Critical	. 0	2,066.4	105,474.8									
14.	Rx Reserve Shtdwn Mrs	. 0	.0	. 0									
15.	Hrs Generator On-Line		2,066.0	100,913.6									
16.	Unit Reserve Shtdwn Hrs		. 0	. 0									
17.	Gross Therm Ener (MWH)	0	4,792,721	206,168,243									
18.	Gross Elec Ener (MWH)	0	1,557,623	66,588,865									
19.	Net Elec Ener (MWH)		1,486,943	63,064,763									
20.	Unit Service Factor	. 0	71.2	68.6									
21.	Unit Avail Factor	. 0	71.2	68.6									
22.	Unit Cap Factor (MDC Net)	. 0	66.3	55.5									
23.	Unit Cap Factor (DER Net)		64.5	54.0									
24.	Unit Forced Outage Rate	. 0	. 0	12.6									
25.	Forced Outage Hours	. 0	. 0	9,463.9									
26.	Shutdowns Sched Over Next NONE	6 Months (Type,Date,	Duration):									
27.	If Currently Shutdown Esti	mated Star	tup Date:	06/25/88									

DRESDEN 3



APRIL 1988

Report Period APR 1988	UNIT	SHU	TDOWN	S / R	EDUCTIONS	**************************************
	 					11 Anti- An Desugat Desugars

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

1 03/27/88 S 719.0 C 4

SCHEDULED REFUELING OUTAGE.

Туре	Reason		Method	System & Component		
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exam	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)		

FACILITY DESCRIPTION

LOCATION STATE.....ILLINOIS

COUNTY.....GRUNDY

DIST AN. DIRECTION FROM NEAFEST POPULATION CTR...9 MI E OF MORRIS, ILL

TYPE UF REACTOR BWR

DATE INITIAL CRITICALITY... JANUARY 31, 1971

DATE ELEC ENER 1ST GENER...JULY 22, 1971

DATE COMMERCIAL OPERATE....NOVEMBER 16, 1971

CONDENSER COOLING METHOD...COOLING LAKE

CONDENSER COOLING WATER....KANKAKEE RIVER

ELECTRIC RELIABILITY COUNCIL.....MID-AMERICA

INTERPOOL NETWORK

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE......COMMONWEALTH EDISON

CORPORATE ADDRESS......P.O. BOX 767 CHICAGO, ILLINOIS 60690

CONTRACTOR

ARCHITECT/ENGINEER..... SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR......UNITED ENG. & CONSTRUCTORS

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....S. DUPONT

LICENSE & DATE ISSUANCE.... DPR-25, MARCH 2, 1971

PUBLIC DOCUMENT ROOM MORRIS PUBLIC LIBRARY 604 LIBERTY STREET MORRIS, ILLINOIS 60450 INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON FEBRUARY 29 THROUGH MARCH 2, 1988 (88004; 88004): ROUTINE, ANNOUNCED INSPECTION OF THE DRESDEN STATION'S ANNUAL EMERGENCY PREPAREDNESS EXERCISE, INVOLVING OBSERVATIONS BY FOUR NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE. NO VIOLATIONS OF NRC REQUIREMENTS WERE IDENTIFIED.

INSPECTION DURING THE PERIOD OF JANUARY 30 THROUGH MARCH 17, 1988 (88005; 88005): ROUTINE UNANNOUNCED SAFETY INSPECTION BY THE RESIDENT INSPECTOR SON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY VERIFICATION; FOLLOWUP OF EVENTS; LICENSEE EVENT REPORTS FOLLOWUP; NRC INFORMATION NOTICE FOLLOWUP; IT-2515/90; MANAGEMENT MEETINGS; CHAIRMAN ZECH VISIT; AND REPORT REVIEW. OF THE 9 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN 7 AREAS; ON VIOLATION WAS IDENTIFIED IN THE AREA OF THE OPERATIONAL SAFETY VERIFICATION (FAILURE TO ENSURE COMPLIANCE WITH A TECHNICAL SPECIFICATION). ADDITIONALLY, ONE VIOLATION WAS ALSO IDENTIFIED IN THE AREA OF LICENSEE EVENT REPORTS; HOWEVER IN ACCORDANCE WITH 10 CFR' 2, APPENDIX C, SECTION V.A., A NOTICE OF VIOLATION WAS NOT ISSUED (FAILURE TO VERIFY THE APRM INOPERATIVE FUNCTION WHILE IN THE STARTUP MODE).

INSPECTION FROM SEPTEMBER 3, 1987 THROUGH MARCH 16, 1988 (87030; 87029): SPECIAL SAFETY INSPEC TION OF PREVIOUSLY IDENTIFIED ITEMS OF NONCOMPLIANCE AND UNRESOLVED ITEMS, AND ONSITE FOLLOWUP OF EVENTS AT OPERATING REACTORS (92701, 92702 AND 93702). NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON FEBRUARY 16-18, 22-26, MARCH 1-4,10 AND 14-16, 1988 (88006): SPECIAL ANNOUNCED SAFETY INSPECTION OF PREVIOUS INSPECTION FINDINGS FROM THE SAFETY SYSTEM OUTAGE MODIFICATION INSPECTION (SSOMI) REPORTS NO. 50-249/86009 AND NO. 50-249/86012. (92701) 10 PREVENT RECURR ENCE OF DEFIENCIES REVEALED BY THE SSOMI, THE LICENSE MANAGEMENT EFFECTED MAJOR CHANGES IN PROCEDURE DAP PAGE 2-130

Report Period APR 1988

INSPECTION SUMMARY

5-1. THE REVISED PROCEDURE IMPOSES RESTRICTIONS ON THE PERFORMANCE OF MODIFI CATIONS WHICH CAN PRECLUDE RECURRENCE OF THE NOTED DEFICIENCIES. ALL 23 INSPECTION FINDINGS WERE CLOSED. FINAL INSTALLATIONS WHICH DEVIATED FROM ORIGINAL SPECIFICATIONS WERE REANALYZED APPROVED AND CORRECTIONS WERE INITIATED FOR AFFECTED DRAWINGS.

ENFORCEMENT SUMMARY

10 CFR 50, APPENDIX B, CRITERION XVI, AS IMPLEMENTED BY CECO TOPICAL REPORT CE-1-A, "QUALITY ASSURANCE PROGRAM FOR NUCLEAR GENERATING STATIONS", AND CECO CORPORATE QUALITY ASSURANCE MANUAL, NUCLEAR GENERATING STATIONS, "QUALITY REQUIREMENT SECTION 16.0", REQUIRES THAT CORRECTIVE ACTIONS IDENTIFIED FROM NONCONFORMANCES, INCIDENTS AND DEVIATIONS ARE VERIFIED FOR SATISFACTORY COMPLETION TO PRECLUDE REPETITION. CONTRARY TO THE ABOVE, THE CORRECTIVE ACTIONS TAKEN TO RESOLVE AN AUGUST 18, 1987, VIOLATION OF TECHNICAL SPECIFICATION TABLE 3.1.1, WHICH REQUIRES A MINIMUM OF TWO OPERABLE APRM DOWNSCALE/IRM HIGH HIGH OR INOPERABLE TRIP FUNCTIONS PER REACTOR PROTECTION SYSTEM CHANNEL WERE NOT EFFECTIVE IN PREVENTING A SECOND IDENTICAL VIOLATION OF THIS TECHNICAL SPECIFICATION REQUIREMENT WHICH OCCURRED FOUR MONTHS LATER ON DECEMBER 18, 1987.

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT SHUTDOWN 3/26/88 FOR REFUELING OUTAGE. (EXPECTED TO LAST UNTIL END OF JUNE)

LAST IE SITE INSPECTION DATE: 03/16/88

INSPECTION REPORT NO: 88006

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-03	032388	041888	FLUED HEAD ANCHOR SUPPORTS IN EXCESS OF FSAR DESIGN CRITERIA DUE TO DESIGN AND CONSTRUCTION DEFICIENCIES
88-04	040488	042888	TYPE B AND C LOCAL LEAK RATE TEST LIMIT EXCEEDED DUE TO LEAKAGE THROUGH PRIMARY CONTAINMENT ISOLATION VALVE
88-05	032688	041888	HPCI SYSTEM INTENTIONALLY MADE INOPERABLE TO FACILITATE PRE-PLA NNED PREVENTIVE MAINTENANCE TESTING
88-06	032988	042688	HPCI AREA TEMPERATURE SWITCHES EXCEEDED TECHNICAL SPECIFICATION LIMIT DUE TO INSTRUMENT SETPOINT DRIFT

THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docket: _50-331 0	OPERAT	ING S	TATUS								
2.	Reporting Period: 04/91/3	88_ Outage	+ On-line	Hrs: 719.0								
3.	Utility Contact: L. MILL	ER (319) 85	1-7204									
4.	Licensed Thermal Power (M)	Ht):		1658								
5.	Nameplate Rating (Gross MWe): 663 X 0.9 = 597											
6.	Design Electrical Rating	(Net MWe):		538								
7.	Maximum Dependable Capacity (Gross MWe):565											
8.	Maximum Dependable Capacit	ty (Net MWe):	565								
9.	If Changes Occur Above Sin	nce Last Re	port, Give	Reasons:								
	ITEM 6 8 7 WILL VARY TO RE	EFLECT SEAS	ONAL CONDIT	TIONS.								
10.	Power Level To Which Rest	icted. If	Any (Net M	Ne):								
11.	Reasons for Restrictions,	If Any:										
	NONE											
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 116,111.0								
13.	Hours Reactor Critical	719.0	2,903.0	83,216.8								
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	172.8								
15.	Hrs Generator On-Line	719.0	2,903.0	81,158.4								
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	. 0								
17.	Gross Therm Ener (MWH)	1,132,702	4,681,749	104,719,030								
18.	Gross Elec Ener (MWH)	385,549	1,601,620	35,161,448								
19.	Net Elec Ener (MWH)	363,664	1,495,896	32,939,224								
20.	Unit Service Factor	100.0	100.0	69.9								
21.	Unit Avail Factor	100.0	100.0	69.9								
22.	Unit Cap Factor (MDC Net)	89.5	97.7	50.2								
23.	Unit Cap Factor (DER Net)	94.0	95.8	52.7								
24.	Unit Forced Outage Rate	. 0	.0	14.7								
25.	Forced Outage Hours	. 0		13,917.7								
26.	Shutdowns Sched Over Next	6 Months (Type, Date,	Duration):								
	REFUEL 9/29/88 - 2 MONTH	DURATION										
27 .	If Currently Shutdown Est	imated Star	tup Date:	N/A								



APRIL 1988

Report Period APR 1988			UN	IT	SHU	тром	NS / R	E D U C T I O N S *********************************		
No.	Date	Түре	Hours	Reason	Method	LER	Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	04/15/88	53	0.0	В	5					POWER REDUCED TO APPROXIMATELY 50% TO REPAIR A FEED PUMP SEAL WATER CONTROL VALVE.
2	04/19/88	S	0.0	В	5					POWER REDUCED TO APPROXIMATELY 50% TO PERFORM MAINTENANCE ON THE *A* FEEDWATER PUMP BEARING.

********** * SUMMARY * ********

DUANE ARNOLD INCURRED 2 POWER REDUCTIONS IN APRIL FOR REASONS STATED ABOVE.

Туре	Reason		Method	System & Component			
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)			

PAGE 2-135

125

FACILITY DESCRIPTION

DIST AND DIRECTION FROM NEAREST POPULATION CTR...8 MI NW OF CEDAR RAPIDS, IA

TYPE OF REACTOR BWR

DATE INITIAL CRITICALITY. .. MARCH 23, 1974

DATE ELEC ENER 1ST GENER. .. MAY 19, 1974

DATE COMMERCIAL OPERATE.... FEBRUARY 1, 1975

CONDENSER COOLING METHOD. ... COOLING TOWER

CONDENSER COOLING WATER....CEDAR RAPIDS RIVER

ELECTRIC RELIABILITY

COUNCIL.....MID-CONTINENT AREA RELIABILITY COORDINATION AGREEMENT

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS.....I E TOWERS, P.O. BOX 351 CEDAR RAPIDS, IOWA 52406

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER......GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....M. PARKER

LICENSE & DATE ISSUANCE..., DPR-49, FEBRUARY 22, 1974

PUBLIC DOCUMENT ROOM......CEDAR RAPIDS PUBLIC LIBRARY 500 FIRST STREET, S.E. CEDAR RAPIDS, IOWA 52401 INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON FEBRUARY 29 THROUGH MARCH 4 AND MARCH 22, 1988 (88005): ROUTINE UNANNOUNCED INSPECTION OF : (1) QUALITY ASSURANCE AND CONFIRMATORY MEASUREMENTS FOR IN-PLANT RADIOCHEM ICAL ANAYSES; (2) VERIFICATION OF TLD COLLOCATION; (3) ACTION ON OPEN ITEMS IDENTIFIED DURING PREVIOUS INSPECTIONS; AND (4) MANAGEMENT CONTROLS AND ORGANIZATION. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED DURING THIS INSPECTION.

INSPECTION ON JANUARY 19, 1988 THROUGH FEBRUARY 29, 1988 (88094): ROUTINE, UNANNOUNCED INS PECTION BY THE RESIDENT INSPECTOR OF LICENSEE ACTICN ON PREVIOUS INSPECTION FINDINGS, OPERA TIONAL SAFETY, MAINTENANCE, SURVEILLANCE, LICENSEE EVENT REPORTS, IE BULLETINS. INFORMATION NOTICES, ALLEGATIONS, GENERIC LETTERS, AND MANAGEMENT MEETINGS. OF THE NINE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN EIGHT AREAS; ONE VIOLATION WAS IDENTIFIED IN THE REMAINING AREA (FAILURE TO PROPERLY WEAR PROTECTIVE CLOTHING AS DIRECTED BY THE RWP AND FAILURE TO PERFORM A WHOLE BODY FRISK UPON EXITING A CONTAMINATED AREA). BOTH EXAMPLES OF THE VIOLATION WERE OF MANOR SAFETY SIGNIFICANCE AND DID NOT AFFECT THE PUBLIC'S HEALTH AND SAFETY.

MEETING ON APRIL 7, 1988 (88008): A SPECIAL MANAGEMENT MEETING WAS CONDUCTED TO DISCUSS THE LICENSEE'S EFFORTS IN RESPONSE TO THE FEDERAL EMERGENCY MANAGEMENT AGENCY'S (FEMA) CONCERN ABOUT THE ADEQUACY OF OFFSITE PLANNING FOR LINN AND BENTON COUNTY, IOWA AND THE STATE OF IOWA AS IT RELATES TO THE EXPANDED EMERGENCY PLANNING ZONE (EPZ) AROUND THE DUANE ARNOLD ENERGY CENTER. THE INFORMATION PROVIDED BY THE LICENSEE INDICATES THAT THE LICENSEE IS AGGRES SIVELY PURSUING RESOLUTION OF THE FEMA IDOLVED.

PAGE 2-136

Report Period APR 1988

• •

**** DUANE ARNOLD × ********************************

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEEURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING ROUTINELY.

LAST IE SITE INSPECTION DATE: 04/07/88

INSPECTION REPORT NO: 88008

REPORTS FROM LICENSEE

NUMBED	DATE OF	DATE OF	
NUMBER	EVENT	REPORT	SUBJECT

1.	Docket: 50-348 0	PERAT	ING S	TATUS									
2.	Reporting Period: 04/01/88 Outage + On-line Hrs: 719.0												
3.	Utility Contact: J. D. WO	ODARD (205	899-5154										
4.	Licensed Thermal Power (MW	t):	· · · · · · · · · · · · · · · · · · ·	2652									
5.	Nameplate Rating (Gross MW	e):		860									
6.	Design Electrical Rating (Net MWe):		829									
7.	Maximum Dependable Capacity	y (Gross M	We):	853									
8.	Maximum Dependable Capacity	y (Net MWe):	813									
9.	If Changes Occur Above Since Last Report, Give Reasons:												
	Prove Level To Which Ports	inted If	Any (Not Mk	(a):									
	Reasons for Restrictions	If Any:	any thet he										
	NONE												
	NVIII.	MONTH	YFAR	CUMULATIVE									
2.	Report Period Hrs	719.0	2,903.0	91,295.0									
3.	Hours Reactor Critical	. 0	2,040.8	67,257.5									
4.	Rx Reserve Shtdwn Hrs	. 0	. 0	3,650.7									
15.	Hrs Generator On-Line	. 0	2,040.1	65,865.6									
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	. 0									
17.	Gross Therm Ener (MWH)	0	5,400,491	167,823,838									
18.	Gross Elec Ener (MWH)	0	1,763,232	53,829,568									
19.	Net Elec Ener (MWH)	0	1,673,430	50,842,626									
20.	Unit Service Factor	. 0	70.3	72.1									
21.	Unit Avail Factor		70.3	72.1									
22.	Unit Cap Factor (MDC Net)	. 0	70.9	69.1									
23.	Unit Cap Factor (DER Net)	. 0	69.5	67.2									
24.	Unit Forced Outage Rate	. 0	. 0	9.4									
25.	Forced Outage Hours	. 0		6,823.1									
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):									





* Item calculated with a Weighted Average

Report Period APR 1988	UN	IT	SHU	TDO	wns /	REDUCTIONS	**************************************
No Date Type Hours Reason	Mothod	IFP	Number	Sueta	Compana	t Causa & Can	nactive Action to Provent Posurrorse

NQ.	Date	TAbé	nours	Keason	Method	LEK Mumber	SARtow	Component	-	Cause (a Correctio	ve Actio	to Preve	INT K	scurrenc
001	03/26/88	S	719.0	С	4				THE CYC	CLE 8-9	REFUELING	OUTAGE	CONTINUED	FROM	3/26/88

********** FARLEY 1 REMAINED SHUTDOWN IN APRIL FOR SCHEDULED REFUELING * SUMMARY * OUTAGE.

Туре	Reason		Method	System & Component
F-Forced S-Schud	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

************************************	ILITY DATA Report Period APR 198
FACILITY DESCRIPTION	UTILITY & CONTRACTOR INFORMATION
LOCATION STATEALABAMA	UTILITY LICENSEEALABAMA POWER CO.
COUNTY	CORPORATE ADDRESS
DIST AND DIRECTION FROM NEAREST POPULATION CTR18 MI SE OF DOTHAN, ALA	CONTRACTOR ARCHITECT/ENGINEERSOUTHERN SERVICES INCORPORATED
TYPE OF REACTORPWR	NUC STEAM SYS SUPPLIERWESTINGHOUSE
DATE INITIAL CRITICALITYAUGUST 9, 1977	CONSTRUCTORDANIEL INTERNATIONAL
DATE ELEC ENER 1ST GENERAUGUST 18, 1977	TURBINE SUPPLIERWESTINGHOUSE
DATE COMMERCIAL OPERATEDECEMBER 1, 1977	REGULATORY INFORMATION
CONDENSER COOLING METHODCOOLING TOWER	IE RÉGION RESPONSIBLEII
CONDENSER COOLING WATERCHATAHOOCHEE RIVER	IE RESIDENT INSPECTORW. BRADFORD
ELECTRIC RELIABILITY COUNCILSOUTHEASTERN ELECTRIC	LICENSING PROJ MANAGERE. REEVES DOCKET NUMBER
RELIABILITY COUNCIL	LICENSE & DATE ISSUANC PF-2, JUNE 25, 1977
	PUBLIC DOCUMENT ROOM JUSTON/LOVE MEMORIAL LIBRARY

212 W. BURDESHAW STREET DOTHAN, ALABAMA 36302

INSPECTION SUMMARY

+ INSPECTION JANUARY 4-7 (8%-01): THIS WAS A SPECIAL, ANNOUNCED INSPECTION CONDUCTED TO FOLLOWUP ON ALLEGATIONS RELATIVE TO THE LICENSEE'S FACILITY. TWENTY GENERAL ALLEGATION SUBJECT AREAS WERE IDENTIFIED TO THE LICENSEE. SOME SIXTY SPECIFIC ALLEGATIONS WERE INVESTIGATED AND ARE ADDRESSED IN THIS REPORT. NRC FOLLOWUP OF THESE ALLEGATIONS CONSISTED OF A REVIEW OF PERTINENT RECORDS, LOGS, AND REPORTS PERTAINING TO PLANT CHEMISTRY, RADIOCHEMISTRY, RADIOACTIVITY COUNTING ROOM/OPERATION, EFFLUENT MONITORING AND ENVIRONMENTAL MONITORING. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

STATUS

INSPECTION

INSPECTION MARCH 11 - APRIL 10 (88-08): THIS ROUTINE OWSITE INSPECTION INVOLVED A REVIEW OF MOWTHLY SURVEILLANCE UBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFETY SYSTEM INSPECTION, RADIOLOGICAL PROTECTION PROGRAM, PHYSICAL SECURITY PROGRAM AND REVIEW OF EMERGENCY OPERATING PROCEDURES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MAR(H 21-24 (88-09): THIS ROUTINE, UNANNOUNCED PHYSICAL SECURITY INSPECTION EXAMINED: SECURITY ORGANIZATION; RECORDS AND REPORTS; TESTING AND MAINTENANCE; LOCKS, KEYS AND COMBINATIONS; PHYSICAL BARRIERS - PROTECTED AREA; PHYSICAL BARRIERS - VITAL AREAS; ACCESS CONTROL - PERSONNEL; ACCESS CONTROLS - VEHICLES; DETECTION AIDS - PROTECTED AREA; ALARM STATIONS; AND PHYSICAL PROTECTION SAFEGUARDS INFORMATION. IN ADDITION, A REVIEW AND EVALUATION OF PERTINENT SECURITY DOCUMENTATION WAS CONDUCTED IN AN ATTEMPT TO SUBSTANTIATE SEVERAL ALLEGATIONS RELATING TO IMPROPRIETIES IN SECURITY FORCE OPERATIONS. THERE WAS ONE VIOLATION OF REGULATORY REQUIREMENT AND ONE LICENSEE IDENTIFIED VIOLATION NOTED DURING THE INSPECTION. FAILURE TO SECURE SAFEGUARDS INFORMATION WHEN UNATTENDED. FAILURE TO ENSURE AN AUTHGRIZED INDIVIDUAL HAD A BADGE BEFORE GRANTING ACCESS TO A PROTECTED AREA. (LICENSEE IDENTIFIED VIOLATION)

INSPECTION STATUS - (CONTINUED)

INSPECTION SUMMARY

INSPECTION MARCH 28-31 (88-11): THIS ROUTINE, UNANMOUNCED INSPECTION WAS IN THE AREAS OF DOCUMENTATION REVIEW FOR WELDING ACTIVITIES AND NONDESTRUCTIVE EXAMINATIONS (NDE) ASSOCIATED WITH EVENTS RELATED TO UNIT 2, LOOP B, SAFETY INJECTION SYSTEM (SIS), SIX INCH PIPE REPLACEMENT WELDS AS A RESULT OF THE THROUGH WALL CRACK DETECTED IN DECEMBER 1987 AND COMMITMENTS AGREED TO BY THE LICENSEE AT THAT TIME. ALSO, A REVIEW OF EXAMINATION DATA GENERATED DURING THE UNIT 2 INSERVICE INSPECTION (ISI) WAS ACCOMPLISHED. ORDER FOR MODIFICATION OF LICENSE RELATIVE TO PRIMARY COLLANT PRESSURE ISOLATION VALVES (UNIT 1) AND IE BULLETIN 87-02 (FASTENER TESTING) (UNITS 1 AND 2) WERE REVIEWED. NO VIO! ATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION APRIL 5-6 (88-12): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED THE REVIEW OF PROCEDURES, RECORDS, AND OPERATIONS FOR THE USE, CONTROL, AND ACCOUNTABILITY OF SPECIAL NUCLEAR MATERIAL. IN THE AREAS INSPECTED, VIOLAITOMS OR DEVIATIONS WERE NOT IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.8.1, FOUR SAFETY-RELATED BREAKERS WERE NGT IN THE POSITION SPECIFIED BY PROCEDURE AND ANOTHER PROCEDURE DID NOT ADEQUATELY SPECIFY FLOW PATH VERIFICATION. CONTRARY TO TS 3.7.11.2, US JANUARY 19 AND 20, UNIT 1 FIRE SUPPRESSION SYSTEM WAS INOPERABLE FOR APPROXIMATELY 14 HOURS WHEN THE FIRE PROTECTION PANEL SWITCH WAS INADVERTENTLY PLACED IN THE OVER RIDE POSITION. THE REQUIRED FIRE WATCHES WERE NOT INITIATED. THE FIRE DETECTION SYSTEM REMAINED INOPERABLE.

CONTRARY TO 10 CFR 50.54(Q), 10 CFR 50.47(B)(15), 10 CFR 50, APPENDIX E, SECTION IV.F, SECTION VIII.B.1 OF THE FARLEY EMERGENCY FLAN, DURING THE CALENDAR YEAR 1987, PERSONNEL DESIGNATED AS OPERATIONS SHIFT AIDE WHO MAY BE APPOINTED BY THE INTERIM EMERGENCY DIRECTOR (SHIFT SUPERVISOR) TO MAKE IN TIAL NOTIFICATIONS TO THE STATES AND/OR LOCAL AUTHORITIES FROM THE CONTROL ROOM, DID NOT RECEIVE THE REQUIRED ANNUAL RETRAINING FOR COMMUNICATIONS PERSONNEL.

(8800 4)

OTHER ITEMS

SYSTERS AND COMPONENT PROBLEMS:

NONE.

3

A. 6.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

10

LAST IE SITE INSPECTION DATE: APRIL 5-6, 1988 +

INSPECTION REPORT NO: 50-348/88-12 +

100

-

.

2

LICENSEE FRCF REPORTS

жжжжжжжжжжжжжжжжжжжжжжжжжжжж ж жжжжт

-

0 · · 0 00 :

1

SUBJECT NUMBER

DATE OF REPORT DATE OF EVENT

NONE.

.

2

2.0

140

1

٢

and a second and

÷

.

3

THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docket: _50-3640	PERAT	INGS	TATUS					
2.	Reporting Period: 04/01/88 Outage + On-line Hrs: 719.0								
3.	Utility Contact: J. D. WC	ODARD (205) 899-5156						
4.	Licensed Thermal Power (MM	4t):		2652					
5.	Nameplate Rating (Gross M	le):		860					
6.	Design Electrical Rating ((Net MWe):		829					
7.	Maximum Dependable Capacity (Gross MWe):86								
8.	Maximum Dependable Capacity (Net MWe): 823								
9.	If Changes Occur Above Sir	nce Last Re	port, Give	Reasons:					
	NONE								
10.	Power Level To Which Restr	ricted, If	Any (Net M	le):					
11.	Reasons for Restrictions,	If Any:							
	NONE								
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE					
13.	Hours Reactor Critical	719.0	2,903.0	50,791.0					
14.	Rx Reserve Shtdwn Hrs		.0	138.4					
15.	Hrs Generator Ou-Line	719.0	2,903.0	50,151.5					
16.	Unit Reserve Shtdwn Hrs		0	(
17.	Gross Therm Ener (MWH)	1,906,960	7,658,453	128,610,573					
18.	Gross Elec Ener (MWH)	629,566	2,546,718	41,749,812					
19.	Net Elec Ener (MWH)	600,703	2,428,570	39,580,308					
20.	Unit Service Factor	100.0	100.0	84.7					
21.	Unit Avail Factor	100.0	100.0	84.7					
22.	Unit Cap Factor (MDC Net)	101.5	101.6	81.2					
23.	Unit Cap Factor (DER Net)	100.8	100.9	80.6					
24.	Unit Forced Outage Rate	.0	0	5.1					
25.	Forced Outage Hours	.0	. 0	2,690.0					
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):					

3

.





..

Report Period APR 1988	UNIT	SHUTDOWNS	<pre>/ REDUCTIONS</pre>	× FARLEY 2 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

********** * SUMMARY * ********

★ FARLEY 2 OPERATED ROUTINELY IN APRIL WITH NO OUTAGES OR \$ SIGNIFICANT POWER RE⊴UCTIONS.

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory les E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

****** * FARLEY 2 * ******

FACILITY DESCRIPTION

LOCATION STATE.....ALABAMA

DIST AND DIRECTION FROM NEAREST POPULATION CTR...28 MI SE OF DOTHAN, ALA

DATE INITIAL CRITICALITY ... HAY 5, 1981

DATE ELEC ENER 1ST GENER...MAY 25, 1981

DATE COMMERCIAL OPERATE....JULY 30, 1981

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER....CHATAHOOCHEE RIVER

ELECTRIC RELIABILITY

RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE ALABAMA POWER CO.

BIRMINGHAM, ALABAMA 35203

CONTRACIOR ARCHITECT/ENGINEER......SOUTHERN SERVICES INCORPORATED

NUC STEAN SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER......WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....W. BRADFORD

LICENSING PROJ MANAGER.....E. REEVES DOCKET NUMBER 50-364

LICENSE & DATE ISSUANCE..., NPF-8, MARCH 31, 1981

PUBLIC DOCUMENT ROOM...... HOUSTON/LOVE MEMORIAL LIBRARY 212 W. BURDESHAW STCEET DOTHAN, ALABAMA 36302 INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION JANUARY 4-7 (88-01): THIS WAS A SPECIAL, ANNOUNCED INSPECTION CONDUCTED TO FOLLOWUP ON ALLEGATIONS RELATIVE TO THE LICENSEE'S FACILITY. TWENTY GENERAL ALLEGATION SUBJECT AREAS WERE IDENTIFIED TO THE LICENSEE. SOME SIXTY SPECIFIC ALLEGATIONS WERE INVESTIGATED AND ARE ADDRESSED IN THIS REPORT. NRC FOLLOWUP OF THESE ALLEGATIONS CONSISTED OF A REVIEW OF PERTINENT RECORDS. LOGS, AND REPORTS PERTAINING TO PLANT CHEMISTRY, RADIOCHEMISTRY, RADIOACTIVITY COUNTING ROOM/OPERATION, EFFLUENT MONITORING AND ENVIRONMENTAL MONITORING. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MARCH 11 - APRIL 10 (88-08): THIS ROUTINE ONSITE INSPECTION INVOLVED A REVIEW OF MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFETY SYSTEM INSPECTION, RADIOLOGICAL PROTECTION PROGRAM, PHYSICAL SECURITY PROGRAM AND REVIEW OF EMERGENCY OPERATING PROCEDURES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MARCH 21-24 (88-09): THIS ROUTINE, UNANNOUNCED PHYSICAL SECURITY INSPECTION EXAMINED: SECURITY ORGANIZATION; RECORDS AND REPORTS; TESTING AND MAINTENANCE; LOCKS, KEYS AND COMBINATIONS; PHYSICAL BARRIERS - PROTECTED AREA; PHYSICAL BARRIERS - VITAL AREAS; ACCESS CONTROL - PERSONNEL; ACCESS CONTROLS - VEHICLES; DETECTION AIDS - PROTECTED AREA; ALARM STATIONS; AND PHYSICAL PROTECTION SAFEGUARDS INFORMATION. IN ADDITION, A REVIEW AND EVALUATION OF PERTINENT SECURITY DOCUMENTATION WAS CONDUCTED IN AN ATTEMPT TO SUBSTANTIATE SEVERAL ALLEGATIONS RELATING TO IMPROPRIETIES IN SECURITY FORCE OPERATIONS. THERE WAS ONE VIOLATION OF REGULATORY REQUIREMENT AND ONE LICENSEE IDENTIFIED VIOLATION NOTED DURING THE INSPECTION. FAILURE TO SECURE SAFEGUARDS INFORMATION WHEN UNATTENDED. FAILURE TO ENSURE AN AUTHORIZED INDIVIDUAL HAD A BADGE BEFORE GRANTING ACCESS TO A PROTECTED AREA. (LICENSEE IDENTIFIED VIOLATION)

PAGE 2-146

Report Period APR 1988

INSPECTION STATUS - (CONTINUED)

INSPECTION SUMMARY

INSPECTION MARCH 28-31 (88-11): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF DOCUMENTATION REVIEW FOR WELDING ACTIVITIES AND NONDESTRUCTIVE EXAMINATIONS (NDE) ASSOCIATED WITH EVENTS RELATED TO UNIT 2, LOOP B, SAFETY INJECTION SYSTEM (SIS), SIX INCH PIPE REPLACEMENT WELDS AS A RESULT OF THE THROUGH WALL CRACK DETECTED IN DECEMBER 1987 AND COMMITMENTS AGREED TO BY THE LICENSEE AT THAT TIME. ALSO, A REVIEW OF EXAMINATION DATA GENERATED DURING THE UNIT 2 INSERVICE INSPECTION (ISI) WAS ACCOMPLISHED. ORDER FOR MODIFICATION OF LICENSE RELATIVE TO PRIMARY COLLANT PRESSURE ISOLATION VALVES (UNIT 1) AND IE BULLETIN 87-02 (FASTENER TESTING) (UNITS 1 AND 2) WERE REVIEWED. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION APRIL 5-6 (88-12): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED THE REVIEW OF PROCEDURES, RECORDS, AND OPERATIONS FOR THE USE, CONTROL, AND ACCOUNTABILITY OF SPECIAL NUCLEAR MATERIAL. IN THE AREAS INSPECTED, VIOLAITONS OR DEVIATIONS WERE NOT IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TECHNICAL SPECIFICATION 6.8.1, FNP-O-AP-6, PROCEDURE ADHERENCE, AND FNP-O-AP-16, CONDUCT OF OPERATIONS, FNP-O-AP-52, EQUIPMENT STATUS CONTROL AND MAINTENANCE AUTHORIZATION AND FNP-O-AP-5, SURVEILLANCE PROGRAM ADMINISTRATIVE CONTROL, ON NOVEMBER 27, 1987: OPERATIONS PERSONNEL MARKED INITIAL CONDITION 3.2 OF SURVEILLANCE TEST FROCEDURE (STP) FNP-2-STP-11.6, RESIDUAL HEAT REMCVAL (RHR) INSERVICE TEST, AS NOT APPLICABLE (NA). THE LICENSEE DEPARTED FROM THE TEST PROCEDURE INITIAL CONDITION WHICH WOULD HAVE REQUIRED TAKING "A" RHR TRAIN OUT OF SERVICE AND CLOSING THE "A" RHR PUMP SUCTION ISOLATION VALVES. THIS DEPARTURE OCCURRED UNDER NON-EMERGENCY PLANT CONDITIONS AND WAS NOT PROCESSED AS A TEMPORARY PROCEDURE CHANGE. AS A RESULT OF THE NA ON INITIAL CONDITION 3.2, THE VALVE TESTING WAS NOT PERFORMED IN ACCORDANCE WITH THE APPROVED TEST PROCEDURE. ADDITIONALLY, THE LICENSEE FAILED TO PROVIDE INSTRUCTIONS FOR THE FILL AND VENT OF THAT PORTION OF THE RHR "A" TRAIN PIPING BETWEEN VALVES 8811A AND 8812A PRIOR TO ITS RETURN TO SERVICE.

CONTRARY TO TS 6.8.1, FOUR SAFETY-RELATED BREAKERS WERE NOT IN THE POSITION SPECIFIED BY PROCEDURE AND ANOTHER PROCEDURE DID NOT ADEQUATELY SPECIFY FLOW PATH VERIFICATION. CONTRARY TO 10 CFR 50.54(Q), 10 CFR 50.47(B)(15), 10 CFR 50, APPENDIX E, SECTION IV.F, SECTION VIII.B.1 OF THE FARLEY EMERGENCY PLAN, DURING THE CALENDAR YEAR 1987, PERSONNEL DESIGNATED AS OPERATIONS SHIFT AIDE WHO MAY BE APPOINTED BY THE INTERIM EMERGENCY DIRECTOR (SHIFT SUPERVISOR) TO MAKE INITIAL NOTIFICATIONS TO THE STATES AND/OR LOCAL AUTHORITIES FROM THE CONTROL ROOM, DID NOT RECEIVE THE REQUIRED ANNUAL RETRAINING FOR COMMUNICATIONS PERSONNEL.

FAILURE TO TAKE COMPENSATORY MEASURES FOR AN INOP ERABLE CAMERA. SAFEGUARDS INFORMATION (8800.4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

LICENSEE CONTINUES TENDON FIELD ANCHORS INSPECTION.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

PLANT STATUS:

OTHER ITEMS

INSPECTION	REPORT NO:	50-364/88-	-12 +												
				REP	ORT	S F	FRO	M	LIC	ENS	EE				
	********			======	******		****		=====	*****	==========	 	========	 ********	
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT												

THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docket: <u>50-341</u> 0	PERAT	INGS	TATUS
2.	Reporting Period: 04/01/8	+ On-line	Hrs: 719.0	
3.	Utility Contact: P. M. AN	THONY (313	586-1617	
4.	Licensed Thermal Power (MW		3292	
5.	Nameplate Rating (Gross MW		1215	
6.	Design Electrical Rating (1093	
7.	Maximum Dependable Capacit	1We):	1093	
8.	Maximum Dependable Capacit	.):	1093	
9.	If Changes Occur Above Sin	ce Last Re	port, Give	Reasons:
10.	Power Level To Which Restr Reasons for Restrictions,	icted, If If Any:	Any (Net Mk	le):
-	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,365.0	CUMULATIVE 2,365.0
13.	Hours Reactor Critical	. 0	830.7	830.7
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	. (
15.	Hrs Generator On-Line	. 0	830.3	830.3
6.	Unit Reserve Shtdwn Hrs	. 0		
17.	Gross Therm Ener (MWH)	0	2,066,876	2,066,876
8.	Gross Elec Ener (MWH)	0	670,845	670,845
19.	Net Elec Ener (MWH)	0	639,601	639,601
20.	Unit Service Factor	. 0	35.1	35.1
21.	Unit Avail Factor	. 0	35.1	35.1
22.	Unit Cap Factor (MDC Net)	. 0	24.7	24.7
23.	Unit Cap Factor (DER Net)	. 0	24.7	24.7
24.	Unit Forced Outage Rate	. 0	7.9	7.9
25.	Forced Outage Hours	. 0	71.7	71.7
26.	Shutdowns Sched Over Next	6 Months (Type,Date,D	Duration):
27.	If Currently Shutdown Estin	mated Star	tup Date:	05/15/88





Report Period APR 1988	UN	IT	SHUT	DO	м	NS	/ R	E	0 0 0	СТ	IC) N	S	* FERMI 2 * **********************************
No. Date Type Hours Reason Me	thod	LE	R Number	Syste	em	Comp	onent	-		Cau	ise	8 (Corre	ective Action to Prevent Recurrence

*

88-01 02/27/88 S 719.0 B 4

CURRENTLY FERMI 2 IS IN AN LLRT OUTAGE.

*********** * SUMMARY * ******

FERMI 2 REMAINED SHUTDOWN IN A SCHEDULED LLRT DUTAGE DURING APRIL.

Type	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION

STATE.....MICHIGAN

COUNTY MONROE

DIST AND DIRECTION FROM NEAREST POPULATION CTR...LAGUNA BEACH, MICH

DATE INITIAL CRITICALITY...JUNE 21, 1985

DATE ELEC ENER 1ST GENER... SEPTEMBER 21, 1986

DATE COMMERCIAL OPERATE.... JANUARY 23, 1988

and contracted at contract of the set of the

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER....LAKE ERIE

ELECTRIC RELIABILITY

COUNCIL.....EAST CENTRAL AREA RELIABILITY COORDINATION

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....DETROIT EDISON

CORPORATE ADDRESS......2000 SECOND AVENUE DETRIOT, MICHIGAN 48226

CONTRACTOR ARCHITECT/ENGINEER......SARGENT & LUNDY

NUC STEAM SYS SUPPLIER GENERAL ELECTRIC

TURBINE SUFPLIER.....NONE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....W. ROGERS

LICENSE & DATE ISSUANCE..., NPF-43, JULY 15, 1985

PUBLIC DOCUMENT ROOM......MONROE COUNTY LIBRARY SYSTEM 3700 SOUTH CUSTER ROAD MONROE, MI. 48161

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON DECEMBER 29, 1987 THROUGH FEBRUARY 5, 1988 (88003): ACTION ON PREVIOUS INSPECTION FINDINGS; FOLLOWUP OF EVENTS; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE TRAINING; REPORT REVIEW; PLANT TRIPS; STARTUP TEST WITNESSING AND OBSERVATION; MANAGE MENT MEETINGS; REGIONAL REQUEST; BULLETIN FOLLOWUP AND LER FOLLOWUP. ONE VIOLATION WAS IDENTIFIED (FAILURE TO HAVE HPCI AND RCIC OPERABLE PRIOR TO EXCEEDING A REACTOR STEAM DOME PRESSURE OF 150 PSIG).

INSPECTION OF FEBRUARY 1-5, 1988 (88002): INCLUDED A REVIEW OF SECURITY ORGANIZATION RECORDS AND REPORTS; PHYSICAL BARRIERS -PROTECTED AND VITAL AREAS; LIGHTING; COMPEN SATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL; DETECTION AIDS - PROTE CIED AREA; ALARM STATIONS; COMMUNICATIONS; PERSONNEL TRAINING AND QUALIFICATION - GENERAL REQUIREMENT AND A REVIEW OF ALLEGATIONS RECEIVED BY NRC REGION III. A FOLLOWUP ON PREVIOUS ITEMS AND REGULATORY EFFECTIVENESS REVIEW (RER) FINDINGS WAS ALSO PERFORMED. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN EACH OF THE AREAS INSPECTED. THE ALLEGATIONS WERE UNSUBSTANTIATED, AND ONE RER OBSERVATION REMAINS OPEN WHICH DEALS WITH LLEA COMMUNICATION AND ONE OPEN ITEM DEALING WITH COMPUTER PROBLEMS REMAINS OPEN.

INSPECTION ON MARCH 7-11, 1988 (88009): ROUTINE, UNANNOUNCED INSPECTION OF THE RADIATION PROTECTION PROGRAM DURING A MAINTENANCE OUTAGE, INCLUDING: ORGANIZATION AND MANAGEMENT CONTROLS (IP 83722); CHANGES IN ORGANIZATION, PERSONNEL, FACILITIES, EQUIPMENT AND PRO CEDURES (IP 83727, 83729); PLANNING AND PREPARATION (IP 83729); TRAINING AND QUALIFICA TIONS OF CONTRACTOR PERSONNEL (IP 83729); INTERNAL AND EXTERNAL EXPOSURE CONTROL (IP 83729) CONTROL OF RADIOACTIVE MATERIALS AND CONTAMINATION (IP 83729); AND THE ALARA PROGRAM (IP 83729). ADDITIONAL AREAS REVIEWED INCLUDE LIQUID AND GASEOUS RADWASTE (IP 84723 84724), EFFLUENT AND AREA MONITOR CALIBRATIONS (IP 84723,84724), AND OPEN ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. DURING THE MAINTENANCE PAGE 2-152

Report Period APR 1988

INSPECTION SUMMARY

OUTAGE, THE LICENSEE'S ALARA MEASURES APPEARED EFFECTIVE FOR REDUCING PERSONNEL EXPOSURE AND THE RADIOLOGICAL CONTROL PROGRAM IMPLEMENTATION WAS GOOD. THE LICENSEE'S PROGRAM FOR CONTROLLING LIQUID AND GASEOUS RADWASTE IS ADEQUATE; HOWEVER TWO UNRESOLVED ITEMS WERE IDENTIFIED CONCERNING QUANTIFICATION OF GASEOUS RELEASES TO THE ENVIRONMENT AND POST DISCHARGE FLUSHING OF LIQUID RADWASTE DISCHARGE LINES.

INSPECTION ON MARCH 28-50, 1988 (88011): SPECIAL UNANNOUNCED INSPECTION OF licensee activities with respect to main steam isolation valve spring failures (92700) and IE Bulletin 85-03 regarding motor-operated valve switch settings (25573). No violations or deviations were identified. INSPECTION ON MARCH 10-24, 1988 (88010): INCLUDED A REVIEW OF SECURITY Program Audits; Records and Reports; Testing and Maintenance; Locks, Keys and Combinations; Vital Area Barriers; Assessment Aids; Access Control-Packages and Personnel; Alarm Stations; Security force Training and Qualification Plan; Safeguards Contingency Plan; Protection for Safeguards Information; followup on previous inspection findings and followup on Licensee Reported Security Events. The licensee was found to be in compliance with NRC requirements within the areas examined except as noted below: a. Security Organization_: An individual apparently violated the Licensee's weapons policy, the incident was not reported by two security officers who witnessed the event nor was the person's unescorted access to the plant terminate pending investigation of the INCIDENT B. ACCESS CONTROL - PROTECTED AND VITAL AREA : ACCESS TO PROTECTED and Vital areas was not denied for certain personnel under conditions requiring such denial Three of five security-related Licensee Event Reports were closed. ONE PREVIOUS VIOLATION PERTAINING TO RECORDING OF COMPENSATORY MEASURES WAS closed. An inspection finding identified in Report NO. 50-341/86014 AS CLOSED was reopened because corrective actions identified in that report were not included in the appropriate procedure. The inspectors also noted two areas which required procedural guidance to assure effective program implementation.

INSPECTION ON APRIL 13, 1988 (88013): INCLUDED A REVIEW AND DISCUSSION OF THE enforcement options pertaining to four potential violations of the licensee's security plan relating to a series of personnel failures involving security organization and access control program failures.

INSPECTION ON MARCH 7-25, 1988 (88007): ROUTINE, ANNOULICED INSPECTION OF maintenance activities and licensee's action on previous inspector-identified problems. The inspection was conducted during a planned outage utilizing selected portions of Inspection Procedures 62700, 62702, 92701, and 92702. In the areas inspected, one violation was identified including four specific examples of inadequate procedures or failure to follow procedures. One deviation was also identified.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

OTHER ITEMS

PLANT STATUS:

PLANT IS CONTINUING STARTUP TESTING FOLLOWING AN LLRT OUTAGE.

LAST IE SITE INSPECTION DATE: 04/13/88

INSPECTION REPORT NO: 88013

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-09	031188	041188	SAFETY RELIEF VALVES FAIL THEIR SET PRESSURE SURVEILLANCE TOLERANCE TEST
88-10	031088	041188	DE-ENERGIZED RADIATION MONITOR CAUSES CONTROL CENTER HEATING VENTILATION AND AIR CONDITIONING TO SHIFT TO THE RECIRCULATION MODE
88-11	031388	041288	FAILURE TO PERFORM SHIFTLY SURVEILLANCE WITHIN THE REQUIRED TIME
88-12	031688	041588	ISOLATION VALVE FOUND PARTIALLY CLOSED FOR TECHNICAL SPECIFICATION HIGH DRYWELL PRESSURE
88-13	031888	041888	INADVERTENT ISOLATION OF SHUTDOWN COOLING WHILE DE-ENERGIZING A MODULAR POWER UNIT
88-14	032088	041988	INADVERTENT START OF THE DIVISION I EMERGENCY DIESEL GENERATORS DUE TO A PROCEDURAL ERROR

THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docket: _50-333	OPERAT	TINGS	TATUS
2.	Reporting Period:	88 Outage	e + On-line	Hrs: 719.0
3.	Utility Contact: COOK	(315) 349-	-6569	
4.	Licensed Thermal Power (M	Wt):		2436
5.	Nameplate Rating (Gross M	We):	981 X	0.9 = 883
6.	Design Electrical Rating	(Net MWe):		816
7.	Maximum Dependable Capaci	ty (Gross t	/We):	805
8.	Maximum Dependable Capaci	ty (Net MWg	•):	778
9.	If Changes Occur Above Si	nce Last Re	eport, Give	Reasons
	ITEM 7 & 8 RECALCULATED U	SING PREVIO	US YEARS D	ATA.
10.	Power Level To Which Rest	ricted, If	Any (Net M	We):
11.	Reasons for Restrictions,	If Any:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE
13.	Hours Reactor Critical	719.0	2,521.3	82,174.0
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	. 0
15.	Hrs Generator On-Line	719.0	2,481.9	79,835.3
16.	Unit Reserve Shtdwn Hrs	. 0	.0	. 0
17.	Gross Therm Ener (MWH)	1,743,384	5,913,624	173,139,940
18.	Gross Elec Ener (MWH)	597,640	2,026,660	58,634,060
19.	Net Elec Ener (MWH)	576,975	1,953,975	56,732,445
20.	Unit Service Factor	100.0	85.5	71.4
21.	Unit Avail Factor	100.0	85.5	71.4
22.	Unit Cap Factor (MDC Net)	103.1	85.6	65.3*
23.	Unit Cap Factor (DER Net)	98.3	82.5	62.2
24.	Unit Forced Jutage Rate		. 0	11.3
25.	Forced Outage Hours	. 0	. 0	10,337.5
26.	Shutdowns Sched Over Next	6 Months (Type,Date,I	Duration):
	ALTOLL - 00/20/00 - 75 DAT	DURATION.		







* Item calculated with a Weighted Average

							美英英美英美美美美美	关关关关关关关关关关关关关关关关关	关关关大大大
Report Period APR 1988	UNIT	SHUTDOWNS	1	RED	UCT	IONS	*	FITZPA RICK	*

Cause & Corrective Action to Prevent Recurrence Date Type Hours Reason Method LER Number System Component No.

NONE

FITZPATRICK OPERATED ROUTINELY IN APRIL WITH NO OUTAGES OR SIGNIFICANT POWER REDUCTIONS. ********

* SUMMARY *

Type	Reason	Method	System & Component	
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)	

FACILITY DESCRIPTION

LOCATION STATE.....NEW YORK COUNTY.....OSWEGO DIST AND DIRECTION FROM NEAREST POPULATION CTR...8 MI NE OF OSWEGO, NY TYPE OF REACTOR.....BWR DATE INITIAL CRITICALITY...NOVEMBER 17, 1974 DATE ELEC ENER 1ST GENER...FEBRUARY 1, 1975 DATE COMMERCIAL OPERATE....JULY 28, 1975 CONDENSER COOLING METHOD...ONCE THRU CONDENSER CGOLING MATER....LAKE ONTARIO ELECTRIC RELIABILITY COUNCIL......NORTHEAST POWER COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE......NEW YORK POWER AUTHORITY

CONTRACTOR ARCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....STONE & WEBSTER

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....A. LUPTAK

LICENSE & DATE ISSUANCE.... DPR-59, OCTOBER 17, 1974

PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO PENFIELD LIBRARY - GOVERNMENT DOCUMENTS COL OSWEGO, NY 13126 (315) 341-2323

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period APR 1988

DACE 2-41

******	*********	*****
×	FITZPATRI	CK ×
******	******	*****

OTHER TEMS

· FOULSED.

MS

+- ED.

S7

. .OVIDED.

SITE SNOPECTION DATE: NO INPUT PROVIDED.

CTION ... PORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

BENSLS DATE OF DATE OF SUBJECT EVENT REPORT

NO INPUT PROVIDED.

1.	Docket: _50-285	OPERAT	ING S	TATUS			
2.	Reporting Period:	88 Outage	+ On-line	Hrs: 719.0			
3.	Utility Contact: T. P. M	ATTHEWS (40	2) 536-473	3			
4.	Licensed Thermal Power (MWt): 1500						
5.	Nameplate Rating (Gross MWe): 591 X 0.85 = 502						
6.	Design Electrical Rating (Net MWe): 478						
7.	Maximum Dependable Capaci	502					
8.	Maximum Dependable Capaci	478					
9.	If Changes Occur Above Since Last Report, Give Reasons:						
	NONE						
10.	Power Level To Which Rest	ricted, If	Any (Net M	Ne):			
11.	Reasons for Restrictions, If Any:						
	NONE						
12.	Report Period Hrs	MONTH 719.0	YEAR 	CUMULATIVE 127,968.0			
13.	Hours Reactor Critical	719.0	2,903.0	100,462.8			
14.	Rx Reserve Shtdwn Hrs		0	1,309.5			
15.	Hrs Generator On-Line	719.0	2,903.0	98,771.9			
16.	Unit Reserve Shtdwn Hrs	0		.0			
17.	Gross Therm Ener (MWH)	1,030,843	3,750,855	128,280,472			
18.	Gross Elec Ener (MWH)		1,275,038	42,559,814			
19.	Net Elec Ener (MWH)	334,203	1,210,776	40,354,844			
20.	Unit Service Factor	100.0	100.0	77.2			
21.	Unit Avail Factor	100.0	100.0	77.2			
22.	Unit Cap Factor (MDC Net)	97.2	87.3	68.4*			
23.	Unit Cap Factor (DER Net)	97.2	87.3	66.0			
24.	Unit Forced Outage Rate		. 0	3.0			
25.	Forced Outage Hours		. 0	1,857.6			
26.	Shutdowns Sched Over Next	6 Months (Type, Date,	Duration):			
	REFUELING - 9/2/88 - 77 D	AY DURATION					
27 .	If Currently Shutdown Est	imated Star	tup Date:	N/A			







* Item calculated with a Weighted Average
| Report | Period A | PR 19 | 88 | | UN | IT | SHU | TDOP | • • | S / R | ED | U C | т 1 | 1 0 | N | xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx |
|--------|----------|-------|-------|--------|--------|-----|--------|--------|-----|---------|-----|------|------|-----|-----|--|
| No. | Date | Type | Hours | Reason | Method | LER | Number | System | Co | mponent | | | Caus | se | 8 C | orrective Action to ?revent Recurrence |
| 88-01 | 02/12/88 | S | 0.0 | н | 5 | | | BK | F | AN | FOR | T CA | LHOU | JN | STA | TION WAS AT 70% POWER UNTIL STARTING |

A POWER ASCENSION ON APRIL 4, 1988. POWER WAS MAINTAINED AT 100% FROM APRIL 8 TO APRIL 29 WHEN IT WAS REDUCED TO 95% IN PREPARATION FOR MODERATOR TEMPERATURE COEFFICIENT (MTC) TESTING.

Туре	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACALITY DESCRIPTION

LOCATION

STATE.....NEBRASKA

COUNTY......WASHINGTON

DIST AND DIRECTION FROM NEAREST POPULATION CTR...19 MI N OF OMAHA, NEB

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY...AUGUST 6, 1973

DATE ELEC ENER 1ST GENER...AUGUST 25, 1973

DATE COMMERCIAL OPERATE....JUNE 20, 1974

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....MISSOURI RIVER

ELECTRIC RELIABILITY

COUNCIL.....MID-CONTINENT AREA RELIABILITY COORDINATION AGREEMENT

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE......OMAHA PUBLIC POWER DISTRICT

CONTRACTOR

ARCHITECT/ENGINEER......GIBBS, HILL, DURHAM & RICHARDSON

NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV

IE RESIDENT INSPECTOR.....P. HARRELL

LICENSE & DATE ISSUANCE.... DPR-40, AUGUST 9, 1973

PUBLIC DOCUMENT ROOM......W. DALE CLARK LIBRARY 215 S. 15TH STREET OMAHA, NEBRASKA 68102

INSPECTION SUMMARY

INSPECTION CONDUCTED MARCH 14-18, 1988 (88-10) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S SURVEILLANCE TESTING AND CALIBRATION CONTROL PROGRAM AND SURVEILLANCE PROCEDURES AND RECORDS. WITHIN THE AREAS INSPECTED AN APPARENT DEVIATION FROM THE LICENSEE COMMITMENT WAS DETERMINED.

INSPECTION STATUS

INSPECTION CONDUCTED MARCH 1-31, 1988 (88-11) ROUTINE, UNANNOUNCED INSPECTION INCLUDING FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS, OPERATIONAL SAFETY VERIFICATION, PLANT TOURS, SAFETY-RELATED SYSTEM WALKDOWNS, MONTHLY MAINTENANCE OBSERVATIONS, MONTHLY SURVEILLANCE OBSERVATIONS, SECURITY OBSERVATIONS, RADIOLOGICAL PPOTECTION OBSERVATIONS, IN-OFFICE REVIEW OF PERIODIC AND SPECIAL REPORTS, FOLLOWUP ON NRC FOLLOWUP ON AN ALLEGATION, AND FOLLOWUP ON AN ENFORCEMENT CONFERENCE ON FIRE PROTECTION. WITHIN THE AREAS INSPECTED, TWO VIOLATIONS AND ONE DEVIATION WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

PAGE 2-162

Report Period APR 1988

.

********** FORT CALHOUN 1 * *************

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS: NONE FACILITY ITEMS (PLANS AND PROCEDURES): NONE MANAGERIAL ITEMS: PLANT STATUS: 100% POLER OPERATION LAST IE SITE INSPECTION DATE: MARCH 31, 1988 INSPECTION REPORT NO: 50-285/88-11 REPORTS FROM LICENSEE NUMBER DATE OF DATE OF SUBJECT EVENT REPORT 01/25/88 02/22/88 FAILURE TO CONTROL A VERY HIGH RADIATION AREA 88-001 88-002 01/25/88 02/25/88 INOPERABILITY OF ISOLATION VALVE ON HPSI 88-003 02/05/88 03/07/88 INADEQUATE KEY CONTROL TO VERY HIGH RADIATION AREAS.

π.	Docket: <u>50-267</u> 0	PERAT	ING S	YATUS							
2.	Reporting Period: _04/01/8	8_ Outage	+ On-line	Hrs: 719.0							
3.	Utility Contact: FRANK_NO	VACHER (30	3) 785-2229								
4.	Licensed Thermal Power (MW	(t):	-	842							
5.	Nameplate Rating (Gross MW	le):	403 X (.85 = 343							
6.	Design Electrical Rating (Net MWe):		330							
7.	Maximum Dependable Capacity (Gross MWe):342										
8.	Maximum Dependable Capacit	y (Net MWe	;):	330							
9.	If Changes Occur Above Sin NONE	ce Last Re	port, Give	Reasons:							
10.	Power Level To Which Restr	icted, If	Any (Net Mk	le): 271							
11.	Reasons for Restrictions,	If Any:									
	REANALYSIS OF SAFE SHUTDOW	N COOLING.									
12.	Report Period Hrs	MONTH 719.0	YEAR 	CUMULATIVE 77,448.0							
13.	Hours Reactor Critical	343.6	2,492.7	35,894.4							
4.	Rx Reserve Shtdwn Hrs	. 0	. 0								
5.	Hrs Generator On-Line	291.8	2,394.1	23,975.1							
6.	Unit Reserve Shtdwn Hrs	.0	.0	0							
7.	Gross Therm Ener (MWH)	160,677	1,259,895	12,041,308							
8.	Gross Elec Ener (MWH)	57,601	458,7.1	4,001,275							
9.	Net Elec Ener (MWH)	52,368	430,646	3,559,621							
20.	Unit Service Factor	40.6	82.5	31.0							
1.	Unit Avail Factor	40.6	82.5	31.0							
z.	Unit Cap Factor (MDC Net)	22.1	45.0	13.9							
3.	Unit Cap Factor (DER Net)	22.1	45.0	13.9							
4.	Unit Forced Outage Rate	59.4	17.5	62.0							
	Forced Outage Hours	427.2	508.9	39,185.5							
25.											
25. 16.	Shutdowns Sched Over Next	6 Months (Type, Date, D	uration):							

.



***** FORT ST VRAIN

*

NET MAE GENERATED

APRIL 1988

PERCENT MDC

Report	Period A	PR 19	88		UN	IT SHU	TDON	NS / R	E D U C T I O N S * FORT ST VRAIN *
No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-07	04/04/88	F	45.7	н	2	88-004	ZZ	222222	TURBINE TRIP AND MANUAL SCRAM DUE TO REGIONAL ELECTRIC DISTRIBUTION SYSTEM UPSET.
88-08	04/07/88	F	381.5	A	2	88-006	NN	EXJ	MANUAL SCRAM DUE TO RUPTURE OF 1A MAIN CIRCULATING WATER PUMP DISCHARGE EXPANSION JOINT. REPLACED THE FAILED EXPANSION JOINT. ALL SIMILAR EXPANSION JOINTS HAVE BEEN OR SOON WILL BE INSPECTED AND REPLACED IF NECESSARY.

Type	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

* FORT ST VRAIN *

FACILITY DESCRIPTION

LOCATION STATE.....COLORADO

COUNTY......WELD

DIST AND DIRECTION FROM NEAREST POPULATION CTR...35 MI N OF DENVER, COL

TYPE OF REACTOR HTGR

DATE INITIAL CRITICALITY... JANUARY 31, 1974

DATE ELEC ENER 1ST GENER...DECEMBER 11, 1976

DATE COMMERCIAL JPERATE....JULY 1, 1979

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER....S. PLATTE RIVER

ELECTRIC RELIABILITY

COUNCIL......WESTERN SYSTEMS COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS......P.O. BOX 840 DENVER, COLORADO 80201

CONTRACTOR ARCHITECT/ENGINEER.....SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ATOMIC CORP.

CONSTRUCTOR.....EBASCO

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV

IE RESIDENT INSPECTOR.....R. FARRELL

LICENSE & PATE ISSUANCE.... DPR-34, DECEMBER 21, 1973

PUBLIC DOCUMENT ROOM......GREELEY PUBLIC LIBRARY CITY COMPLEX BUILDING GREELEY, COLORADO 80631 INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION CONDUCTED FEB 22-26, 1988 (88-04) ROUTINE, UNANNOUNCED INSPECTION OF FIRE PROTECTION/PREVENTION PROGRAM AND IMPLEMENTATION. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED FEB.9 - MARCH 4, 1988 (88-05) ROUTINE, UNANNOUNCED INSPECTION OF PREVIOUSLY IDENTIFIED ITEMS OF CONCERN; SECURITY PLAN AND PROCEDURES; SECURITY ORGANIZATION; LOCKS, KEYS, AND COMBINATIONS; PROTECTED AREA - PHYSICAL BARRIERS; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL; PROTECTED AREA - DETECTION AIDS, AND PERSONNEL TRAINING AND QUALIFICATIONS. WITHIN THE AREAS INSPECTED, THREE VIOLATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED FEB. 29 - MARCH 4, 1988 (88-06) ROU, INE, UNANNO ICED INSPECTION OF LICENSEE'S ACTIONS RELATED TO IE BULLETIN 85-03. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTFILED.

INSPECTION CONDUCTED MARCH 21-25, 1988 (88-08) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S QUALITY ASSURANCE PROGRAM INCLUDING IMPLEMENTATION IN THE AREAS OF RECORDS MANAGEMENT, DOCUMENT CONTROL, PROCUREMENT, RECEIVING INSPECTION OF MATERIALS AND COMPONENTS; IMPLEMENTATION OF 10 CFR PART 21 REQUIREMENT; LICENSEE EVENT REPORT (LER) FOLLOWUP; AND ACTIONS ON PREVIOUS INSPECTION FINDINGS.

PAGE 2-166

Report Period APR 1988

********* × FORT ST VRAIN ****

ENFORCEMENT SUMMARY

FAILURE TO MAKE MANAGEMENT NOTIFICATIONS REQUIRED BY SEC.2.1 AND ATTACHMENT 2 OF FT.ST.VRAIN MEDICAL EMERGENCY PROCEDURE, ISSUE 20. (8702 5)

LACK OF PROCEDURAL CONTROLS - INADEQUATE PROCEDURES, 2 EXAMPLES; FAILURE TO FOLLOW PROCEDURES -(8703 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

ONE

MANAGERIAL ITEMS:

PLANT STATUS:

POWER OPERATION

LAST IE SITE INSPECTION DATE: MARCH 25, 1988

INSPECTION REPORT NO: 50-267/88-08

REPORTS FROM LICENSEE

NUMBER	DATE OF EVCHT	STE OF	SUBJECT
88-007	01/02/88	11/88	TECHNICAL SPECIFICATION SURVEILLANCE NOT PERFORMED WITHIN REQUIRED INTERVALS

1.	Docket: _50-244	OPERAT	ING S	TATUS							
2.	Reporting Period:	88_ Outage	+ On-line	Hrs: 719.0							
3.	Utility Contact:ANDREW	MC NAMARA	315) 524-44	446							
4.	Licensed Thermal Power (2	Wt):	_	1520							
5.	Nameplate Rating (Gross M	We):	608 X 1	0.85 = 517							
6.	Design Electrical Rating	(Net MWe):		470							
7.	Maximum Dependable Capacity (Gross MWe):490										
8.	Maximum Dependable Capacity (Net MWe): 470										
9.	If Changes Occur Above Si	nce Last Re	port, Give	Reasons:							
_	NONE			<u> 19 20 20 20 20 20 20 20 20 20 20 20 20 20 </u>							
10.	Power Level To Which Rest	ricted, If	Any (Net M	Ne):							
11.	Reasons for Restrictions,	If Any:									
	NONE										
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 							
13.	Hours Reactor Critical	719.0	1,885.2	125,903.0							
14.	Rx Reserve Shtdwn Hrs		0	1,687.7							
15.	Hrs Generator On-Line	719.0	1,820.5	123,468.2							
16.	Unit Reserve Shtdwn Hrs			8.5							
17.	Gross Therm Ener (MWH)	1,072,037	2,451,015	173,378,348							
18.	Gross Elec Ener (MWH)	366,504	829,059	56,956,645							
19.	Net Elec Ener (MWH)	349,058	785,428	53,996,713							
20.	Unit Service Factor	100.0	62.7	76.4							
21.	Unit Avail Factor	100.0	62.7	76.4							
22.	Unit Cap Factor (MDC Net)	103.3	57.6	72.6*							
23.	Unit Cap Factor (DER Net)	103.3	57.6	72.6*							
24.	Unit Forced Outage Rate	.0	11.2	6.4							
25.	Forced Outage Hours	.0	229.5	4,553.9							
26.	Shutdowns Sched Over Next	6 Months (Type,Date,I	Duration):							
27	If Currently Stutdown Fet	imated Star	tup Date:	NZA							





* Item calculated with a Weighted Average

Report Period APR 1988	UNIT	SHUI	TDOWNS /	REDUCTIONS	* GIMMA *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence	
88-1	04/30/88	S	0.0	Α	5		HF	HTEXCH	LOAD REDUCTION - TUBE LEAKS IN 1A2 CONDENSER	

Type	Reason	Method	System & Component		
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Proparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)		

FACILITY DESCRIPTION

LOCATION STATE.....NEW YORK

DIST AND DIRECTION FROM NEAREST POPULATION CTR...15 MI NE OF ROCHESTER, NY

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...NOVEMBER 8, 1969

DATE ELEC ENER 1ST GENER...DECEMBER 2, 1969

DATE COMMERCIAL OPERATE....JULY 1, 1970

CONDENSER COOLING METHOD. . . ONCE THRU

CONDENSER COOLING WATER....LAKE ONTARIO

ELECTRIC RELIABILITY COUNCIL.....NORTHEAST POWER COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

CONTRACTOR ARCHITECT/ENGINEER.....GILBERT ASSOCIATES

NUC STEAM SYS SUPPLIER ... WESTINGHOUSE

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....C. MARSCHALL

LICENSE & DATE ISSUANCE.... DPR-18, DECEMBER 10, 1984

PUBLIC DOCUMENT ROOM......ROCHESTER PUBLIC LIBRARY BUSINESS AND SOCIAL SCIENCE DIVISION 115 SOUTH AVENUE ROCHESTER, NEW YORK 14610

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

PAGE 2-170

Report Period APR 1938

FACTLETY DA

xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx	£.
* GINNA *	í.
*****	e.

OT	- 14	E 1	0	- T	· •	E	-	10
U I	•		ĸ	- 3			m	3
36.1		20.	-			200		- 22

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

	***********		=======================================	
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT	
		and the last har and one are the last the last	the set we det the the set and and the set of the set of the set	
NO INPUT	PROVIDED.			

1.	Docket: <u>50-416</u>	PERAT	ING S	TATUS
2.	Reporting Period: _04/01/8	0utage	+ On-line	Hrs: 719.0
3.	Utility Contact: S. H. HO	DBBS (601)	969-2458	
4.	Licensed Thermal Power (MM	(t):		3833
5.	Nameplate Pating (Gross M	Ne):		1373
6.	Design Electrical Rating ((Net MWe):		1250
7.	Maximum Dependable Capacit	ty (Gross M	We):	1190
8.	Maximum Dependable Capacit	ty (Net MWa):	1142
9.	If Changes Occur Above Sir	nce Last Re	port, Give	Reasons:
			A	
10.	Power Level To Which Kestr	ficted, If	Any thet M	
11.	Reasons for Restrictions,	IT Any:		
	NONE	NOUTU	VEID	CUMUL ATTYLE
12.	Report Period Hrs	MUNTH 719.0	2,903.0	24,840.0
13.	Hours Reactor Critical	719.0	2,688.9	18,400.2
14.	Rx Reserve Shtdwn Hrs	. 0	.0	
15.	Hrs Generator On-Line	719.0	2,558.5	17,681.5
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	0
17.	Gross Therm Ener (MWH)	2,739,436	9,357,821	58, 553, 493
18.	Gross Elec Ener (MWH)	901,460	3,100,590	18,292,000
19.	Net Elec Ener (MWH)	867,064	2,979,138	17, 458, 332
20.	Unit Service Factor	100.0	88.1	71.2
21.	Unit Avail Factor	100.0	88.1	71.2
22.	Unit Cap Factor (MDC Net)	105.6	89.9	61.5
23.	Unit Cap Factor (DER Net)	96.5	82.1	56.2
24.	Unit Forced Outage Rate	. 0	.0	7.0
25.	Forced Outage Hours	. 0	221.2	1,329.4
26.	Shutdowns Sched Over Next	6 Months (Type, Date, I	Duration):
	NONE			المتحدث والمستحدث
27.	If Currently Shutdown Est	imated Star	tup Date:	N/A



APRIL 1988

Report Period APR 1988

UNIT SHUTDOWNS / REDUCTIONS

No.	Date	Туре	Hours	Reason	Method	LER Number	System	Component	Cause	& Corrective	Action	to Prevent	Recurrence	-

NONE

Ivpe	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE......MISSISSIPPI POWER & LIGHT COMPANY

CORPORATE ADDRESS......P.O. BOX 1640 JACKSON, MISSISSIPPI 39205

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER. .. GENERAL ELECTRIC

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER ALLIS-CHALMERS

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....R. BUTCHER

LICENSE & DATE ISSUANCE..., NPF-29, NOVEMBER 1, 1984

PUBLIC DOCUMENT ROOM......HINDS JUNIOR COLLEGE MC LENDON LIBRARY RAYMOND, MISSISSIPPI 39154

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MARCH 7-11 (88-04): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED IN SELECTED ASPECTS OF OPERATIONS, DESIGN CONTROL AND LICENSEE ACTION ON PREVIOUSLY IDENTIFIED INSPECTION FINDINGS. NO VIOLATIONS/DEVIATIONS WERE IDENTIFIED.

INSPECTION MARCH 7-11 (88-05): THIS SPECIAL, ANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF OFFGAS SYSTEM HYDROGEN CONTROL AND OFFSITE DOSE ASSESSMENTS DURING CHARCOAL BED BYPASSES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

PAGE 2-174

Report Period APR 1988

Report Period APR 1988

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

IN STARTUP FOLLOWING REFUELING AND REPAIR OF NO. 10 MAIN GENERATOR BEARING.

LAST IE SITE INSPECTION DATE: MARCH 7-11, 1988 +

INSPECTION REPORT NO: 50-416/88-05 +

REPORTS FROM LICENSEE

NUMBER DATE OF DATE OF SUBJECT EVENT REPORI CONDENSER MANWAY LEAKAGE ON HOTWELLLOW LEVEL SWITCHES TRIPS ALL CONDEN, BOOSTER PUMPS; RX SCRAM 88-006 01/20/88 62/19/88 ON LOW WATER LEVEL 88-007 02/04/88 03/04/88 FAILURE TO TAKE THE REQUIRED ACTION IN TECH SPECS FOR INOPERABLE RADIATION MONITOR ON STANDBY SERVICE WATER SYSTEM 88-008 02/08/88 03/09/88 MSIV-LCS DILUTION AIR INLET FOUND SEALED WITH TAPE 88-009 02/27/88 03/29/88 HYDROGEN IGNITION IN OFFGAS SYSTEM WHILE SWAPPING STEAM JET AIR EJECTORS 88-010 03/15/88 04/13/88 REACTOR SCRAM ON LOW WATER LEVEL 88-011 03/17/88 04/15/88 INADVERTENT RHR PUMP START DUE TO PERSONNEL ERROR

1.	Docket: _50-213	OPERAT	INGS	TATUS						
2.	Reporting Period:04/01/	88_ Outage	+ On-line	Hrs: 719.0						
3.	Utility Contact: STAN	FORD (203)	267-2556 X	452						
4.	Licensed Thermal Power (M	Licensed Thermal Power (MWt): 1825								
5.	Nameplate Rating (Gross M	Ke):	667 X (0,9 = 600						
5.	Design Electrical Rating	(Net MWe):		582						
7.	Maximum Dependable Capaci	ty (Gross M	(We):	596						
8.	Maximum Dependable Capaci	ty (Net MWe	.):	569						
9.	If Changes Occur Above Si	nce Last Re	port, Give	Reasons:						
	NONE									
10.	Power Level To Which Rest	ricted, If	Any (Net M	Ne):						
11.	Reasons for Restrictions,	If Any:								
	NONE									
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 178,223.0						
13.	Hours Reactor Critical	706.5	964.2	_147,153.4						
16.	Rx Reserve Shtdwn Hrs	. 0	. 0	1,221.5						
15.	Hrs Generator On-Line	706.5	835.5	141,035.6						
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	398.0						
17.	Gross Therm Ener (MWH)	1,221,711	1,303,835	244,073,839						
18.	Gross Elec Ener (MWH)	406,271	431,601	80,211,979						
19.	Net Elec Ener (MWH)	386,962	396,113	75,956,727						
20.	Unit Service Factor	98.3	28.8	79.1						
21.	Unit Avail Factor	98.3	28.8	79.4						
22.	Unit Cap Factor (MDC Net)	94.6	24.0	77.8×						
23.	Unit Cap Factor (DER Net)	92.5	23.4	73.3*						
24.	Unit Forced Outage Rate	.0	.0	5.9						
25.	Forced Outage Hours	.0		2,432.8						
26.	Shutdowns Sched Over Next NONE	6 Months (Type,Date,	Duration):						
27	If Currently Shutdown Est	imated Star	tup Date:	05/16/88						







* Item calculated with a Weighted Average

Report	Period Al	PR 19	88		UN	ІТ ЅНО	тром	NS / P.	E D U C T I O N S HANNAKAKAKAKAKAKAKAKAKAKAKAKAKAKAKAKAKAK
No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-02	04/29/88	S	0.0	Α	5		AB	P/SEAL	POWER REDUCTION TO REMOVE PLANT FROM SERVICE TO REPLACE NO. 3 REACTOR COOLANT PUMP SEALS.
88-03	04/30/88	S	12.5	F	3	88-012	JC		REACTOR TRIPPED DURING SCHEDULED POWER REDUCTION TO SHUTDOWN FOR NO. 3 REACTOR COOLANT PUMP MAINTENANCE. WHILE RETURNING IDLED LOOP TO SERVICE, POWER INCREASED ABOVE P8 AND PLANT TRIPPED ON LOW FLOW. PLANT CONTINUED WITH SCHEDULED SHUTDOWN.

Туре	Reason		Method	System & Component	
F-Forced S-Sched	A-Equip Failure F- B-Maint or Test G- C-Refueling H- D-Regulatory Restri E-Operator Training & License Examin	Admin Oper Error Other Iction Mation	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)	

FACILITY DESCRIPTION

LOCATION STATE.....CONNECTICUT COUNTY.....MIDDLESEX DIST AND DIRECTION FROM NEAREST POPULATION CTR...13 MI E OF MERIDEN, CONN TYPE OF REACTOR......PWR

DATE INITIAL CRITICALITY...JULY 24, 1967 DATE ELEC ENER 1ST GENER...AUGUST 7, 1967

DATE COMMERCIAL OPERATE.... JANUARY 1, 1968

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER....CONNECTICUT RIVER

ELECTRIC RELIABILITY COUNCIL.....NORTHEAST POWER COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE......CONNECTICUT YANKEE ATOMIC POWER

CONTRACTOR ARCHITECT/ENGINEER.....STONE & WEBSTER NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....STONE & WEBSTER

TURBINE SUPPLIER......WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....T. SCHEDLOSKY

LICENSE & DATE ISSUANCE.... DPR-61, DECEMBER 27, 1974

PUBLIC DOCUMENT ROOM......RUSSELL LIBRARY 123 BROAD STREET MIDDLETOWN, CONNECTITCUT 06457

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period APR 1988

***** HADDAM NECK × * ******************************

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT	PROVIDED.		

1.	Docket: _50-400_	OPERAI	TING S	TATUS
2.	Reporting Period: _04/01/	88 Outage	+ On-line	Hrs: 719.0
3.	Utility Contact: MARK W.	HALE (919)	362-2944	
4.	Licensed Thermal Power (M	Wt):		2775
5.	Nameplate Rating (Gross M	We):		950
6.	Design Electrical Rating	(Net MWe):		900
7.	Maximum Dependable Capaci	ty (Gross M	(We):	920
8.	Maximum Dependable Capaci	ty (Net MWe	»):	860
9.	If Changes Occur Above Sin NONE	nce Last Re	eport, Give	Reasons:
10.	Power Level To Which Rest	ricted, If	Any (Net M	le).
11.	Reasons for Restrictions,	If Any:		- 496-3
2	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 8,760.0
13.	Hours Reactor Critical	719.0	2,713.2	7,163.1
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	. 0
15.	Hrs Generator On-Line	719.0	2,701.4	7,025.0
16.	Unit Reserve Shtdwn Hrs	. 0	.0	.0
17.	Gross Therm Ener (MWH)	1,988,410	7,411,514	18,561,655
18.	Gross Elec Ener (MWH)	670.833	2,506,616	6,171,834
19.	Net Elec Ener (MWH)	630,153	2,346,422	5,725,251
20.	Unit Service Factor	100.0	93.1	80.2
21.	Unit Avail Factor	100.0	93.1	80.2
22.	Unit Cap Factor (MDC Net)	101.9	94.0	76.0
23.	Unit Cap Factor (DER Not)	97.4	89.8	72.6
24.	Unit Forced Outage Rate	. 0	6.9	9.1
25.	Forced Outage Hours	. 0	201.6	704.9
26.	Shutdowns Sched Over Next	6 Months (Type, Date, D	Ouration):





APRIL 1988

Report	Period Af	PR 198	88		UN	IT	SHU	TDOW	NS / R	EDUCTI	0 N S * HARRIS 1 *
No.	Date	Type	Hours	Reason	Method	TER	Number	System	Component	Cause	& Corrective Action to Prevent Recurrence
88-009	04/29/88	S	0.0	В	5			НА	VALVEX	LOAD REDUCED TESTING. TH	TO 70% TO PERFORM TURBINE VALVE E REQUIRED TESTS WERE COMPLETED AND RETURNED TO FULL POWER.

Туре	Reason		Method	System & Component	
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161	

PAGE 2-181

********** HARRIS 1 *************

FACILITY DESCRIPTION

LOCATION STATE.....NORTH CAROLINA

COUNTY......WAKE

DIST AND DIRECTION FROM NEAREST POPULATION CTR...20 MI SW OF RALEIGH, NC

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... JANUARY 3, 1987

DATE ELEC ENER 1ST GENER... JANUARY 19, 1987

DATE COMMERCIAL OPERATE....MAY 2, 1987

CONDENSER COOLING METHOD...NDCT

RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE.....CAROLINA POWER & LIGHT

RALEIGH, NORTH CAROLINA 27602

CONTRACTOR

ARCHITECT/ENGINEER.....EBASCO

NUC STEAM SYS SUPPLIER. .. WESTINGHOUSE

CONSTRUCTOR......DANIEL INTERNATIONAL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....G. MAXWELL

LICENSING PROJ MANAGER.....B. BUCKLEY

LICENSE & DATE ISSUANCE....NPF-63, JANUARY 12, 1987

PUBLIC DOCUMENT ROOM......RICHARD B. HARRISON LIBRARY 1313 NEW BERN AVE. RALEIGH, N. C., 27610 INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 20 - MARCH 20 (88-06): THIS ROUTINE, ANNOUNCED INVOLVED INSPECTION IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, ON-SITE FOLLOW-UP OF EVENTS AND SUBSEQUENT WRITTEN REPORTS OF NONROUTINE EVENTS, OPERATIONAL SAFETY VERIFICATION, MONTHLY SURVEILLANCE OBSERVATION, AND MONTHLY MAINTENANCE OBSERVATION. IN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED, "FAILURE TO REQUIRE EOPS TO BE CONSISTENT WITH THE FSAR".

INSPECTION MARCH 28-31 (88-07): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREA OF PLANT CHEMISTRY. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

PAGE 2-182

Report Period APR 1988

CONDENSER COOLING WATER....MAKEUP RESERVOIR ELECTRIC RELIABILITY

OTHER ITEMS

+ WESTINGHOUSE INFORMED HARRIS OF AN UNANALYZED CONDITION INVOLVING LTOP SYSTEM DURING MSLB OR S/G TUBE RUPTURE LTOP SYSTEM MODIFICATION IS REQUIRED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: MARCH 28-31, 1988 +

INSPECTION REPORT NO: 59-400/88-07 +

REPORTS FROM LICENSEE

	**********	*********	
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
		and and our out one and one and the set and	
88-007	03/09/88	04/08/88	PLANT TRIP DUE TO LOSS OF FEEDWATER TO "B" STEAM GENERATOR CAUSED BY A FAILED FUSE

1.	Docket: <u>50-321</u> 0	PERAT	INGS	TATUS
2.	Reporting Period:8	8 Outage	+ On-line	Hrs: 719.0
3.	Utility Contact:	HARDSON (9	12) 367-77	81 X2878
4.	Licensed Thermal Power (MW	lt):		2436
5.	Nameplate Rating (Gross MW	le):		850
6.	Design Electrical Rating (Net MWe):		776
7.	Maximum Dependable Capacit	y (Gross M	1We):	789
8.	Maximum Dependable Capacit	y (Net MWe		756
9.	If Changes Occur Above Sin NONE	ce Last Re	eport, Give	Reasons:
10.	Power Level To Which Restr	icted, If	Any (Net M	Ne):
11.	Reasons for Restrictions,	If Any:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE
13.	Hours Reactor Critical	299.0	2,442.9	77,207.8
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	. 0
15.	Hrs Generator On-Line	268.5	2,401.5	73,178.2
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	
17.	Gross Therm Ener (MWH)	568,830	5,732,092	158,487,472
18.	Gross Elec Ener (MWH)	176,110	1,845.330	51,224,710
19.	Net Elec Ener (MWH)	162,785	1,756,987	48,688,206
20.	Unit Service Factor	37.3	82.7	67.7
21.	Unit Avail Factor	37.3	82.7	67.7
22.	Unit Cap Factor (MDC Net)	29.9	8.1	59.6
23.	Unit Cap Factor (DER Net)	29.2	78.0	58.0
24.	Unit Forced Outage Rate	51.0	12.1	13.5
25.	Forced Outage Hours	279.9	330.9	11,194.0
26.	Shutdowns Sched Over Next	6 Months (Type, Date, D	Duration):
27.	If Currently Shutdown Esti	mated Star	tup Date:	05/11/88



----- MAX. DEPEND. CAP. - 756 (100%) 1000 PERCENT MDC MOD OWN BE EXCEEDED UNDER OPTIMAL CONDITIONS 80 500 60 40 - 20 0+0 0 5 10 15 20 25 30 DAYS

NET MUE GENERATED

APRIL 1988

	the state of the state of the state of the	and the set in the set of the set	the ball has been been been been been	the loss has been been
M M	******	********	********	****

Report Period APR 1988

UNIT SHUTDOWNS / REDUCTIONS * HATCH 1

* HATCH 1 *

No.	Date	Туре	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-003	04/05/88	S	0.0	В	5		CI	VESSEL	POWER REDUCTION FOR UNIT SHUTDOWN. (MAINTENANCE OUTAGE)
88-004	04/06/88	s	170.6	В	2		CI	VESSEL	UNIT SHUTDOWN TO INVESTIGATE AND REPAIR SOURCE(S) OF HIGH DRYWELL LEAKAGE.
88-005	04/19/88	F	279.9	н	3	1-88-005	HA	INSTRU	AUTUMATIC SCRAM DUE TO INADEQUATE PROCEDURE FOR SWAPPING OF TURBINE LUBE OIL COOLERS WHICH CAUSED A TRIP SIGNAL TO BE GENERATED BY THE THRUST BEARING WEAR DETECTOR ON THE MAIN TURBINE.

* SUMMARY *

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Rest E-Operator Traini & License Exam	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161

FACILITY DESCRIPTION

LOCATION STATE.....GEORGIA COUNTY.....APPLING DIST AND DIRECTION FROM NEAREST POPULATION CTR...11 MI N OF BAXLEY, GA TYPE OF REACTOR.....BWR DATE INITIAL CRITICALITY...SEPTEMBER 12, 1974 DATE ELEC ENER 1ST GENER...NOVEMBER 11, 1974 DATE COMMERCIAL OPERATE....DECEMBER 31, 1975 CONDENSER COOLING METHOD...COOLING TOWER CONDENSER COOLING WATER....ALTAMAHA RIVER ELECTRIC RELIABILITY COUNCIL......SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....GEORGIA POWER

CONTRACTOR

ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR......GEORGIA POWER CO.

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

STATUS

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....P. HOLMES RAY

LICENSE & DATE ISSUANCE.... DPR-57, OCTOBER 13, 1974

PUBLIC DOCUMENT ROOM..... APPLING COUNTY PUBLIC LIBRARY 301 CITY HALL DRIVE BAXLEY, GEORGIA 31513

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 20 - MARCH 25 (88-07): THIS ROUTINE INSPECTION WAS CONDUCTED AT THE SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATION, SURVEILLANCE TESTING OBSERVATION, RADIOLOGICAL PROTECTION, PHYSICAL SECURITY, REPORTABLE OCCURRENCES, OPERATING REACTOR EVENTS, REACTOR STARTUP AFTER REFUELING OUTAGE, PART 21 REPORT FOLLOWUP, AND NRC BULLETIN FOLLOWUP. THREE VIOLATIONS WERE IDENTIFIED INVOLVING A FAILURE TO PERFORM AN ADEQUATE AVERAGE POWER RANGE MONITOR (APRM) SURVEILLANCE, TWO EXAMPLES OF FAILURE TO FOLLOW SURVEILLANCE PROCEDURE, AND A FAILURE TO HAVE AN ADEQUATE TURBINE CONTROL VALVE TEST PROCEDURE.

INSPECTION MARCH 7-11 (88-08): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF COMPLEX SURVEILLANCE TESTING AND IE BULLETIN FOLLOW-UP. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION

INSPECTION APRIL 4-8 (88-10): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED A REVIEW OF PROCEDURES, RECORDS, OPERATIONS, AND PHYSICAL INVENTORY FOR USE, CONTROL AND ACCOUNTABILITY OF SPECIAL NUCLEAR MATERIAL. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TS 6.8.1.A, IN OCTOBER OF 1987, THE INSTRUCTIONS OF MWO 1-86-7823 FOR THE REWIRING OF VACUUM BREAKER TEST SOLENOID VALVES 1T48-342C, E, AND F WERE INADEQUATE AND RESULTED IN INCORRECT WIRING OF THE TEST CIRCUITRY. SUBSEQUENT TO THIS

PAGE 2-186

Report Period APR 1988

Report Period APR 1988

ENFORCEMENT SUMMARY

MAINTENANCE, VACUUM BREAKERS 1148-F323 C, E, AND F FAILED TO TEST PROPERLY DURING THE MONTHS OF NOVEMBER AND DECEMBER IN 1987. THE INCORRECT WIRING OF THE TEST SOLENOID VALVES DID NOT IMPAIR THE ABILITY OF THE TORUS TO DRYWELL VACUUM BREAKERS TO FUNCTION IN THE NORMAL, SELF-ACTUATED MODE. CONTRARY TO TABLE 3.1-1 OF THE TS, ON FEBRUARY 9, 1988, UNIT 1 WAS OPERATING AT 100 PERCENT OF RATED POWER WITH ONLY ONE APRM CHANNEL AVAILABLE TO PROVIDE APRM DOWNSCALE SCRAM INPUT TO RPS CHANNEL A, AND THE RPS CHANNEL WAS UNTRIPPED. APRM CHANNELS A AND C HAD BEEN BYPASSED AND ONLY CHANNEL E REMAINED AVAILABLE FOR THE DOWNSCALE SCRAM INPUT FOR AT LEAST SEVERAL HOURS. (8800 4)

```
OTHER ITEMS
```

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

+ NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: APRIL 4-8, 1988 +

INSPECTION REPORT NO: 50-321/88-10 +

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT					

1.	Docket: _50-366	DPERAT	ING S	TATUS
2.	Reporting Period: 04/01/8	88 Outage	+ On-line	Hrs: 719.0
3.	Utility Contact: J. H. R.	CHARDSON ((912) 367-7	781 X2878
4.	Licensed Thermal Power (MW	Nt):		2436
5.	Nameplate Rating (Gross MW	Ne):		850
6.	Design Electrical Rating ((Net MWe):	· · · · · · · · · · · · · · · · · · ·	784
7.	Maximum Dependable Capacit	ty (Gross M	1We):	801
8.	Maximum Dependable Capacit	ty (Net MWe		768
9.	If Changes Occur Above Sir NONE	nce Last Re	eport, Give	Reasons:
10.	Power Level To Which Restr	icted, If	Any (Net M	We):
11.	Reasons for Restrictions,	If Any:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 75,864.0
13.	Hours Reactor Critical	384.9	1,000.5	53,692.5
14.	R× Reserve Shtdwn Hrs	. 0	. 0	. 0
15.	Hrs Generator On-Line	384.9	893.9	51,467.7
16.	Unit Reserve Shtdwn Hrs	. 0	.0	.0
17.	Gross Therm Ener (MWH)	916,949	1,836,255	110,574,578
18.	Gross Elec Ener (MWH)	306,900	602,050	3. 357,150
19.	Net Elec Ener (MWH)	290,369	562,806	34,607,318
20.	Unit Service Factor	53.5	30.8	67.8
21.	Unit Avail Factor	53.5		67.8
22.	Unit Cap Factor (MDC Net)	52.6	25.2	59.4
23.	Unit Cap Factor (DER Net)	51.5	24.7	58.2
24.	Unit Forced Outage Rate	46.5	29.2	8.8
25.	Forced Outage Hours	334.1	369.2	4,953.0
26.	Shutdowns Sched Over Next NONE	6 Months (Type, Date, I	Duration):
27	If Currently Shutdown Esti	mated Star	tup Dato:	05/16/88



HATCH 2



APRIL 1968

Report	Feriod AF	PR 19	88		UN	IT SHU	мсат	NS / R	E D U C T I O N S #**********************************
No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-005	04/17/88	F	334.1	н	2	2-88-011	IA	**!STRU	DURING THE PERFORMANCE OF THE WEEKLY TURBINE STOP VALVE TEST (WHICH CAUSES A SCRAM SIGNAL TO EXIST IN THE ASSOCIATED RPS CHANNEL) A SPURIOUS SCRAM SIGNAL WAS RECEIVED IN THE REDUNDANT RPS CHANNEL. THE EXISTANCE OF SCRAM SIGNAL IN BOTH RPS CHANNELS SIMULTANEOUSLY CAUSED THE REACTOR TO SCRAM.

HATCH 2 INCURRED 1 FORCED OUTAGE IN APRIL FOR REASONS STATED ABOVE. *********

* SUMMARY *

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161

FACILITY DESCRIPTION

LOCATION STATE.....GEORGIA

COUNTY APPLING

DIST AND DIRECTION FROM NEAREST POPULATION CTR...11 MI N OF BAXLEY, GA

TYPE OF REACTOR......BWR

DATE INITIAL CRITICALITY...JULY 4, 1978

DATE ELEC ENER 1ST GENER...SEPTEMBER 22, 1978

DATE COMMERCIAL OPERATE....SEPTEMBER 5, 1979

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER....ALTAMAHA RIVER

ELECTRIC RELIABILITY

COUNCIL.....SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE.....GEORGIA POWER

CONTRACTOR

ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....P. HOLMES RAY

LICENSE & DATE ISSUANCE....NPF-5, JUNE 13, 1978

PUBLIC DOCUMENT ROOM......APPLING COUNTY PUBLIC LIBRARY 301 CITY HALL DRIVE BAXLEY, GEORGIA 31513 INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 20 - MARCH 25 (88-07): THIS ROUTINE INSPECTION WAS CONDUCTED AT THE SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS, OPERATIONAL SAFETY VERIFICATION, MAINTENANCE OBSERVATION, SURVEILLANCE TESTING OBSERVATION, RADIOLOGICAL PROTECTION, PHYSICAL SECURITY, REPORTABLE OCCURRENCES, OPERATING REACTOR EVENTS, REACTOR STARTUP AFTER REFUELING OUTAGE, PART 21 REPORT FOLLOWUF, AND NRC BULLETIN FOLLOWUP. THREE VIOLATIONS WERE IDENTIFIED INVOLVING A FAILURE TO PERFORM AN ADEQUATE AVERAGE POWER RANGE MONITOR (APRM) SURVEILLANCE, TWO EXAMPLES OF FAILURE TO FOLLOW SURVEILLANCE PROCEDURE, AND A FAILURE TO HAVE AN ADEQUATE TURBINE CONTROL VALVE TEST PROCEDURE.

INSPECTION MARCH 7-11 (88-08): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF COMPLEX SURVEILLANCE TESTING AND IE BULLETIN FOLLOW-UP. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION APRIL 4-8 (88-10): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED A REVIEW OF PROCEDURES, RECORDS, OPERATIONS, AND PHYSICAL INVENTORY FOR USE, CONTROL AND ACCOUNTABILITY OF SPECIAL NUCLEAR MATERIAL. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period APR 1988

****	(XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX	*******
×	HATCH 2	×
****	**********************	*******

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

+ REFUELING OUTAGE.

LAST IE SITE INSPECTION DATE: APRIL 4-8, 1988 +

INSPECTION REPORT NO: 50-366/88-10 +

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-005	03/05/88	03/31/88	PERSONNEL ERRO RESULTS IN INSTRUMENTS INOPERABLE LONGER THAN ALLOWED FOR SURVEILLANCE
88-006	03/18/88	04/18/88	PROCEDURE DEFICIENCY CAUSES SCRAM AND ONE VALVE FAILS TO CLOSE ON GROUP 1 ISOLATION
88-008	03/21/88	04/20/88	CALIBRATION PROCEDURAL DEFICIENCY FOR FEEDWATER CONTROLLER CAUSES LOW WA TER LEVEL SCRAM
88-009	03/21/88	04/18/88	PERSONNEL ERRORS CAUSE MISSED TESTS RESULTING IN CONDITION PROHIBITED BY TECHNICAL SPECIFICATIONS

1.	Docket: _50-354_	OPERAT	INGS	TATUS
2.	Reporting Period: 04/01/	88 Outage	+ On-line	Hrs: 719.0
3.	Utility Contact:BRYAN W	GORMAN (6	09) 339-340	0
4.	Licensed Thermal Power (M	Wt):		3293
5.	Nameplate Rating (Gross M	We):		1118
6.	Design Electrical Rating	(Net Mke):		1067
7.	Maximum Dependable Capaci	ty (Gross M	[We):	1118
8.	Maximum Dependable Capaci	ty (Net MWe		1067
9.	If Changes Occur Above Si	nce Last Re	port, Give	Reasons:
10.	Power Level To Which Rest	ricted, If	Any (Net Mk	Ne):
11.	Reasons for Restrictions,	If Any:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE
13.	Hours Reactor Critical	482.4	1,527.4	9,385.5
14.	Rx Reserve Shtdwr Hrs	. 0	.0	.0
15.	Hrs Generator On-Line	355.3	1,393.2	9,138.3
16.	Unit Reserve Shtdwn Hrs	.0	0	
17.	Gross Therm Ener (MWH)	1,125,571	4,503,855	28, 312, 422
18.	Gross Elec Ener (MWH)	368,984	1,502,968	9,414,665
19.	Net Elec Ener (MWH)	347,186	1,432,261	8,997,299
20.	Unit Service Factor	49.4	48.0	76.5
21.	Unit Avail Factor	49.4	48.0	76.5
22.	Unit Cap Factor (MDC Net)	45.3	46.2	54.7*
23.	Unit Cap Factor (DER Net)	45.3	46.2	70.6
24.	Unit Forced Outage Rate	4.1	1.1	7.8
25.	Forced Outage Hours	15.1	15.1	
26.	Shutdowns Sched Over Next NONE	6 Months (Type, Date, D)uration):
27.	If Currently Shutdown Est	imated Star	tup Date:	05/02/88

*******	*******	OOF O		*****	****
*	HOPE	E	K 1		*
******	*****		*****	*****	exxxx
AVERAGE	DAILY P	JAER	LEVEL	(MWe)	PLOT
	HOP	E CR	FEK 1		





* Item calculated with a Weighted Average

Report Period APR 1988			UN	IT	SHU	тром	NS / F	/ R	ED	DUCTIONS ****					xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx				i i i				
No .	Date	Туре	Hours	Reason	Method	LER	Number	System	Compo	nent			Caus	e &	Cor	rectiv	e Act	tion to	Preve	ent F	Recurr	ence	
3	02/13/88	S	348.6	С	4						CON	TINU	ATIO	N OI	FRE	FUELIN	IG OUT	TAGE.					
4	04/30/88	F	15.1	Α	2						MAN CAU COM	UAL SED TROL	REAC BY TI ROOI	TOR HE I	SCR FAIL ND T	AM DUE URE OF HE CIR	TO I THE CULAT	MULTING W	E CIRCO	BETH	ING WA NEEN T ING.	TER HE	

英美关关关关关关关关系	HOPE CREEK ENTERED MONTH SHUTDOWN FOR SCHEDULED REFUELING	
* SUMMARY *	OUTAGE. SUBSEQUENTLY RETURNED TO POWER AND EXPERIENCED	
*********	1 POWER CUTAGE.	

Туре	Reason		Method	System & Component				
F-Forced S-Sched	A-Equip Failu: e B-Main ⁺ or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sweet Licensee Event Report (LER) File (NUREG-0161)				

FACILITY DESCRIPTION

LOCATION STATE.....NEW JERSEY

COUNTY......SALEM

DIST AND DIRECTION FROM NEAREST POPULATION CTK...18 MI SE OF WILMINGT N, DEL

TYPE OF REACTOR......BWR

DATE INITIAL CRITICALITY...JUNE 28, 1986

DATE ELEC ENER 1ST GENER...AUGUST 1, 1986

DATE COMMERCIAL OPERATE.... DECEMBER 20, 1986

CONDENSER COOLING METHOD...NDCT

CONDENSER COOLING WATER....DELAWARE RIVER

ELECTRIC RELIATINY COUNCIL......MID-ATLANTIC AREA COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....BECHTFL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

.E REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR......

LICENSE & DATE ISSUANCE....NPF-57, JULY 25, 1986

PUBLIC DOCUMENT ROOM.....PENNSVILLE PUBLIC LIBRARY 190 SOUTH BROADWAY PENNSVILLE, N. J. 08070

INSPECTION STATUS

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY RECION

PAGE 2-194

Report Period APR 1988

Report Period APR 1988

PLANT STATUS:

INFO. NOT SUPPLIED BY REGION LAST IE SITE INSPECTION DATE: INFO. NOT SUPPLIED BY REGION INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION R E P O R T S F R O M L I C E N S E E INTERDEDITED INFO. NOT SUPPLIED BY REGION NUMBER DATE OF DATE OF SUBJECT EVENT REPORT INFO. NOT SUPPLIED BY REGION

1.	Docket: _50-247	PERAT	ING S	TATUS					
2.	Reporting Period: _04/01/8	8 Ontage	+ On-line	Hrs: 719.0					
3.	Utility Contact: K. KRIEGER (914) 526-5155								
4.	Licensed Thermal Power (MWt):2758								
5.	Nameplate Rating (Gross M	le):	1126 X	0.9 = 1013					
6.	Design Electrical Rating (873							
7.	Maximum Dependable Capacit	885							
8.	Maximum Dependable Capacit):	809						
9.	If Changes Dccu. Above Since Last Report, Give Reasons:								
	ITEMS 6 8 7 REFLECT SUMMER RATINGS.								
10.	Power Level To Which Restr	ricted, If	Any (Net M	de):					
11.	. Reasons for Restrictions. If Any:								
	NONE								
12.	Report Period Hrs	MONTH 719.0	YEAP 2,903.0	CU-JULATIVE 121,272.0					
13.	Hours Reactor Critical	7:9.0	2,392,3	δ3,011.4					
4.	Rx Reserve Shtdwn Hrs		0	2,867.6					
5.	Hes Generator On-Line	719.0	2,258.9	80,655.2					
6.	Unit Reserve Shtdwn Hrs			. 0					
7.	Gross Therm Ener (MWH)	1,981,921	5,939,557	210,782,427					
8.	Gross Elec Ener (MWH)	654,002	1,950,744	65,564,300					
19.	Net Elec Ener (MWH)	632,402	1,868,468	62,004,256					
20.	Unit Service Factor	100.0	77.8	66.5					
21.	Unit Avail Factor	100.0	77.8	66.5					
22.	Unit Cap Factor (MDC Net)	103.6	74.8	60.1×					
	Unit Cap Factor (DER Net)	100.8	73.7	58.0					
23.		.0	1.1	8.5					
23.	Unit Forced Outage Rate								
23. 24. 25.	Unit Forced Outage Rate Forced Outage Hours	.0	25.3	7,283.3					



INDIAN POINT 2





* Item calculated with a Weighted Average
UNIT SHUTDOWNS / REDUCTIONS

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence	
										2

NONE

Туре	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE.....NEW YORK

COUNTY......WESTCHESTER

DIST AND DIRECTION FROM NEAREST POPULATION CTR...25 MI N OF NEW YORK CITY, NY

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALIYY... MAY 22, 1973

DATE ELEC ENER 1ST GENER...JUNE 26, 1973

DATE COMMERCIAL OPERATE....AUGUST 1, 1974

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....HUDSON RIVER

ELECTRIC RELIABILITY COUNCIL.....NORTHEAST POWER COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE.....CONSOLIDATED EDISON

CORPORATE ADDRESS...... 4 IRVING PLACE NEW YORK, NEW YORK 10003

CONTRACTOR

ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR......WESTINGHOUSE DEVELOPMENT CORP

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....L. ROSSBACH

LICENSE & DATE ISSUANCE.... DPR-26, SEPTEMBER 28, 1973

PUBLIC DOCUMENT ROOM......WHITE PLAINS PUBLIC LIBRARY 100 MARTINE AVENUE WHITE PLAINS, NEW YORK 10601

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

PAGE 2-198

Report Period APR 1988

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

		================	
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT	PROVIDED.		

٤.	Docket: 50-286	OPERAT	ING S	TATUS
2.	Reporting Period: 04/01/	88_ Outage	+ On-line	Hrs: 719.0
3.	Utility Contact: L. KELL	Y (914) 739	-8200	
4.	Licensed Thermal Power (M	Wt):		3025
5.	Nameplate Rating (Gross M	We):	1126 X	0.9 = 1013
6.	Design Electrical Rating	(Net MWe):		965
7.	Maximum Dependable Capaci	ty (Grass M	1We):	1000
8.	Haximum Dependable Capaci	ty (Net MWe):	965
9.	If Changes Occur Above Sin NONE	nce Last Re	port, Give	Reasons:
10.	Power Level To Which Rest	ricted, If	Any (Net M	we):
11.	Reasons for Restrictions,	If Any:		
1	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 102,288.0
13.	Hours Reactor Critical	684.7	2,842.7	62,188.0
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	
15.	Hrs Generator On-Line	678.0	2,830.5	60,296.4
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	.0
17.	Gross Therm Ener (MWH)	2,007,147	8,486,778	160,498,921
18.	Gross Elec Ener (MWK)	662,750	2,805,570	51,183,626
19.	Net Elec Ener (MWH)	640,168	2,710,657	49,101,215
20.	Unit Service Factor	94.3	97.5	58.9
21.	Unit Avail Factor	94.3	97.5	58.9
22.	Unit Cap Factor (MMC Net)	92.3	96.8	49.7
23.	Unit Cap Factor (DER Net)	92.3	96.8	49.7
24.	Unit Forced Outage Rate	5.7	2.5	17.9
25.	Forced Outage Hours	41.0	72.5	13,161.9
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):
	MAINTENANCE-MAY, 1988-18	DAY DURATIC	N.	
27.	If Currently Shutdown Est	imated Star	tup Date:	N/A



APRIL 1988

Report	Period A	PR 19	88		ΨN	IT SHUT	тром	NS / R	E D U C T I O N S
No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
02	03/31/88	F	41.0	Α	4	88-002-00	нн	PUMPXX	UNIT TRIP ON HIGH LEVEL IN NO. 31 STEAM GENERATOR DUE TO THE STEAM GENERATOR LEVEL TRANSIENTS WHICH FOLLOWED AN INADVERTANT AUTOMATIC TRIP OF NO. 32 MAIN BOILER FEED PUMP.

TypeReasonMethodSystem & ComponentF-Forced
S-SchedA-Equip Failure F-Admin
B-Maint or Test G-Oper Error
C-Refueling
B-Maint or Test G-Oper Error
C-Refueling
B-Regulatory Restriction
E-Operator Training
& License Examination1-Manual
2-Manual Scram
3-Auto Scram
4-Continued
5-Reduced Load
9-OtherExhibit F & H
Instructions for
Data Entry Sheet
Licensee Event Report
(LER) File (NUREG-0161)

PAGE 2-201

6

FACILITY DESCRIPTION

LOCATION STATE.....NEW YORK

COUNTY.....WESTCHESTER

DIST AND DIRECTION FROM NEAREST POPULATION CTR...25 MI N OF NEW YORK CITY, NY

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... APRIL 6, 1976

DATE ELEC ENER 1ST GENER... APRIL 27, 1976

DATE COMMERCIAL OPERATE.... AUGUST 30, 1976

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER....HUDSON RIVER

ELECTRIC RELIABILITY COUNCIL.....NORTHEAST POWER COORDINATING COUNCIL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

CONTRACTOR

ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.......WESTINGHOUSE DEVELOPMENT CORP

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....P. KOLTAY

LICENSE & DATE ISSUANCE.... DPR-64, APRIL 5, 1976

PUBLIC DOCUMENT ROOM......WHITE PLAINS PUBLIC LIBRARY 100 MARTINE AVENUE WHITE PLAINS, NEW YORK 10601

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

FAILURE TO FOLLOW QA PROCEDURE 1601 SECTION 6-2 REQUIREMENTS TO PROVIDE TIMELY ESCALATED ACTION FOR LATE RESPONSES TO QA FINDING AND NONCONFORMANCE AND CORRECTIVE ACTION REQUESTS (NOBS). (8702 4)

FAILURE TO FOLLOW ANSI N45.2-9-1974 SECTION 5-3 REQUIREMENTS FOR WRITTEN PROCEDURES WHICH: (1) DESCRIBE THE RECORD STORAGE AREAS, (2) DESCRIBE THE RECORD FILING SYSTEM USED, (3) DESCRIBE THE METHOD USED TO VERIFY THAT THE RECORDS RECEIVED IN AGREEMENT WITH THE TRANSMITTAL DOCUMENT OR A PREESTABLISHED CHECK LIST. ALSO LICENSEE HAD NOT ESTABLISHED A PROGRAM FOR VERIFYING THAT RECEIVED RECORDS WERE IN AGREEMENT WITH THE TRANSITTAL DOCUMENT OR A PREESTABLISHED CHECK LIST. 10 CFR 20.203(E) REQUIRESS IN PART, THAT EACH AREA OR ROOM IN WHICH LICENSED MATERIAL IS USSED OR STORED AND WHICH CONTAINS ANY RADIOACTIVE MATERIAL IN AN AMOUNT EXCEEDING 10 TIMES THE QUANTITY OF SUCH MATERIAL IN APPENDIX C OR THIS PART, SHALL BE CONSPICIOUSLY POSTED WITH A SIGN OR SIGNS BEARIN' THE RADIATION CAUTION SYMBOL AND THE WORDS "CAUTION RADIOACTIVE MATERIALS". CONTRARY TO THE ABOVE, AS OF DECEMBER 4, 1987, THE JOL STORAGE AREA, AN AREA LOCATED ON THE 36' ELEVATION OF THE PAB, WHICH CONTAINED LICENSED RADIOACTIVE MATERIAL IN EXCESS OF 10 TIMES THE AMOUNT SPECIFIED IN APPENDIX C OF 10 CFR, WAS NOT POSTED WAS SIGN BEARING THE WORDS "CAUTION RADIOACTIVE MATERIALS."

ENFURCEMENT SUMMARY

(8702 5)

CTHER ITEMS

SYSTEMS AND COMPONENTS: NO INPUT PROVIDED. FACILITY ITEMS (PLANS AND PROCEDURES) : NO INPUT PROVIDED. MANAGERIAL ITERS: HO INFUT PROVIDED. PLANT STATUS: NO INPUT PROVIDED. LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED. INSPECTION REPORT NO: NO INPUT PROVIDED. REPORTS FROM LICENSEE NUMBER DATE OF DATE OF SUBJECT EVENT REPORT

NO INPUT PROVIDED.

1.	Docket: _50-3050	PERAT	INGS	TATUS			
2.	Reporting Period: 04/01/6	8_ Outage	+ On-line	Hrs: 719.0			
3.	Utility Contact: G. RUITE	R (414) 38	8-2560 X225				
<i>i</i> .	Licensed Thermal Fouer (MMt):1650						
5.	Nameplale Kating (Gross MW	e):	622 X 0	.9 = 560			
6.	Design Electrical Rating (Net MWe):		535			
7.	Maximum Dependable Capacit	y (Gross M	We):	529			
8.	Maximum Dependable Capacit	y (Net Mue):	503			
9.	If Changes Occur Above Sin	ce Last Re	port, Give	Reasons:			
	NONE						
IC.	Power Level To Which Restr	icted, If	Any (Net Mk	le):			
11.	Reasons for Restrictions,	If Any:					
	NONE						
	Denset Denier Her	MONTH	YEAR	CUMULATIVE			
12.	House Poster Critical	472.2	1.950.0	103.412.3			
13.	Paraneus Shtdun Hos			2.330.5			
14.	Her Conceter An-Line	411.4	1.889.2	101.771.0			
16	Unit Reserve Shtdue bes	.0		10.0			
17	Gross Therm Fuer (MWH)	478.696	2.888.872	160, 508.746			
19	Gross Flac Ener (MWH)	159,200	959.700	52.946.800			
10.	Net Fler Fner (MNH)	150.318	914.802	50,419,312			
20	Unit Service Factor	57.2	65.1	83.7			
21	Unit Avail Factor	57.2	65.1	83.7			
22	Unit Cap Factor (MDC Nat)	41.6	62.6	80.4			
23	Unit Cap Factor (DER Net)	39.1	58.9	77.5			
24	Unit Forced Outage Rate	9.3	2.2	2.9			
25	Forced Dutage Hours	42.0	42.9	2,385.7			
26	Shutdowns Schod Over Next	6 Months (Type, Date	Duration):			
20.	NONE	o nontino t					





* Item calculated with a Weighted Average

UNIT SHUTDOWNS / REDUCTIONS * KEWAUNEE *

Report Period APR 1988

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
2	03/02/88	S	263.4	С	4		ZZ	ZZZZZZ	CONTINUED CYCLE XIII-XIV REFUELING OUTAGE. THE DUTAGE WAS COMPLETED ON APRIL 12, 1988.
3	04/12/88	F	* 2	G	3		нн	222222	DURING THE TURBINE WARMUP RUN PRIOR TO OVERSPEED TRIP TESTING, CONDENSER FLUSHING OPERATIONS WERE BEING PERFORMED TO REDUCE THE AMOUNT OF IMPURITIES BEING FED TO THE STEAM GENERATORS. WHILE MANUALLY DUMPING THE CONDENSER HOTWELL A LOW-LOW HOTWELL LEVEL CONDITION OCCURRED WHICH INITIATED THE SEQUENCE: CONDENSATE PUMP TRIP, MAIN FEEDWATER PUMP TRIP, TURBINE TRIP, AND REACTOR TRIP.
4	04/12/88	F	37.8	A	1		EB	GENERA	AFTER THE UNIT WAS PLACED ON LINE FOLLOWING THE TRIP S/D NO. 3, AN EXCESSIVE AMOUNT OF OIL WAS DETECTED AT THE GENERATOR DRAINS. GENERATOR SEAL OIL UNIT PRESSURE IMBALANCE HAD PERMITTED SEAL OIL TO ENTER THE GENERATOR. THE UNIT WAS TAKEN OFF LINE TO PERMIT CLEANING THE GENERATOR LEAD BOXES AS A PRECAUTIONARY MEASURE.
5	04/14/88	S	2.2	В	1		НА	222222	A SHORT OUTAGE WAS TAKEN TO PERFORM THE TURBINE

Туре	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Cther D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE......WISCONSIN COUNTY......KEWAUNEE DIST AND DIRECTION FROM NEAREST POPULATION CTR...27 MI E OF GREEN BAY, WI. TYPE OF REACTOR.....PWR DATE INITIAL CRITICALITY...MARCH 7, 1974 DATE ELEC ENER 1ST GENER...APRIL 8, 1974 DATE COMMERCIAL OPERATE...JUNE 16, 1974 CONDENSER COOLING METHOD...ONCE THRU CONDENSER COOLING WATER...LAKE MICHIGAN ELECTRIC RELIABILITY COUNCIL.......MID-AMERICA

INTERPOOL NETWORK

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....WISCONSIN PUBLIC SERVICE

CORPORATE ADDRESS......P.O. BOX 19002 GREEN BAY, WISCONSIN 54307

CONTRACTOR ARCHITECT/ENGINEER......PIONEER SERVICES & ENGINEERING

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....R. NELSON

LICENSE & DATE ISSUANCE.... DPR-43, DECEMBER 21, 1973

PUBLIC DOCUMENT ROOM.....UNIVERSITY OF WISCONSIN LIBRARY LEARNING CENTER 2420 NICOLET DRIVE GREEN BAY, WISCONSIN 54301 IN SPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON FEBRUARY 16-23, 1988 (87005): INCLUDED A REVIEW OF A SECURITY incident involving a vital area (VA) barrier degradation that was discovered on February 9, 1988, and has existed since construction of the plant. Based on this inspection, one violation was identified: Physical Barriers - Vital Areas: The licensee failed to control access to a vital area because of a degraded physical barrier which was not monitored.

INSPECTION ON MARCH 10-11, 15-18, 21-23 1988 (88007): UNANNOUNCED SAFETY inspection of eddy current examination of steam generator tubing, ultrasonic examination of steam generator transition girth weld and sleeving of steam generator tubes (73052), (73753) and (73755). No violations or deviation were identified.

INSPECTION ON MARCH 22-24, 1988 (88009): SPECIAL SAFETY INSPECTION OF licensee activities relative to damaged 4160 volt bus and implementation of commitments to Generic Letter 83-28. Closed TI 2515/64RI and TI 2515/91. (22591B) (22564B) (93702B) No violations or deviations were identified.

INSPECTION FROM JANUARY 1 1988, THROUGH FEBRUARY 15, 1988 (88003): ROUTINE unannounced inspection by resident inspectors of previous inspection findings; operational safety; surveillance; maintenance; regional requests; design change modifications; TI Natural Circulation; TI Circulation; TI Fastener Testing; and Event V valves. Two findings from previous inspections were closed, one open item (Report No. 305/85017), and one unresolved item (Report No. 305/87019). One Level IV violation was identified, for details see Section 6 OF THIS REPORT.

PAGE 2-206

Report Period APR 1988

INSPECTION SUMMARY

INSPECTION FROM MARCH 1-31, 1988 (88006): ROU; INE UNANNOUNCED INSPECTION by resident inspectors of previous inspection findings; operational safety; surveillance; maintenance; licensee events; and spent fuel pool activities. No significant safety issues were identified.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

LICENSING PROJECT MANAGER - J.G. GIITTER

PLANT STATUS:

SHUT DOWN FOR REFUELING; SCHEDULED STARTUP ON APRIL 12, 1988.

LAST IE SITE INSPECTION DATE: 03/25/88

INSPECTION REPORT NO: 88009

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-02	032888	042788	UNPLANNED ACTUATION OF SAFETY INJECTION DUE TO PROCEDURAL WEAKNESS AND PERSONNEL ERROR

1.	Docket: 50-373 0	PERAT	ING S	TATUS			
2.	Reporting Period: 04/01/8	8_ Outage	+ On-line	Hrs: 719.0			
3.	Utility Contact: _ G. J. KI	RCHNER (81	5) 357-6761	X 705			
4.	Licensed Thermal Power (MWt): 3323						
5.	Nameplate Rating (Gross MW	e):		1078			
6.	Design Electrical Rating (Net MWe):		1078			
7.	Maximum Dependable Capacit	y (Gross M	lWe):	1078			
8.	Maximum Dependable Capacit	y (Net MWe):	1036			
9.	If Changes Occur Above Sin NONE	ce Last Re	port, Give	Reasons:			
10.	Power Level To Which Restr	icted, If	Any (Net Mk	le):			
11.	Reasons for Restrictions,	If Any:					
	NONE						
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 37,967.0			
13.	Hours Reactor Critical	. 0	1,729.8				
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	1,640.9			
15.	Hrs Generator On-Line	. 0	1,729.8	21,158.9			
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	1.0			
17.	Gross Therm Ener (MWH)	0	5,252,088	63,222,404			
8.	Gross Elec Ener (MWH)	0	1,777,631	18,744,890			
9.	Net Elec Ener (MWH)	-2,920	1,708,826	17,818,614			
20.	Unit Service Factor	. 0	59.6	55.7			
21.	Unit Avail Factor	. 0	59.6	55.7			
22.	Unit Cap Factor (MDC Net)	. 0	56.8	45.3			
23.	Unit Cap Factor (DER Net)	.0	54.6	43.5			
24.	Unit Forced Outage Rate	, 0		13.4			
25.	Forced Outage Hours	. 0	. 0	3,264.6			
26.	Shutdowns Sched Cver Next	6 Months (Type,Date,D	Juration):			
77	If Currently Shutdown Estin	natod Star	tun Dato:	07/03/88			





APRIL 1988

Report Period APR 1988	UNIT SHU	TDOWNS / REDUCTIONS	**************************************
No. Date Type Hours Reason Me	thed LER Number	System Component Cause & Corr	rective Action to Prevent Recurrence

4 03/13/88 S 719.0 C 4

CONTINUING UNIT ONE SECOND REFUEL OUTAGE.

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Rest E-Operator Train & License Example	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....COMMONWEALTH EDISON

CORPORATE ADDRESS......P.O. BOX 767 CHICAGO, ILLINOIS 60690

CONTRACTOR

ARCHITECT/ENGINEER......SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....M. JORDAN

LICENSING PROJ MANAGER....P. SHEMANSKI DOCKET NUMBER.....50-373

LICENSE & DATE ISSUANCE....NPF-11, AUGUST 13, 1982

PUBLIC DOCUMENT ROOM.....ILLINOIS VALLEY COMMUNITY COLLEGE RURAL ROUTE NO. 1 OGLESBY, ILLINOIS 61348

INSPECTION SUMMARY

INSPECTION ON MARCH 14-18, 1988 (88006; 88006): ROUTINE, ANNOUNCED INSPECTION of maintenance activities and licensee's action on a previous inspection finding, scheduled to coincide with a planned outage, using selected portions of Inspection Modules 62700, 62702, 62704, 62705, 92701 and 92720. In the areas inspected, one violation was identified for failure to take timely corrective action. With the exception noted, the inspectors concluded that overall maintenance was adequately accomplished, effective, and self assessed.

INSPECTION ON FEBRUIRY 10 THROUGH MARCH 25, 1988 (88004;88004): ROUTINE, unannounced inspection conducted by resident inspectors of licensee actions on previous inspection findings; operational safety; surveillance; training; Licensee Event Reports; outages; unit trips; and management meeting. Of the eight areas inspected, no violations or deviations were identified. The licensee has had several problems during this report period in which the resident inspector has expressed his concerns. Some of these are the personnel error resulting in a reactor scram, a missed Technical specification surveillance and a problem not identifying degraded equipment. Several of these items are still being investigated. The licensee started a planned 15 week outage on Unit 1 which, to date, appears to be progressing well. major items to be accomplished are drywell cooling modification, decontamination of the reactor recirculation piping, and snubber reduction.

INSPECTION ON APRIL 13-15, 1988 (88014; 88013): ROULINE CLOSEOUT INSPECTION of licensee action on previously identified Items (92701). No violation or deviations were identified.

INSPECTION ON MARCH 2-10, 18, 24, 1988 (88005; 88004): ROUTINE ANNOUNCED inspection of: (1) the chemistry program, including

PAGE 2-210

Report Period APR 1988

****	×	×	¥	¥	Ħ	×	¥	×	×	×	×	×	×	¥	×	×	×	×	¥	×	×	ж	×	×	×	×	×	×	×	ж	×
*								L	A	5	A	L	L	E		1															×
*****	×	×	×	×	×	×	×	×	×	×	×	*	×	×	*	×	×	×	×	×	×	×	×	×	×	*	×	×	×	×	×

INSPECTION SUMMARY

procedures, organization, and training; (2) reactor systems water quality control programs; (3) quality assurance/quality control program in the laboratory; and (4) nonradiological confirmatory measurements. No violations or deviations were identified.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT SHUTDOWN FOR REFUELING OUTAGE ON 3/15/88 (EXPECTED TO LAST END OF JUNE)

LAST IE SITE INSPECTION DATE: 04/15/88

INSPECTION REPORT NO: 88014

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-02	031688	041588	TYPE B AND TYPE C LEAKAGE EXCEEDED 0.6 LA DURING LEAK RATE TESTING
88-03	032588	042588	TWO INOPERABLE INTERMEDIATE RANGE MONITORS DURING REFUEL DUE TO PERSONNEL ERROR

1.1	Docket: _50-374 (PERAT	ING S	TATUS
2. 1	Reporting Period: _04/01/8	88_ Outage	+ On-line	Hrs: 719.0
3. 1	Utility Contact: <u>G. J. K</u>	IRCHNER (81	5) 357-6761	X 704
4.1	Licensed Thermal Power (M	lt):		3323
5. 1	Nameplate Rating (Gross M	Ne):	- <u>- 111</u>	1078
6.1	Design Electrical Rating ((Net MWe):		1078
7. 1	Maximum Dependable Capacit	ty (Gross M	We):	1078
8.1	Maximum Dependable Capacit	ty (Net MWe):	1036
9. 1	If Changes Occur Above Sir NONE	nce Last Re	port, Give	Reasons:
10. 1	Power Level To Which Restr	ricted, If	Any (Net MW	le):
11. 1	Reasons for Restrictions,	If Any:		
	NONE			
12. 1	Report Period Hrs	MCNTH 719.0	YEAR 2,903.0	CUMULATIVE 30,959.0
13. 1	Hours Reactor Critical	719.0	2,701.5	19,486.2
14. 1	Rx Reserve Shtdwn Hrs			1,716.7
15. 1	Hrs Generator On-Line	719.0	2,684.9	19,156.9
16. 1	Unit Reserve Shtdwn Hrs			
17. 1	Gross Therm Ener (MWH)	2,073,168	7,913,808	55,708,863
8.	Gross Elec Ener (MWH)	694,986	2,648,921	18,457,132
19.1	Net Elec Ener (MWH)	668,945	2,552,307	17,634,830
20.	Unit Service Factor	100.0	92.5	61.9
21.	Unit Avail Factor	100.0	92.5	61.9
22.	Unit Cap Factor (MDC Net)	89.8	84.9	55.0
23.	Unit Cap Factor (DER Set)	86.3	81.6	52.8
24.	Unit Forced Outage Rate		7.5	18.4
25.	Forced Outage Hours	.0	218.1	4,317.9
26.	Shutdowns Sched Over Next	é Months (Type, Date, I	Duration):
1	REFUELING OUTAGE - OCTOBE	R 12, 1988.		
27.	If Currently Shutdown Est	imated Star	tup Date:	N/A





Report	Period Al	PR 19	88		UN	IT	SHU	TDO	4 N 3	5 /	R	ED	υc	τI	0 1	NS	xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx
No.	Date	Туре	Hours	Reason	Method	LER	Number	System	Cor	pone	nt		C	ause	8	Corr	rective Action to Prevent Recurrence
8	04/06/88	S	0.0	н	5							AND	TDRP	F WA	AL	BROUG	GHT OFF LINE TO REPLACE COUPLING

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE.....COMMONWEALTH EDISON

CORPORATE ADDRESS......P.O. BOX 767 CHICAGO, ILLINOIS 60690

CONTRACTOR ARCHITECT/ENGINEER......SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR......COMMONWEALTH EDISON

REGULATORY INFORMATION

I€ REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....M. JORDAN

LICENSE & DATE ISSUANCE....NPF-18, MARCH 23, 1984

PUBLIC DOCUMENT ROOM.....ILLINOIS VALLEY COMMUNITY COLLEGE RURAL ROUTE NO. 1 OGLESBY, ILLINOIS 61348 INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON MARCH 14-18, 1988 (88006; 88006); ROUTINE ANNOUNCED INSPECTION of maintenance activities and licensee's action on a previous inspection finding, scheduled to coincide with a planned outage, using selected portions of Inspection Modules 62700, 62702, 62704, 62705, 92701 and 92720. In the areas inspected, one violation was identified for failure to take timely corrective action. With the exception noted, the inspectors concluded that overall main'enance was adequately accomplished, effective, and selected assessed.

INSPECTION ON FEBRUARY 10 THROUGH MARCH 25, 1988 (88004;88004): ROUTINE, unannounced inspection conducted by resident inspectors of licensee actions on previous inspection findings: operational safety; surveillance; training; Licensee Event Reports; outages; unit trips; and management meeting. Of the eight areas inspected, no violations or deviations were identified. The licensee has had several problems during this report period in which the resident inspector has expressed his concerns. Some of these are the personnel error resulting in a reactor scram, a missed Technical spicification surveillance and a problem not identifying degraded equipment. Several of these items are still being investigated. The licensee started a planned 15 week outage on Unit 1 which, to date, appears to be progressing well. major items to be accomplished are drywell cooling modification, decontamination of the reactor recirculation piping, and snubber reduction.

INSPECTION ON APRIL 13-15, 1988 (88014; 88013): ROUTINE CLOSEOUT INSPECTION of licensee action on previously identified Items (92701). No violation or deviations were identified.

INSPECTION ON MARCH 2-10, 18, 24, 1988 (88005;88004): ROUTINE, ANNOUNCED inspection of: (1) the chemistry program, including

PAGE 2-214

Report Period APR 1988

INSPECTION SUMMARY

procedures, organization, and training; (2) reactor systems water quality control programs; (3) quality assurance/quality control program in the laboratory; and (4) nonradiological confirmatory measurements. No violations or deviations were identified.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

ON MARCH 9, 1988 THE UNIT RECEIVED A DUAL RECIRC PUMP TRIP WHICH RESULTED IN CORE POWER OSCILLATIONS. AN AIT WAS DISPATCHED TO FOLLOWUP ON THIS EVENT. THE DETAILS WILL BE CONTINUED IN INSPECTION REPORT 373/88008; 374/88008

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT OPERATING AT FULL POWER.

LAST IE SITE INSPECTION DATE: 04/15/88

INSPECTION REPORT NO: 88013

REPORTS FROM LICENSEE

*********		*********	
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-04	032188	042088	MISSED TECHNICAL SPECIFICATION SURVEILLANCE DUE TO PERSONNEL ERROR

1. De	ocket: <u>50-352</u>	OPERA	TINGS	TATUS
2. R	eporting Period:04/01/	88 Outage	e + On-line	Hrs: 719.0
3. U	ility Contact: <u>R. W. G</u>	ROPP (215)	841-5058	
4. Li	censed Thermal Power (A	Wt):		3293
5. Na	meplate Rating (Gross M	lWe):	-	1138
6. De	sign Electrical Rating	(Net MWe):	1.00	1055
7. Ma	ximum Dependable Capaci	ty (Gross !	1We):	1092
8. Ma	ximum Dependable Capaci	ty (Net MW	e):	1055
9. If	Changes Occur Above Si	nce Last Re	eport, Give	Reasons:
10. Po 11. Re	wer Level To Which Rest asons for Restrictions,	ricted, If If Any:	Any (Net M	4e):
NC	INE			
12. Re	port Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 19,679.0
13. Ho	urs Reactor Critical	411.3	2,595.3	15,439.3
14. R×	Reserve Shtdwn Hrs	. 0	.0	
15. Hr	s Generator On-Line	405.0	2,589.0	15,151.7
16. Un	it Reserve Shtdwn Hrs			, 0
17. Gr	oss Therm Ener (MWH)	1,025,916	8,077,664	46,974,045
18. Gr	oss Elec Ener (MWH)	325,680	2,608,230	15,307,640
19. Ne	t Elec Ener (MWH)	309,445	2,511,624	14,679,461
20. Un	it Service Factor	56.3		77.0
21. Un	it Avail Factor	56.3	89.2	77.0
22. Un	it Cap Factor (MDC Net)	40.8	82.0	70.7
23. Un	it Cap Factor (DER Net)	40.8	82.0	70.7
24. Un	it Forced Outage Rate	43.7	10.8	5.1
25. Fo	rced Outage Hours	314.0		805.9
26. Sh ND	utdowns Sched Over Next NE	6 Months (Type,Date,D	luration):
27. If	Currently Shutdown Esti	imated Star	tup Date:	N/A

******	*****	*****	*****	*****	*****
×	L	IMERIC	K 1		*
******	*****	*****	*****	*****	*****
AVERAGE	DAILY	POWER	LEVEL	(MWe)	PLOT
	11 A A	IMPRI	CK 1		



APRIL 1968

Report	Period A	PR 9	88		UN	IТ	SHU	TDOW	NS /	R	EDU	c	τI	0	N	S * LIMERICK 1 * *******************
No.	Date	Туре	Hours	Reason	Method	LER	R Number	System	Componen	nt :		-ĉ	aus	e ł	§ C	Corrective Action to Prevent Recurrence
2	04/09/88	F	314.0	В	3			HC	HTEXCH	1	MAINT	ENA	NCE	01	UTA	AGE FOR CLEANING OF CONDENSER TUBES.

LIMERICK 1 INCURRED 1 OUTAGE IN APRIL FOR CLEANING OF CONDENSER TUBES. * SUMMARY *

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Re≤t E-Operator Traini & License Exam	F-Admin G-Oper Error d-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161

FACILITY DESCRIPTION

LOCATION STATE.....PENNSYLVANIA COUNTY.....MONTGOMERY DIST AND DIRECTION FROM NEAREST POPULATION CTR...21 MI NW OF PHILADELPHIA,PA TYPE OF REACTOR.....BWR DATE INITIAL CRITICALITY...DECEMBER 22, 1984 DATE ELEC ENER 1ST GENER...APRIL 13, 1985 DATE COMMERCIAL OPERATE....FEBRUARY 1, 1986 CONDENSER COOLING METHOD...CC HNDCT CONDENSER COOLING WATER...SCHUYLKILL RIVER ELECTRIC RELIABILITY COUNCIL.....MID-ATLANTIC AREA COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE......PHILADELPHIA ELECTRIC

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....G. KELLY

LICENSE & DATE ISSUANCE....NPF-39, AUGUST 8, 1985

PUBLIC DOCUMENT ROOM......POTTSTOWN PUBLIC LIBRARY 500 HIGH STREET POTTSTOWN, PENNSYLVANIA 19464

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS A., PROCEDURES):

NO INPUT PROVIDED.

Report Period APR 1988

****	*****	*********	*****
×	LIMERI	ICK 1	×
*****	******	*********	******

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT			
				e an air air an an an an air an	 	

*

NO INPUT PROVIDED.

1. Doc	ket: <u>50-309</u>	OPERAT	INGS	TATUS
2. Rep	orting Period: 04/01/	88_ Outage	+ On-line	Hrs: 719.0
3. Uti	lity Contact: J. M. I	AYLOR (207)	882-6321	
4. Lic	ensed Thermal Power (M	SWt):		2630
5. Nam	eplate Rating (Gross M	We):		864
6. Des	ign Electrical Rating	(Net MWe):		825
7. Max	imum Dependable Capaci	ty (Gross M	1He):	850
8. Max	imum Dependable Capaci	ty (Net MMe):	810
9. If	Changes Occur Above Si	nce Last Re	port, Give	Reasons:
NON	E			
0. Pou	er Level To Which Rest	ricted, If	Any (Net M	Ne):
1. Rea	sons for Restrictions,	If Any:		
NON	E			
2. Rep	ort Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 135,659.6
3. Hou	rs Reactor Critical	719.0	2,886.9	_108,739.5
6. R×	Reserve Shtdwn Hrs	. 0	. 0	. 0
5. Hrs	Generator On-Line	719.0	2,873.8	105,532,7
G. Uni	t Reserve Shtdwn Hrs	. 0	. 0	
7. Gro	ss Therm Ener (MWH)	1,886,660	7,514,991	241,875,325
8. Gro	ss Elec Ener (MWH)	592,360	2,362,050	79,250,780
9. Net	Elec Ener (MWH)	573,079	2,284,618	75,759,567
0. Uni	t Service Factor	100.0		77.8
1. Uni	t Avail Factor	100.0	99.0	77.8
2. Uni	t Cap Factor (MDC Net)	98.4		70.5×
3. Uni	t Cap Factor (DER Net)		95.4	68.7×
4. Uni	t Forced Outage Rate	. 0	1.0	7.5
5. For	ced Outage Hours	. 0	29.2	7,739.8
6. Shu	tdowns Sched Over Next	6 Months (Type, Date, I	Duration):
REF	UELING OUTAGE - 10/15/	88 - 8 WEEK	DURATION.	A The Case
7. If	Currently Shutdown Est	imated Star	tup Date:	N/A





* Item calculated with a Weighted Average

Report	Period Al	PR 19	88		UN	ΙŢ	SHU	TDOW	N S	1	RE	D	U C	т	1 (N	xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx
No.	Date	Туре	Hours	Reason	Method	LER	Number	System	Com	onen	Ŧ _			Cau	SQ	8	Corrective Action to Prevent Recurrence
LR TO	04/29/88	F	0.0	В	5			EA	ELI	ECON	RUFE	ED9		D D D	WER OWN V/		UE TO A MALFUNCTION ON A TRANSMISSION LINE IME TO PERFORM TURBINE VALVE AND EXCESS E TESTING. LINE PROBLEM CORRECTED AND

Type	Reason		Method	System & Component			
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Rest E-Operator Traini & License Exam	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Liconsee Event Report (LER) File (NUREG-0161			

FACILITY DESCRIPTION

LOCATION STATE......MAINE CGUNTY.....LINCOLN DIST AND DIRECTION FROM NEAREST POPULATION CTR...10 MI N OF BATH, ME TYPE OF REACTOR.....PWR DATE INITIAL CRITICALITY...OCTOBER 23, 1972 DATE ELEC ENER 1ST GENER...NOVEMBER 8, 1972 DATE COMMERCIAL OPERATE....DECEMBER 28, 1972 CONDENSER COOLING METHOD...ONCE THRU CONDENSER COOLING WATER....BACK RIVER ELECTRIC RELIABILITY COUNCIL......NORTMEAST POWER COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE......MAINE YANKEE ATOMIC POWER

CONTRACTOR ARCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER ... COMBUSTION ENGINEERING

TURBINE SUPPLIER......WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....C. HOLDEN

LICENSE & DATE ISSUANCE.... DPR-36, JUNE 29, 1973

PUBLIC DOCUMENT ROOM......WISCASSET PUBLIC LIBRARY HIGH STREET WISCASSET, MAINE 04578

IMSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period APR 1988

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

FUENT DECODT	NUMBER DATE C	OF DATE OF SUBJECT	
EVENI REPORT	EVENT	NT REPORT	

1. Docket: 50-369	OPERAT	ING S	TATUS
2. Reporting Period:04/01.	/88 Outage	+ On-line	Hrs: 719.0
3. Utility Contact: J. A.	REAVIS (704)	373-7567	
4. Licensed Thermal Power (MWt):		3411
5. Nameplate Rating (Gross	MWe):		1305
6. Design Electrical Rating	(Net MWe):		1180
7. Maximum Dependable Capac	ity (Gross M	We):	1225
8. Maximum Dependable Capac	ity (Net MWe):	1129
9. If Changes Occur Above S	ince Last Re	port, Give	Reasons:
NONE			
10. Power Level To Which Res	tricted, If	Any (Net M	Ne):
11. Reasons for Restrictions	, If Any:		
NONE			
12. Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 56,231.0
13. Hours Reactor Critical	702.6	2,848.5	39,712.9
14. R× Reserve Shtdwn His	.0		. 0
15. Hrs Generator On-Line	700.5	2,840.5	39,184.1
16. Unit Reserve Shtdwn Hrs	.0	.0	.0
17. Gross Therm Ever (MWH)	2,314,604	9,390,223	114,458,640
18. Gross Elec Ener (MWH)	806,837	3,262,504	39,658,081
19. Net Elec Ener (MWH)	778,201	3,145,944	37,811,442
20. Unit Service Factor	97.4	97.8	69.7
21. Unit Avail Factor	97.4	97.8	69.7
22. Unit Cap Factor (MDC Net)95.9	96.0	59.6
23. Unit Cap Factor (DER Net)91.7	91.8	57.0
24. Unit Forced Outage Rate	2.6	2.2	13.4
25. Forced Outage Hours	18.5	62.5	6,085.2
26. Shutdowns Sched Over Nex	t 6 Months (Type, Date,	Duration):
REFUELING - OCTOBER 14,	1988, 10 WEE	K DURATION	
27. If Currently Shutdown Fe	timated Star	tup Date:	N/A





APRIL 1988

****** MCGUIRE 1 UNIT SHUTDOWNS / REDUCTIONS Report Period APR 1988 × ******* Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence No. VALVEX STEAM DRAIN VALVE GROUND CAUSED ALL HEATER BLEED STEAM 04/12/88 F 0.0 5 HB 18-P A & STEAM DRAIN VALVES TO CLOSE. HH FAILURE OF CARD IN CONTROL CABINET CAUSED FEED REG. 3 04/16/88 F 18.5 A 1 VALVEX VALVE TO CLOSE. POWER HOLD PER DISPATCHER. S F 5 ZZ 222221 19-P 04/17/88 0.0 20-P 04/18/88 S 0.0 B 5 IE INSTRU NUCLEAR INSTRUMENTATION CALIBRATION.

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exam	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION		
	the second second second second	and the same last of a

STATE.....NORTH CAROLINA

COUNTY.....MECKLENBURG

DIST AND DIRECTION FROM NEAREST POPULATION CTR...17 MI N OF CHARLOTTE, NC

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... AUGUST 8, 1981

DATE ELEC ENER 1ST GENER...SEPTEMBER 12, 1981

DATE COMMERCIAL OPERATE.... DECEMBER 1, 1981

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LAKE NORMAN

ELECTRIC RELIABILITY

FACILITY A

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....DUKE POWER

CONTRACTOR

ARCHITECT/ENGINEER.....DUKE POWER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTPUCTOR.....DUKE POWER

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE II

IE RESIDENT INSPECTOR.....W. ORDERS

LICENSE & DATE ISSUANCE....NPF-9, JULY 8, 1981

PUBLIC DOCUMENT ROOM.....MS. DAWN HUBBS ATKINS LIBRARY UNIVERSITY OF NORTH CAROLINA - CHARLOTTE UNCC STATION, CHARLOTTE, NC 28223

INSPECTION SUMMARY

+ INSPECTION MARCH 7-11 (88-06): THIS WAS A ROUTINE, UNANNOUNCED INSPECTION IN THE AREAS OF ORGANIZATION AND QUALIFICATIONS, EXTERNAL EXPOSURE CONTROL AND DOSIMETRY, INTERNAL EXPOSURE CONTROL AND ASSESSMENT, CONTROL OF RADIOACTIVE MATERIALS AND CONTAMINATION, LICENSEE'S PROGRAM FOR MAINTAINING EXPOSURES AS LOW AS REASONABLY ACHIEVABLE (ALARA), SOLID WASTES, AND TRANSPORTATION. ONE VIOLATION WAS IDENTIFIED INVOLVING FAILURE TO BARRICADE AND POST A HIGH RADIATION AREA AND FAILURE OF AN INDIVIDUAL ENTERING THE AREA TO HAVE THE PROPER RADIATION MONITORING DEVICE.

INSPECTION MARCH 14-18 (88-08): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF SEISMIC MONINTORING, FIRE PROTECTION/PREVENTION AND FOLLOWUP OF LICENSEE IDENTIFIED LICENSEE EVENT REPORTS (LER'S) 50-369/87-34 AND 50-370/87-18-01. NO VIOLATIONS OR DEVIATION WERE IDENTIFIED.

INSPECTION MARCH 29 - APRIL 1 (88-10): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED THE AREAS OF THE SNUBBER SURVEILLANCE PROGRAM AND FOLLOW-UP ON A LICENSEE IDENTIFIED ITEM (LER). IN THE ARLAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INFORCEMENT SUMMARY

PAGE 2-226

Report Period APR 1988

INSPECTION STATUS - (CONTINUED)

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, TECHNICAL SPECIFICATION (TS) 6.8.1, ON DECEMBER 28, 1987 AN ERROR ON A PLANT ELECTRICAL DRAWING LED TO AN ACTUATION OF THE REACTOR PROTECTION SYSTEM, CAUSING A REACTOR TRIP. WHILE PERFORMING MONTHLY SURVEILLANCE TEST, PT/1/4/4601/02, PROTECTIVE SYSTEM CHANNEL 2 FUNCTIONAL TEST, A DRAWING ERROR ON SCHEMATIC DIAGRAM MCM 1399.03-0368 001 CAUSED LICENSEE PERSONNEL CONDUCTING THE TEST ON CHANNEL 2 OF NARROW RANGE STEAM GENERATOR LEVEL INSTRUMENTATION TO MAKE AN ADJUSTMENT IN CHANNEL 4 WHICH TOGETHER WITH THE EXISTING SIGNAL IN CHANNEL 2 CAUSED THE REACTOR TRIP. ALSO, ON DECEMBER 28, 1987 LICENSEE PERSONNEL FAILED TO FOLLOW A PROCEDURE STEP CAUSING AN ACTUATION OF THE REACTOR PROTECTION SYSTEM. WHILE PERFORMING PERIODIC TEST PT/0/A/4600/14C, NUCLEAR INST/UMENTATION SYSTEM SDURCE RANGE FUNCTIONAL TEST, LICENSEE PERSONNEL ELECTED TO MANIPULATE A TEST SWITCH IN THE SOLID STATE PROTECTION SYSTEM WITHOUT MEETING THE CONDITIONS FOR DOING SO AS SPECIFIED IN THE PROCEDURE. THIS RESULTED IN A REACTOR TRIP.

CONTRARY TO TS 6.8.1.A, MCGUIRE NUCLEAR STATION PROCEDURE IP/0/A/3061/08, WATER ADDITION AND EQUALIZING CHARGE FOR VITAL BATTERIES, STEP 10.4.3., AND MCGUIRE NUCLEAR STATION PROCEDURE OP/1/A/6200/01 ENCLOSURE 4.7: (1) PROCEDURE IP/0/A/3061/08 WAS NOT PROPERLY IMPLEMENTED IN THAT AN OUTPUT VOLTAGE OF APPROXIMATELY 148 VDC RATHER THAN THE REQUIRED 141.0 VDC WAS BEING USED ON FEBRUARY 10, 1988, WHEN CONDUCTING AN FQUALIZING CHARGE ON VITAL BATTERY EVCB. INSTRUMENT AND ELECTRICAL (IAE) TECHNICIANS AND ENGINEERS WERE AWARE OF THE PROCEDURAL REQUIREMENT TO ESTABLISH 141.0 VDC BUT CHOSE TO ESTABLISH A HIGHER VOLTAGE WITHOUT MAKING THE REQUIRED CHANGE TO THE PROCEDURE. (2) THE PROCEDURE FOR REMOVING THE CATION BED DEMINERALIZER FROM SERVICE, OP/1/A/6200/01 CHEMICAL AND VOLUME CONTROL SYSTEM, WAS NOT PROPERLY MAINTAINED IN THAT STEPS WERE CHANGED DURING A REVISION LEADING TO OVERPRESSURIZATION OF THE SYSTEM. THIS OVERPRESSURIZATION ON FEBRUARY 3, 1988, LED TO THE RUPTURE OF THE DIAPHRAM ON VALVE 1NV-474 AND A CONTAMINATED SPILL. (8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATION.

LAST IE SITE INSPECTION DATE: MARCH 29 - APRIL 1. 1988 +

INSPECTION REPORT NO: 50-369/88-10 +

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-003	03/09/88	04/08/88	TRAIN B OF THE CCS WAS INOPERABLE DUE TO A NUCLEAR SERVICE WATER SYSTEM VALVE BEING IN A NONCONSERV. POSITION LOOSE TRVL S
88-004	03/09/88	04/08/88	UNIT 1 AND 2 ENTERED TS 3.0.3 WHEN EVCB VITAL BATTERY CHARGER WAS DENEERGIZED DUE TO UNKNOWN REASONS EVCA BATTERY WAS INOPERABLE
88-005	03/23/88	04/22/88	SPURIOUS TRAIN A SAFETY INJECTION AND M AINSTEAM SYSTEM ISOLATION RESULTING IN A REACTOR TRIP

THIS PAGE "MTENTIONALLY LEFT BLANK

2.	Reporting Period: 04/01/8	0utage	+ On-line	
3.			· on rine	Hrs: 719.0
	Utility Contact: J. A. RE	EAVIS EXT (704) 373-75	67
4.	Licensed Thermal Power (MW	4t):		3411
5.	Nameplate Rating (Gross M	de):	1450 X	,9 = 1305
6.	Design Electrical Rating ((Net MWe):		1180
7.	Maximum Dependable Capacit	ty (Gross M	We):	1225
8.	Maximum Dependable Capacit	ty (Net MWe):	1129
9.	If Changes Occur Above Sir	nce Last Re	port, Give	Reasons:
10. 11.	Power Level To Which Restr Reasons for Restrictions, NONE	icted, If If Any:	Any (Net Mk	le):
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 36,527.0
13.	Hours Reactor Critical	719.0	2,885.1	_ 27,331.2
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	0
15.	Hrs Generator On-Line	719.0	2,880.2	26,707.7
16.	Unit Reserve Shtdwn Hrs	. 0	.0	. 0
17.	Gross Therm Ener (MWH)	2,446,326	9,722,758	87,968,362
18.	Gross Elec Ener (MWH)	854,124	3,397,998	30,473,226
19.	Net Elec Ener (MWH)	824,271	3,277,382	29,213,384
20.	Unit Service Factor	100.0	99.2	73.1
21.	Unit Avail Factor	100.0	99.2	73.1
22.	Unit Cap Factor (MDC Net)	101.5	100.0	70.8
23.	Unit Cap Factor (DER Net)	97.2	95.7	67.8
24.	Unit Forced Outage Rate	. 0		11.3
25.	Forced Outage Hours	.0	22.8	3,417.3
26.	Shutdowns Sched Over Next	6 Months (Type, Date, I	Duration):
	REFUELING - MAY 27, 1988	- 9 WEEK DU	RATION.	





APRIL 1988

UNIT SHUTDOWNS / REDUCTIONS

Report	Period	APR	1988	U	N	I	Т	s	н	U	Т	D
--------	--------	-----	------	---	---	---	---	---	---	---	---	---

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence	_

NGUE

¥	¥	¥	¥	¥	¥	¥	÷	¥	¥	×.	
-									~		

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train	F-Admin G-Oper Error H-Other triction ing	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & 3 Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUSEG-0161)

***** MCGUIRE 2 24 ******

FACILITY DESCRIPTION

LOCATION STATE NORTH CAROLINA COUNTY......MECKLENBURG DIST AND DIRECTION FROM NEAREST POPULATION CTR ... 17 MI N OF CHARLOTTE, NC TYPE OF REACTOR PWR DATE INITIAL CRITICALITY ... MAY 8, 1983 DATE ELEC ENER 1ST GENER. .. MAY 23, 1983 DATE COMMERCIAL OPERATE....MARCH 1, 1984 CONDENSER COOLINC METHOD... ONCE THRU CONDENSER COOLING WATER....LAKE NORMAN ELECTRIC RELIABILITY

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE DUKE POWER

CORPORATE ADDRESS POWER 5LDG., BOX 2178 CHARLCTTE, NORTH CAROLINA 28201

CONTRACTOR ARCHITECT/ENGINEER..... DUKE POWER

NUC STEAM SYS SUPPLIER. .. WESTINGHOUSE

CONSTRUCTOR DUKE POWER

TURBINE SUPPLIER WESTINGHOUSE

REGULATORY INFORMATION

TE RESIDENT INSPECTOR N. ORDERS

LICENSE & DATE ISSUANCE. ... NPF-17, MAY 27, 1983

PUBLIC DOCUMENT ROOM MS. DAWN HUBBS ATKINS LIBRARY UNIVERSITY OF NORTH CAROLINA - CHARLOTTE UNCC STATION, CHARLOTTE, NC 28223

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MARCH 7-11 (88-06): THIS WAS A ROUTINE, UNANNOUNCED INSPECTION IN THE AREAS OF ORGANIZATION AND QUALIFICATIONS, EXTERNAL EXPOSURE CONTROL AND DOSIMETRY, INTERNAL EXPOSURE CONTROL AND ASSESSMENT, CONTROL OF RADIOACTIVE MATERIALS AND CONTAMINATION, LICENSEE'S PROGRAM FOR MAINTAINING EXPOSUPES AS LOW AS REASONABLY ACHIEVABLE (ALARA), SOLID WASTES, AND TRANSPORTATION. ONE VIOLATION WAS IDENTIFIED INVOLVING FAILURE TO BARRICADE AND POST A HIGH RADIATION AREA AND FAILURE OF AN INDIVIDUAL ENTERING THE AREA TO HAVE THE PROPER RADIATION MONITORING DEVICE.

INSPECTION MARCH 14-18 (88-08): THIS ROUTINE, UNANNOUNCED INSPECTION WAS IN THE AREAS OF SEISMIC MONINTORING, FIRE PROTECTION/PREVENTION AND FOLLOWUP OF LICENSEE IDENTIFIED LICENSEE EVENT REPORTS (LER'S) 50-369/87-34 AND 50-370/87-18-01. NO VIOLATIONS OR DEVIATION WERE IDENTIFIED.

INSPECTION MARCH 29 - APRIL 1 (88-10): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED THE AREAS OF THE SNUBBER SURVEILLANCE PROGRAM AND FOLLOW-UP ON A LICENSEE IDENTIFIED ITEM (LER). IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

PAGE 2-232

Caport Period APR 1988

RELIABILITY COUNCIL
Report Period APR 1988

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:
NONE .
FACILITY ITEMS (PLANS AND PROCEDURES):
NONE.
MANAGERIAL ITEMS:
NONE.
PLANT STATUS:
POWER OPERATION.
LAST IE SITE INSPECTION DATE: MARCH 29 - APRIL 1, 1988 +
INSPECTION REPORT NO: 50-370/88-10 +
REPORTS FROM LICENSEE
NUMBER DATE OF SUBJECT EVENT REPORT
NONE.

Docket: 50-245	DPERAT	ING S	TATUS							
Reporting Period: 04/01/8	88_ Outage	+ On-line	Hrs: 719.0							
Utility Contact: G. NEWBURGH (203) 447-1791 X4400										
Licensed Thermal Power (MWt):2011										
Nameplate Rating (Gross MWe): 735 X 0.9 = 662										
Design Electrical Rating (Net MWe):660										
Maximum Dependable Capacity (Gross MWe): 684										
Maximum Dependable Capacit	ty (Net MWe):	654							
If Changes Occur Above Sin NONE	nce Last Re	port, Give	Reasons:							
Power Level To Which Restr	ricted, If	Any (Net M	ve):							
Reasons for Restrictions,	If Any:									
NONE										
Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 152,711.0							
Hours Reactor Critical	719.0	2,873.8	119,200.1							
Rx Reserve Shtdwn Hrs	. 0	. 0	3,283.3							
Hrs Generator On-Line	719.0	2,864.6	116,057.1							
Unit Reserve Shtdwn Hrs	. 0	. 0	277.4							
Gross Therm Ener (MWH)	1,402,583	5,672,056	215,878,151							
Gross Elec Ener (MWH)	479,000	1,943,400	72,719,996							
Net Elec Ener (MWH)	458,365	1,859,491	69,376,952							
Unit Service Factor	100.0	98.7	76.0							
Unit Avail Factor	100.0	98.7	76.2							
Unit Cap Factor (MDC Net)	97.5	97.9	69.5							
Unit Cap Factor (DER Net)	96.6	97.1	68.8							
Unit Forced Outage Rate		1.3	11.0							
Forced Dutage Hours	. 0		6,344.9							
Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):							
	Reporting Period: <u>04/01/3</u> Utility Contact: <u>G. NEWBM</u> Licensed Thermal Power (MW Nameplate Rating (Gross MW Design Electrical Rating M Maximum Dependable Capacit Maximum Dependable Capacit If Changes Occur Above Sin NONE Power Level To Which Restr Reasons for Restrictions, NONE Report Period Hrs Hours Reactor Critical Rx Reserve Shtdwn Hrs Hrs Generator On-Line Unit Reserve Shtdwn Hrs Gross Therm Ener (MWH) Gross Elec Ener (MWH) Net Elec Ener (MWH) Net Elec Ener (MWH) Unit Service Factor Unit Avail Factor Unit Cap Factor (DER Net) Unit Cap Factor (DER Net) Unit Forced Outage Rate Forced Outage Hours Shutdowns Sched Over Next	Reporting Period: 04/01/88 Outage Utility Contact: G. NEWBURGH (203) Licensed Thermal Power (MWt): Nameplate Rating (Gross MWe): Design Electrical Rating (Net MWe): Maximum Dependable Capacity (Gross M Maximum Dependable Capacity (Net MWe) If Changes Occur Above Since Last Re NONE Power Level To Which Restricted, If Reasons for Restrictions, If Any: NONE Report Period Hrs Mours Reactor Critical 719.0 Hours Reactor On-Line Mit Reserve Shtdwn Hrs 0 Gross Therm Ener (MWH) 1,602,583 Gross Elec Ener (MWH) 0,458,365 Unit Service Factor 100.0 Unit Avail Factor 100.0 Unit Cap Factor (DER Net) 97.5 Unit Forced Outage Rate 0 Forced Uutage Hours 0 Shutdowns Sched Over Next 6 Months (Reporting Period: 04/01/88 Outage + On-line Utility Contact: G. NEWBURGH (203) 447-1791 X4 Licensed Thermal Power (MWt):							





APRIL 1988

Report Period APR 1988	UNIT	S H U T D O W N	S / REDUCTIONS	**************************************
No Date Type Hours Reason Me	thod LER M	lumber System C	omponent Cause & Corre	ective Action to Prevent Recurrence

88-02 04/28/88 S 0.0 H 5

POWER REDUCTION TO FIND AND REPAIR STEAM LEAKS.

Туре	Reason	Method	System & Component	
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)	

FACILITY DESCRIPTION

LOCATION

STATE.....CONNECTICUT

COUNTY.....NEW LONDON

DIST AND DIRECTION FROM NEAREST POPULATION CTR...5 MI SW OF NEW LONDON, CONN

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...OCTOBER 26, 1970

DATE ELEC ENER 1ST GENER...NOVEMBER 29, 1970

DATE COMMERCIAL OPERATE.... MARCH 1, 1971

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LONG ISLAND SOUND

ELECTRIC RELIABILITY COUNCIL.....NORTHEAST POWER COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE......NORTHEAST NUCLEAR EN'RGY

CORPORATE ADDRESS......P.O. BOX 270 HARTFORD, CONNECTICUT 06101

CONTRACTOR ARCHITECT/ENGINEER.....EBASCO

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR......EBASCO

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....W. RAYMOND

LICENSING PROJ MANAGER.....M. BOYLE DOCKET NUMBER......50-245

LICENSE & DATE ISSUANCE.... DPR-21, OCTOBER 26, 1970

PUBLIC DOCUMENT ROOM...... WATERFORD PUBLIC LIBRARY 49 ROPE FERRY ROAD WATERFORD, CONNECTICUT 06385

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

10 CFR 50.72(B)(2)(III) REQUIRES THAT THE NRC BE NOTIFIED WITHIN FOUR HOURS OF ANY EVENT OR CONDITION THAT ALONE COULD HAVE PREVENTED THE FULFILLMENT OF THE SAFETY FUNCTION OF SYSTEMS NEEDED TO SAFELY SHUT DOWN THE REACTOR OR MITIGATE THE CONSEQUENCES OF AN ACCIDENT. CONTRARY TO THE ABOVE, THE LICENSEE FAILED TO NOTIFY THE NRC THAT 8 OUT OF 12 CHECK VALVES IN THE MILLSTONE 1 NITROGEN SUPPLY SYSTEM TO THE AUTOMATIC PRESSURE RELIEF (APR) SYSTEM VALVES FAILED TO PASS THE REQUIRED LEAK TEST CONDUCTED ON NOVEMBER 2, 1985. (8703 4)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

PAGE 2-236

Report Period APR 1988

******************************* * MILLSTONE 1 * *

OTHER ITEMS
NO INPUT PROVIDED.
FACILITY ITEMS (PLANS AND PROCEDURES):
NO INPUT PROVIDED.
MANAGERIAL ITEMS:
NO INPUT PROVIDED.
PLANT STATUS:
NO INPUT PROVIDED.
LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.
INSPECTION REPORT NO: NO INPUT PROVIDED.
REPORTS FROM LICENSEE
NUMBER DATE OF DATE OF SUBJECT EVENT REPORT
NO INPUT PROVIDED.

eporting Period: <u>04/01/3</u> cility Contact: <u>G. NERO</u> censed Thermal Power (M emeplate Rating (Gross M esign Electrical Rating (eximum Dependable Capacit eximum Dependable Cap	88_ Outage N (203) 447 Wt): Ne): (Net MWe): ty (Gross M ty (Net MWe nce Last Re ricted, If If Any:	+ On-line 	Hrs: 719.0 2700 0.° = 910 870 889 857 Reasons: le):
censed Thermal Power (M meplate Rating (Gross M esign Electrical Rating eximum Dependable Capaci eximum Dependable Capaci f Changes Occur Above Sin DNE DNE DWer Level To Which Restrictions,	N (203) 447 Wt): Ne): (Net MWe): ty (Gross M ty (Net MWe nce Last Re ricted, If If Any:	-1791 X4417 1011 X IWe): 	2700 0.° = 910 870 889 857 Reasons:
censed Thermal Power (M ameplate Rating (Gross M esign Electrical Rating (aximum Dependable Capaci eximum Dependable Capaci f Changes Occur Above Sin NE ower Level To Which Rest easons for Restrictions,	Wt): We): (Net MWe): ty (Gross M ty (Net MWe nce Last Re ricted, If If Any:	<u>1011 X</u> We):): port, Give Any (Net M	2700 0.9 = 910 870 889 857 Reasons: le):
ameplate Rating (Gross M esign Electrical Rating eximum Dependable Capaci eximum Dependable Capaci f Changes Occur Above Sin ONE ower Level To Which Rest easons for Restrictions,	We): (Net MWe): ty (Gross M ty (Net MWe nce Last Re ricted, If If Any:	<u>1011 X</u> [We): .): .port, Give Any (Net MW	0.9 = 910 870 889 857 Reasons: le):
esign Electrical Rating eximum Dependable Capaci eximum Dependable Capaci f Changes Occur Above Sin DNE ower Level To Which Rest easons for Restrictions,	(Net MWe): ty (Gross M ty (Net MWe nce Last Re ricted, If If Any:	We): .): port, Give Any (Net M	870 889 857 Reasons: le):
eximum Dependable Capaci eximum Dependable Capaci Changes Occur Above Sin INE ower Level To Which Rest easons for Restrictions,	ty (Gross M ty (Net MWe nce Last Re ricted, If If Any:	We):): port, Give Any (Net MW	889 857 Reasons: le):
eximum Dependable Capaci Changes Occur Above Sin DNE Dwer Level To Which Rest Pasons for Restrictions,	ty (Net MWe nce Last Re ricted, If If Any:): port, Give Any (Net M	857 Reasons: le):
Changes Occur Above Sin NE ower Level To Which Rest Pasons for Restrictions,	nce Last Re ricted, If If Any:	Any (Net M	Reasons:
DNE Dwer Level To Which Rest Pasons for Restrictions,	ricted, If If Anv:	Any (Net M	le):
ower Level To Which Restreasons for Restrictions,	ricted, If If Any:	Any (Net Mi	le):
easons for Restrictions,	If Any:		
		the second second second	
INE			
eport Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 108,239.0
ours Reactor Critical	597.2	1,633.7	
Reserve Shtdwn Hrs			2,166.9
s Generator On-Line	580.2	1,539.0	74,790.7
nit Reserve Shtdwn Hrs	. 0	. 0	468.2
oss Therm Ener (MWH)	1,494,187	3,940,635	191,260,626
oss Elec Ener (MWH)	493,199	1,297,999	62,160,572
et Elec Ener (MWH)	473,449	1,240,330	59,616,587
nit Service Factor	80.7	53.0	69.1
nit Avail Factor	80.7	53.0	69.5
nit Cap Factor (MDC Net)	76.8	49.9	<u>65.0</u> *
nit Cap Factor (DER Net)	75.7	49.1	64.0×
nit Forced Outage Rate	.0	.0	14.9
orced Outage Hours	.0	. 0	11,785.4
utdowns Sched Over Next	6 Months (Type, Date, I	Duration):
	s Generator On-Line it Reserve Shtdwn Hrs oss Therm Ener (MWH) oss Elec Ener (MWH) t Elec Ener (MWH) it Service Factor it Avail Factor it Cap Factor (MDC Net) it Cap Factor (DER Net) it Forced Outage Rate rced Outage Hours utdowns Sched Over Next	s Generator On-Line	seconder of Sindam in S

MILLSTONE 2





* Item calculated with a Weighted Average

**** MILLSTONE 2 Report Period APR 1988 UNIT SHUTDOWNS / REDUCTIONS × ***** No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence INITIATED REACTOR POWER REDUCTION FROM 100% POWER 88-01 04/08/88 S 138.8 B 1 88-08 AA CL, CCL FOR PLANNED MAINTENANCE OUTAGE; CEA NO. 22 DROPPED AND POWER WAS REDUCED TO 70%; CONTINUED REACTOR SHUTDOWN - UNABLE TO RECOVER THE DROPPED CEA; CEA NO. 4 ALSO DROPPED BEFORE REACTOR WAS SUB-CRITICAL; THE DROPPING OF CEA'S NO. 4 AND NO. 22 WAS DETERMINED TO HAVE BEEN CAUSED BY MAJOR LOSS OF UPPER GRIPPER COIL RESISTANCE DUE TO OVERHEATING; IN ADDITION, A HIGH RESISTANCE OF THE CEA NO. 5 UPPER GRIPPER COIL WAS FOUND, AND WAS DETERMINED TO HAVE BEEN CAUSED BY A LOOSE COIL STACK CONNECTION; OVERHEATING WAS CAUSED BY THE REDUCTION OF THE CEDM COOLER EFFICIENCY DUE TO BORON CLOGGING OF THE FAN INTAKES; NEW CEDM COIL STACKS WERE

INSTALLED FOR CEA'S NO. 4, 5, AND 22; CEDM COOLER INTAKES WERE CLEANED; DETERM. OF BORON SOURCE UNDER INVESTIGATION.

Туре	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operacor Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE.....CONNECTICUT

COUNTY......NEW LONDON

DIST AND DIRECTION FROM NEAREST POPULATION CTR...5 MI SW OF NEW LONDON, CONN

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY...OCTOBER 17, 1975

DATE FLEC ENER 1ST GENER. .. NOVEMBER 9, 1975

DATE COMMERCIAL OPERATE.... DECEMBER 26, 1975

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LONG ISLAND SOUND

ELECTRIC RELIABILITY

COUNCIL.....NORTHEAST POWER COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....NORTHEAST NUCLEAR ENERGY

CORPORATE ADDRESS......P.O. BOX 270 HARTFORD, CONNECTICUT 06101

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....W. RAYMOND

LICENSING PROJ MANAGER....D. JAFFE DOCKET NUMBER.....50-336

LICENSE & DATE ISSUANCE..., DPR-65, SEPTEMBER 30, 1975

PUBLIC DOCUMENT ROOM......WATERFORD PUBLIC LIBRARY 49 ROPE FERRY ROAD WATERFORD, CONNECTICUT 06385

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

MILLSTONE UNIE 2 TS 6.2.2A REQUIRES THAT ADMINISTRATIVE PROCEDURES BE DEVELOPED AND IMPLEMENTED TO LIMIT WORKING HOURS OF UNIT STAFF WHO PERFORM SAFETY-RELATED FUNCTIONS. PLANT PROCEDURE ACP 1.19/NDO 1.09, "OVERTIME CONTROLS FOR PERSONNEL WORKING AT THE OPERATING NUCLEAR STATION," REV 1, DEVELOPED PURSUANT TO THE ABOVE THE THREE MILE ISLAND ACTION PLAN, REQUIRES THAT AN INDIVIDUAL NOT BE PERMITTED TO WORK MORE THAN 24 HOURS IN ANY 48 HOUR PERIOD OR MORE THAN 72 HOURS IN ANY WORK EEK, UNLESS SUCH OVERTIME USE IS AUTHENTICATED AND CONTROLLED BY STATION MANAGEMENT. CONTRARY TO THE ABOVE, DURING ONE WEEK WORK INTERVALS IN THE PERIOD FROM JANUARY 26, 1987 TO FEBRUARY 15, 1987 SIX INDIVIDUALS WORKED MORE THAN 72 HOURS IN A WORK WEEK WITHOUT THE REQUIRED MANAGEMENT APPROVAL, AND ONE INDIVIDUAL WORKED MGRE THAN 72 HOURS IN A WEEK AND MORE THAN 24 HOURS IN A 48 HOUR PERIOD WITHOUT THE REQUIRED MANAGEMENT APPROVAL.

(8702 5)

OTHER ITEMS

PAGE 2-240

Report Period APR 1988

******	******************	*****
×	MILLSTONE 2	×
******	*****	********

OTHER ITEMS

SYSTEMS AND COMPONENTS:
NO INPUT PROVIDED.
FACILITY ITEMS (PLANS AND PROCEDURES):
NO INPUT PROVIDED.
MANAGERIAL ITEMS:
NO INPUT PROVIDED.
PLANT STATUS:
NO INPUT PROVIDED.
LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.
INSPECTION REPORT NO: NO INPUT PROVIDED.
REPORTS FROM LICENSEE
NUMBER DATE OF DATE OF SUBJECT EVENT REPORT
NO INPUT PROVIDED

1. Docket: _50-423_	OPERAT	INGS	TATUS							
2. Reporting Period:04/01/	Reporting Period: 04/01/88 Outage + On-line Hrs: 719.0									
3. Utility Contact: A. ELM	S (203) 444-	5388								
4. Licensed Thermal Power (!	Licensed Thermal Power (MWt):									
5. Nameplate Rating (Gross !		1253								
6. Design Electrical Rating		1154								
7. Maximum Dependable Capac	. Maximum Dependable Capacity (Gross MWe):									
8. Maximum Dependable Capac	. Maximum Dependable Capacity (Net MWe):									
9. If Changes Occur Above S	If Changes Occur Above Since Last Report, Give Reasons:									
 Power Level To Which Rest Reasons for Restrictions, NONE 	tricted, If , If Any:	Any (Net Mk	le):							
12. Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 17,735.0							
13. Hours Reactor Critical	405.3	1,764.0	13,527.5							
14. Rx Reserve Shtdwn Hrs	20.2	20.2	246.2							
15. Hrs Generator On-Line	380.4	1,572.9	13,163.4							
16. Unit Reserve Shtdwn Hrs	. 0	.0	. 0							
17. Gross Therm Ener (MWH)	1,285,473	5,060,904	47,330,335							
18. Gross Elec Ener (MWH)	417,168	1,761,565	14,970,835							
19. Net Elec Ener (MWH)	389,431	1,658,642	14,262,719							
20. Unit Service Factor	52.9	54.2	74.2							
21. Unit Avail Factor	52.9	54.2	74.2							
22. Unit Cap Factor (MDC Net)	47.5	50.0	70.4							
23. Unit Cap Factor (DER Net)	47.0	49.5	69.7							
24. Unit Forced Outage Rate	47.1	19.3	9,9							
25. Forced Outage Hours	338.6	375.7	1,450.2							
26. Shutdowns Sched Over Next NONE	t 6 Months (Type,Date,D)uration):							
27. If Currently Shutdown Est	timated Star	tup Date:	N/A							



NET MWE GENERATED

500

0+0

APRIL 1988

15

DAYS

20

25

10

5

PAGE 2-242

- 60

- 40

- 20

- 0

30

Report	Period A	PR 19	88		UN	ΤI	SHU	трож	NS /	R	REDUCTIONS ************************************
No.	Date	Туре	Hours	Reason	Method	LER	Number	System	Componen	nt	nt Cause & Corrective Action to Prevent Recurrence
88-03	04/13/88	F	330.4	н	2	88-014	4-00	KE	SCN		TURBINE TRIP DUE TO LOW CONDENSOR VACUUM CAUSED BY LOSS OF BOTH CIRCULATING WATER PUMPS SUPPLYING THE 'A' CONDENSOR BAY. THE CIRCULATING WATER PUMPS TRIPPED DUE TO A HIGH DIFFERENTIAL PRESSURE ACROSS THE INTAKE TRAVELING SCREENS. THE ROOT CAUSE WAS BLOCKAGE OF THE INTAKE STRUCTURE SCREENS DUE TO ENVIRONMENTAL CONDITIONS. IMMEDIATE CORRECTIVE ACTION WAS PLACING ALL SCREEN WASH PUMPS IN SERVICE (ONE PUMP WAS OUT OF SERVICE). SEE LER FOR SUBSEQUENT CORRECTIVE ACTION.
88-04	04/28/88	F	8.2	Α	2						TURBINE OFF LINE TO REPAIR STEAM LEAK ON DRAIN PIPING.

Туре	vpe Reason		Method	System & Component	
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train	F-Admin G-Oper Error H-Other triction ing	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LEP) File (NUREG-0161	

FACILITY DESCRIPTION

LOCATION STATE.....CONNECTICUT COUNTY.....NEW LONDON DIST AND DIRECTION FROM NEAREST POPULATION CTR...3.2 MI WSW OF NEW LONDON CT. TYPE OF REACTOR.....PWR DATE INITIAL CRITICALITY...JANUARY 23, 1986

DATE ELEC ENER 1ST GENER...FEBRUARY 12, 1986

DATE COMMERCIAL OPERATE.... APRIL 23, 1986

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER....NIANTIC BAY

ELECTRIC RELIABILITY

COUNCIL.....NORTHEAST POWER COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....NORTHEAST NUCLEAR ENERGY

CORPORATE ADDRESS......P.O. BOX 270 HARTFORD, CONNECTICUT 06101

CONTRACTOR

ARCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR......STONE & WEBSTER

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....W. RAYMOND

LICENSE & DATE ISSUANCE....NPF-49, JANUARY 31, 1986

PUBLIC DOCUMENT ROOM......WATERFORD PUBLIC LIBRARY 49 ROPE FERRY ROAD WATERFORD, CONNECTICUT 06385

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

Report Period APR 1988

******* * MILLSTONE 3 *

PLANT STATUS:
INFO. NOT SUPPLIED BY REGION
LAST IE SITE INSPECTION DATE: INFO. NOT SUPPLIED BY REGION
INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION
REPORTS FROM LICENSEE
NUMBER DATE OF DATE OF SUBJECT EVENT REPORT
INFO. NOT SUPPLIED BY REGION

	Docket: <u>50-263</u>	OPERAI	TING S	TATUS								
. 2.	Reporting Period: 04/01/	88_ Outage	e + On-line	Hrs: 719.0								
3.	Utility Contact: A. L. M	yrabo (612)	295-5151									
4.	Licensed Thermal Power (MWt):1670											
5.	Nameplate Rating (Gross MWe): 632 X 0.9 = 569											
6.	Design Electrical Rating (Net MWe): 545											
7.	Maximum Dependable Capacity (Gross MWe): 564											
8.	Maximum Dependable Capaci	ty (Net MWe	.):	536								
9.	If Changes Occur Above Si	nce Last Re	port, Give	Reasons:								
	NONE											
10.	Power Level To Which Rest	ricted, If	Any (Net M	We):								
11.	Reasons for Restrictions,	If Any:										
_	NONE											
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 147,576.0								
13	Hours Reactor Critical	719.0	2,903.0	115,140.0								
14.	Rx Reserve Shtdwn Hrs	. 0		940.7								
15	Hrs Generator On-Line	719.0	2,903.0	112,916.6								
12.												
16.	Unit Reserve Shtdwn Hrs		. 0	. 0								
16. 17.	Unit Reserve Shtdwn Hrs Gross Therm Ener (MWH)	<u>.0</u> 1,194,835	.0 4,824,008	.0 1 <u>80,502,082</u>								
16. 17. 18.	Unit Reserve Shtdwn Hrs Gross Therm Ener (MWH) Gross Elec Ener (MWH)	.0 1,194,835 403,946	.0 4,824,008 1,635,133	.0 1 <u>80,502,082</u> 58,515,189								
13. 16. 17. 18. 19.	Unit Reserve Shtdwn Hrs Gross Therm Ener (MWH) Gross Elec Ener (MWH) Net Elec Ener (MWH)	.0 1,194,835 403,946 388,910	.0 <u>4,824,008</u> <u>1,635,133</u> <u>1,574,370</u>	.0 1 <u>80,502,082</u> 58,515,189 55,945,488								
16. 17. 18. 19. 20.	Unit Reserve Shtdwn Hrs Gross Therm Ener (MWH) Gross Elec Ener (MWH) Net Elec Ener (MWH) Unit Service Factor	.0 1,194,835 403,946 388,910 100.0	.0 4,824,008 1,635,133 1,574,370 100.0	.0 1 <u>80,502,082</u> 58,515,189 <u>55,945,488</u> 76.5								
16. 17. 18. 19. 20. 21.	Unit Reserve Shtdwn Hrs Gross Therm Ener (MWH) Gross Elec Ener (MWH) Net Elec Ener (MWH) Unit Service Factor Unit Avail Factor	.0 1,194,835 403,946 388,910 100.0 100.0	.0 4,824,008 1,635,133 1,574,370 100.0 100.0	.0 1 <u>80,502,082</u> 58,515,189 55,945,488 76.5 76.5								
13. 16. 17. 18. 19. 20. 21. 22.	Unit Reserve Shtdwn Hrs Gross Therm Ener (MWH) Gross Elec Ener (MWH) Net Elec Ener (MWH) Unit Service Factor Unit Avail Factor Unit Cap Factor (MDC Net)	.0 1,194,835 403,946 388,910 100.0 100.0 100.9	.0 4,824,008 1,635,133 1,574,370 100.0 100.0 101.2	.0 180,502,082 58,515,189 55,945,488 76.5 76.5 76.5								
16. 17. 18. 19. 20. 21. 22. 23.	Unit Reserve Shtdwn Hrs Gross Therm Ener (MWH) Gross Elec Ener (MWH) Net Elec Ener (MWH) Unit Service Factor Unit Avail Factor Unit Cap Factor (MDC Net) Unit Cap Factor (DER Net)	0 1,194,835 403,946 388,910 100.0 100.0 100.9 99.2	.0 4,824,008 1,635,133 1,574,370 100.0 100.0 101.2 99.5	.0 180,502,082 58,515,189 55,945,488 76.5 76.5 76.5 70.7 69.6								
16. 17. 18. 19. 20. 21. 22. 23. 24.	Unit Reserve Shtdwn Hrs Gross Therm Ener (MWH) Gross Elec Ener (MWH) Net Elec Ener (MWH) Unit Service Factor Unit Avail Factor Unit Cap Factor (MDC Net) Unit Cap Factor (DER Net) Unit Forced Outage Rate	0 1,194,835 403,946 388,910 100.0 100.0 100.9 99.2 .0	.0 4,824,008 1,635,133 1,574,370 100.0 100.0 101.2 99.5 .0	0 180,502,082 58,515,189 55,945,488 76.5 76.5 76.5 70.7 69.6 4.3								
 16. 17. 18. 19. 20. 21. 22. 23. 24. 25. 	Unit Reserve Shtdwn Hrs Gross Therm Ener (MWH) Gross Elec Ener (MWH) Net Elec Ener (MWH) Unit Service Factor Unit Avail Factor Unit Cap Factor (MDC Net) Unit Cap Factor (DER Net) Unit Forced Outage Rate Forced Outage Hours	0 1,194,835 403,946 388,910 100.0 100.0 100.9 99.2 0 .0	0 4,824,008 1,635,133 1,574,370 0 0 0 0 0	0 180,502,082 58,515,189 55,945,488 76.5 76.5 70.7 69.6 4.3 1,498.3								



MONTICELLO



APRIL 1988

Report	Period APR 1988		UNIT	SHUT	TDOWNS / R	E D U C T I O N S * MONTICELLO * *********************************	
No.	Date Type Hours	Reason Met	thod LE	R Number	System Component	Cause & Corrective Action to Prevent Recurrence	_

NONE

Type	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE.....MINNESOTA

COUNTY......WRIGHT

DIST AND DIRECTION FROM NEAREST POPULATION CTR...30 MI NW OF MINNEAPOLIS, MINN

TYPE OF REACTOR......BWR

DATE INITIAL CRITICALITY...DECEMBER 10, 1970

DATE ELEC ENER 1ST GENER...MARCH 5, 1971

DATE COMMERCIAL OPERATE....JUNE 30, 1971

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER....MISSISSIPPI RIVER

ELECTRIC RELIABILITY

COUNCIL.....MID-CONTINENT AREA RELIABILITY COORDINATION AGREEMENT

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE......NORTHERN STATES POWER

CORPORATE ADDRESS.......414 NICOLLET MALL MINNEAPOLIS, MINNESOTA 55401

CONTRACTOR

ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....P. HARTMAN

LICENSING PROJ MANAGER....J. STEFANO DOCKET NUMBER.....50-263

LICENSE & DATE ISSUANCE....DPR-22, JANUARY 9, 1981

PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY MINNEAPOLIS PUBLIC LIBRARY 300 NICOLLET MALL MINNEAPOLIS, MINNESOTA 55401

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

10 CFR 50.49, PARAGRAPHS (F) AND (G) REQUIRE EQUIPMENT IMPORTANT TO SAFETY TO BE QUALIFIED BY TESTING AND ANALYSIS PRIOR TO THE EQ FEADLINE OF NOVEMBER 30, 1985. CONTRARY TO THE ABOVE, THE FOLLOWING EQUIPMENT WAS NOT QUALIFIED BY TEST AND/OR ANALYSIS FOR THEIR I STALLED CONDITIONS. IN ADDITION, APPROPRIATE MAINTENANCE ACTIVITIES WERE NOT SPECIFIED IN THE LICENSEE'S QUALIFICATION FILES AIS I SCESSARY TO MAINTAIN THE ENVIRONMENTAL QUALIFICATION (EQ) OF THE EQUIPMENT, AND THE LICENSEE COULD NOT PROVIDE EVIDENCE OF HAVING PERFORMED THESE ACTIVITIES. EQ REPORT 0910-111-FR-14 FOR LIMITORQUE OPERATORS STATES THAT THE AGING OF LUBRICANTS IS NOT A CONCERN IF REGULAR INSPECTION AND REPLACEMENT OF LUBRICANTS IS PERFORMED. LIMITORQUE PROCEDURE LC8 INDICATES THAT THE LUBRICANT IN THE LIMITORQUE MAIN GEAR CASE AND THE LIMIT SWITCH COMPARTMENT SHOULD BE INSPECTED AND CHANGED, IF NECESSARY, AT 18 MONTH INTERVALS AND 36 MONTH INTERVALS RESPECTIVELY. THIS PROCEDURE ALLOWS FOR EXTENDING THESE INTERVALS IF PRCVIDUS INSPECTIONS HAVE NOT IDENTIFIED ANY DEGRADATION OF THE LUBRICANT. THE INSPECTORS OBSERVED THAT THE LUBRICANT IN LIMITORQUE MOTOR OPERATORS 2012 AND 2373 HAD NOT BEEN INSPECTED SINCE 1984, AND THAT THE LICENSEE COULD NOT PROVIDE EVIDENCE THAT PRIOR INSPECTIONS HAD BEEN PERFORMED TO IDENTIFY ANY DEGRADATION OF THE LUBRICANT. (50-263/87013-01(A)(DRS)) (B) EQ REPORT 0910-111-FR-33, PAGE 21 OF 42, PAKAGRAPH 4.2.3, FOR RELIANCE MOTORS, REQUIRES LUBRICANTS TO BE EXAMINED ON A PERIODIC BASIS TO IDENTIFY ANY DEGRADATION OF THE LUBRICANT. (50-263/87013-01(A)(DRS)) (B) EQ REPORT 0910-111-FR-33, PAGE 21 OF 42, PAKAGRAPH 4.2.3, FOR RELIANCE MOTORS, REQUIRES LUBRICANTS TO BE EXAMINED ON A PERIODIC BASIS TO IDENTIFY ANY DEGRADATION AND REQUIRES PERIODIC MAINTENANCE PROCEDURES TO INCLUDE ACTIVITIES FOR SUVELLANCE AND REPLACEMENT OF LUBRICANTS. THE INSPECTORS OBSERVED THAT THIS REQUIREMENT WAS NOT IDENTIFIED IN THE LICENSEE'S EQ MAINTENANCE OR PREVENTATIVE MAINTENANCE PROGRAMS, AND THAT

PAGE 2-248

Report Period APR 1988

Report Period APR 1988

ENFORCEMENT SUMMARY

THERE WAS NO EVIDENCE THAT THE LICENSEE HAD PERFORMED SUCH SURVEILLANCE INSPECTIONS. (50-263/87013-01(B)(DRS)) (C) DURING EXAMINATION OF RHR PUMP MOTOR P-202B THE INSPECTORS OBSERVED THAT THE INSTALLED MOTOR LEAD JUNCTION BOX CONTAINED WATER AND SLUDGE, AND THAT THE CABLE AND CABLE SPLICES IN THE BOX WERE WET DUE TO CONDENSATION IN THE CONDUIT AND DRAINAGE INTO THE MOTOR LEAD JUNCTION BOX. THIS CONDITION WAS CONTRARY TO THE TESTED CONDITIONS AND INSTALLATION REQUIREMENTS. (50-263/87013-01(C)(DRS)). (D) MOBILUX EPO IS USED TO LUBRICATE THE MAIN GEAR CASE LIMITORQUE OPERATORS(50-263/87013-01(D)) (8701 4)

TECHNICAL SPECIFICATION 6.5, PLANT OPERATING PROCEDURES, STATES THAT DETAILED WRITTEN PROCEDURES, INCLUDING THE APPLICABLE CHECK-OFF LISTS AND INSTRUCTIONS, SHALL BE PREPARED AND FOLLOWED. CONTRARY TO THE ABOVE, DURING THE PERIOD OF DECEMBER 1, 1987 TO JANUARY 12, 1988 SEVERAL EXAMPLES OF FAILURE TO FOLLOW APPROVED PLANT PROCEDURES WERE IDENTIFIED. EACH EXAMPLE IS DISCUSSED BELOW; (A) DURING THE PERFORMANCE OF TEST PROCEDURE #0417-2, REVISION 0, "B" CGCS RECOMBINER REACTION CHAMBER OPERABILITY TEST AN OPERATOR FAILED TO PERFORM A SOAK OF THE CGCS RECOMBINATION REACTION CHAMBER IN ACCORDANCE WITH THE PROCEDURE. (B) DURING THE PERFORMANCE OF TEST PROCEDURE #0189-1, REVISION 12, EMERGENCY DIESEL GENERATOR AUTOMATIC FAST START INITIATION OPERATORS FAILED TO FOLLOW APPROVED METHODS OF INDEPENDENT VERIFICATION SPECIFIED IN 4 ACD (ADMINISTRATIVE CONTROL DOCUMENT)-04.07, REVISION 12, SECTION 6.16. (C) DURING THE PERFORMANCE OF TEST PROCEDURE #0036-1/0039-1, REVISION 10, ECCS EMERGENCY BUS UNDERVOLTAGE TEST-1/ECCS LOSS OF NORMAL AUXILIARY POWER TEST-1 OPERATORS FAILED TO FOLLOW APPROVED METHODS OF INDEPENDENT VERIFICATION SPECIFIED IN 4 ACD-04.07, REVISION 12, SECTION 6.16. (D) DURING PERFORMANCE OF TEST PROCEDURE NO.1025A, A RADIATION PROTECTION SPECIALIST FAILED TO FOLLOW AN APPROVED PROCEDURE BY TESTING A DIFFERENT RADIATION MONITOR THAN REQUIRED BY THE TEST PROCEDURE. THIS RESULTED IN ENGINEERED SAFETY FEATURE (ESF) ACTUATIONS. (E) DURING PERFORMANCE OF TEST PROCEDURE NO. 0067, A LICENSED OPERATOR FAILED TO FOLLOW AN APPROVED PROCEDURE STEP OF INSTALLING A JUMPER ON A SPECIFIED TERMINAL. THIS RESULTED IN AN ESF ACTUATION. (F) DURING PERFORMANCE OF THE MODIFICATION PREOPERATIONAL TEST PROCEDURE FOR RESIDUAL HEAT FEMOVAL VALVE MO-2407, A LICENSED OPERATOR FAILED TO INSTALL & JUMPER ON THE PROPER TERMINAL AS REQUIRED. THE ERROR RESULTED FROM INSTALLATION BY WIRE IDENTIFICATION RATHER THAN TERMINAL VERIFICATION. THIS RESULTED IN ESF ACTUATIONS. (8702 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING ROUTINELY

LAST IE SITE INSPECTION DATE: 04/01/88

INSPECTION REPORT NO: 88005

Report Perio	d APR 1988		REPORTS FROM LICENSEE * MONTICELLO *
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-03	032988	042888	MISSED SURVEILLANCE OF EDG LOAD SEQUENCING DUE TO PERSONNEL ERROR

THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docket: <u>50-220</u>	PERAT	INGS	TATUS								
2	Reporting Per od: _ <u>94/01/8</u>	8 Outage	+ On-line	Hrs: 719.0								
3.	Utility Contact:	. ROMAN (3	515) 349-2	422								
4.	Licensed Thermal Power (MM	lt):	<u></u>	1850								
5.	Nameplate Rating (Gross MWe): 755 X 0.85 = 642											
6.	Design Electrical Rating (Net MWe): 620											
7.	Maximum Dependable Capacit	y (Gross Mb	(e):	630								
8.	Maximum Dependable Capacit	y (Net MWe)	:	610								
9.	If Changes Occur Above Sin	ce Last Rep	ort, Give	Reasons:								
-	NONE											
10.	Power Level To Which Restr	icted, If A	ny (Net M	He):								
11.	Reasons for Restrictions,	If Any:										
1	NONE											
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE								
13,	Hours Reactor Critical	.0		115,235.2								
14.	Rx Reserve Shtdun Hrs	. 0	. 0	1,204.2								
15.	Hrs Generator On-Line	. 0	. 0	112,102.6								
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	20.2								
17.	Gross Therm Ener (MWH)	0	0	188,473,049								
18.	Gross Elec Ener (MWH)	0	0	62, 473, 071								
19.	Net Elec Ener (MWH)	0	0	60, 524, 379								
20.	Unit Service Factor	.0	. 0	69.1								
21.	Unit Avail Factor	. 0		69.2								
22.	Unit Cap Factor (MDC Net)	. 0	. 0	61.2								
23.	Unit Cap Factor (DER Net)	. 0	. 0	60.2								
24.	Unit Forced Outage Rate	. 0	100.0	14.9								
25.	Forced Outage Hours	. 0	516.0	15,047.9								
26.	Shutdowns Sched Over Next (6 Months (T	ype,Date,D	luration)								
1994	tere ter ser ser te bildet ser de											

27. If Currently Shutdown Estimated Startup Date: ______06/17/88

NINE MILE POINT 1



APRIL 1988

Report Pe	eriod AP	R 198	88		** N	IT	SHU	тром	NS /	RI	EDUCTI	0 N S	× NINE MILE POINT 1 ×
<u>No.</u>	Date	Type S	Hours 719.0	Reason C	Methad 4	LER	Number	System	Componen	E I	Cause THE DECISION THE PLANT WA THE F.W. SYS	A Cor MAS MAS MAS ALRE	TRECTIVE Action to Prevent Recurrence MADE TO START THE REFUEL OUTAGE SINCE EADY SHUTDOWN DUE TO PROBLEMS WITH

Method System & Compo Reason Туре Exhibit F & H 1-Manual F-Forced A-Equip Failure F-Admin 2-Manual Scram Instructions for B-Maint or Test G-Oper Error S-Sched 3-Auto Scram Preparation of C-Refueling H-Other D-Regulatory Restriction E-Operator Training 4-Continued Data Entry Sheet 5-Reduced Load Licensee Event Report 9-Other (LER) File (NUREG-0161) & License Examination

FACILITY DESCRIPTION

LOCATION STATE.....NEW YORK COUNTY.....OSWEGO DIST AND DIRECTION FROM NEAREST POPULATION CTR...8 MI NE OF OSWEGO, NY TYPE OF REATOR.....BWR DATE INITIAL CR.,ICALITY...SEPTEMBER 5, 1969 DATE ELEC ENER 1ST GENER...NOVEMBER 9, 1969 DATE COMMERCIAL OFERATE....DECEMBER 1, 1969 CONDENSER COOLING METHOD...ONCE TH : CONDENSER COOLING MATER....LAKE ONTARIO ELECTRIC RELIABILITY COUNCIL......NORTHEAST POWER COORDINATING COUNCIL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

CONTRACTOR

ARCHITECT/ENGINSER.....NIAGARA MOHAWK POWER CORP.

NUC STEAM SYS SUPPLIER... GENERAL ELECTRIC

CONSTRUCTOR.....STONE & WEBSTER

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....S. HUDSON

LICENSE & DATE ISSUANCE.... DPR-63, DECEMBER 26, 1974

PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO PENFIELD LIBRARY - DOCUMENTS OSWEGO, NY 13126 (315) 341-2323

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

ER ITEMS	
O INPUT PROVIDED.	
ANAGERIAL ITEMS:	
D INPUT PROVIDED.	
LANT STATUS:	
O INPUT PROVIDED.	
AST IE SITE INSPECTION DATE: NO INPUT PROVIDED.	
NSPECTION REPORT NO: NO INPUT PROVIDED.	
REPORTS FROM LICENSEE	
NUMBER DATE OF DATE OF SUBJECT EVENT REPORT	
NO "NPUT PROVIDED.	

1.	Docket: _50-410_	OPERAT	INGS	TATUS								
2.	Reporting Period:04/01/	88 Outage	+ On-line	Hrs: 719.0								
3.	Utility Contact: E. TOML	INSOM (315)	349-2761									
4.	Licensed Thermal Power (MWt):											
5.	Nameplate Rating (Gross MWe): 1214											
6.	Design Electrical Rating	(Net MWe):		1080								
7.	Maximum Dependable Capaci	ty (Gross M	We):	1080								
8.	Maximum Dependable Capaci	ty (Net Mike):	1080								
9.	If Changes Occur Above Si	nce Last Re	port, Give	Reasons:								
10. 11.	fower Level To Which Rest Reasons for Restrictions, NONE	ricted, If If Any:	Any (Net MW	le):								
12.	Report Period Mrs	MONTH 719.0	YEAR 1,208.0	CUMULATIVE								
13.	Hours Reactor Critical	719.0	1,023.4	1,023.4								
14.	R× Reserve Shtdwn Hrs		. 0	. 0								
15.	Hrs Generator On-Line	719.0	991.0	99:.0								
16.	Unit Reserve Shtdwn Hrs											
17.	Gross Therm Ener (MWH)	2,287,430	3,180,789	3,180,789								
18.	Gross Elec Ener (MWH)	772,200	987,840	987,840								
19.	Net Elec Ener (MWH)	727,760	921,850	921,850								
20.	Unit Service Factor	100.0	82.0	82.0								
21.	Unit Avail Factor	100.0	82.0	82.0								
22.	Unit Cap Factor (MDC Net)	93.7	70.7	70.7								
23.	Unit Cap Factor (DER Net)	93.7	70,7	70.7								
24.	Unit Forced Outage Rate		18.0	18.0								
25.	Forced Dutage Hours		217.0	217.0								
26.	Shutdowns Sched Over Next	6 Months (Type, Date, D	uration):								
	SURV. 5/2/88-21 DAYS. MAI	NT/SURV-9/8	8-48 DAY DU	RATION.								
27.	If Currently Shutdown Est	imated Star	tup Date:	N/A								

******	****	*****	******	*****	XXXX
×	NINE I	MILE PI	DINT 2		×
*****	****	*****	******	*****	****
AVERAGE	DAILY	POWER	LEVEL	(MWe)	PLOT

NINE MILE POINT 2



APRIL 1988

Report	Period A	PR 19	88		UN	IT	SHU	TDOW	N S	/ R	E D U C T I O N S * NINE MILE POINT 2 * *********************************
No.	Date	Type	Hours	Reason	Method	LER	Number	System	Comp	onent	Cause & Corrective Action to Prevent Recurrence
88-3	04/01/88	F	0.0	А	5						REDUCED POWER BECAUSE OF LEAK IN MSR REHEATER DRAIN RECEIVER. RETURNED TO FULL POWER UPON COMPLETION OF CONTROL ROD SEQUENCE EXCHANGE.
88-4	04/06/88	F	0.0	F	5	88-1	8				REDUCED POWER DUE TO MISSED SURVEILLANCE ON PRIMARY CONTAINMENT PENETRATION. RESUMED FULL POWER UPON SATISFACTORY COMPLETION OF THE SURVEILLANCE.
88-5	04/29/88	s	0.0	в	5						PLANNED SHUTDOWN FOR 21 DAY OUTAGE. UNIT NOT OFF LINE AT END OF REPORTING PERIOD.

Туре	Reason		Method
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling	F-Admin G-Oper Error H-Other	1-Manual 2-Manual Scra 3-Auto Scram

B-Maint or TestG-Oper Error2-Manual ScramInstructions forC-RefuelingH-Other3-Auto ScramPreparation ofD-Regulatory Restriction4-ContinuedData Entry SheetE-Operator Training5-Reduced LoadLicensee Event Report& License Examination9-Other(LER) File (NUREG-0161)

System & Component

Exhibit F & H

FACILITY DESCRIPTION

LOCATION STATE.....NEW YORK COUNTY.....OSWEGO DIST AND DIRECTION FROM NEAREST POPULATION CTR...8 M1 NE OF OSWEGO, NY TYPE OF REACTOR.....BWR DATE INITIAL CRITICALITY...MAY 23, 1987 DATE ELEC ENER 1ST GENER...AUGUST *, 1987 DATE COMMERCIAL OPERATE....MARCH 11, 1988 CONDENSER COOLING METHOD...COOLING TOWER CONDENSER COOLING WATER....LAKE ONTARIO ELECTRIC RELIABILITY COUNCIL......NORTHEAST POWER COORDINATING COUNCIL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

ARCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR......STONE & WEBSTER

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSFECTOR.....W. COOK

LICENSE & DATE ISSUANCE....NPF-69, JULY 2, 1987

PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO PENFIELD LIBRARY - DOCUMENTS OSWEGO, N7 13126 (315) 341-2323 INSPECTION STATUS

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

****** * NINE MILE POINT 2 *****

PLANT STATUS:

INFO. NOT SUPPLIED BY REGION LAST VE SITE INSPECTION DATE: INFO. NOT SUPPLIED BY REGION INSPECTION REFORT NO: INFC. NOT SUPPLIED BY REGION REPORTS FRON LICENSEE NUMBER DATE OF DATE OF SUBJECT EVENT REPORT INFO. NOT SUPPLIED BY REGION

1.	Docket: _50-338	OPERAT	INGS	TATUS
2.	Reporting Period: 04/01/1	88 Outage	+ On-line	Hrs: 719,0
3.	Utility Contact: B. GARNI	ER (703) 89	4-5151 X252	27
is.	Licensed Thermal Power (M	ut):	· · · · · · · · · · · · · · · · · · ·	2893
5.	Nameplate Rating (Gross M	947		
6.	Design Electrical Rating	(Net MWe):		907
7.	Maximum Dependable Capaci	ty (Gross M	Ke):	963
8.	Maximum Dependable Capacit	ty (Net MWe):	915
2.	If Changes Occur Above Sin	nce Last Re	port, Give	Reasons:
	NONE			
10.	Power Level To Which Rest	ricted, If	Any (Net M	We):
11.	Reasons for Restrictions,	If Any:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 86,808.0
13.	Hours Reactor Critical	719.0	2,177.8	59,609.0
14.	Rx Reserve Shtdwn Hrs		148.6	5,796.6
15.	Hrs Generator On-Line	719.0	2,017.5	57,786.0
16.	Unit Reserve Shtdwn Hrs		. 0	
17.	Gross Therm Ener (MWH)	2,978,640	5,580,001	151,756,775
18.	Gross Elec Ener (MWH)	693,097	1,849,690	49,753,578
19.	Net Elec Ener (MWH)	658,236	1,754,434	47,049,028
20.	Unit Service Factor	100.0	69.5	66.6
21.	Uni* Avail Factor	100.0	69.5	66.6
22.	Unit Cap Factor (MDC Net)	100.1	66.0	59.2
23.	Unit Cap Factor (DER Net)	100.9	66.6	59.8
24.	Unit Forced Outage Rate	. 0	27.7	15.6
25.	Forced Outage Hours	.0	771.7	:0,593.2
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):
27	If Currently Shutdown Est	imated Star	tup Date:	N/A

AVERAGE DAILY POWER LEVEL (MMo) PLOT

NORTH ANNA 1



APRIL 1968

Report Period APR 1988	UNIT	SHUTD	DOWNS / REDUCTI	IONS	**************************************
any water and a second se					

 0.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause 8	Correctiv	e Action	to	Prevent	Recurrent	ce

NONE

¥	黃	×	×	×	¥	黃	×	×	×	×	

TYPe	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Adm'n B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

******* NORTH ANNA 1 * ******

FACILITY DESCRIPTION

LOCATION STATE.....VIRGINIA

COUNTY LOUISA

DIST AND DIRECTION FROM NEAREST POPULATION CTR...40 MI NW OF RICHMOND, VA

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY. .. APRIL 5, 1978

DATE ELEC ENER 1ST GENER... APRIL 17, 1978

DATE COMMERCIAL OPERATE....JUNE 6, 1978

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER....LAKE ANNA

ELECTRIC RELIABILITY

RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE......VIRGINIA POWER

RICHMOND, VIRGINIA 23261

CONTRACTOR ARCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER... WESTINGHOUSE

CONSTRUCTOR......STONE & WEBSTER

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR M. BRANCH

LICENSING PROJ MANAGER....L. ENGLE DOCKET NUMBER 50-338

LICENSE & DATE ISSUANCE....NPF-4, APRIL 1, 1978

PUBLIC DOCUMENT ROOM......ALDERMAN LIBRARY/MANUSCRIPTS DEPT. UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MARCH 21-25 (88-07): THIS ROUTINE, UNANNOUNCED PHYSICAL SECURITY INSPECTION INVOLVED A REVIEW OF THE FOLLOWING AREAS: SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; TESTING AND MAINTENANCE; BARRIERS - VITAL AREAS; DETECTION AIDS - PROTECTED AND VITAL AREAS; ALARY, STATIONS; AND CONTINGENCY PLAN RESPONSE. ONE VIOLATION AND ONE INSPECTOR FOLLOW-UP ITEM WERE IDENTIFIED. VIOLATION 88-07-01 INADEQUATE PROTECTED AREA ALARM ZONES IFI 88-07-02 TAMPER CIRCUITS TO BE REWIRED.

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION III, AND THE LICENSEE'S ACCEPTED QUALITY ASSURANCE (QA) PROGRAM, UPDATE FINAL SAFETY ANALYSIS REPORT, SECTION 17.2.3, A DESIGN CHANGE WAS MADE TO PIPE HANGER 01-CC-R-173 AND THE ANALYSIS WAS NOT PERFORMED IN A PLANNED, CONTROLLED AND CORRECT MANNER IN THAT A DOCUMENTED ANALYSIS WAS NOT PERFORMED AND THE SUPPORTING CALCULATIONS WERE NOT IDENTIFIED. ADDITIONALLY, THE DESIGN CHANGE WAS NOT DOLUMENTED. (8800 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

PAGE 2-262

Report Period APR 1988

********************************** NORTH ANNA 1 × *******

OTHER ITEMS

+ RESIN IN SECONDARY PLANT.

FACILITY ITEMS (PLANS AND PROCEDURES)

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

+ COLD SHUTDOWN FOR RESIN CLEANUP.

LAST IE SITE INSPECTION DATE: MARCH 21-25, 1988 +

INSPECTION REPORT NO: 50-338/88-07 +

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-011	03/11/88	04/07/88	POST MODIFICATION TESTING NOT PERFORMED AS REQUIRED BY TWO TECHNICAL SPECIFICATIONS
88-012	03/15/88	04/08/88	LOSS OF RHR CAPABILITY DUE TO FAILED SOLENOID OPERATED VALVE
88-013	03/19/88	04/14/88	TURBINE TRIP/REACTOR TRIP - EHC SYSTEM MALFUNCTION
88-014	03/18/88	04/15/88	REACTOR TRIP DUE TO "C" S/G LEVEL SIGNAL
88-015	03/22/88	04/14/88	RHR PUMPS NOT TESTED DURING STEAM GENERATOR TUBE RUPTURE OUTAGE
88-017	02/16/88	04/14/88	FAILURE TO TEST CONTAINMENT PERSONNEL AIRLOCK EQUALIZING VALVES

1.	Docket: _50-339	OPERAT	INGS	TATUS	
2.	Reporting Period:	88 Outage	+ On-line	Hrs: 719.0	
5.	Utility Contact:B. GARN	ER (703) 89	4-5151 X252	27	
4.	Licensed Thermal Power (M	Wt):		2893	
5.	Nameplate Rating (Gross M		947		
6.	Design Electrical Rating		907		
7.	Maximum Dependable Capaci	1We):	e):963		
8.	Maximum Dependable Capaci):	915		
9.	If Changes Occur Above Sin NONE	nce Last Re	port, Give	Reasons:	
:2.	Power Level To Which Rest	ricted, If	Any (Net M	le):	
11.	Reasons for Restrictions,	If Any:			
	NONE				
12.	Report Period Hrs	MONTH 719.0	YEAR 2,9:3.0	CUMULATIVE 64,679.0	
3.	Hours Reactor Critical	719.0	2,853.9	51,314.7	
4.	Rx Reserve Shtdwn Hrs	.0	49.1	4,093.1	
5.	Hrs Generator On-Line	719.0	2,827.2	50,255.3	
6.	Unit Reserve Shtdwn Hrs	. 0	. 0		
7.	Gross Therm Ener (MWH)	2,079,069	8,141,634	132,464,388	
8.	Gross Elec Ener (MWH)	692,441	2,711,402	43,938,583	
9.	Net Elec Ener (MWH)	657,804	2,578,461	41,636,819	
20.	Unit Service Factor	100.0	97.4	77.7	
21.	Unit Avail Factor	100.0	97.4	77.7	
22.	Unit Cap Factor (MDC Net)	100.0	97.1	70.4	
23.	Unit Cap Factor (DER Net)	100.9	97.9	71.0	
24.	Unit Forced Outage Rate			8.7	
25.	Forced Outage Hours	.0		4,768.9	
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):	
26.	Shutdowns Sched Over Next NONE If Currently Shutdown Est	6 Months (imated Star	Type,Date,	Duration):	





NET MUE GENERATED

APRIL 1988

Report Period APR 1988

UNIT SHUTDOWNS / REDUCTIONS

No.	Date	Type Ho	urs Reason	Method	LER Number	System	Component	Cause &	Corrective	Action	to	Prevent	Recurrence	

NONE

Type	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE.....VIRGINIA

COUNTY.....LOUISA

DIST AND DIRECTION FROM NEAREST POPULATION CTR...40 MI NW OF RICHMOND, VA

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY...JUNE 12, 1980

DATE ELEC ENER 1ST GENER...AUGUST 25, 1980

DATE COMMERCIAL OPERATE.... DECEMBER 14, 1980

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LAKE ANNA

ELECTRIC RELIABILITY

COUNCIL.....SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

CORPORATE ADDRESS......P.O. BOX 26666 RICHMOND, VIRGINIA 23261

CONTRACTOR ARCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....STONE & WEBSTER

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....M. BRANCH

LICENSE & DATE ISSUANCE....NPF-7, AUGUST 21, 1980

PUBLIC DOCUMENT ROOM.....ALDERMAN LIBRARY/MANUSCRIPTS DEPT. UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MARCH 21-25 (88-07): THIS ROUTINE, UNANNOUNCED PHYSICAL SECURITY INSPECTION INVOLVED A REVIEW OF THE FOLLOWING AREAS: SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; TESTING AND MAINTENANCE; BARRIERS - VITAL AREAS; DETECTION AIDS - PROTECTED AND VITAL AREAS; ALARM STATIONS; AND CONTINGENCY PLAN RESPONSE. ONE VIGLATION AND ONE INSPECTOR FOLLOW-UP ITEM WERE IDENTIFIED. VIOLATION 88-07-01 INADEQUATE PROTECTED AREA ALARM ZONES IFI 88-07-0? MPER CIRCUITS TO BE REWIRED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ RESIN IN SECONDARY PLANT.

FACILITY ITEMS (PLANS AND PROCEDURES):

PAGE 2-266

Report Period APR 1988

**** × NORTH ANNA 2 *******************************

OTHER ITEMS

NONE.
MANAGERIAL ITEMS:
NONE.
PLANT STATUS:
+ COLD SHUTDOWN FOR RESIN CLEANUP.
LAST IE SITE INSPECTION DATE: MARCH 21-25, 1988 +
INSPECTION REPORT NO: 50-338/88-07 +
REPORTS FROM LICENSEE
NUMBER DATE OF DATE OF SUBJECT EVENT REPORT
NONE.

1.	Docket: _50-2690	PERAT	INGS	TATUS				
2.	Reporting Period: _04/01/8	8_ Outage	+ On-line	Hrs: 719.0				
3.	Utility Contact: J. A. RE	AVIS (704)	373-7567					
4.	Licensed Thermal Power (MM	Licensed Thermal Power (MWt):						
5.	Nameplate Rating (Gross M	1038 X	0.9 = 934					
6.	Design Electrical Rating (887					
7.	Maximum Dependable Capacit	ty (Gross M	We):	899				
8.	Maximum Dependable Capacit	ty (Net MWe):	846				
9.	If Changes Occur Above Sir	nce Last Re	port, Give	Reasons:				
	NONE							
0.	Power Level To Which Restr	icted, If	Any (Net M	le):				
	Reasons for Restrictions,	If Any:						
	NONE							
		MONTH	YEAR	CUMULATIVE				
12.	Report Period Hrs	719.0	2,903.0	129,672.0				
3.	Hours Reactor Critical	719.0	2,903.0	96,212.3				
4.	Rx Reserve Shtdwn Hrs	.0	0					
5.	Mrs Generator On-Line	719.0	2,903.0	92,600,4				
6.	Unit Reserve Shtdwn Hrs		0	0				
17.	Gross Therm Ener (MWH)	1,842,792	7,289,808	223,774,873				
8.	Gross Elec Ener (MWH)	635,724	2,521,302	77,628,959				
19.	Net Elec Ener (MWH)	608,515	2,411,285	73,622,390				
20.	Unit Service Factor	100.0	100.0	71.4				
21.	Unit Avail Factor	100.0	100.0	71.4				
22.	Unit Cap Factor (MDC Net)	100.0	98.2	65.9				
23.	Unit Cap Factor (DER Net)	95.4	93.6	64.19				
24.	Unit Forced Outage Rate			:3.5				
25.	Forced Outage Hours	.0	. 0	13,514.7				
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):				
	HUNL							

OCONEE 1





* Item calculated with a Weighted Average
| | | | ****************************** |
|--------|-----------------|-----------------------------|--------------------------------|
| Report | Period APR 1988 | UNIT SHUTDOWNS / REDUCTIONS | * OCONEE 1 * * |
| | | | |

No.	Date	IVPe	Hours	Reason	Method	LER Number	System	Component	Caus	se & Corr	rective	Action to	Prevent	Recurrence	-
6-P	04/15/88	F	0.0	В	5		нн	HTEXCH	LOSS OF VAC	CUUM DUE	TO WORK	ON HEATER	ORIFICE	E FLANGES.	

*********** * SUMMARY * HEATER OFFICE FLANGES.

Type	Reason	Method	System & Component			
F-Forced S-Sched	A-Eq ip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & Liconse Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Liconsee Event Report (LER) File (NUREG-0161)			

FACILITY DESCRIPTION

- LOCATION

COUNTY.....OCONEE

DIST AND DIRECTION FROM NEAREST POPULATION CTR...30 MI W OF GREENVILLE, SC

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... APRIL 19, 1973

DATE ELEC ENER 1ST GENER. .. MAY 6, 1973

DATE COMMERCIAL OPERATE....JULY 15, 1973

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LAKE KEOWEE

ELECTRIC RELIABILITY

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....DUKE POWER

CORPORATE ADDRESS..... .422 SOUTH CHURCH STREET CHARLOTTE, NORTH CAROLINA 28242

CONTRACTOR ARCHITECT/ENGINEER.....DUKE & BECHTEL

NUC STEAM SYS SUPPLIER ... BABCOCK & WILCOX

CONSTRUCTOR DUKE POWER

TURBINE SUPPLIER GENERAL ELECTRIC

REGULATORY INFORMATION

STATUS

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....J. BRYANT

LICENSE & DATE ISSUANCE.... DPR-38, FEBRUARY 6, 1973

PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY 501 W. SOUTH BROAD ST. WALHALLA, SOUTH CAROLINA 29691

INSPECTION SUMMARY

+ INSPECTION MARCH 21-25 (88-10): THIS UNANNOUNCED, ROUTINE, PHYSICAL SECURITY INSPECTION EXAMINED THE AREAS OF: SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; TESTING AND MAINTENANCE; LOCKS, KEYS AND COMBINATIONS; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; LIGHTING; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL, PACKAGES AND VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS; ALARM STATION; AND COMMUNICATIONS. ONE VIOLATION WAS IDENTIFIED INVOLVING TWO EXAMPLES OF FAILURE TO MAINTAIN THE VITAL AREA BARRIER INTEGRITY AND BULLET RESISTANCE. SECOND VIOLATION IDENTIFIED INVOLVED FAILURE TO COMPLY WITH PROTECTED AREA ACCESS REQUIREMENTS.

INSPECTION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

PAGE 2-270

Report Period APR 1988

*******	××	××	××	××	××	××	××	×	××	×	×	×	×	×	×
×	OCI	ON	EE	1											×
****	**	**	**	**	**	**	**	10	6.36	*	*	×	*	×	¥

HER_ITEMS
NONE.
FACILITY ITEMS (PLANS AND PROCEDURES):
NONE.
MANAGERIAL ITEMS:
NONE.
PLANT STATUS:
POWER OPERATION.
LAST IE SITE INSPECTION DATE: MARCH 21-25, 1988 +
INSPECTION REPORT NO: 50-269/88-10 +
REPORTS FROM LICENSEE
NUMBER DATE OF DATE OF SUBJECT EVENT REPORT
88-004 02/22/88 04/06/88 EMERGENCY POWER SWITCHING LOGIC RETRANSFER TO STARTUP LOGIC DEFEATED DUE TO DESIGN DEFICIENCY

arting Period: <u>04/01/8</u> ity Contact: <u>J. A. RE</u> msed Thermal Power (MW splate Rating (Gross MW gn Electrical Rating (mum Dependable Capacit mum Dependable Capacit changes Occur Above Sin the Level To Which Restr cons for Restrictions, art Period Hrs is Reactor Critical	8 Outage AVIS (704) Ht): Net MWe): Y (Gross M Y (Net MWe ce Last Re icted, If If Any: MONTH 719.0	+ On-line <u>373-7567</u> <u>1038 X</u> <u>1038 X</u> We): <u>)</u> : port, Give Any (Net Mk <u>YEAR</u> <u>2,903.0</u>	Hrs: 719.0 2568 0.9 = 934 837 899 846 Reasons: le): CUMULATIVE 119,592.0
ity Contact: <u>J. A. RE</u> msed Thermal Power (MW splate Rating (Gross MW gn Electrical Rating (mum Dependable Capacit mum Dependable Capacit changes Occur Above Sin r Level To Which Restr cons for Restrictions, ert Period Hrs s Reactor Critical	AVIS (704) (t): (e): Net MWe): y (Gross M y (Net MWe ce Last Re icted, If If Any: <u>MONTH</u> 719.0 578.0	373-7567 <u>1038 X</u> <u>1038 X</u> We): port, Give Any (Net Mb <u>YEAR</u> <u>2,903.0</u>	2568 0.9 = 934 857 899 846 Reasons: le): CUMULATIVE 119,592.0
ensed Thermal Power (MW eplate Rating (Gross MW gn Electrical Rating (mum Dependable Capacit mum Dependable Capacit changes Occur Above Sin er Level To Which Restr cons for Restrictions, ert Period Hrs is Reactor Critical	t): Net MWe): y (Gross M y (Net MWe ce Last Re icted, If If Any: MONTH 	<u>1038 X</u> We):): port, Give Any (Net Mk YEAR 903.0	2568 0.9 = 934 837 899 846 Reasons: le): CUMULATIVE 119,592.0
plate Rating (Gross MW gn Electrical Rating (mum Dependable Capacit mum Dependable Capacit changes Occur Above Sin r Level To Which Restr cons for Restrictions, ert Period Hrs s Reactor Critical	We): Net MWe): y (Gross M y (Net MWe ce Last Re icted, If If Any: MONTH 	<u>1038 X</u> We):): port, Give Any (Net Mk YEAR 903.0	0.9 = 934 899 846 Reasons: le): CUMULATIVE 119,592.0
gn Electrical Rating (mum Dependable Capacit mum Dependable Capacit changes Occur Above Sin r Level To Which Restr cons for Restrictions, ert Period Hrs s Reactor Critical	Net MWe): y (Gross M y (Net MWe ce Last Re icted, If If Any: MONTH 	We): port, Give Any (Net Mk YEAR 2,903.0	8.07 899 846 Reasons: Ne): CUMULATIVE 119,592.0
mum Dependable Capacit mum Dependable Capacit changes Occur Above Sin or Level To Which Restr cons for Restrictions, ort Period Hrs s Reactor Critical	y (Gross M y (Net MWe ce Last Re icted, If If Any: MONTH 	We): port, Give Any (Net Mk YEAR 2,903.0	899 846 Reasons: le): CUMULATIVE 119,592.0
mum Dependable Capacit Changes Occur Above Sin or Level To Which Restr cons for Restrictions, ort Period Hrs rs Reactor Critical	y (Net MWe ce Last Re icted, If If Any: MONTH): port, Give Any (Net MM YEAR 	846 Reasons: le): CUMULATIVE
Changes Occur Above Sin Fr Level To Which Restr Sons for Restrictions, Frt Period Hrs	ce Last Re icted, If If Any: MONTH 	port, Give Any (Net Mk YEAR 2,903.0	Reasons: le): CUMULATIVE
er Level To Which Restr cons for Restrictions, construction for Restrictions, construction for the state of t	icted, If If Any: MONTH 719.0	Any (Net Mk YEAR 2,903.0	CUMULATIVE 119,592.0
ons for Restrictions, ort Period Hrs s Reactor Critical	If Any: MONTH 	YEAR 2,903.0	CUMULATIVE 119,592.0
ert Period Hrs s Reactor Critical	MONTH 719.0	YEAR 2,903.0	CUMULATIVE
ort Period Hrs s Reactor Critical	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 119,592.0
s Reactor Critical	E79 0		
	230.7	1,336.3	90,033.0
leserve Shtdwn Hrs	. 0		,0
Generator On-Line	441.1	1,237.2	88,530.6
Reserve Shtdwn Hrs	.0		. 0
s Therm Ener (MWH)	982,416	2,719,224	210,359,325
s Elec Ener (MWH)	325,095	905,785	71,588,466
Elec Ener (MWH)	302,503	848,815	68,046,133
Service Factor	61.3	42.6	74.0
Avail Factor	61.3	42.6	74.0
Cap Factor (MDC Net)	49.7	34.6	66.0
Cap Factor (DER Net)	47.4	33.0	64.2
Forced Outage Rate	12.3	4.8	11.8
ad Autaca House	62.1	62.1	11,025.1
ed uurage nours	(Mantha (Type, Date.	Duration):
	Cap Factor (MDC Net) Cap Factor (DER Net) Forced Outage Rate ed Outage Hours	Cap Factor (MDC Net) Cap Factor (DER Net) Forced Dutage Rate ed Dutage Hours Cause Sched Over Next 6 Months (Cap Factor (MDC Net) 49.7 34.6 Cap Factor (BER Net) 47.4 33.0 Forced Outage Rate 12.3 4.8 ced Outage Hours 62.1 62.1 cdowns Sched Over Next 6 Months (Type, Date, I





* Item calculated with a Weighted Average

Report	Period A	PR 19	88		UN	IT SH	утром	NS / R	E D L C T I O N S *********************************
No.	Date	Туре	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/03/88	s	215.8	С	4		RC	FUELXX	END OF CYCLE 9 REFUELING OUTAGE.
2	04/11/88	F	62.1	в	1		НА	MECFUN	TURBINE GENERATOP ALTREX COUPLING LEAK REPAIR.
10-P	04/16/88	F	0.0	А	5		HJ	PUMPXX	PROBLEM WITH STARTING 'E' HEATER DRAIN PUMP.
11-P	04/18/88	F	0.0	А	5		НА	TURBIN	TURBINE GENERATOR STATOR COOLANT RUNBACK.
12-P	04/18/88	F	0.0	В	5		НА	INSTRU	REPAIR TURBINE GENERATOR STATOR COOLER INSTRUMENTATION.
13-P	04/25/88	F	0.0	в	5		HD	VALVEX	REPAIR EXTRACTION STEAM VALVE CONTROLLER.
14-P	04/25/88	F	0.0	A	5		HB	HTEXCH	SOLATED '2A2' FEEDWATER HEATER DUE TO TUBE LEAKS.

********OCONEE 2 COMPLETED SCHEDULED REFUELING OUTAGE IN APRIL.* SUMMARY *SUBSEQUENTLY RETURNED TO POWER AND INCURRED 1 POWER************OUTAGE AND SEVERAL POWER REDUCTIONS.

Type	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res	F-Admin G-Oper Error H-Other triction	1-Manual 2-Manual Scram 3-Auto Scram 4-Contirued	Exhibit F & H Instructions for Preparation of Data Entry Sheet
	E-Operator Train & License Exa	ing mination	5-Reduced Load 9-Other	Licensee Event Report (LER) File (NUREG-0161

FACILITY DESCRIPTION

LOCATION

STATE.....SOUTH CAROLINA

COUNTY......OCONEE

DIST AND DIRECTION FROM NEAREST POPULATION CTR...30 MI W OF GREENVILLE, SC

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...NOVEMBER 1: 1973

DATE ELEC ENER 1ST GENER...DECEMBER 5, 1973

DATE COMMERCIAL OPERATE....SEPTEMBER 9, 1974

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....LAKE KEOWEE

ELECTRIC RELIABILITY

COUNCIL.....SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....DUKE POWER

CONTRACTOR

ARCHITECT/ENGINEER..... DUKE & BECHTEL

NUC STEAM SYS SUPPLIER... BABCOCK & WILCOX

CONSTRUCTOR.....DUKE POWER

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....J. BRYANT

LICENSING PROJ MANAGER.....H. PASTIS DOCKET NUMBER......50-270

LICENSE & DATE ISSUANCE.... DPR-47, OCTOBER 6, 1973

PUBLIC DOCUMENT ROOM.....OCDNEE COUNTY LIBRARY 501 W. SOUTH BROAD ST. WALHALLA, SOUTH CAROLINA 29691

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MARCH 21-25 (88-10): THIS UNANNOUNCED, ROUTINE, PHYSICAL SECURITY INSPECTION EXAMINED THE AREAS OF: SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; TESTING AND MAINTENANCE; LOCKS, KEYS AND COMBINATIONS; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; LIGHTING; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL, PACKAGES AND VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS; ALARM STATION; AND COMMUNICATIONS. ONE VIOLATION WAS IDENTIFIED INVOLVING TWO EXAMPLES OF FAILURE TO MAINTAIN THE VITAL AREA BARRIER INTEGRITY AND BULLET RESISTANCE. SECOND VIOLATION IDENTIFIED INVOLVED FAILURE TO COMPLY WITH PROTECTED AREA ACCESS REQUIREMENTS.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

PAGE 2-274

Report Period APR 1988

0	ITHER ITEMS
	NONE.
	FACILITY ITEMS (PLANS AND PROCEDURES):
	NONE .
	MANAGERIAL ITEMS:
	NONE.
	PLANT STATUS:
	POWER OPERATION.
	LAST IE SITE INSPECTION DATE: MARCH 21-25, 1988 +
	INSPECTION REPORT NO: 50-270/88-10 +
	REPORTS FROM LICENSEE
	NUMBER DATE OF DATE OF SUBJECT EVENT REPORT
	NONE

1.	Docket: 50-287 0	PERAT	TING S	TATUS		
2.	Reporting Period: 04/01/8	8 Outage	+ On-line	Hrs: 719.0		
3.	Utility Contact:A. RE	AVIS (704)	373-7567			
4.	Licensed Thermal Power (MM	it):		2568		
5.	Nameplate Rating (Gross Mk	le):	1038 X	0.9 = 934		
6.	Design Electrical Rating (Net MNe):		887		
7	Maximum Dependable Capacit	1We) 1	899			
8.	Maximum Dependable Capacit	y Net MWa		846		
9.	If Changes Occur Above Sin NONE	ce Last Re	eport, Give	Reasons:		
10.	Power Level To Which Restr	icted, If	Any (Net M	He):		
11.	Reasons for Restrictions,	If Any:				
_	NONE					
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE		
13.	Hours Reactor Critical	410.0	2,594.0	85,943.1		
14.	Rx Reserve Shtdwn Hrs					
15.	Hrs Generator On-Line	409.8	2,593.8	84,579.7		
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	. 9		
17.	Gross Therm Ener (MWH)	934,968	6,480,000	207, 379, 461		
18.	Gross Elec Ener (MWH)	324,190	2,245,451	71,455,996		
19.	Net Elac Ener (MWH)	308,183	2,151,389	68, 380, 019		
20.	Unit Service Factor	57.0	89.3	72.1		
21.	Unit Avail Factor	57.0	89.3	72.1		
22.	Unit Car Factor (MDC Net)	50.7	87.6	67.4		
23.	Unit Cap Factor (DER Net)	48.3	83.6	65.5		
24.	Unit Forced Outage Rate	43.0	10.7	13.1		
25.	Forced Outage Hours	309.2	309.2	12,934.5		
26.	Shutdowns Sched Over Next	6 Months (Type, Date,	Curation):		
27	If Currently Shutdaw Est	mated St	tun Data	35,00,00		
Acres 14	IT CONTRACTLY SHULDOWN ESTI	mated star	LUD DATE.	07/07/68		



OCONEE 3





* Item calculated with a Weighted Average

Report	Period A	PR 19	88		UN	хт зни	TDOW	NS / R	EDUCTIONS * OCONEE 3 * ********************************
No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5-P	04/02/88	5	0.0	F	5		ZZ	ZZZZZZ	CORE CONSERVATION PER DISPATCHER'S REQUEST.
6-P	04/17/88	F	0.0	А	5		СЯ	HTEXCH	POWER REDUCTION DUE TO STEAM GENERATOR TUBE LEAK.
	04/18/88	F	309.2	в	1		CH	HTEXCH	STEAM GENERATOR TUBE LEAK OUTAGE.

********** OCONEE 3 INCURRED 2 POWER REDUCTIONS AND 1 FORCED DUTAGE IN * SUMMARY * APRIL FOR REASONS STATED ABOVE.

Туре	Reason	Method	System & Component			
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Uther D-Regulatory Restriction E-Operator Training & License Examination	>-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER; File (NUREG-0161)			

FACILITY DESCRIPTION

LOCATION

STATE..... SOUTH CAROLINA

COUNTY.....OCONEE

DIST AND DIRECTION FROM NEAREST POPULATION CTR...30 MI W OF GREENVILLE, SC

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY...SEFTEMBER 5, 19/4

DATE ELEC ENER 1ST GENER...SEPTEMBER 18, 1974

DATE COMMERCIAL OPERATE DECEMBER 16, 1974

CONDENSER COOLING METHOD ... ONCE THRU

CONDENSER COOLING WATER....LAKE KEOWEE

ELECTRIC RELIABILITY

COUNCIL.....SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....DUKE POWER

CORPORATE ADDRESS......422 SOUTH CHURCH STREET CHARLOTTE, NORTH CAROLINA 28242

CONTRACTOR

ARCHITECT/ENGINEER..... DUKE & BECHTEL

NUC STEAM SYS SUPPLIER... BABCOCK & WILCOX

CONSTRUCTOR......DUKE POWER

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....J. BRYANT

LICENSE & DATE ISSUANCE.... DPR-55, JULY 19, 1974

PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY 501 W. SOUTH BROAD ST. WALHALLA, SOUTH CAROLINA 29691

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MARCH 21-25 (88-10): THIS UNANNOUNCED, ROUTINE, PHYSICAL SECURITY INSPECTION EXAMINED THE AREAS OF: SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; TESTING AND MAINTENANCE; LOCKS, KEYS AND COMBINATIONS; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS, SECURITY SYSTEM POWER SUPPLY; LIGHTING; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL, PACKAGES AND VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS; ALARM STATION; AND COMMUNICATIONS. ONE VIOLATION WAS IDENTIFIED INVOLVING THO EXAMPLES OF FAILURE TO MAINTAIN THE VITAL AREA BARRIER INTEGRITY AND BULLET RESISTANCE. SECOND VIOLATION IDENTIFIED INVOLVED FAILURE TO COMPLY WITH PROTECTED AREA ACCESS REQUIREMENTS.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

PAGE 2-278

Report Period APR 1988

OTHER ITEMS

*****	*****	****	****	*****	*****
×		000	NEE 3		*
*****	*****	****	*****	*****	****

Y TING ALL BLOCK	
NONE.	
FACILITY ITEMS (PLANS AND PROCEDURES):	
NGNE.	
MANAGERIAL ITEMS:	
NONE.	
PLANT STATUS:	
POWER OPERATION.	
LAST IE SITE INSPECTION DATE: MARCH 21-25,	1988 +
INSPECTION REPORT NO: 50-287/88-10 +	
	REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT					
				ter ne en en en ter	n ann ann ann ann ann ann ann ann ann a	 		
NONE.								

2. Roporting Peri ·: 04/01/88 Outage + On-line Hrs: 719.0 3. Otility Contact: JOHN H. SEDAR J., (609) 971-4698 4. Licensed Thermal Power (MHt): 1930 5. Nameplate Rating (Gross MMe): 687.5 X .98 = 674 4. Design Electrical Rating (Net MMe): 650 7. Maximum Dependable Capacity (Gross MMe): 642 8. Maximum Dependable Capacity (Net MMe): 620 9. If Changes Occur Above Since Last Report, Give Reasons: MDC GROSS CHANGED TO REFLECT SUMMER GENEXATION. 10. Power Level To Which Restricted, If Any (Net MMe): 11. 11. Reasons for Restrictions, If Any: Net MMe): 10. 12. Report Period Hrs 719.0 2.903.0 160.895.0 13. Hours Reactor Critical 719.0 2.903.0 104.054.5 14. Rx Reserve Shtdwn Hrs 0 0 1.761.4 17. Gross Therm Ener (MMH) 1.356.000 5.516.000 168.280.408 18. Gross Elec Ener (MMH) 4647.695 1.831.844 54.554.732 20. Unit Service Factor 100.0 63.7 21. Unit Avail Factor 100.9 100.0 63.7 22. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate 0 0 14.666.5 <td< th=""><th>1.</th><th>Docket: _50-219</th><th>OPERAT</th><th>ING S</th><th>TATUS</th></td<>	1.	Docket: _50-219	OPERAT	ING S	TATUS
3. Utility Contact: JOHN H. SEDAR Jr. (609) 971-4698 4. Licensed Thermal Power (MWt): 1930 5. Nameplate Rating (Gross MWe): 687.5 X .98 = 674 7. Design Electrical Rating (Net MWe): 650 7. Maximum Dependable Capacity (Gross MWe): 642 8. Maximum Dependable Capacity (Net MWe): 620 9. If Changes Occur Above Since Last Report, Give Reasons: MDC GROSS CHANGED TO REFLECT SUMMER GENERATION. 10. Power Level To Which Restricted, If Any (Net MWe): 11. 11. Reasons for Restrictions, If Any: NONE 12. Report Period Hrs 719.0 2.903.0 104.054.5 13. Hours Reactor Critical 719.0 2.903.0 104.054.5 14. Rx Reserve Shtdwn Hrs .0 .0 1.208.0 15. Hrs Generator On-Line 719.0 2.903.0 100.694.9 16. Unit Reserve Shtdwn Hrs .0 .0 1.761.4 17. Gross Therm Ener (MWH) 1.356.000 5.516.000 168.280.408 18. Gross Elec Ener (MWH) 464.380 1.899.770 56.818.124 19. Net Flec Ener (MWH) 464.360 1.899.770 56.818.124 19. Net Flec Ener (MWH) 464.360	2.	Reporting Peri 1 04/01/	88 Outage	+ On-line	Hrs: 719.0
4. Licensed Thermal Power (MWt): 1930 5. Nameplate Rating (Gross MWe): 687.5 X .98 = 674 7. Design Electrical Rating (Net MWe): 650 7. Maximum Dependable Capacity (Gross MWe): 642 8. Maximum Dependable Capacity (Net MWe): 620 9. If Changes Occur Above Since Last Report, Give Reasons: MDC GROSS CHANGED TO REFLECT SUMMER GENEXATION. 10. Power Level To Which Restricted, If Any (Net MWe): 11. 11. Reasons for Restrictions, If Any: 100. 12. Report Period Hrs 719.0 2.903.0 13. Hours Reactor Critical 719.0 2.903.0 100.6595.0 14. Rx Reserve Shtdwn Hrs 0 0 1.208.0 15. Hrs Generator On-Line 719.0 2.903.0 100.694.9 16. Unit Reserve Shtdwn Hrs 0 0 1.761.4 17. Gross Therm Ener (MWH) 1.356.000 5.516.000 168.280.408 18. Gross Elec Ener (MWH) 447.695 1.831.844 54.554.732 20. Unit Service Factor 100.0 100.0 63.7 21. Unit Avail Factor 100.0 100.0 63.7 22. Unit Cap Factor (DER Net) 95.8 97.1 <	3.	Utility Contact: JOHN H.	SEDAR JA.	(609) 971-	4698
5. Nameplate Rating (Gross MWe): 687.5 X .98 = 674 7. Design Electrical Rating (Net MWe): 650 7. Maximum Dependable Capacity (Gross MWe): 642 8. Maximum Dependable Capacity (Net MWe): 623 9. If Changes Occur Above Since Last Report, Give Reasons: MDC GROSS CHANGED TO REFLECT SUMMER GENERATION. 10. Power Level To Which Restricted, If Any (Net MWe): 11. 11. Reasons for Restrictions, If Any: 11. NONE 719.0 2.903.0 160.895.0 13. Hours Reactor Critical 719.0 2.903.0 104.054.5 14. Rx Reserve Shtdwn Hrs .0 .0 1.208.0 15. Hrs Generator On-Line 719.0 2.903.0 100.694.9 16. Unit Reserve Shtdwn Hrs .0 .0 1.761.4 17. Gross Therm Ener (MWH) 1.356.000 5.516.000 168.280.408 18. Gross Elec Ener (MWH) 447.695 1.831.844 54.554.732 20. Unit Service Factor 100.0 100.0 63.7 21. Unit Avail Factor 100.0 100.0 63.7 22. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate	4.	Licensed Thermal Power (M	Wt):		1930
Design Electrical Rating (Net MWe): 650 7. Maximum Dependable Capacity (Gross MWe): 642 8. Maximum Dependable Capacity (Net MWe): 622 9. If Changes Occur Above Since Last Report, Give Reasons: MDC GROSS CHANGED TO REFLECT SUMMER GENERATION. 10. Power Level To Which Restricted, If Any (Net MWe):	5.	Nameplate Rating (Gross M	We):	687.5	x .98 = 674
7. Maximum Dependable Capacity (Gross MWe): 642 8. Maximum Dependable Capacity (Net MWe): 620 9. If Changes Occur Above Since Last Report, Give Reasons: MDC GROSS CHANGED TO REFLECT SUMMER GENERATION. 10. Power Level To Which Restricted, If Any (Net MWe): 11. Reasons for Restrictions, If Any: NONE 12. Report Period Hrs 719.0 2.903.0 104,059.0 13. Hours Reactor Critical 719.0 2.903.0 104,059.5 14. Rx Reserve Shtdwn Hrs .0 .0 1.208.0 15. Hrs Generator On-Line 719.0 2.903.0 100,694.9 16. Unit Reserve Shtdwn Hrs .0 .0 1.761.4 17. Gross Therm Ener (MNH) 1.356,000 18. Gross Ele: Ener (MNH) 464,380 1.899,770 19. Net Flec Ener (MNH) 447,695 1.831,844 20. U	×	Design Electrical Rating	(Net Mike):		650
8. Maximum Dependable Capacity (Net MNe): 620 9. If Changes Occur Above Since Last Report, Give Reasons: MDC GROSS CHANGED TO REFLECT SUMMER GENERATION. 10. Power Level To Which Restricted, If Any (Net MNe): 11. Reasons for Restrictions, If Any: NONE 12. Report Period Hrs 13. Hours Reactor Critical 719.0 2,903.0 14. Rx Reserve Shtdwn Hrs 0 .0 15. Hrs Generator On-Line 719.0 2,903.0 100,694.9 16. Unit Reserve Shtdwn Hrs .0 .0 1,761.4 17. Gross Therm Ener (MNH) 1,356,000 18. Gross Ele: Ener (MNH) 464,380 1,899,770 19. Net Flec Ener (MNH) 464,695 1,831,844 19. Net Flec Ener (MNH) 464,695 1,831,844 20. Unit Service Factor 100.0 63.7 21. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate .0 .0 14,0466.5 25. Forced Outage Hours .0 .0 14,0466.5 26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): REFUELING - 10/1	7.	Maximum Dependable Capaci	ty (Gross M	file):	642
9. If Changes Occur Above Since Last Report, Give Reasons: MDC GROSS CHANGED TO REFLECT SUMMER GENERATION. 10. Power Level To Which Restricted, If Any (Net MWe): 11. Reasons for Restrictions, If Any: NONE 12. Report Period Hrs MC:4TH YEAR CUMULATIVE 719.0 2.903.0 160.895.0 160.895.0 160.895.0 160.895.0 160.895.0 160.895.0 100.054.5 13. Hours Reactor Critical 719.0 2.903.0 104.054.5 14. Rx Reserve Shtdwn Hrs .0 .0 1.208.0 100.694.9 15. Hrs Generator On-Line 719.0 2.903.0 100.694.9 16. Unit Reserve Shtdwn Hrs .0 .0 1.761.4 17. Gross Therm Ener (MWH) 1.356.000 5.516.000 168.280.408 18. Gross Elec Ener (MWH) 464.380 1.899.770 56.818.124 19. Net Flee Ener (MWH) 447.695 1.831.844 54.554.732 20. Unit Service Factor 100.0 100.0 63.7 21. Unit Avail Factor 100.9 100.0 63.7 22. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate .0 .0 14.946.5 25. Forced Outage Hours .0 .0 14.946.5 26. Shutdowns Sched Over Next 6 Months (Type, Date, Buration): REFUELING - 10/1/8E - 90 DAY DURATION.	8.	Maximum Dependable Capaci	ty (Net MWe):	620
MDC GROSS CHANGED TO REFLECT SUMMER GENERATION. 10. Power Level To Which Restricted, If Any (Net MWe): 11. Reasons for Restrictions, If Any: NONE 12. Report Period Hrs 13. Hours Reactor Critical 719.0 2,903.0 10. 2,903.0 10. 40,54.5 14. Rx Reserve Shtdwn Hrs 0 .0 15. Hrs Generator On-Line 719.0 2,903.0 10. 10,494.9 16. Unit Reserve Shtdwn Hrs 0 .0 17.203.0 100,494.9 16. Unit Reserve Shtdwn Hrs .0 17. Gross Therm Ener (MWH) 1,356,000 18. Gross Elec Ener (MWH) 1,356,000 19. Net Flec Ener (MWH) .447,695 19. Net Flec Ener (MWH) .447,695 10.1 Service Factor 100.0 .0 22.0 Unit Avail Factor 100.0 .00.0 23. Unit Cap Factor (DER Net) .0 24. Unit Forced Outage Rate .0 .0 .0 25. Forced Outage	9.	If Changes Occur Above Si	nce Last Re	port, Give	Reasons:
10. Power Level To Which Restricted, If Any (Net MWe): 11. Reasons for Restrictions, If Any: NONE 12. Report Period Hrs MC4TH 719.0 YEAR 2.903.0 CUMULATIVE 160,895.0 13. Hours Reactor Critical 719.0 2,903.0 104,054.5 14. Rx Reserve Shtdwn Hrs .0 .0 1,208.0 15. Hrs Generator On-Line 719.0 2,903.0 100,694.9 16. Unit Reserve Shtdwn Hrs .0 .0 1,761.4 17. Gross Therm Ener (MWH) 1,356,000 5,516,000 168,280,408 18. Gross Elec Ener (MWH) 464,380 1,899,770 56,818,124 19. Net Flec Ener (MWH) 447,695 1,831,844 54,554,732 20. Unit Service Factor 100.0 100.0 63.7 22. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate .0 .0 14,046.5 25. Forced Outage Hours .0 .0 14,646.5 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): REFUELING - 10/1/88 - 90 DAY DURATION.		MDC GROSS CHANGED TO REFL	ECT SUMMER	GENERATION	
11. Reasons for Restrictions, If Any: NONE 12. Report Period Hrs MCHTH 719.0 YEAR 2.903.0 CUMULATIVE 160.895.0 13. Hours Reactor Critical 719.0 2.903.0 104,054.5 14. Rx Reserve Shtdwn Hrs 0 0 1.208.0 15. Hrs Generator On-Line 719.0 2.903.0 100,694.9 16. Unit Reserve Shtdwn Hrs 0 0 1,761.4 17. Gross Therm Ener (MWH) 1,356,000 5,516,000 168,280,408 18. Gross Elec Ener (MWH) 464,380 1,899,770 56,818,124 19. Net Flec Ener (MWH) 464,695 1,831,844 54,554,732 20. Unit Service Factor 100.0 100.0 62,6 21. Unit Avail Factor 100.4 191.8 54.7 22. Unit Cap Factor (DER Net) 95.8 97.1 52.2 23. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate .0 .0 14,646.5 25. Forced Outage Nours .0 .0 14,646.5 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): REFUELING - 10/1/88 - 90 DAY DURATION.	10.	Power Level To Which Rest	ricted, If	Any (Net M	Ne):
NONE 12. Report Period Hrs MC4TH YEAR CUMULATIVE 13. Hours Reactor Critical 719.0 2,903.0 160,895.0 13. Hours Reactor Critical 719.0 2,903.0 104,054.5 14. Rx Reserve Shtdwn Hrs .0 .0 1,208.0 15. Hrs Generator On-Line 719.0 2,903.0 100,694.9 16. Unit Reserve Shtdwn Hrs .0 .0 1,761.4 17. Gross Therm Ener (MWH) 1,356,000 5,516,000 168,280,408 18. Gross Elec Ener (MNH) 464,380 1,899,770 56,818,124 19. Net Elec Ener (MNH) 4647,695 1,831,844 54,554,732 20. Unit Service Factor 100.0 100.0 63.7 21. Unit Avail Factor 100.4 101.8 54.7 23. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate .0 .0 14,496.5 25. Forced Outage Nours .0 .0 14,646.5 26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): REFUELING - 10/1/88 - 90 DAY DURA	11.	Reasons for Restrictions,	If Any:		
M0:4TH YEAR CUMULATIVE 12. Report Period Hrs 719.0 2,903.0 160,895.0 13. Hours Reactor Critical 719.0 2,903.0 104,054.5 14. Rx Reserve Shtdwn Hrs 0 0 1,208.0 15. Hrs Generator On-Line 719.0 2,903.0 100,694.9 16. Unit Reserve Shtdwn Hrs 0 0 1,761.4 17. Gross Therm Ener (MWH) 1,356,000 5,516,000 168,280,408 18. Gross Elec Ener (MWH) 447,695 1,831,844 54,554,732 20. Unit Service Factor 100.0 100.0 62.6 21. Unit Avail Factor 100.0 100.0 63.7 22. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate .0 .0 14.0 25. Forced Outage Hours .0 .0 14,646.5 26. Shutdowns Sched Over Next 6 Months (Type, Date, Buration): REFUELING - 10/1/88 - 90 DAY DURATION.	-	NONE			
13. Hours Reactor Critical 719.0 2,903.0 104,054.5 14. Rx Reserve Shtdwn Hrs 0 0 1,208.0 15. Hrs Generator On-Line 719.0 2,903.0 100,694.9 16. Unit Reserve Shtdwn Hrs 0 0 1,761.4 17. Gross Therm Ener (MWH) 1,356,000 5,516,000 168,280,408 18. Gross Elec Ener (MWH) 464,380 1,899,770 56,818,124 19. Net Flec Ener (MWH) 447,695 1,831,844 54,554,732 20. Unit Service Factor 100.0 100.0 62.6 21. Unit Avail Factor 100.4 101.8 54.7 22. Unit Cap Factor (MOC Net) 100.4 101.8 54.7 23. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate 0 0 14.0 25. Forced Outage Hours 0 0 14.0466.5 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): REFUELING - 10/1/88 - 90 DAY DURATION.	12.	Report Period Hrs	MCHTH 719.0	YEAR 2,903.0	CUMULATIVE 160,895.0
14. Rx Reserve Shtdwn Hrs .0 .0 1,208.0 15. Hrs Generator On-Line 719.0 2,903.0 100,694.9 16. Unit Reserve Shtdwn Hrs .0 .0 1,*61.4 17. Gross Therm Ener (MWH) 1,356,000 5,516,000 168,280,408 18. Gross Elec Ener (MWH) .356,000 5,516,000 168,280,408 18. Gross Elec Ener (MWH) .464,380 1,899,770 56,818,124 19. Net Elec Ener (MWH) .467,695 1,831,844 54,554,732 20. Unit Service Factor .00 .00 .62.6 21. Unit Avail Factor .00.0 .00 .63.7 22. Unit Cap Factor (MOC Net) .100.4 .101.8 .54.7 23. Unit Cap Factor (DER Net) .95.8 .97.1 .52.2 24. Unit Forced Outage Rate .0 .0 .14.0 25. Forced Outage Hours .0 .0 .14,646.5 26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): REFUELING - 10/1/88 - 90 DAY DURATION.	13.	Hours Reactor Critical	719.0	2,903.0	104,054.5
15. Hrs Generator On-Line 719.0 2,903.0 100,694.9 16. Unit Raserve Shtdwn Hrs .0 .0 1,761.4 17. Gross Therm Ener (MWH) 1,356,000 5,516,000 168,280,408 18. Gross Eler Ener (MWH) .464,380 1,899,770 56,818,124 19. Net Elec Ener (MWH) .447,695 1,831,844 54,554,732 20. Unit Service Factor .00 .00 .62.6 21. Unit Avail Factor .100.0 .00 .63.7 22. Unit Cap Factor (MOC Net) .100.4 .101.8 .54.7 23. Unit Cap Factor (DER Net) .95.8 .97.1 .52.2 24. Unit Forced Outage Rate .0 .0 .14.0 25. Forced Outage Nours .0 .0 .14,646.5 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): REFUELING - 10/1/88 - 90 DAY DURATION.	14.	Rx Reserve Shtdwn Hrs	0	.0	1,208.0
16. Unit Raserve Shtdwn Hrs .0 .0 1,761.4 17. Gross Therm Ener (MWH) 1,356,000 5,516,000 168,280,408 18. Gross Elec Ener (MWH) .464,380 1,899,770 56,818,124 19. Net Elec Ener (MWH) .447,695 1,831,844 54,554,732 20. Unit Service Factor .00 .00 .62.6 21. Unit Avail Factor .00 .00 .63.7 22. Unit Cap Factor (MDC Net) .00 .00 .63.7 23. Unit Cap Factor (DER Net) .95.8 .97.1 .52.2 24. Unit Forced Outage Rate .0 .0 .14.0 25. Forced Outage Nours .0 .0 .14,646.5 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): REFUELING - 10/1/88 - 90 DAY DURATION.	15.	Hrs Generator On-Line	719.0	2,903.0	100,694.9
17. Gross Therm Ener (MWH) 1,356,000 5,516,000 168,280,408 18. Gross Elec Ener (MWH) 464,380 1,899,770 56,818,124 19. Net Elec Ener (MWH) 447,695 1,831,844 54,554,732 20. Unit Service Factor 109.0 100.0 62.6 21. Unit Avail Factor 100.0 100.0 63.7 22. Unit Cap Factor (MOC Net) 100.4 191.8 54.79 23. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate .0 .0 14.0 25. Forced Outage Nours .0 .0 14,646.5 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): REFUELING - 10/1/88 - 90 DAY DURATION.	16.	Unit Raserve Shtdwn Hrs			1, 161.4
18. Gross Elec Ener (MNH) 464,380 1,899,770 56,818,124 19. Net Elec Ener (MNH) 447,695 1,831,844 54,554,732 20. Unit Service Factor 100.0 100.0 62.6 21. Unit Avail Factor 100.0 100.0 63.7 22. Unit Cap Factor (MOC Net) 100.4 101.8 54.7 23. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate .0 .0 14.0 25. Forced Outage Nours .0 .0 14,646.5 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): REFUELING - 10/1/88 - 90 DAY DURATION.	17.	Gross Therm Ener (MWH)	1,356,000	5,516,000	168,280,408
19. Net Elec Ener (MWH) 447,695 1,831,844 54,554,732 20. Unit Service Factor 100.0 62.6 21. Unit Avail Factor 100.0 62.7 22. Unit Cap Factor (MOC Net) 100.4 101.8 54.7 23. Unit Cap Factor (MOC Net) 100.4 101.8 54.7 23. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate .0 .0 14.0 25. Forced Outage Nours .0 .0 14,646.5 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): REFUELING - 10/1/88 - 90 DAY DURATION.	18.	Gross Elec Ener (MNH)	464,380	1,899,770	56,818,124
20. Unit Service Factor 100.0 62.6 21. Unit Avail Factor 100.0 63.7 22. Unit Cap Factor (MOC Net) 100.4 101.8 54.7 23. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate .0 .0 14.0 25. Forced Outage Hours .0 .0 14,646.5 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): REFUELING - 10/1/88 - 90 DAY DURATION.	19.	Net Flec Ener (MWH)	447,695	1,831,844	54, 554, 732
21. Unit Avail Factor 100.0 63.7 22. Unit Cap Factor (MOC Net) 100.4 101.8 54.7 23. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate .0 .0 14.0 25. Forced Outage Nours .0 .0 14,666.5 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): REFUELING - 10/1/88 - 90 DAY DURATION.	20.	Unit Service Factor	100.0	100.0	62.6
22. Unit Cap Factor (MDC Net) 100.4 101.8 54.7 23. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate .0 .0 14.0 25. Forced Outage Hours .0 .0 14.646.5 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): REFUELING - 10/1/88 - 90 DAY DURATION.	21.	Unit Avail Factor	100.0	100.0	63.7
23. Unit Cap Factor (DER Net) 95.8 97.1 52.2 24. Unit Forced Outage Rate .0 .0 14.0 25. Forced Outage Hours .0 .0 14,646.5 26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): REFUELING - 10/1/88 - 90 DAY DURATION.	22.	Unit Cap Factor (MDC Net)	100.4	101.8	54.7*
24. Unit Forced Outage Rate .0 .0 14.0 25. Forced Outage Nours .0 .0 14,646.5 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): REFUELING - 10/1/88 - 90 DAY DURATION.	23.	Unit Cap Factor (DER Net)	95.8	97.1	52.2
25. Forced Outage Hours	24.	Unit Forced Outage Rate			14.0
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): REFUELING - 10/1/88 - 90 DAY DURATION.	25.	Forced Outage Hours	.0	0	14,446.5
KEFUELING - 10/1/88 - 90 DAY DURATION.	26.	Shutdowns Sched Over Next	6 Months (Type,Date,I	Duration):
		REFUELING - 10/1/88 - 90	DAY DURATIO	N .	





* Item calculated with a Weighted Average

				关关关关关关关关关关关关关关关关关关关关关关关关关关关关关关
Report Period APR 1988	UNIT	SHUTDOWNS	<pre>/ REDUCTIONS</pre>	* OYSTER CREEK 1 * * ******************************

No.	Date	Type Hours	Reason Metho	d LER Number	System Component	Cause &	Corrective Act	ion to Prevent	Recurrence
-----	------	------------	--------------	--------------	------------------	---------	----------------	----------------	------------

NONE

********** OYSTER CREEK OPERATED ROUTINELY IN APRIL WITH NO OUTAGES.

* SUMMARY *

Туре	e Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Main: or Test C-Refueling D-Regulatory Rest E-Operator Traini & License Exam	F-Admin G-Oper Error H-Other riction ng ination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE.....NEW JERSEY COUNTY.....OCEAN DIST AND DIRECTION FROM NEAREST POPULATION CTR...9 MI S OF TOMS RIVER, NJ TYPE OF RLACTOR.....BWR DATE INITIAL CRITICALITY...MAY 3, 1969 DATE ELEC ENER 1ST GENER...SEPTEMBER 23, 1969 DATE COMMERCIAL OPERATE....DECEMBER 1, 1969 CONDENSER COOLING METHOD...ONCE THRU CONDENSER COOLING MATER....BARNEGAT BAY ELECTRIC RELIABILITY COUNCIL......MID-ATLANTIC AREA COUNCIL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE......GPU NUCLEAR CORPORATION

CONTRACTOR ARCHITECT/ENGINEER......BURNS & ROE

김 나이는 것이 많은 바람에 적히 가지 않는 것이 많습니다.

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR......BURNS & RUE

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....J. WECHELBERGER

LICENSE & DATE ISSUANCE.... DPR-16, AUGUST 1, 1969

PUBLIC DOCUMENT ROOM.....OCEAN COUNTY LIBRARY 161 WASHINGTON STREET TOMS RIVER, NEW JERSEY 08753

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

FAILURE TO REQUALIFY ARMED PERSONNEL WITH FIREARMS WITHIN A 12 MONTH PERIOD. (8702 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

VID_D.											
TEMS :											
VIDED.											
:											
VIDED.											
INSPECTIO	DN DATE: N	INPUT PRO	IDED.								
EPORT NO:	NO INPUT	PROVIDED.									
			EPORTS	FROM	LICE	NSEE					
		**********				*******				182221 -02223	
DATE OF EVENT	DATE OF REPORT	SUBJECT									
	IDED. IDED. IDED. INSPECTIO EPORT NO:	IDED. IDED. IDED. INSPECTION DATE: N EPORT NO: NO INPUT	IDED. IDED. IDED. INSPECTION DATE: NO INPUT PROV EPORT NO: NO INPUT PROVIDED. R DATE OF DATE OF SUBJECT	IDED. IDED. IDED. INSPECTION DATE: NO INPUT PROVIDED. EPORT NO: NO INPUT PROVIDED. R E P O R T S R E P O	IDED. IDED. IDED. INSPECTION DATE: NO INPUT PROVIDED. EPORT NO: NO INPUT PROVIDED. R E P O R T S F R O M R E P O R T S F R O M EDITEOF DATE OF SUBJECT	IDED. IDED. IIDED. INSPECTION DATE: NO INPUT PROVIDED. EPORT NO: NO INPUT PROVIDED. R E P O R T S F R O M L I C E R E P O R T S F R O M L I C E	IDED. IDED. IIDED. INSPECTION DATE: NO INPUT PROVIDED. EPORT NO: NO INPUT PROVIDED. REPORTS FROM LICENSEE DATE OF DATE OF SUBJECT	IDED. IDED. IIDED. INSPECTION DATE: NO INPUT PROVIDED. EPORT NO: NO INPUT PROVIDED. REPORTS FROM LICENSEE DATE OF DATE OF SUBJECT	IDED. EMS: IDED. IDED. INSPECTION DATE: NO INPUT PROVIDED. EPORT NO: NO INPUT PROVIDED. R E P O R T S F R O M L I C E N S E E DATE OF DATE OF SUBJECT	IDED. IDED. IDED. INSPECTION DATE: NO INPUT PROVIDED. EPORT NO: NO INPUT PROVIDED. R E P O R T S F R O M L I C E N S E E DATE OF DATE OF SUBJECT	IDED. IDED. IDED. INSPECTION DATE: NO INPUT PROVIDED. EPORT NO: NO INPUT PROVIDED. R E P O R T S F R O M L I C E N S E E DATE OF SUBJECT

1.	Docket: _50-255	OPERA	TING S	TATUS
2.	Reporting Period04/01/	88 Outage	+ On-line	Hrs: 719.0
3.	Utility Contact: G. C. P	ACKARD (61	5) 764-8913	
4.	Licensed Thermal Power (M	Wt):		2530
5.	Nameplate Rating (Gross M	We):	<u>955 X</u>	0.85 = 812
6.	Design Electrical Rating	(Net MWe):		805
7.	Maximum Dependable Capaci	ty (Gross M	1We):	770
8.	Maximum Dependable Capaci	ty (Net MWg	;):	730
9.	If Changes Occur Above Si NONE	nce Last Re	port, Give	Reasons:
10.	Power Level To Which Rest	ricted, If	Any (Net M	We):
11.	Reasons for Restrictions,	If Any:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE
13.	Hours Reactor Critical	640.3	2,214.5	
14.	Rx Reserve Shtdwn Wrs	.0	.0	. 0
15.	Hrs Generator On-Line	637.2	2,182.0	72,448.7
16.	Unit Reserve Shtdwn Hrs	. 0	.0	.0
17.	Gross Therm Ener (MWH)	1,522,344	5,090,136	152,278,053
18.	Gross Elec Ener (MWH)	490,440	1,645,275	47,555,795
19.	Net Elec Ener (MWH)	464,567	1,557,687	44,774,721
20.	Unit Service Factor	88.6	75.2	50.5
21.	Unit Avail Factor	88.6	75.2	50.5
22.	Unit Cap Factor (MDC Net)	88.5	73.5	42.8
23.	Unit Cap Factor (DER Net)	80.3	60.7	38.8
24.	Unit Forced Outage Rate	11.4	24.8	35.6
25.	Forced Outage Hours	81.8	721.0	_25,980.5
26.	Shutdowns Sched Over Next	6 Months (Type, Date, I	Duration):
_	REFUELING, SEPT. 9, 1988,	86 DAY DUR	ATION.	
27.	If Currently Shutdown Est	imated Star	tup Date:	05/01/88

PALISADES



APRIL 1988

Report	Period A	PR 19	88		UN	ΙT	SHU	TDOW	N	s /	R	EDU	C 1	I	0 1	N S	********	PAL	ISADES	****	******** * *	
No.	Date	Type	Hours	Reason	Method	LER	Number	System	Co	mponer	nt :		Ca	NUSP	8	Corr	rective *	ion to	Prevent	Recu	rrence	
19	04/27/88	F	81.8	Α	1						1		DH N	KOD	NO.	. 6 1	DROPPED IN	TO THE	CORE DUE	E TO F	AILURE	

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Rest E-Operator Trainin & License Exam	F-Admin G-Oper Error H-Other riction ng ination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

**************************************	LITY DAT Report Period APR 1988
FACILITY DESCRIPTION	UTILITY & C. CTOR INFORMATION
LOCATION STATEMICHIGAN	UTILITY LICENSEECONSUMERS POWER
COUNTYVANBUREN	CORPORATE ADDRESS
DIST AND DIRECTION FROM NEAREST POPULATION CTR5 MI S OF SOUTH HAVEN, MI	JACKSON, MICHIGAN 49261 CONTRACTOR ARCHITECT/ENGINEERBECHTEL
TYPE OF REACTORPWR	NUC STEAM SYS SUPPLIERCOMBUSTION ENGINEERING
DATE INITIAL CRITICALITYMAY 24, 1971	CONSTRUCTORBECHTEL
DATE ELEC ENER 1ST GENERDECEMBER 31, 1971	TURBINE SUPPLIERWESTINGHOUSE
DATF COMMERCIAL OPERATEDECEMBER 31, 1971	REGULATORY INFORMATION
CONDENSER COOLING METHODCOOLING TOWERS	IE REGION RESPONSIBLEIII
CONDENSER COOLING WATERLAKE MICHIGAN	IE RESIDENT INSPECTORE. SWANSON
ELECTRIC RELIABILITY COUNCILEAST CENTRAL AREA	LICENSING PROJ MANAGERT. WAMBACH DOCKET NUMBER
AGREEMENT	LICENSE & DATE ISSUANCEDPR-20, OCTOBER 16, 1972
	PUBLIC DOCUMENT ROOMVAN ZOEREN LIBRARY HOPE COLLEGE
INSPECT	ION STATUS

INSPECTION SUMMARY

INSPECTION ON MARCH 3 THROUGH APRIL 4, 1988 (88008): ROUTINE, UNANNO. ACED inspection by resident inspectors and Region III staff of followup of previous inspection findings; operational safety; maintenance; surveillance; physical security; radiological protection; bulletins; generic letters; information notices; and quarterly management meeting. Of the area inspected two violations were identified. The first involves inadequate evaluation and documentation of an issue involving an unreviewed safety question. The second involves an improperly performed surveillance test where technician performance was not adequate.

INSPECTION ON FEBRUARY 4 THROUGH MARCH 2, 1988 (88007): ROUTINE UNANNOUNCED inspection by resident inspectors and Region III staff of followup of previous inspection findings; operational safety; maintenance; surveillance; physical security; radiological protection; bulletins; and reportable events. Of the areas inspected, no violations or deviations were identified.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period APR 1988

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

REFUELING OUTAGE PLANNED FOR 9/6/88

MANAGERIAL ITEMS:

D.P. HOFFMAN SELECTED AS NEW V.P. NUCLEAR

PLANT STATUS:

OPERATED ENTIRE MONTH. DERATED TO 40% POWER ON 3/31 TO INVESTIGATE CONDENSER TUBS LEAK.

LAST IE SITE INSPECTION DATE: 04/04/88

INSPECTION REPORT HO: 88008

R"PORTS FROM LICENSEE

 NUMBER
 DATE OF EVENT
 DATE OF REPORT
 SUBJECT

 88-06
 032788
 042688
 INADVERTENT NANUAL AUXILIARY FEEDWATER ACTUATION

1.	Docket: _50-528	OPERA	TING S	TATUS					
2.	Reporting Period:04/01/	88 utage	+ On-line	Hrs: 720.0					
3.	Utility Contact:	ULL (602)	593-2679						
4.	Licensed Thermal Power (M		3800						
5.	Nameplate Rating Gross M	We):		1403					
6.	Design Electrical Rating	(Net MWe):		1270					
7.	Maximum Dependable Capaci	ty (Gross M	1We):	1303					
8.	Maximum Dependable Capaci	ty (Net MWa):	1221					
9.	If Changes Occur Above Since Last Report, Give Reasons:								
10.	Power Level To Which Rest	ricted, If	Any (Net Mk	4e):					
11.	Reasons for Restrictions,	If Any:							
	NONE								
12.	Report Period Hrs	MONTH 720.0	YEAR 2,904.0	CUMULATIVE					
13.	Hours Reactor Critical	635.8	1,216.0						
14.	R× Reserve Shtdwn Hrs	.0							
15.	Hrs Generator On-Line	623.6		10 859.4					
16.	Unit Reserve Shtdwn Hrs	.0							
17.	Gross Thorm Ener (MWH)	2,300,328	3,967,829	39,000,666					
18.	Gross Elec Ener (MWH)	805,300	1,387,300	13,530,600					
19.	Net Elec Ener (MWH)	758,479	1,288,858	12,616,972					
20.	Unit Service Factor	86.6	39.3	54.9					
21.	Unit Avail Factor	86.6		54.9					
22.	Unit Cap Factor (MDC Net)	86.3	36.3	52.3					
23.	Unit Cap Factor (DER Net)	82.9	34.9	50.2					
24.	Unit Forced Outage Rate	13.4		34.6					
25.	Forced Outage Hours	96.4	1,477.2	5,748.9					
26.	Shutdowns Sched Over Next NONE	6 Months (Type,Date,D	Ouration):					
27.	If Currently Shutdown Est	imated Star	top Date:	N/A					

******	(*****	*****	*****	*****	XXXXX	
×	PAI	O VERI	DE 1		×	
******	(XXXXXX)	****	******	******	XXXXX	
AVERAGE	DAILY	POWER	LEVEL	(MWe)	PLOT	

PALO VERDE 1



APRIL 1988

Report	Period Al	PR 19	88		UN	IT SHU	тром	NS / R	E D U C T I O N S * PALO VERDE 1 *
No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3	04/19/88	F	48.9	G	3	1-88-011	FK	DISC	REACTOR TRIP RESULTING FROM INADVERTENT OPENING OF MAIN GENERATOR OUTPUT BREAKER.
4	04/28/88	F	47.5	А	1				LEAKING OIL FILTER ON REACTOR COOLANT PUMP NECESSITATED A REACTOR SHUTDOWN TO REPLACE FILTER.

********* PALO VERDE 1 INCURRED 2 FORCED OUTAGES IN APRIL FOR REASONS * SUMMARY * STATED ABOVE.

TypeReasonMethodF-Forced
S-SchedA-Equip Failure
B-Maint or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training1-Manual
2-Manual
S-Reduced L

& License Examination

1-Manual Exhibit F 3 H 2-Manual Scram Instructions for 3-Aute Scram Preparation of 4-Continued Data Entry Sheet 5-Reduced Load Licensee Event Report 9-Other (LER) File (NUREG-0161)

System & Component

PAGE 2-289

FACILITY DESCRIPTION

LOCATION	
STATE	ARIZONA
C0 JNTY	.MARICOPA
DIST AND DIRECTION FROM NEAREST POPULATION CTR.	.36 MI W OF FHOENIX, AZ
TYPE OF REACTOR	. PWR
DATE INITIAL CRITICALITY	.MAY 25, 1985
DATE ELEC ENER. 1ST GENER	JUNE 10, 1985
DATE COMMERCIAL OPERATE	.JANUARY 28, 198
CONDENSER COOLING METHOD	.TREATED SEWAGE
CONDENSER COOLING WATER	.SEWAGE TREATMEN
ELECTRIC RELIABILITY COUNCIL	.WESTERN SYSTEMS COORDINATING

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE...... ARIZONA PUBLIC SERVICE

CORPORATE ADDRESS......P.O. BOX 21666 PHOENIX, ARIZONA 85036

CONTRACTOR

ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V

IE RESIDENT INSPECTOR.....T. POLICH

LICENSE & DATE ISSUANCE....NPF-41, JUNE 1, 1985

PUBLIC DOCUMENT ROOM.....MS STEFANIE MORITZ DOCUMENTS LIBRARIAN PHOENIX PUBLIC LIBRARY 12 EAST MCDOWELL ROAD PHOENIZ, ARIZONA 85004

INSPECTION SUMMARY

+ INSPECTION ON JANUARY 17 - MARCH 5, 1928 (REPORT NO. 50-528/88-02) AREAS INSPECTEJ: ROUTINE, ONSITE, REGULAR AND BACKSHIFT INSPECTION BY THE THREE RESIDENT INSPECTORS AND ONE REGIONALLY BASED INSPECTOR. AREAS INSPECTED INCLUDED: PREVIOUSLY IDENTIFIED ITEMS; REVIEW OF PLANT ACTIVITIES; PLANT TOURS, HOUSEKEEPING; ENGLAEERED SAFETY FEATURE SYSTEM WALKDOWNS; SURVEILLANCE TESTING; PLANT MAINTENANCE; INOPERABLE CONTROL ELEMENT ASSEMBLY; INOPERABLE, HIGH PRESSURE SAFETY INJECTION PUMPS DURING MODE 4; ESSENTIAL COOLING PUMP ROOM ALARMS; CONTROL ROOM ANNUNCIATORS; OPERATIONAL ERRORS; FUEL RECEIPT AND STORAGE; PREPARATION OR REFUELING; REVIEW OF LICENSEE PROGRAMS FOR FOLLOWUP OF NRC INFORMATION NOTICES AND BULLETINS; NRC COMPLIANCE BULLETIN NUMBER 87-02; FASTENER TESTING TO DETERMINE CONFORMANCE WITH APPLICABLE MATERIAL SPECIFICATIONS; FOLLOWUP OF LICENSEE EVENT REPORTS; AND REVIEW OF PERIODIC AND SPECIAL REPORTS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: OF THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

+ INSPECTION ON MARCH 6 - APRIL 16, 1988 (REPORT NO. 50-528/88-10) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 4 - 8, 1988 (REPORT NO. 50-528/88-12) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

COUNCIL

+ INSPECTION ON MAY 16 - 27, 1988 (REPORT NO. 50-528/88-13) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

PAGE 2-290

Report Period APR 1983

Report Period APR 1988

INSPECTION SUMMARY

- + INSPECTION ON APRIL 17 MAY 21, 1988 (REPORT NO. 50-528/88-14) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON APRIL 4 20, 1988 (REPORT NO. 50-528/88-15) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

+ NONE

PLANT STATUS:

+ PRESENTLY OPERATING AT FULL POWER.

LAST IE SITE INSPECTION DATE: 05/16 - 27/88+

INSPECTION REPORT NO: 50-528/88-13+

REPORTS FROM LICENSEE

NUMBER	DATE OF	DAT: OF	SUBJECT
	EVENT	REPORT	

88-01-S0 02-17-88 03-18-88 UNCOMPENSATED OPENING BETWEEN VITAL AREAS (SAFEGUARDS EVENT)

88-01-X0 01-22-88 92-16-88 MONITOR RV-142 (SPECIAL REPORT)

1. D	ocket: <u>50-529</u> 0	PERAT	ING S	TATUS
2. R	eporting Period: _04/01/8	8_ Outage	+ On-line	Hrs: 720.0
3. U	tility Contact: J. L. HU	LL (602) 3	93-2679	
4. L	icensed Thermal Power (MW		3800	
5. N	ameplate Rating (Gross MW	e):		1403
6. D	esign Electrical Rating (Net MWe):		1270
7. M	aximum Dependable Capacit	y (Gross M	We):	1303
8. M	aximum Dependable Capacit	y (Net MWe):	1221
9. I	f Changes Occur Above Sin	ce Last Re	port, Give	Reasons:
N	ONE			
10. P	ower Level To Which Restr	icted, If	Any (Net Mk	le):
11. R	easons for Restrictions,	If Any:		
N	ONE			
12. R	eport Period Hrs	MONTH 720.0	YEAR 2,904.0	CUMULATIVE 14,160.0
13. H	ours Reactor Critical	. 0	1,202.0	10,477.1
14. R	x Reserve Shtdwn Hrs	.0	0	
15. H	rs Generator On-Line	. 0	1,202.0	10,328.2
16. U	nit Reserve Shtdwn Hrs	.0	,0	0
17. G	ross Therm Ener (MWH)	0	4,508,600	37,715,767
18. G	iross Elec Ener (MWH)	0	1,588,100	13,249,370
19. N	let Elec Ener (MWH)	0	1,487,775	12,424,657
20. U	nit Service Factor	.0	41.4	72.9
21. U	nit Avail Factor	.0	41.4	72.9
22. U	nit Cap Factor (MDC Net)	. 0	42.0	71.9
23. U	Init Cap Factor (DER Net)	.0	40.3	69.1
24. U	Init Forced Outage Rate	.0		5.8
25. F	orced Outage Hours	.0		637.1
26. S	hutdowns Sched Over Next	6 Months (Type,Date,I)uration):
27 1	f Currently Shutdown Esti	mated Star	tup Date:	06/16/88



PALO VERDE 2



APRIL 1988

Report Period APR 1988	UNIT SHUTDOWNS / 1	REDUCTIONS * PALO VERDE 2 * *********************************
No. Date Type Hours Reason Me	thod LER Number System Component	Cause & Corrective Action to Prevent Recurrence

2 02/20/88 S 720.0 C 4 REFUELING OUTAGE UNDERWAY.

********** PALO VERDE 2 REMAINED SHUTDOWN IN APRIL FOR SCHEDULED REFUELING OUTAGE.

Туре	Reason	Method	System & Component	
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)	

FACILITY DESCRIPTION

LOCATION STATE.....ARIZONA

DIST AND DIRECTION FROM NEAREST POPULATION CTR...36 MI W OF PHOENIX, AZ

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... APRIL 18, 1986

DATE ELEC ENER 1ST GENER...MAY 20, 1986

DATE COMMERCIAL OPERATE....SEPTEMBER 19, 1986

CONDENSER COOLING METHOD...COOLING TOWERS

CONDENSER COOLING WATER....SEWAGE TREATMENT

ELECTRIC RELIABILITY COUNCIL.....WESTERN SYSTEMS COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE..... ARIZONA PUBLIC SERVICE

CORPORATE ADDRESS......P.O. 80X 21666 PHOENIX, ARIZONA 85036

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V

IE RESIDENT INSPECTOR......T. POLICH

LICENSE & DATE ISSUANCE....NPF-51, APRIL 24, 1986

PUBLIC DOCUMENT ROOM.....MS STEFANIE MORITZ DOCUMENTS LIBRARIAN PHOENIX PUBLIC LIBRARY 12 EAST MCDOWELL ROAD PHOENIZ, ARIZONA 85004

INSPECTION SUMMARY

+ INSPECTION ON JANUARY 17 - MARCH 5, 1988 (REPORT NO. 50-529/88-02) AREAS INSPECTED: ROUTINE, ONSITE, REGULAR AND BACKSHIFT INSPECTION BY THE THREE RESIDENT INSPECTORS AND ONE REGIOMALLY BASED INSPECTOR. AREAS INSPECTED INCLUDED: PREVIOUSLY IDENTIFIED ITEMS; REVIEW OF PLANT ACTIVITIES; PLANT TOURS; HOUSEKEEPING; ENGINEERED SAFETY FEATURE SYSTEM WALKDOWNS; SURVEILLANCE TESTING; PLANT MAINTENANCE; INOPERABLE CONTROL ELEMENT ASSEMBLY; INOPERABLE HIGH PRESSURE SAFETY INJECTION PUMPS DURING MODE 4; ESSENTIAL COOLING PUMP ROPM ALARMS; CONTROL ROOM ANNUNCIATORS; OPERATIONAL ERRORS; FUEL RECEIPT AND STORAGE; PREPARATION FOR REFUELING; REVIEW OF LICEN EE PROGRAMS FOR FOLLOWUP OF NRC INFORMATION NOTICES AND BULLETINS; NRC COMPLIANCE BULLETIN NUMBER 87-02; FASTENER TESTING TO DETERMINE CONFORMANCE WITH APPLICABLE MATERIAL SPECIFICATIONS; FOLLOWUP OF LICENSEE EVENT REPORTS; AND REVIEW OF PERIODIC AND SPECIAL REPORTS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: OF THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION ON MARCH 6 - APRIL 16, 1988 (REPORT NO. 529/88-10) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON MARCH 21 - 25, 1988 (REPORT NO. 50-529/88-12) AREAS INSPECTED: ROUTINE. UNANNOUNCED INSPECTION BY A REGIONALLY BASED INSPECTOR OF INSERVICE INSPECTION ACTIVITIES. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMLIANCE OR DEVIATIONS WERE IDENTIFIED.

PAGE 2-294

Report Period APR 1988

Report Period APR 1988

INSPECTION SUMMARY

- + INSPECTION ON APRIL 4 8, 1988 (REPORT NO. 50-529/88-13) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON MAY 16 27, 1988 (REPORT NO. 50-529/88-14) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON APRIL 17 MAY 21, 1988 (REPORT NO. 529/88-15) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON APRIL 4 20, 1988 (REPORT NO. 50-529/88-16) REPORT BEING PREFARED; TO BE REPORTED NEXT MONTH.

FNFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

+ AN ORDER WAS ISSUED NGVEMBER 19, 1987, MODIFYING THE UNIT 2 LICENSE. THIS ORDER CONFIRMED COMMITMENTS BY THE LICENSEE TO PROVIDE VIBRATION MONITORING FOR REACTOR COOLANT PUMP SHAFTS.

PLANT STATUS:

+ THE UNIT SHUT DOWN FOR THE FIRST REFUELING OUTAGE ON FEBRUARY 10, 1988, AND IS PRESENTLY IN MODE 6.

LAST IE SITE INSPECTION DATE: 05/16 - 27/88+

INSPECTION REPORT NO: 50-529/88-14+

REPORTS FROM LICENSEE

NUMBER DATE OF DATE OF SUBJECT EVENT REPORT

NONE

1.	Docket: _50-530	OPERAI	ING S	TATUS					
2.	Reporting Period: 04/01/88 Outage + On-line Hrs: 720.0								
3.	Utility Contact: J.M. CO	LVILLE 602-	-393-2679						
4.	Licensed Thermal Power (M	3800							
5.	Nameplate Rating (Gross M	We):	1403						
6.	Design Electrical Rating	(Net MWe):		1270					
7.	Maximum Dependable Capaci	ty (Gross M	(We):	1303					
8.	Maximum Dependable Capaci	ty (Net MWa	;):	1221					
9.	If Changes Occur Above Sin	nce Last Re	port, Give	Reasons:					
10.	Power Level To Which Rest	ricted, If	Any (Net MW	le):					
	NONE								
12.	Report Period Hrs	MONTH 720.0	YEAR 2,736.0	CUMULATIVE					
13.	Hours Reactor Critical	720.0	2,736.0	2,736.0					
14.	Rx Reserve Shtdwn Hrs	.0	. 0						
15.	Hrs Generator On-Line	720.0	2,736.0	2,736.0					
16.	Unit Reserve Shtdwn Hrs	. 0							
17.	Gross Therm Ener (MWH)	2,543,723	10,131,635	10,131,635					
18.	Gross Elec Ener (MWH)	894,800	3,576,800	3,576,800					
19.	Net Elec Ener (MWH)	843,053	3,380,837	3,380,837					
20.	Unit Service Factor	100.0	100.0	100.0					
21.	Unit Avail Factor	100.0	100.0	100.0					
22.	Unit Cap Factor (MDC Net)	95.9	101.2	101.2					
23.	Unit Cap Factor (DER Net)	92.2	97.3	97.3					
24.	Unit Forced Outage Rate	,0	.0	0					
25.	Forced Outage Hours	.0	.0						
26.	Shutdowns Sched Over Next NONE	6 Months	Type,Date,D	Ouration):					
27	If Currently Shutdown Est	imated Star	tup Date:	N/A					

******	*****	*****	*****	*****	****
×	PA	LO VER	DE 3		×
******	*****	*****	*****	******	*****
AVERAGE	DAILY	POWER	LEVEL	(MWe)	PLOT

PALO VERDE 3



APRIL 1988

Report	Period A	PR 19	88		UN	IT	SHU	тром	NS / R	E D U C T I O N S
<u>No.</u> 2	Date 04/18/88	Type S	Hours 0.0	<u>Reason</u> B	Method 5	LER	Number	System	Component	Cause & Corrective Action to Prevent Recurrence POWER REDUCTION TO 60% IN PREPARATION FOR FEEDWATER PUMP AND CONDENSER MAINTENANCE.

POWER REDUCTION FOR FEEDWATER PUMP AND CONDENSER MAINTENANCE.

********** PALO VERDE INCURRED 2 SCHEDULED REDUCTIONS IN POWER IN APRIL. * SUMMARY *

5

3

04/21/88 S 0.0 B

Туре	Reason	Method	System & Component	
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)	

FACILITY DESCRIPTION

LOCATION STATE.....ARIZONA

COUNTY.....MARICOPA

DIST AND DIRECTION FROM NEAREST POPULATION CTR...36 (W OF PHOENIX, AZ

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY...OCTOBER 25, 1987

DATE ELEC ENER 1ST GENER...NOVEMBER 28, 1987

DATE COMMERCIAL OPERATE....JANUARY 8, 1988

CONDENSER COOLING METHOD...COOLING TOWERS

CONDENSER COOLING WATER....SEWAGE TREATMENT

ELECTRIC RELIABILITY COUNCIL......WESTERN SYSTEMS

COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE..... ARIZONA PUBLIC SERVICE

CORPORATE ADDRESS......P.O. BOX 21666 PHOENIX, ARIZONA 85036

CONTRACTOR

ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V

IE RESIDENT INSPECTOR.....T. POLICH

LICENSE & DATE ISSUANCE....NPF-74, NOVEMBER 25, 1987

PUBLIC DOCUMENT ROOM.....MS STEFANIE MORITZ DOCUMENTS LIBRARIAN PHOENIX PUBLIC LIBRARY 12 EAST MCDOWELL ROAD PHOENIZ, ARIZONA 85004

INSPECTION SUMMARY

+ INSPECTION ON JANUARY 17 - MARCH 5, 1988 (REPORT NO. 50-530/88-02) AREAS INSPECTED: ROUTINE, ONSITE REGULAR AND BACKSHIFT INSPECTION BY THE THREE RESIDENT INSPECTORS AND ONE REGIONALLY BASED INSPECTOR. AREAS INSPECTED INCLUDED: PREVIOUSLY IDENTIFIED ITEMS; REVIEW OF PLANT ACTIVITIES; PLANT TOURS; HOUSEKEEPING; ENGINEERED SAFETY FEATURE SYSTEM WALKDOWNS; SURVEILLANCE TESTING; PLANT MAINTENANCE; INOPERABLE CONTROL ELEMENT ASSEMBLY; INOPERABLE HIGH PRESSURE SAFETY INJECTION PUMPS DURING MODE 4; ESSENTIAL COOLING PUMP ROOM ALARMS; CONTROL ROOM ANNUNCIATORS; OPERATIONAL ERRORS; FUEL RECEIPT AND STORAGE; PREPARATION FOR REFUELING; REVIEW OF LICENSEE PROGRAMS FOR FOLLOWUP OF NRC INFORMATION NOTICES AND BULLETINS; NRC COMPLIANCE BULLETIN NUMBER 87-02; FASTENER IESTING TO DETERMINE CONFORMANCE WITH APPLICABLE MATERIAL SPECIFICATIONS; FOLLOWUP OF LICENSEE EVENT REPORTS; AND REVIEW OF PERIODIC AND SPECIAL REPORTS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MARCH 16 - APRIL 16, 1988 (REPORT NO. 50-530/88-10) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 4 - 8, 1988 (REPORT NO. 50-530/88-12) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON MAY 16 - 27, 1988 (REPORT NO. 50-530/88-13) REPORT SEING PREPARED; TO BE REPORTED NEXT MONTH.

PAGE 2-298

Report Period APR 1988

Report Period APR 1988

INSPECTION SUMMARY

- + INSPECTION ON APRIL 17 MAY 21, 1988 (REPORT NO. 50-530/88-14) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON APRIL 4 20, 1988 (REPORT NO. 50-530/88-15) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

```
SYSTEMS AND COMPONENT PROBLEMS:
```

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

NONE

LAST IE SITE INSPECTION DATE: 05/16 - 27/88+

INSPECTION REPORT NO: 50-530/88-13+

REPORTS FROM LICENSEE

NUMBER DATE OF DATE OF SUBJECT EVENT REPORT

NONE

2.					
	Reporting Period: _04/01/8	8 Outage	+ On-line	Hrs: 719,0	
3.	Utility Contact: L. L. MI	DDLETON (21	5) 841-637	4	
4.	Licensed Thermal Power (MW	3293			
5.	Nameplate Rating (Gross MW	0.9 = 1152			
6.	Design Electrical Rating (1065			
7.	Maximum Dependable Capacit	le):	1098		
8.	Maximum Dependable Capacit		1051		
9.	If Changes Occur Above Sin NONE	ce Last Rep	ort, Give	Reasons:	
10	Power level To Which Restr	icted. If A	ny (Net M	le):	
11	Reasons for Restrictions.	If Any:			
	NRC ORDER OF 3/31/87				
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 121,175.0	
13.	Hours Reactor Critical	.0	.0	74,196.2	
14.	Rx Reserve Shtdwn Hrs	.0	.0	.0	
15.	Hrs Generator On-Line	.0	.0	71,866.8	
16.	Unit Reserve Shtdwn Hrs	.0	.0		
17.	Gross Therm Ener (MWH)	0	0	212,810,745	
18.	Gross Elec Ener (MWH)	0	0	70,019,230	
19.	Net Elec Ener (MWH)	-3,582	-16,709	67,024,407	
20.	Unit Service Factor	.0	.0	59.3	
21.	Unit Avail Factor	, 0		59.3	
22.	Unit Cap Factor (MDC Net)	. 0	. 0	52.6	
23.	Unit Cap Factor (DER Net)	. 0	.0	51.9	
24.	Unit Forced Outage Rate	. 0	.0	14.6	
25.	Forced Outage Hours	.0		12,304.0	
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):	





APRIL 1988

Report	Period A	PR 19	88		UN	IT	SHU	TDO	WN	NS /	R	E	DU	јст	I	0	NS	*	PE	ACH (XX)	BOTTOM	2	EXXX EXXX
No.	Date	Туре	Hours	Reason	Method	LER	Number	Syste	m C	Compone	ent	-		Ça	use	8	Cor	rective	Action	to	Prevent	Recurrenc	e
7	03/31/87	s	719.0	С	4			RC		FUELX	x	NR	CR	REQUI	RED	1 5	HUTD	OWN .					

PEACH BOTTOM 2 REMAINED SHUTDOWN IN APRIL IN ACCORDANCE WITH NRC ORDER, HOWEVER, CONTINUED RESTART ACTIVITIES.

Туре	Reason	Method	System & Component			
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (IFR) File (NURFG-0161)			

PAGE 2-301

****** PEACH BOTTOM 2 ********** FACILITY DESCRIPTION 1 OCATION STATE.....PENNSYLVANIA DIST AND DIRECTION FROM NEAREST POPULATION CTR...19 MI S OF LANCASTER, PA TYPE OF REACTOR BWR DATE INITIAL CRITICALITY... SEPTEMBER 16, 1973 DATE ELEC ENER 1ST GENER... FEBRUARY 18, 1974 DATE COMMERCIAL OPERATE ... JULY 5, 1974 CONDENSER COOLING METHOD ... ONCE THRU CONDENSER COOLING WATER....SUSQUEHANNA RIVER ELECTRIC RELIABILITY COUNCIL......MID-ATLANTIC AREA COUNCIL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....PHILADELPHIA ELECTRIC

CORPORATE ADDRESS.......2301 MARKET STREET PHILADELTHIA, PENNSYLVANIA 19105

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER. .. GENERAL ELECTRIC

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....T. JOHNSON

LICENSE & DATE ISSUANCE.... DPR-44, DECEMBER 14, 1973

PUBLIC DOCUMENT ROOM......GOVERNMENT PUBLICATIONS SECTION STATE LIBRARY OF PENNSYLVANIA FORUM BUILDING COMMONWEALTH AND WALNUT STREET HARRISBURG, PENNSYLVANIA 17105

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period APR 1988

OTHER ITEMS

NO INPUT PROVIDED. MANAGERIAL ITEMS: NO INPUT PROVIDED. CLANT STATUS: NO INPUT PROVIDED. LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED. INSPECTION REPORT NO: NO INPUT PROVIDED. REPORTS FROM LICENSEE DATE OF NUMBER DATE OF SUBJECT REPORT EVENT NO INPUT PROVIDED.

1.	D.cket: _50-2730	PERAT	INGS	TATUS
2.	Reporting Period: _04/01/8	8 Outage	+ On-line	Hrs: 719.0
3.	Utility Contact: L. L. MI	DOLETON (21	5) 841-63	79
4.	Licensed Thermal Power (MW	3293		
5.	Nameplate Rating (Gross MW	0.9 = 1152		
6.	Design Electrical Rating (1065		
7.	Maximum Dependable Capacit	1098		
8.	Maximum Dependable Capacit		1035	
9.	If Changes Occur Above Sin NONF	ce Last Rep	ort, Give	Reasons:
10	Power Level To Which Restr	icted. If I	Inv (at MI	(ok
10.	Reasons for Restrictions.	If Any:	any v at n	ne) -
	NPC OPDER OF 3/31/87	11 Mily		
	Inte output of your of t	MONTH	YEAR	
12.	Report Period Hrs	719.0	2.903.0	117,071.0
3.	Hours Reactor Critical	.0	.0	76,366.3
4.	Rx Reserve Shtdwn Hrs	.0	.0	0
5.	Hrs Generator On-Line	. 0		74,059.3
16.	Unit Reserve Shtdwn Hrs	. 0		
17.	Gross Therm Ener (MWH)	0	0	215,278,901
8.	Gross Elec Ener (MWH)	0	0	70,611,432
19.	Net Elec Ener (MWH)	-3,582	-16,709	67,685,44.
20.	Unit Service Factor	.0		63.3
21.	Unit Avail Factor	.0	. 0	63.3
	Unit Cap Factor (MDC Net)	. 0	. 0	55.9
22.		.0	. 0	54.3
22.	Unit Cap Factor (DER Net)	And the second sec		
22.	Unit Cap Factor (DER Net) Unit Forced Outage Rate	. 0	. 0	13.3
22. 23. 24. 25.	Unit Cap Factor (DER Net) Unit Forced Outage Rate Forced Outage Hours	. 0	.0	13.3
22. 23. 24. 25. 26.	Unit Cap Factor (DER Net) Unit Forced Outage Rate Forced Outage Hours Shutdowns Sched Over Next	<u>.0</u> .0 6 Months (1	0 0 [ype,Date,1	<u>13.3</u> <u>11,372.7</u> Duration):



PEACH BOTTOM 3



APRIL 1988
Report	Period Al	PR 19	88		UN	ΙT	SHU	гром	NS /	REDUCTIONS * PEACH BOTTOM 3 * XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
No.	Date	Type	Hours	Reason	Method	LER	Number	System	Compone	t Cause & Correc(ive Action to Prevent Recurrence
7	03/31/87	s	719.0	С	4			RC	FUELXX	PIPE REPLACEMENT OUTAGE

********** PEACH BOTTOM 3 REMAINED SHUTDOWN IN ACCORDANCE WITH NRC * SUMMARY * ORDER, HOWEVER, CONTINUED RESTART ACTIVITIES.

Type	Reason	Method	System & Component			
F-Forced S-Sched	A-Equip Failure F-Adm B-Maint or Test G-Ope C-Refueling H-Oth D-Regulatory Restricti E-Operator Training & Licone Examinati	in 1-Manual rError 2-Manual Scram er 3-Auto Scram on 4-Continued 5-Reduced Load on 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LFR) File (NUREG-01(1))			

FACILITY DESCRIPTION

LOCATION STATE.....PENNSYLVANIA

DIST AND DIRECTION FROM NEAREST POPULATION CTR... '9 MI S OF LANCASTER, PA

TYPE OF REACTOR BMR

DATE INITIAL CRITICALITY...AUGUST 7, 1974 DATE ELEC ENER 1ST GENER...SEPTEMBER 1, 1974 DATE COMMERCIAL OFERATE....DECEMBER 23, 1974 CONDENSER COOLING METHOD...ONCE THRU CONDENSER COOLING WATER....SUSQUEHANNA RIVER

ELECTRIC RELIABILITY

FACILITY DATA

Report Period APR 1983

UTILITY & CONTRACTOR INFORMATION

UTILITY

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER......GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....T. JOHNSON

LICENSE & DATE ISSUANCE.... DPR-56, JULY 2, 1974

PUBLIC DOCUMENT ROOM......GOVERNMENT PUBLICATIONS SECTION STATE LIBRARY OF PENNSYLVANIA FORUM BUILDING COMMONWEALTH AND WALNUT STREET HARRISBURG, PENNSYLVANIA 17105

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

NTHER ITENS

SYSTEMS AND COMPONENTS: NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period AFR 1988

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

*********	**********	***********	
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
	-		

NO INPUT PROVIDED.

1.	Docket: _50-440	0 P 2 R A 1	ING S	TATUS						
2.	Reporting Period:	88 Outrige	+ On-line	Hrs: 719.0						
3.	Utility Contact: <u>G. A. D</u>	UNN (216) 2	259-3737							
4.	Licensed Thermal Power (M		3579							
5.	Nameplate Rating (Gross M	· · · · · · · · · · · · · · · · · · ·	1250							
6.	Design Electrical Rating		1205							
7.	Maximum Dependable Capaci	ty (Gross *	1We):	1250						
8.	Maximum Dependable Capaci	ty (Net MWa):	1205						
9.	. If Changes Occur Above since Last Report, Give Repsons:									
10. 11.	Power Level To Which Rest Reasons for Restrictions, NONE	ricted, lf If Any:	Any (Net M	/e):						
12.	Report Period Hrs	MONTH 719.0	YEAk 2,903.0	CUMULATIVE						
13.	Hours Reactor Critical		_2,170.7	2,982.0						
14.	Rx Reserve Shtdwn Hrs			.0						
15.	Hrs Generator On-Line	645.2	2,086.5	2,859.9						
16.	Unit Reserve Shtdwn Hrs			. 0						
17.	Gross Therm Ener (MWH)	2,287,404	7,047,115	9,608,634						
18.	Gross Elec Ener (MWH)	795,741	2,438,650	3, 317, 112						
19.	Net Elec Ener (MWH)	_ 756,550	2,304,733	3,133,217						
20.	Unit Service Factor	89.7	71.9	72.5						
21.	Unit Avail Factor	89.7	71.9	72.5						
22.	"nit Cap Factor (MBC M-t)	87.3	65.9	65.9						
23.	Unit Cap Factor (DEr	87.3	65.9	65.9						
24.	Unit Forced Outage Rate	10.3	8.4	13.9						
25.	Forced Outage Hours	73.8	190.6	461.2						
26.	Shutdowns Sched Over Next MAINTENANCE, OCTOBER, 1981	6 Months (Type, Date, D	uration):						
27.	If Currently Shutdown Est	imated Star	tup Date:	05/01/88						





0-'n

DAYS

PRIL 1988

PAGE 2-308

Report	Period A	PR 19	88		UN	IT SHU	TDOW	NS / R	EDUCTIONS * PERPY 1 * *********************************
No.	Dute	Туре	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-6	04/、7/88	F	67.7	G	2	88012	EI	SWGR	PERSONNEL ERROR DURING DC ELECTRICAL LINEUP CHANGES RESULTED IN A LOSS OF FEEDWATER, LEADING TO A REACTOR SCRAM ON LOW REACTOR WATER LEVEL. PLANT SYSTEMS RESPONDED AS DESIGNED, WATER LEVEL WAS RESTORED, AND THE PLANT WAS STABILIZED IN HOT SHUTDOWN.
88-7	04/30/88	F	6.1	н	3	88015	SB	ISV	A PROCEDURAL DEFICIENCY DURING REACTOR STARTUP RESULTED IN STEAM BYPASS VALVE OPERATION UPON OPENING MSIV'S, LEADING TO A REACTOR SCRAM ON LOW REACTOR WATER LEVEL. APPLICABLE OPERATING INSTRUCTIONS HAVE BEEN REVISED.

PERRY 1 INCURRED 2 FORCED OUTAGES IN APRIL FOR REASONS STATED ABOVE. ********

* SUMMARY *

Type	Reason		Method	System & Component			
F-Førced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Rest E-Operator Train & License Exam	F-Admin G-Oper Errcr H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Jata Entry Sheet Licensee Event Report (LER) File (NUREG-0161			

**************************************	. ITY DATA Report Period APR 1988
FACILITY DESCRIPTION	UTILITY & CONTRACTOR INFORMATION
LOCATION STATEOHIO	UTILITY LICENSEECLEVELAND ELECTRIC ILLUMINATING
COUNTYLAKE	CORPORATE ADDR.55
DI3T AND DIRECTION FROM NEAREST POPULATION CTR7 MI NE OF PAINESVILLE, OHIO	CLEVELAND, DHID 44101 CONTRACTOR ARCHITECT/ENGINEERGILBERT ASSOCIATES
TYPE OF REACTORBWR	NUC STEAM SYS SUPPLIERGENERAL ELECTRIC
DATE INITIAL CRITICALITYJUNE 6, 1986	CONSTRUCTOR
DATE ELEC ENER 1ST GENERDECEMBER 19, 1986	TURBINE SUPPLIERGENERAL ELECTRIC
DATE COMMERCIAL OPERATE NOVEMBER 18, 1987	REGULATORY INFORMATION
CONDENSER COOLING METHODCC HNDCT	1E REGION RESPONSIBLEIII
CONJENSER COOLING WATERLAKE ERIE	IE RESIDENT INSPECTORK. CONNAUGHTON
ELECTRIC RELIABILITY COUNCIL	LICENSING PROJ MANACTT. COLBURN DOCKET NUMBER
AGREEMENT	LICENSE & DATE ISSUANCENPF-58, NOVEMBER 13, 1986
	PUBLIC DOCUMENT ROOMPERRY PUBLIC LIBRARY 3753 MAIN ST.
INSPECI	ION STATUS

INSPECTION SUMMARY

INSPECTION ON JANUARY 11-15, JANUARY 25-29 AND FEBRUARY 9. 1988 (87025): Special, announced team inspection of licensee action regarding an allegation and maintenance activities, using selected portions of Inspection Procedures 62700, 62702, 62704 and 92720. In the areas inspected, one violation was identified concerning four specific examples of failure to follow maintenance and audit procedures. With the exceptions noted, the team concluded that overall maintenance was adequately accomplished, effective, and self assessed.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

*****	******	******	**************
×		PERRY	1 *
*****	******	******	******

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NGNE

PLANT STATUS:

PLANT IS IN NORMAL OPERATION

LAST JE SITE INSPECTION DATE: 12/04/87

INSPECTION REPORT NO: 37027

REPORTS FROM LICENSEE

ESSERTIFIES			
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
	040489	047988	A MUMENTARY DECREASE OF THE DIESEL GENERATOR CONTROL TACHOMETER RESULTED IN AN UNEXPECTED START
00-11	040400	042300	OF THE DIESEL GENERATOR BUILDING VENTILATION SYSTEM

1. Docket:0_293 0	PERAT	INGS	TATUS							
2. Reporting Period: _04/01/8	0utage	+ On-line	Hrs: 719.0							
3. Utility .untact: P. HAMIL	TON (617) 7	46-7900								
4. Licensed Thermal Power (Mb	. Licensed Thermal Power (MWt): 1998									
. Nameplate Rating (Gross MWe): 780 X 0.87 = 678										
6. Design Electrical Rating (Net MWe):		655							
7. Maximum Dependable Capacit	y (Gross MW	le):	690							
8. Maximum Dependable Capacit	y (Net MWe)		670							
9. If Changes Occur Above Sin	ice Last Rep	ort, Give	Reasons:							
NONE										
10. Power Lavel To Which Restr	icted, If A	ny (Net M	We):							
11. Reasons for Restrictions,	If Any:									
NONE										
12. Report Feriod Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE							
13. Hours Reactor Critical	.0	. 0								
14. Rx Reserve Shtdwn Hrs		.0	0							
15. Hrs Generator On-Line										
16. Unit Reserve Shtdwn Hrs		. 0								
17. Gross Th⊴rm Ener (MWH)	0	0	135,480,048							
18. C. uss Elec Ener (MWH)	0	0	45,444,604							
19. Net Elec Ener (MWH)	0	0	43,675,429							
20. Unit Service Factor	<u> </u>	. 0	57.2							
21. Unit Avail Factor	.0	. 0	57.2							
22. Unit Cap Factor (MDC Net)	.0	. 0	48.3							
23. Unit Cap Factor (DER Net)	.0	.0	49.4							
24. Unit Forced Outage Rate		. 0	12.4							
25. Forced Outage Hours		.0	10,922.7							
26. Shutdowns Sched Over Next	6 Months (T	ype,Date,I	Duration):							
27. If Currently Shutdown Esti	mated Start	up Date:	08/01/88							





APRIL 1988

Report	Period AF	PR 19	88		UN	ΙT	s	н	т	D	0 1	4 N	s	/	R	ε	DU	с	T	0 1	N	XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
No.	Date	Туре	Hours	Reason	Method	LE	R Nur	nber	Ξ3	Sys	ster		omp	one	nt			(Cau	58	8 (Corrective Action to Prevent Recurrence
01	07/25/86	s	719.0	с	4											SH	UTD	OM	N FI	OR	RFC	07.

XXXXXXXXXX FILGRIM 1 REMAINED SHUTDOWN FOR REFUELING OUTAGE.

* SUMMARY *

Тура	keason		Methon	System & Component			
F-Forced S-Sched	A-Equip Failure B-Maint or Test C xefueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other tristion ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Luad 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161			

FACILITY DESCRIPTION

LUCATION

DIST AND DIPECTION FROM NEAREST POPULATION CTR... 4 MI SE OF PLYMOUTH, MASS

DATE INITIAL CRITICALITY...JUNE 16, 15??

DATE ELEC ENER 1ST GENER...JULY 19, 1972

DATE COMMERCIAL OPERATE.... DECEMBER 1, 1972

CONDENSER COOLING METHOD ... ONCE THRU

CUNDENSER COOLING WATER....CAPE COD BAY

ELECTRIC RELIABILITY COUNCIL.....NORTHEAST POWER

COORDINATING COUNCIL

FACILIIY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....BOSTON EDISC.

CONTRACTOR

ARCHITECT/ENGINEER. BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER......GEMERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.... I

TE RESIDENT INSPECTOR.....C. WARREN

LICENSE & DATE ISSUANCE.... DPR-35, SEPTEMBER 15, 1972

PUBLIC DOCUMENT ROGM.....PLYMOUTH PUBLIC LIBRARY 11 NORTH STREET PLYMOUTH, MASSACHUSETTS 02360

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMERY

10 CFR 30.49(E)(1) REQUIRES FOR SAFETY RELATED ELECTRICAL EQUIPMENT LOCATED IN AN MARSH EMIRONMENTTHAT THE MOSE SEVERE DESIGN BASIS TIME REPENDENT TEMPERATURE BE ESTABLISHED AND THAT THE EQUIPMENT BE QUALIFIED FOR THE MOST SEVERE DESIGN BASIS TEMPERATURE CONDITION. CONTRARY TO THE ABOVE AS OF AUGUST 20, 1987, THE MOST SEVERE DESIGN BASIS TIME DEPENDENT TEMPERATURE HAD NOT BEEN ESTABLISHED FOR THE FOLLOWING ELECTRICAL EQUIPMENT IN THE DRYWELL: SOLENOID VALVE SV-220-44 AND CABLE SPLICE ASSEMBLIES Q102A, Q102B, 4203A AND Q103B. IT HAD BEEN ESTABLISHED ONLY THAT THE ABOVE DEVICES WERE QUALIFIED FOR A 'ARGE BREAK LOSS OF COLANT ACCIDDENT UP TO 290 DEGREES F. THIS TEMPERATURE WAS 30DEGREES F LOWER THAN THE TEMPERATURE PROFILE FOR A SMALL BREAK LOSA TO WHICH DRYWLL EQUIPMENT WOULD BE SUBJECTED, SUBSEQUENT TO THE INSPECTION, IT WAS DETERMINED THAT THESE DEVICES WERE ACTUALLY QUALIFIED TO THE MOST SEVERE TEMPERATURE PROFILE.

OTHER ITEMS

PAGE 2-314

Report Period APR 1988

英英英英英英英英英英英	英英兴美美兴美华美美美美美美美美美美美美	**
×	PILGRIM 1	×
!****	关关方关关关关关关关关关关关关关关关关	¥Ħ

OTHER ITEMS

SYSTEMS AND COMPONENTS:	
NO SNPUT PROVIDED.	
FACILITY ITEMS (PLANS AND PROCEDURES):	
NO INPUT PROVIDED.	
MANAGERIAL ITEMS:	
. INPUT PROVIDED.	
PLANT STATUS:	
NO INPUT PROVIDED.	
LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.	
INSPECTION REFORT NO: NO INFUT PROVIDED.	
REPORTS FROM LICENSEE	
NUMBER DATE OF DATE OF SUBJECT EVENT REPORT	
NO INPUT PROVIDED.	***************************************

1. Docket: _50-266_	OPERAT	TING S	TATUS					
2. Reporting Period: <u>04/01/83</u> Outage + On-line Hrs: <u>719.0</u>								
3. Utility Contact: C. W. K	RAUSE (414)	221-2001						
4. Licersed Thermal Power (M	Wt):		1518					
5. Nameplate Rating (Gross M	Nameplate Rating (Gross MWe): 582 X 0.9 = 524							
6. Design Electrical Rating	Design Electrical Rating (Net MWe): 497							
7. Maximum Dependable Capaci	Maximum Dependable Capacity (Gross MWe):509							
8. Maximum Dependable Capaci	Maximum Dependable Capacity (Net MWe): 485							
9. If Changes Occur Above Si	nce Last Re	port, Give	Reasons:					
NONE								
10. Power Level To Which Rest	ricted, If	Any (Net M	We):					
11. Reasons for Restrictions,	If Any:							
NONE								
12. Report Period Hrs	MON(H 719.0	YEAR 2.903.0	CUMULATIVE 153,263.0					
13. Hours Reactor Critical	195.4	2,379.4	125,147.2					
14. Rx Reserve Shtdwn Hrs	. 0	. 0	652.7					
15. Hrs Generator On-Line	193.4	2,377.4	122,422.1					
16. Unit Reserve Shtdwn Hrs	. 0	0	837.3					
17. Gross Therm Ener (MWH)	270,238	3,580,507	169,207,561					
18. Gross Elec Erer (MWH)	91,980	1,224,730	57,048,080					
19. Net Elec Ener (MWH)	86,164	1,172,729	54, 341, 157					
20. Unit Service Factor	26.9	81.9	79.9					
21. Unit Avail Factor	26.9	81.9	80.4					
22. Unit Cap Factor (MDC Net)	24.7	83.3	72.63					
23. Unit Cap Factor (DER Net)	24.1	81.3	71.3					
24. Unit Forced Outage Rate			2.1					
25. Forced Outage Hours	. 0	0	2,464.3					
26. Shutdowns Sched Over Next NONE	6 Months (Type,Date,I	Duration):					
27. If Currently Snutdown Est	imated Star	tup Date:	05/21/85					

POINT BEACH 1





* Item calculated with a Weighted Average

Report Farlod APR	1988		UN	IT	SHU	TDO	W N	IS .	R	E	DU	c	TI	0	N S	**************************************
No. Date 1	ype Hours	Reason	Method	LE	R Number	Syste	m C	ompor	nent	-		Ċ.	ause	8	Cor	rective Action to Prevent Recurrence
1 06/09/88	\$ 525 6	C	1			ZZ		ZZZZZ	ZZ	SH	UTD	DWN	FOR	R A	NNUA	L REFUELING AND MAINTENANCE.

POINT BEACH 1 SHUTDOWN ON APRIL 9 FOR SCHEDULED REFUELING OUTAGE. *****

* SUMMARY *

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint cr Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NU^EG-0161

FACILITY DESCRIPTION

LJCATION STATE.....WISCONSIN COUNTY.....MANITOWOC DIST AND DIRECTION FROM NEAREST POPULATION CTR...15 MI N OF MAMITOWOC, WISC TYPE OF REACTOR.....PWR DATE INITIAL CRITICALITY...NOVEMBER 2, 1970 DATE ELEC ENER 1ST GENER...NOVEMBER 2, 1970 DATE COMMERCIAL OPERATE....DECEMBER 21, 1970 CONDENSER COOLING METHOD...ONCE THRU CONDENSER COOLING WATER....LAKE MICHIGAN ELECTPIC RELIABILITY COUNCIL......MID-AMERICA

INTERPOOL NETWORK

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS......231 WEST MICHIGAN STREET MILWAUKEE, WISCONSIN 53201

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER. .. WESTINGHOUSE

CONSTRUCTOR BECHTEL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....R. HAGUE

LICENSE & DATE ISSUANCE.... DPR-24, OCTOBER 5, 1970

PUBLIC DOCUMENT ROOM.....JOSTPH MANN PUBLIC LIBRARY 1516 16TH ST. TWO RIVERS, WISCONSIN 54241 IN SPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON MARCH 7-11, 1988 (28007; 88007): ROUTINE, UNANNOUNCED inspection of the following areas of the Point Beach Nuclear Power Plant emergency preparedness program: action on previous Open Items; activations of the licensee's Emergency Plan; LER Review; operational status of the emergency preparecness program; emergency detection and classification; protective action decisionmaking; notifications and communications; shift staffing and augmentation; knowledge and performance of Juties (training); licensee audits; and handling of Information Notice 87-58. This inspection involved two NRC inspectors. No violations,

INSPECTION ON FEBRUARY 1, 1988 THROUGH MARCH 15, 1988 (88006; 88006): ROUTINE UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF LICENSEE ACTION ON previous inspection findings; temporary instructions; operational safety; maintenance; surveillance; physical security; radiological protection; bulletin followup; spent fuel pit activities; and licensee event report follow-up. No violations or deviations were identified.

INSPECTION ON MARCH 21 THROUGH 31, 1988 (88008; 88008): MANAGEMENT Effectiveness; Security Organization; Records and Reports; Testing and Maintenance; Physical Barriers - Protected and Vital Areas; Compensatory Measures; Assessment Aids; Access Control - Personnel, Packages and Vehicles; Detection Aids - Protected Areas; Alarm Stations, Training and Qualification; Safeguards Contingency Plan; Licensee action on previous inspection findings and a review of the circumstances surrounding the degraded sacurity barrier

XXXXXXXX	******	******	**********	****
×	POINT	BEACH	11	×
*******	******	******	******	****

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING AT POWER.

LAST IE SITE INSPECTION DATE: 03/31/88

INSPECTION REPORT NO: 88008

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

1.	Docket: <u>50-301</u>	PERAT	ING S	TATUS
2.	Reporting Period:	0utage	+ On-line	Hrs: 719.0
3.	Utility Contact: _ C. W. KR	RAUSE (414)	221-2001	
4.	Licensed Thermal Power (N)	4t):		1518
5.	Nameplate Rating (Gross M	le):	582 X	0.9 = 524
6.	Design Electrical Rating (Net MWe):		497
7.	Maximus Dependable Capacit	ty (Gross M	1We):	509
8.	Maximum Dependable Capacit	ty (Net MWe):	485
9.	If Changes Occur Above Sin NONE	nce Last Re	eport, Give	Reasons:
10.	Power Level To Which Restr	icted, If	Any (Net M	We):
11.	Reasons for Restrictions.	If Any:	1. S.	
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 138,048.0
13.	Hours Reactor Critical	699.6	2,883.6	121,278.0
14.	Rx Reserve Shtdwn Hrs	1.1	1.1	216.1
15.	Hrs Generator On-Line	656.2	2,840.2	_119,310.3
16.	Unit Reserve Shtdwn Hrs	5.0	5.0	297.4
17.	Gross Therm Ener (MWH)	949,345	4,255,442	168,826,037
18.	Gross Elec Ener (MWH)	323,700	1,457,430	57,237,650
19.	Net Elec Ener (MWH)	307,901	1,393,482	54,537,896
20.	Unit Service Factor	91.3	97.8	86.4
21.	Unit Avail Factor	92.0	98.0	86.6
22.	Uni Cap Factor (MDC Net)	88.3		80.6×
23.	Unit Cap Factor (DER Net)	86.2	96.6	79.5
24.	Unit Forced Outage Rate	3.5		1.2
25.	Forced Outage Hours	23.6	23.6	874.8
26.	Shutdowns Sched Over Next REFUELING/MAINT-SEPTEMBER	6 Months (Type,Date,1	Duration):
27.	If Currently Shutdown Esti	mated Star	tup Date:	N/A



* Item calculated with a Weighted Average

04/10/88 S 39.2 B 1 CH VALVEX SEPARATION BETWEEN THE VALVE STEM AND DISK OCCURRED ON A MAIN FEED PUMP DISCHARGE VALVE. THE UNIT WAS TAKEN OFF LINE WHILE REPAIRS WERE MADE.

********* POINT BEACH 2 INCURRED 2 POWER OUTAGES IN APRIL FOR * SUMMARY * REASONS STATED ABOVE.

2

Туре	Reason		Method	System & Component	
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)	

FACILITY DESCRIPTION

LOCATION STATE.....WISCONSIN

COUNTY.....MANITOWOC

DIST AND DIRECTION FROM AREST POPULATILY CTR...15 MI N OF MANITOWOC, WISC

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... MAY 30, 1972

DATE ELEC ENER 1ST JENER...AUGUST 2, 1972

DATE COMMERCIAL OPERATE.... OCTOBER 1, 1972

CONDENSER COOL: N3 METHOD...ONCE THRU

CONDENSER COOLING WATER....LAKE MICHIGAN

ELECTRIC RELIABILITY

COUNCIL.....MID-AMERICA INTERPOOL NETWORK

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE......WISCONSIN ELECTRIC POWER COMPANY

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC SIEAM SYS SUPPLIER ... WESTINGHOUSE

CONSTRUCTOR BECHTEL

TURBINE SUPPLIER......WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....R. HAGUE

LICENSE & DATE ISSUANCE.... DPR-27, MARCH 8, 1973

PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY 1516 16TH ST. TWO RIVERS, WISCONSIN 54241 IN SPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON MARCH 7-11, 1988 (88007; 88007): ROUTINE, UNANNOUNCED inspection of the following areas of the Point Beach Nuclear Power Plant emergency preparedness program: action on previous Open Items; activations of the licensee's Emergency Plan; LER Review; operational status of the emergency preparedness program; emergency detection and classification; protective action decisionmaking; notifications and communications; shift staffing and augmentation; knowledge and performance of duties (training); licensee audits; and handling of Information Notice 87-58. This inspection involved two NRC inspectors. No violations, deficiencies or deviations were identified. INSPECTION FROM FEBRUARY 1, 1988 THROUGH MARCH 15, 1988 (88006; \$8006): ROUTINE, UNANNOUCED INSPECTION BY RESIDENT INSPECTORS OF LICENSEE ACTION ON revious inspection findings; temporary instructions; operational safety; maintenance; surveillance; physical security; r diological protection; bulletin followup; spent fuel pit act.vities; and licensee event report follow-up. No violations or deviations were identified.

INSPECTION ON MARCH 21 THROUGH 31, 1988 (88008; 88008): MANAGEMENT Effectiveness; Security Organization; Records and Reports; Testing and Maintenance; Physical Barriers - Protected and Vital Areas; Compensatory Measures; As essment Aids; Access Control - Personnel, Packages and Vehicles; Detection Aids - Protected Areas; Alarm Stations, Training and Qualification; Safeguards Contingency Plan; Licensee action on previous inspection findings and a review of the circumstances surrounding the degraded security barrier

Report Period APR 1988

ENFORCEMENT SUMMARY

NONE

OTHEP ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UPERATING AT POWER.

LAST IE SITE INSPECTION DATE: 03/31/88

INSPECTION REPORT NO: 88008

REPORTS FROM LICENSEE

**********	**********		
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

1.	Docket: _50-282	PERAT	ING S	TATUS				
2.	Reporting Period:	88 Outage	+ On-line	Hrs: 719.0				
3.	Utility Contact:	STAD (612)	388-1121	Section 200				
4.	Licensed Thermal Power (M	Nt):		1650				
5.	Nameplato Rating (Gross M	Ne):	659 X (.9 = 593				
6.	Design Electrical Rating (Net MNe):530							
7.	Maximum Dependable Capacit	ty (Gross M	We):	534				
δ.	Maximum Dependable Capacit	ty (Net MWe):	503				
9.	If Changes Occur Above Sin NUNE	nce Last Re	port, Give	Reasons:				
10.	Power Level To Which Rest	ricted, If	Any (Net M	Ne):				
11.	Reasons for Restrictions, NONE	If Any:						
12.	Report Period Hrs	MCNTH 719.0	YEAR 2,903.0	CUMULATIVF _125,999.0				
13.	Hours Reactor Critical	715.0	2.821.4	105,364.6				
14.	R× Reserve Shtdwn Hrs		0	5,571.1				
15.	Hrs Generator On-Line	719.0	2,817.8	103,925.8				
16.	Unit Reserve Shtdwn Hrs		. 0					
17.	Gross Therm Ener (MWH)	1,177,831	4,562,258	163,616,182				
18.	Gross Elec Ener (MWH)	386,410	1,528,110	53,602,120				
19.	Net Elec Ener (MWH)	363,129	1,446,728	50,284,393				
20.	Unit Service Factor	100.0	97.1	32.5				
21.	Unit Avail Factor	100.0	97.1	82.5				
22.	Unit Cap Factor (MDC Net)	100.4	99.1	79.3				
23.	Unit Cap Factor (DER Net)	95.3	94.0	75.3				
24.	Unit Forced Outage Rate	.0		6.6				
25.	Forced Outage Hours	0	0					
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):				
27.	If Currently Shutdown Est	imated Star	tup Date:	N/A				

AVERAGE DAILY POWER LEVEL (MWe) PLOT PRAIRIE ISLAND 1



Report	Period APR 198*	UNIT SKUT	DOWNS / REDUCTION	S * PRAIRIE ISLAND 1 *
No.	Date Type Hours Reas	son Method LER Number	System Component Cause & /	Corrective Action to Provent Recurrence

		146.2	Live set. ac	TYR MIN ALL	LINLALINE.M	 A14594	A A IND ALLALLY			116 81 811	AV 11 414
1	04/09/88	S	0.0	В	5			TURBINE VALVES	TESTING.		

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE.....MINNESOTA

DIST AND DIRECTION FROM NEAREST POPULATION CTR...28 MI SE OF MINNEAPOLIS, MINN

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY...DECEMBER 1, 1973

DATE ELEC ENER 1ST JENER. .. DECEMBER 4, 1973

DATE COMMERCIAL OPERATE.... DECEMBER 16, 1973

CONDENSER COOLING METHOD...COOLING TOWERS

CONDENSER COOLING WATER....MISSISSIPPI RIVER

ELECTRIC RELIABILITY

COUNCIL.....MID-CONTINENT AREA RELIABILITY COORDINATION AGREEMENT

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS.......414 NICOLLET MALL MINNEAPOLIS, MINNESOTA 55401

CONTRACTOR ARCHITECT/ENGINEER......FLUOR PIONEER, INC.

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR......NORTHERN STATES POWER COMPANY

TURBINE SUPPLIER......WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....J. HARD

LICENSE & DATE ISSUANCE.... DPR-42, APRIL 5, 1974

PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY MINNEAPOLIS PUBLIC LIBRARY 300 NICOLLET MALL MINNEAPOLIS, MINNESOTA 55401

INSPECTION SUMMARY

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

Report Period APR 1988

Report Period APR 1988

GTHER ITEMS

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATED AT POWER TILL MARCH 10, 1988 TO REPAIR A LEAKING CANOPY SEAL WELD ON A REACTOR HEAD INSTRUMENT COLUMN. RESUMED POWER OPERATIONS ON MARCH 14, 1988 AND CONTINUED THRU THE END OF THE MONTH.

LAST IE SITE INSPECTION DATE: 04/02/88

INSPECTION REPORT NO: 88004

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

1.	Docket: _50-3060	PERAT	ING S	TATUS				
2.	Reporting Period: 04/01/88 Dutage + On-line Hrs: 719.0							
3.	Utility Contact: DALE DUGSTAD (612) 388-1121							
4.	Licensed Thermal Power (M)	4t):	199 <u></u>	1650				
5.	Nameplate Rating (Gross MWe): 659 . 0.9 = 593							
6.	Design Electrical Rating (Net MWe):530							
7.	Maximum Dependable Capacity (Gross MWe): 531							
8.	Maximum Dependable Capacit	ty (Net MWe):	500				
9.	If Changes Occur Above Since Last Report, Give Reasons:							
10.	Power Level To Which Restr	icted, If	Any (Net M	4e):				
11.	Reasons for Restrictions,	If Any:						
	NONE							
12.	Report Period Hrs	MONTH 719.0	2,903.0	117,117.0				
13.	Hours Reactor Critical	719.0	2,004.7	102,239.7				
14.	Rx Resorve Shtdwn Hrs	.0	.0	1,516.1				
15.	Hrs Canerator On-Line	719.0	1,985.2	<u>101,180.0</u>				
16.	Unit Reserve Shtdwn Hrs		0					
17.	Gross Therm Ener (MWH)	1,167,617	3,136,207	159,282,284				
18.	Gross Elec Ener (MWH)	380,710	1,030,360	51,862,690				
19.	Net Elec Ener (MWH)	358,475	972,202	48,751,625				
20.	Unit Service Factor	100.0	68.4	86.4				
21.	Unit Avail Factor	100.0	68.4	86.9				
22.	Unit Cap Factor (MDC Net)	99.7	67.0	83.3				
23.	Unit Cap Factor (DER Net)	94.1	63.2	78.5				
24.	Unit Forced Outage Rate	. 0		3.1				
25.	Forced Outage Hours		1.1	3,360.1				
26.	Shutdowns Sched Uver Next NONE	6 Months (Type,Date,	Duration):				
27	If Currently Shutdown Est	imated Star	tup Date:	NZA				

PRAIRIE ISLAND 2



APRIL 1968

Report	Period A	PR 19	88		UN	ΙT	SHU	тром	NS /	R	EDU) C	TI	0	N 5	S # PRAIRIE ISLAND 2 #
No.	Date	Type	Hours	Reason	Method	LER	Number	System	Compone	nt		¢	aus	e 8	3 Co	orrective Action to Prevent Recurrence
88-04-	04/04/88	s	0.0	F	5						LOAD	FOL	LOW	ι.		
880410	04/10/88	S	0.0	В	5						TURBI	NE	VAL	VES	S TE	ESTING AND 22 FEEDWATER PUMP WORK.

********** PRAIRIE ISLAND 2 INCURRED 2 POWER REDUCTIONS IN APRIL FOR * SUMMARY * REASONS STATED ABOVE.

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exam	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

***** PRAIRIE ISLAND 2 *******

FACILITY DESCRIPTION

LOCATION STATE.....MINNESOTA

DIST AND DIRECTION FROM NEAREST POPULATION CTR. .. 28 MI SE OF MINNEAPOLIS, MINN

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY., DECEMBER 17, 1974

DATE ELEC ENER 1ST GENER... DECEMBER 21, 1974

DATE COMMERCIAL OPERATE..., DECEMBER 21, 1974

CONDENSER COOLING METHOD...COOLING TOWERS

CONDENSER CGOLING WATER....MISSISSIPPI RIVER

ELECTRIC RELIABILITY

COUNCIL MID-CONTINENT AREA RELIABILITY COORDINATION AGREEMENT

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE......NORTHERN STATES POWER

MINNEAPOLIS, MINNESOTA 55401

CONTRACTOR ARCHITECT/ENGINEER......FLUOR PIONEER, INC.

NUC STEAM SYS SUPPLIER. .. WESTINGHOUSE

CONSTRUCTOR......NORTHERN STATES POWER COMPANY

TURBINE SUPPLIER......WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....J. HARD

LICENSING PROJ MANAGER.....D. DIIANNI DOCKET NUMBER 50-306

LICENSE & DATE ISSUANCE.... DPR-60, OCTUBER 29, 1974

PUBLIC DOCUMENT ROOM...... ENVIRONMENTAL CONSERVATION LIBRARY MINNEAPOLIS PUBLIC LIBRARY 300 NICOLLET MALL MINNEAPOLIS, MINNESOTA 55401 INSPECTION STATUS

INSPECTION SUMMARY

Inspection on February 14 through April 2, 1988 (88004; 88004): Routine unannounced inspection by resident inspectors of previous inspection findings, plant operational safety, maintenance, surveillances, ESF systems, LER followup, compliance bulletin followup, information notice followup, closeout of instructions. meetings with corporate management, and meetings with public officials. Of the ten areas inspected, one violation was identified; however, in accordance with 10 CFR 2, Appendix C, Section V.A., a Notice of Violation was not issued (failure to follow procedures).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

PAGE 2-330

Report Period APR 1988

Report Period APR 1988

OTHER ITEMS

NONE

FA_ILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATED CONTINUALLY THROUGHOUT MONTH.

LAST IE SITE INSPECTION DATE: 04/02/88

INSPECTION REPORT NO: 88004

REPORTS FROM LICENSEE

NUMBER DATE OF DATE OF SUBJECT EVENT REPORT

NONE

1.	Docket: _50-254_ 0	PERAT	ING S	TATUS			
2.	Reporting Period: _04/01/8	0utage	+ On-line	Hrs: 719.0			
3.	Utility Contact: K.A. SCH	MIDT (309)	654-2241)	2147			
4.	Licensed Thermal Power (MWt):2511						
5.	Nameplate Rating (Gross M	ie):	920 X 0	.9 = 828			
6.	Design Electrical Rating ((Net MKe):	-	789			
7.	Maximum Dependable Capacit	ty (Gross M	We):	813			
8.	Maximum Dependable Capacit	ty (Net MWe):	769			
9.	If Changes Occur Above Sin	nce Last Re	port, Give	Reasons:			
	NONE						
10.	Power Level To Which Restr	icted, If	Any (Net M	le):			
11.	Reasons for Restrictions,	If Any:					
	NONE						
		MONTH	YEAR	CUMULATIVE			
12.	Report Period Hrs	719.0	2,903.0	139,991.0			
3.	Hours Reactor C. 'tical		2,903.0				
4.	Rx Reserve Shtdwn Hrs	.0	0	3,421.9			
15.	Hrs Generator On-Line	659.2	2,836.3	108,293.8			
16.	Unit Reserve Shtdwn Hrs	.0	.0	909.3			
17.	Gross Therm Ener (MWH)	1,576,514	6,769,569	230,110,326			
18.	Gross Elec Ener (MWH)	510,823	2,210,059	74,635,677			
19.	Not Elec Ener (MWH)	486,946	2,112,685	70,016,75			
20.	Unit Service Factor	91.7	97.7	77.4			
21.	Unit Avail Factor	91.7	97.7	78.0			
	Unit Cap Factor (MDC Net)	88.1	94.6	65.0			
cz.	Unit Cap Factor (DER Net)	85.8	92.2	63.4			
23.				5.1			
23.	Unit Forced Outage Rate	8.3	2.5				
23. 24. 25.	Unit Forced Outage Rate Forced Outage Hours	<u>8.3</u> 59.8	66.7	3,503.1			
23. 24. 25. 26.	Unit Forced Outage Rate Forced Outage Hours Shutdowns Sched Over Next	8.3 59.8 6 Months (



APRIL 1988

Report Period APR 1988	UNIT SHUTDOWNS /	REDUCTIONS * QUAF	AREAR AREA
No. Date Type Hours Reason Me	athod LER Number System Compone	t Cause & Corrective Action to	Prevent Recurrence

88-3 04/08/88 F 59.8 A 9 HE PIPEXX MANUALLY TRIPPED TURBINE DUE TO EHC LINE OIL LEAK -UNIT REMAINED IN STARTUP/HOT STANDBY.

Type	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) file (NUREG-0161)

FACILITY DESCRIPTION

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE.....COMMONWEALTH EDISON

CORPORATE ADDRESS.....P.O. BOX 767 CHICAGO, ILLINOIS 60690

CONTRACTOR ARCHITECT/ENGINEER.....SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR......UNITED ENG. & CONSTRUCTORS

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....A. MADISON

LICENSE & DATE ISSUANCE.... DPR-29, DECEMBER 14, 1972

PUBLIC DOCUMENT ROOM.....DIXON PUBLIC LIBRARY 221 HENNEPIN AVENUE DIXON, ILLINOIS 61021 INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON MARCH 15-17, 1988 (88006; 88007): SPECIAL, ANNOUNCED FOLLOWUP inspection on the following areas of the emergency preparedness program: licensee actions on previously-identified items; evergency plan activations; review of licensee initiatives to improve the program following the November 1987 routine inspection; and perational status of the program. The inspection involved one NRC inspector. No violations of NRC requirements were identified.

INSPECTION ON FEBRUARY 7 THRCUGH APRIL 2, 1988 (88004; 88004): ROUTINE, unannounced resident inspection of Operation, Maintenance, surveillance, LER Review, Routine Reports, Temporary Instructions, Administrative Controls Affecting Quality, Radiation Control, and Outages. In the 9 areas inspected, no violations or deviations were identified in 8 areas; one violation was identified in the remaining area (failure to perform a surveillance within the required time interval); however, in accordance with 10 CFR 2 Appendix C, Section V.G.1, a Notice of Violation was not issued. This violation was of minor safety significance.

INSPECTION FROM SEPTEMBER 14, 1987 THROUGH MARCH 4, 1988 (87028; 87028): Special safety inspection of snubber surveillance and functional testing (70370), non-licensed training (41400) and licensee action on previously identified items (92700). Two apparent violations were identified (failure to accomplish activities in accordance with documented drawings; inadequate design control).

PAGE 2-334

Report Period APR 1988

Report Period APR 1988

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.2 REQUIRES THAT PROCEDURES BE ADHERED TO DURING PREVENTATIVE AND CORRECTIVE MAINTENANCE OPERATIONS. CONTRARY TO THE ABOVE, STATION PROCEDURE QIP 5700-2, "FILLING PROCEDURE FOR THE CHLORINE ANALYZER PROBE," WHICH CAUTIONS THAT A CONTROL ROOM ISOLATION WILL OCCUR DURING THIS PROCEDURE AND THAT THE CONTROL ROOM SHOULD BE NOTIFIED, WAS NOT FOLLOWED ON FEBRUARY 1, 1988, RESULTING IN AN UNEXPECTED ESF ACTUATION. (8703 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

CURRENTLY SHUTDOWN ON 5/7 FOR DUAL UNIT OUTAGE EXPECTED TO END 5/16/88.

LAST IE SITE INSPECTION DATE: 04/08/88

INSPECTION REPORT NO: 88008

REPORTS FROM LICENSEE

N	IUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
8	8-06	032588	041288	MISSED TECHNICAL SPECIFICATIONS REQUIRED SURVEILLANCE DUE TO SCHEDULING LAPS
8	8-08	040888	042688	GROUP I ISOLATION IN STARTUP/HOT STANDBY MODE CAUSED BY REACTOR MODE SWITCH ROTATIONAL PLAY

1. Docke	t: <u>57-265</u> 0	PERAT	ING S	TATUS				
2. Repor	Reporting Period: 04/01/88 Outage + On-line Hrs: 719.0							
3. Utili	Utility Contact: K.A. SCHMIDT (309) 654-2241 X 2147							
4. Licer	Licensed Thermal Power (MWt):2511							
5. Namer	late Rating (Gross MW	e):	920 X (1.9 = 828				
6. Desig	m Electrical Rating (Net MWe):		789				
7. Maxim	um Dependable Capacit	y (Gross M	We):	813				
8. Maxim	um Dependable Copacit	y (Net MWe):	769				
9. If CH	anges Occur Above Sin	ce Last Re	port, Give	Reasons:				
NONE								
10. Power	Level To Which Restr	icted, If	Any (Net M	4e):				
11. Reaso	ons for Restrictions,	If Any:						
NONE								
12. Repor	t Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 139,101.0				
13. Hours	s Reacior Critical	228.9	2,289.8	106,947.2				
14. R× R	eserve Shtdwn Hrs	. 0	. 0	2,985.8				
15. Hrs (Generator On-Line	228.4	2,261.9	103,797.3				
16. Unit	Reserve Shtdwn Hrs	. 0	. 0	702.9				
17. Gross	s Therm Ener (MWH)	490,072	5,138,743	222,509,310				
18. Gross	s Elec Ener (MWH)	162,610	1,669,730	71,227,504				
19. Net 1	Elec Ener (MWH)	154,459	1,599,345	67,150,776				
20. Unit	Service Factor	31.8	77.9	74.6				
21. Unit	Avail Factor	31.8	77.9	75.1				
22. Unit	Cap Factor (MDC Net)	27.9	71.6	62.8				
23. Unit	Cap Factor (DER Net)	27.2	69.8	61.2				
24. Unit	Forced Outage Rate	. 0	6.2	8.2				
25. Forc	ed Outage Hours	. 0	150.5	5,433.7				
26. Shut	downs Sched Over Next	6 Months (Type,Date,	Duration):				
NONE								

QUAD CITIES 2



APRIL 1988

Report Period APR 1988	UNIT SHU	TDOWNS / REDUCTIONS	xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx
		Entre Course & Course	active Action to Provent Recurrence

 No.
 Date
 Type
 Hours
 Reason
 Method
 LER
 Number
 System
 Component
 Cause & Corrective Action to Prevent Recurrence

 88-5
 04/10/88
 S
 490.6
 C
 1
 RC
 FUEiXX
 END OF CYCLE NINE REFUELING OUTAGE.

********* QUAD CITIES 2 COMMENCED REFUELING OUTAGE IN APRIL. * SUMMARY *

Type	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161

FACILITY DESCRIPTION

INTERPOOL NETWORK

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....COMMONWEALTH EDISON

CORPORATE ADDRESS......P.O. BOX 767 CHICAGO, ILLINOIS 60690

CONTRACTOR ARCHITECT/ENGINEER......SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.......UNITED ENG. & CONSTRUCTORS

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....A. MADISON

LICENSE & DATE ISSUANCE.... DPR-30, DECEMBER 14, 1972

PUBLIC DOCUMENT ROOM.....DIXON PUBLIC LIBRARY 221 HENNEPIN AVENUE DIXON, ILLINOIS 61021 INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON MARCH 15-17, 1988 (88006; 88007): SPECIAL, ANNOUNCED FOLLOWUP inspection on the following areas of the emergency preparedness program: licensee actions on previously-identified items; emergency plan activations; review of licensee initiatives to improve the program following the November 1987 routine inspection; and operational status of the program. The inspection involved one NRC inspector. No violations of NRC requirements were identified.

INSPECTION ON FEBRUARY 7 THROUGH APRIL 2, 1988 (88004; 88004): ROUTINE, unannounced resident inspection of Operation, Maintenance, surveillance, LER Review, Routine Reports, Temporary Instructions, Administrative Controls Affecting Quality, Radiation Control, and Outages. In the 9 areas inspected, no violations or deviations were identified in 8 areas; one violation was identified in the remaining area (failure to perform a surveillance within the required time interval); however, in accordance with 10 CFR 2 Appendix C, Section V.G.1, a Notice of Violation was not issued. This violation was of minor safety significance.

INSPECTION FROM SEPTEMBER 14, 1987 THROUGH MARCH 4, 1988 (87028; 87028): Special safety inspection of snubber surveillance and functional testing (70370), non-licensed training (41400) and licensee action on previously identified items (92700). Two apparent violations were identified (failure to accomplish activities in accordance with documented drawings; inadequate design control).

**** QUAD CITIES 2 × *****

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT S/D FOR REFUELING ON 4/10/88.

LAST IE SITE INSPECTION DATE: 04/08/88

INSPECTION REPORT NO: 88009

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-03	032988	042888	INITIATION OF 'PHASE A' CONTAINMENT ISOLATION DURING SAFEGUARDS TESTING DUE TO OPERATOR ERROR. LIMITS

1.	Docket: 50-312 0	PERAT	INGS	TATUS	
2.	Reporting Period: _04/01/8	8_ Outage	+ On-line	Hrs: 719.0	
3.	Utility Contact: R. MILLE	R (916) 452	-3211 X447	7	
4.	Licensed Thermal Power (MW		2772		
5.	Nameplate Rating (Gross MW	1070 X	1070 X 0.9 = 963		
6.	Design Electrical Rating (Net MWe):		918	
7.	Maximum Dependable Capacit	y (Gross MW	le):	917	
8.	Maximum Dependable Capacit	y (Net MWe)	2	873	
9	If Changes Occur Above Sin	ce Last Rep	ort, Give	Reasons:	
	NONE				
10	Power Level To Which Restr	icted. If A	ny (Net M	4e):	
11	Reasons for Restrictions.	If Any:			
	NONE				
-	NUME	MONTH	YFAR		
12.	Report Period Hrs	719.0	2,903.0	114,288.0	
13.	Hours Reactor Critical	688.1	691.6	53,256.6	
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	10,647.7	
15.	Hrs Generator On-Line	449.8	449.8	50,813.6	
16.	Unit Reserve Shtdwn Hrs	. 0	.0	1,210.2	
17.	Gross Therm Ener (MWH)	377,080	377,080	124,605,615	
18.	Gross Elec Ener (MWH)	112,743	112,743	41,640,892	
19.	Net Elec Ener (MWH)	85,894	45,569	39,034,764	
20.	Unit Service Factor	62.6	15.5	44.5	
21.	Unit Avail Factor	62.6	15.5	45.5	
22.	Unit Cap Factor (MDC Net)	13.7	1.8	39.1	
23.	Unit Cap Factor (DER Net)	13.0	1.7	37.2	
24.	Unit Forced Outage Rate	. 0	82.7	44.7	
25.	Forced Outage Hours	. 0	2,143.0	41,048.5	
26.	Shutdowns Sched Over Next	6 Months (1	ype, Date,	Duration):	
	REACTOR TRIPS 5/5 THRU 5/1	1 AND 9/24	THRU 9/28		
27	If Currently Shutdown Esti	mated Start	tup Pate:	N/A	
del 1	at our tencay should user			the second data and the se	

×	RANO	CHO SEC	CO 1		*
******	******	*****	*****	*****	EXXXX
AVERAGE	DAILY	POWER	LEVEL	(MWe)	PLOT

RANCHO SECO 1



APRIL 1988
Report	Period Af	PR 19	88		U N	тт сни	трэм	NS / R	E D U C T I O N S RANCHO SECO 1 * *********************************
No.	Date	Туре	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
2	03/30/88	s	260.8	Ε	4				OPERATOR TRAINING AND TESTING PRIOR TO POWER GENERATION (REACTOR BROUGHT CRITICAL 17 TIMES IN APRIL FOR TRAINING)
3	04/11/88	s	8.4	В	1				THE TURBINE WAS TRIPPED AS PART OF THE POWER ASCENSION

******	RANCHO SECO 1	INCURRED	2	SCHEDULED	OUTAGES	IN	APRIL	FOR
* SUMMARY *	REASONS STATE	D ABOVE.						

Type	Reason	Method	System & Component				
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)				

FACILITY DESCRIPTION

LOCATION STATE.....CALIFORNIA COUNTY.....SACRAMENTO DIST AND DIRECTION FROM NEAREST POPULATION CTR...25 MI SE OF SACRAMENTO, CA TYPE OF REACTOR.....PWR DATE INITIAL CRITICALITY...SEPTEMBER 16, 1974 DATE ELEC ENER 1ST GENER...OCTOBER 13, 1974 DATE COMMERCIAL OPERATE....APRIL 17, 1975 CONDENSER COOLING METHOD...COOLING TOWERS CONDENSER COOLING WATER....FOLSOM CANAL ELECTRIC RELIABILITY COUNCIL......WESTERN SYSTEMS COORDINATING COUNCIL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER... BABCOCK & WILCOX

COWSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V

IE RESIDENT INSPECTOR.....A. DANGELO

LICENSING PROJ MANAGER.....G. KALMAN DOCKET NUMBER......50-312

LICENSE & DATE ISSUANCE.... DPR-54, AUGUST 16, 1974

PUBLIC DOCUMENT ROOM.....BUSINESS AND MUNICIPAL DEPARTMENT SACRAMENTO LIBRARY 828 I STREET SACRAMENTO, CALIFORNIA 95814

INSPECTION SUMMARY

+ INSPECTION ON DECEMBER 7, 1987 - FEBRUARY 18, 1988 (REPORT NO. 50-312/87-40) HEADQUARTERS' REPORT - LETTER ISSUED ON APRIL 26, 1988.

RESULTS: NO TEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JANUARY 4 - MARCH 10, 1988 (REPORT NO. 50-312/88-02) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 4 - MARCH 25, 1988 (REPORT NO. 50-312/88-05) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON MARCH 7 - 22, 1988 (REPORT NO. 50-312/88-08) AREAS INSPECTED: SPECIAL UNNANNOUNCED INSPECTION BY A REGIONALLY BASED INSPECTOR TO REVIEW THE LICENSEE'S CAPABILITIES FOR THE MANAGEMENT AND IMPLEMENTATION OF AN EFFECTIVE LIQUID AND GASEOUS EFFLUENT PROGRAM AFTER RESTART; REVIEW THE STATUS OF UNRESOLVED ITEM 88-07-01 RELATED TO A POTENTIAL OVEREXPOSURE REPORTED BY THE LICENSEE ON FEBRUARY 4, 1988; REVIEW THE LICENSEE'S RADIATION PROTECTION, CHEMISTRY AND RADWASTE ORGANIZATION, INCLUDING A REVIEW OF THE RADIATION PROTECTION, CHEMISTRY AND RADWASTE STAFF QUALIFICATION AND TRAINING PROGRAM; REVIEW OF FOLLOWUP ITEMS; AND A TOUR OF THE FACILITY. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: OF THE AREAS INSPECTED, TWO VIOLATIONS RELATED TO UNRESOLVED ITEM 88-07-01 WERE IDENTIFIED INVOLVING FAILURE TO ADHERE TO RADIATION PROTECTION PROCEDURES, TECHNICAL SPECIFICATION 6.11, AND FAILURE TO PROVIDE INSTRUCTIONS TO WORKERS, 10 CFR PART PAGE 2-342 Report Period APR 1988

INSPECTION SUMMARY

19.12. THE LICENSEE'S PERFORMANCE IN THE REMAINING AREAS THAT WERE EXAMINED MET THE REGULATORY REQUIREMENTS. AS A RESULT OF THE INSPECTION FINDINGS AND THE MANAGEMENT MEETING, REGION V FOUND THAT THE RADIATION PROTECTION PROGRAM WAS ADEQUATE TO SUPPORT RESTART.

+ INSPECTION ON MARCH 20 - APRIL 8, 1988 (REPORT NO. 50-312/88-10) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON MARCH 17, 1988 (REPORT NO. 50-312/88-11) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF AN UNUSUAL EVENT ON MARCH 15, 1988. DURING THIS INSPECTION, ONE INSPECTION PROCEDURE WAS UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MARCH 30 - MAY 2, 1988 (REPORT NO. 50-312/88-12) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 8 - 19, 1988 (REPORT NO. 50-312/88-13) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH,.

+ INSPECTION ON APRIL 21 - 29, 1988 (REPORT NO. 50-312/88-14) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

QAP-17 AND 10 CFR 50 APPENDIX B REQUIRED COMPLETION OF ECN/DCN DISPOSITION PRIOR TO CLOSURE OF A RELATED NONCOMFORMANCE REPORT. CONTRARY TO THIS REQUIREMENT, ON THREE OCCASIONS NOTED, AN NCR WAS CLOSED PRIOR TO COMPLETION OF THE RELATED ENGEMEERING CHANGE NOTICE (ECN) OR OF THE ACTIONS OF THE NCR ITSELF.

(8704 4)

10 CFR 50, APPENDIX B, CRITERION V, REQUIRES THAT ACTIVITIES AFFECTING QUALITY SHALL BE PRESCRIBED BY DOCUMENTED INSTRUCTIONS, PROCEDURES OR DRAWINGS AND SHALL BE ACCOMPLISHED IN ACCORDANCE WITH THESE INSTRUCTIONS, PROCEDURES, OR DRAWINGS. SMUD MATERIALS MANAGEMENT PROCEDURE MMP-0025, "PRESERVATION, STORAGE, AND MAINTENANCE OF ITEMS IN STORAGE," PARAGRAPH 7.6.5, REQUIRES THAT ITEMS WHOSE SHELF LIFE HAS EXPIRED SHALL BE REMOVED FROM THEIR STORAGE LOCATION AND PLACED IN A "HOLD" LOCATION RANCHO SECC MANAGEMENT INFORMATION SYSTEM REPORT RSM4 0330, DATED JANUARY 4, 1988, IDENTIFIED MATERIALS WITH EXPIRATION DATES F& THE FIRST QUARTER OF 1988. CONTRARY TO THE STATLD REQUIREMENTS, ON FEBRUARY 4, 1988, THREE SAFETY-RELATED RSMM 0330 GALKET LINE ITEMS (9 PIECES), WITH EXPIRED SHELF LIVES, WAD NOT BEEN TAGGED OR PLACED IN A HOLD LOCATION. TECHNICAL SPECIFICATION 6.12, HIGH RADIATION AREA, READS IN PART: "IN LIEU JF THE "CONTROL DEVICE" OR "ALARM SIGNAL" REQUIRED BY PARAGRAPH 20.203(C)(2) OF 10 CFR 20, EACH HIGH RADIATION AREA IN WHICH THE INTENSITY OF RADIATION IS GREATER THAN 100 MREM/HR BUT LESS THAM 100 MREM/HR SHALL BE BARRICADED AND CONSPICUOUSLY POSTED AS / HIGH RADIATION AREA AND ENTRANCE THERETO SHALL BE CONTROLLED BY REQUIRING ISSUANCE OF A RADIATION EXPOSURE PERMIT...." CONTRARY TO THE STATED REQUIREMENTS, ON MARCH 1, 1988, A HIGH RADIATION AREA BEHIND STEAM GENERATOR "A" ON THE 31" ELEVATION OF THE UNIT 1 CONTALIMENT IN WHICH THE INTENSITY OF RADIATION RANGED UP TO 200 MREM/HR WAS NOT BARRICADED AND POSTED AS A HIGH RADIATION AREA.

(8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

PLANT IS PERFORMING HOT SHUTDOWN TESTING AND WILL BE PERFORMING STEPPED INCREASES TO COMMERCIAL OPERATION. TDI EDG TESTING IS ALSO IN PROGRESS.

Report Period APR 1988

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

+ PLANT HAD BEEN SHUT DOWN SINCE DECEMBER 26, 1985. NUCLEAR REGULATORY COMMISSION APPROVAL FOF RESTART WAS OBTAINED ON MARCH 22, 1988. STARTUP COMMENCED MARCH 30, 1988.

NRC SALP BOARD MEETING WAS HELD ON AUGUST 12, 1986.

PLANT STATUS:

+ THE PLANT IS CURRENTLY PERFORMING A GRADUAL APPROACH TO FULL POWER TEST PROGRAM. A TURBINE TRIP FROM APPROXIMATELY 25 PERSENT POWER WAS PERFORMED ON MAY 4, 1988

LAST IE SITE INSPECTION DATE: 03/30 - 05/02/88+

INSPECTION REPORT NO: 50-312/88-12+

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

88-02-LO 02-03-88 02-25-88 PERSONNEL ERROR EDG "A" INADVERTENT START.

Page 2-345

THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docket: <u>50-458</u> 0 P E R A T I N (S STATUS
2.	Reporting Period: 04/0:/88 Outage + On-	line Hrs: 719.0
3.	Utility Contact: N. MARTIN (504) 635-6	5094 X4836
4.	Licensed Thermal Power (MWt):	2894
5.	Namoplate Rating (Gross MWe):	2894
6.	Design Electrical Rating (Net MWe):	936
7.	Maximum Dependable Capacity (Gross MWe):	936
8.	Maximum Dependable Capacity (Net MWe):	936
9.	If Changes Occur Above Since Last Report,	Give Reasons:

10. Power Level To Which Restricted, If Any (Net HWe):_____

11. Reasons for Restrictions, If Any:____

-	NONE			A second second
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 21,119.0
13.	Hours Reactor Critical	719.0	2,735.7	14,449.8
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	. 0
15.	Hrs Generator On-Line	719.0	2,678.3	13,210.1
16.	Unit Reserve Sittdwn Hrs	. 0	. 0	. 0
17.	Gross Therm Ener (MWH)	2,058,013	7,484,314	32,954,198
18.	Gross Elec Ener (MWH)		2,589,791	11,210,665
19.	Net Elec Ener (MWH)	666,420	2,429,895	10,455,100
20.	Unit Service Factor	100.0	92.3	62.6
21.	Unit Avail Factor	100.0	92.3	62.6
22.	Unit Cap Factor (MDC Net)	99.0	89.4	52.9
23.	Unit Cap Factor (DER Net)		89.4	52.9
24.	Unit Forced Outage Rate	. 0	6.7	13.1
25.	Forced Outage Hours	. 0	193.5	1,991.0
26.	Shutdowns Sched Over Next NONE	6 Months (Type,Date,D	Ouration):
27 .	If Currently Shutdown Est	imated Star	tup Date:	N/A



RIVER BEND 1



APRIL 1000

Report	Period Af	PR 19	88		UN	ΙT	SH	U T	D	0 4	I N	S	1	R	E I	DU	с	T I	0	N	s	x RIVER BEND 1 x xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx
No.	Date	Type	Hours	Reason	Method	LER	Numbe	<u> </u>	Sy:	ster	Ē	011,2	onen	<u>t</u> :	-		C	aus	Q .	8 0	orr	ective Action to Prevent Recurrence
88-06	04/15/88	s	0.0	Α	5									1	REI	DUCE	D	POW R H	ER	TER	0 65 1 LE	Z TO FIX ACTUAYOR ON FIRST POINT VEL VALVE 1HDH-SOV6A.

*********	RIVER BEND	1	INCURRED	1	POWER	REDUCTION	IN	APRIL	TO	REPAIR
* SUMMARY *	VALVE.									

Туре	Reason		Method	System & Component			
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exam	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161			

FACILITY DESCRIPTION

LOCATION STATELOUISIANA
COUNTYWEST FELICIANA
DIST AND DIRECTION FROM NEAREST POPULATION CTR24 MI NNW OF BATON ROUGE, LA
TYPE OF REACTORBWR
DATE INITIAL CRITICALITYOCTOBER 31, 1985
DATE ELEC ENER 1ST GENERDECEMBER 3, 1985
DATE COMMERCIAL OPERATEJUNE 16, 1986
CONDENSER COOLING METHODMDCT
CONDENSER COOLING WATERMISSISSIPPI RIVER
ELECTRIC RELIABILITY COUNCIL

FACILITY DATA

Report Period APR 1980

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE......GULF STATES UTILITIES

CORPORATE ADDRESS......P.O. BOX 2951 BEAUMONT, LOUISIANA 77704

CONTRACTOR ARCHITECT/ENGINEER......STONE & WEBSTER

NUC STEAM SYS SUPPLIER ... GENERAL ELECTRIC

CONSTRUCTOR......STONE & WEBSTER

TURBINE SUPPLIER......GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV

IE RESIDENT INSPECTOR.....D. CHAMBERLAIN

LICENSE & DATE ISSUANCE....NPF-47, NOVEMBER 20, 1985

PUBLIC DOCUMENT ROOM......GOVERNMENT DOCUMENTS DEPARTMENT TROY H. MIDDLETON LIBRARY LOUISIANA STATE UNIVERSITY BATON ROUGE, LOUISIANA 70803

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

PLANT ST	ATUS											
INFO.	NOT SUPPLIE	D BY REGION										
LAST IE	SITE INSPEC	TION DATE:	NFO. NOT SUPPLIED BY REGION									
INSPECTI	INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION											
REPO	RTS FR	OM LIC	NSEE									
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT									
INFO.	NOT SUPPLIE	D BY REGION										

1.	Docket: _50-261	DPERAI	FING S	TATUS						
2.	Reporting Period: 04/01/8	0utage	+ On-line	Hrs: 719.0						
3.	Utility Contact: V.E. FR	ZIER (893)	383-4524	x 1229						
4.	Licensed Thermal Power (M)	(t):		2300						
5.	5. Nameplate Rating (Gross MWe): 854 X 0									
6.	Design Electrical Rating (700							
7.	Maximum Dependable Capacit	ty (Gross M	tkie):	700						
8.	Maximum Dependable Capacit	:	665							
9.	. If Changes Occur Above Since Last Report, Give Reasons: NUNE									
10.	Power Level To Which Restr	icted, If	Any (Net M	We): 420						
11.	Reasons for Restrictions,	If Any:								
_	ADMINISTRATIVE									
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE						
13.	Hours Reactor Critical	699.1	1,888.0	107,417.2						
14,	R× Reserve Shtdwn Hrs	. 0	. 0	3,159.6						
15.	Hrs Generator On-Line	696.7	1,848.3	104,872.6						
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	23.2						
17.	Gross Therm Ener (MWH)	947,988	3,050,147	211,202,708						
18.	Gross Elec Ener (MWH)	299,504	995,736	68, 379, 073						
19.	Net Elec Ener (MWH)	280,431	934,654	64,612,583						
20.	Unit Service Factor	96.9	63.7	69.7						
21.	Unit Avail Factor	96.9	63.7	69.7						
22.	Unit Cap Factor (MDC Net)	58.7	48.4	64.6						
23.	Unit Cap Factor (DER Net)	55.7	46.0	61.4						
24.	Unit Forced Outage Rate	3.1	36.3	14.0						
25.	Forced Outage Hours	22.3	1,053.8	11,256.5						
26.	Shutdowns Sched Over Next	6 Months (Type, Date, D)uration):						
-	REFUELING/MAINT, NOV. 12,	1988, 49 D	AY DURATION							
27.	If Currently Shutdown Estin	mated Star	tup Date:	05/02/88						

******	*****	*****	*****	*****	****
×	R	BINSO	N 2		×
******	*****	*****	******	*****	****
AVERAGE	DAILY	POWER	LEVEL	(Mke)	PLOT

ROBINSON 2



* RIL 1988

PAGE 2~350

Report	Period Al	PR 19	88		UN	ŢΤ	SHU	тром	NS / R	E D U C T I O N S ROBINSON 2 K
No	Date	Type	Hours	Reason	Method	LER	Number	System	Component	Cause & Corrective Action to Prevent Recurrence
0401	04/18/88	F	0.0	Α	5			сJ	INSTRU	THE UNIT WAS REDUCED IN POWER FROM 60% TO 35% FOR REPLACEMENT AND RECALIBRATION OF REACTOR COOLANT FLOW TRANSMITTER (FT-436). THE TRANSMITTER WAS REPLACED, RECALIBRATION WAS COMPLETED, AND THE UNIT RETURNED TO 60% REACTOR POWER.
0402	04/30/88	F	22.3	۸	1.			CB	VALVEX	THE UNIT WAS TAKEN TO HOT SHUTDOWN DGE TO RCS LEAK IN CV. THE LEAK WAS DETERMINED TO BE FROM "C" RTD BYPASS LOOP ISO:ATION VALVE PACKING. MAINTENANCE WAS PERFORMED, THE LEAK STOPPED, AND THE UNIT RETURNED TO POWER.

********* * SUMMARY	** ROBINSON 2 * INCURRED 1 ** FOR REASON	OPERATED AT A POWER REDUCTI S STATED ABOVE	NOMINAL POWER L ON AND 1 FORCED	EVEL OF 60% AND OUTAGE IN APRIL
Type	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test	F-Admin G-Oper Error	1-Manual 2-Manual Scram	Schibit F & H Instructions for

C-Refueling H-Other 3-Auto Scram Preparation of D-Regulatory Restriction 4-Continued Data Entry Sheet E-Operator Training 5-Reduced Load Licensee Event Report & License Examination 9-Other (LER) File (NUREG-0161)

******** ROBINSON 2 ********

FACILITY DESCRIPTION

LOCATION STATE.....SOUTH CAROLINA

COUNTY......DARLINGTON

DIST AND DIRECTION FROM NEAREST POPULATION CTR...5 MI NW OF HARTSVILLE, SC.

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY...SEPTEMBER 20, 1970

DATE ELEC ENER 1ST GENER...SEPTEMBER 26, 1970

DATE COMMERCIAL OPERATE.... MARCH 7, 1971

CONDENSER COOLING METHOD...RECIRCULATION

CONDENSER COOLING WATER....ROBINSON IMPOUNDMENT

ELECTRIC RELIABILITY

RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE.....CAROLINA POWER & LIGHT

CORPORATE ADDRESS......411 FAYETTEVILLE STREET RALEIGH, NORTH CAROLINA 27601

CONTRACTOR ARCHITECT/ENGINEER.....EBASCO

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR..... EBASCO

TURBINE SUPPLIER......WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

LICENSE & DATE ISSUANCE....DPR-23, SEPTEMBER 23, 1970

PUBLIC DOCUMENT ROOM HARTSVILLE MEMORIAL LIBRARY 220 N. FIFTH ST. HARTSVILLE, SOUTH CAROLINA 29550 INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION JANUARY 11-29 (88-01): THIS SPECIAL, ANNOUNCED QUALITY VERIFICATION INSPECTION WAS CONDUCTED IN THE AREAS OF MAINTENANCE, DESIGN CONTROL, OPERATIONS, COMMERCIAL GRADE PROCUREMENT, AND QUALITY ASSURANCE/ QUALITY CONTROL. FOUR VIOLATIONS WERE IDENTIFIED INVOLVING FAILURE TO MEET REPORTABILITY REQUIREMENTS, FAILURE TO PERFORM FOST-MODIFICATION TESTING, FAILURE TO MAINTAIN RECORDS, AND FAILURE TO FOLLOW PROCEDURES RELATING TO TEMPORARY REPAIRS, WORK REQUESTS, AND THE TREND ANALYSIS PROGRAM. ONE UNRESOLVED ITEM WAS IDENTIFIED RELATED TO USE OF COMMERCIAL GRADE PROCURED ITEMS AND USE OF COMMERCIAL GRADE PROCURED ITEMS IN EQ APPLICATIONS.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

PAGE 2-352

Report Period APR 1988

IE RESIDENT INSPECTOR.....P. KRUG LICENSING PROJ MANAGER.....R. LO

Report Period APR 1988

OTHER ITEMS

+ (SEE PLANT STAUTS)

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

+ DUE TO SINGLE FAILURE EDG/SI PUMP CONCERN, PLANT IS LIMITED TO 60% POWER OPER. UNIT TRIPPED ON 5/12 DURING LOGIC TESTING OF TURBINE REDUNDENT OVERSPEED TRIP

LAST IE SITE INSPECTION DATE: JANUARY 11-29, 1988 +

INSPECTION REPORT NO: 50-261/88-01 +

REPORTS FROM LICENSEE

********	*********	*********		
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT	
	take and and take has take the data for the loss	and the second second problem and the second		

NONE.

P/ SE 2-353

1.	Docket: 50-272	PERAT	ING S	TATUS
2.	Reporting Period: _04/01/8	0utage	+ On-line	Hrs: 719.0
3.	Utility Contact:BRYAN N.	GORMAN (6	09) 339-340	0
4.	Licensed Thermal Power (MM	it):		3411
5.	Nameplate Rating (Gross M	le):	1300 X	0.9 = 1170
6.	Design Electrical Rating (Net MWe):		1115
7.	Maximum Dependable Capacit	ty (Gross M	We):	1149
8.	Maximum Dependable Capacit	ty (Net MWe):	1106
9.	If Changes Occur Above Sir NONE	nce Last Re	port, Give	Reasons:
10.	Power Level To Which Restr	icted, If	Any (Net M	le):
11.	Reasons for Restrictions,	If Any:		
_	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE
13.	Hours Reactor Critical	375.3	1.7- 3	58,919.4
14.	Rx Reserve Shtdwn Hrs		.0	3,088.4
15.	Hrs Generator On-Line	369.7	1,141.2	56,932.8
16.	Unit Reserve Shtdwn Hrs			
17.	Gross Therm Ener (MWH)	1,244,849	3,766,834	176,238,047
18.	Gross Elec Ener (MWH)	418,050	1,263,400	58,455,688
19.	Net Elec Ener (MWH)	397,875	1,186,440	55,583,149
20.	Unit Service Factor	51.4	39.3	59.5
21.	Unit Avail Factor	51.4	39.3	59.5
22.	Unit Cap Factor (MDC Net)	50.0		52.5
23.	Unit Cap Factor (DER Net)	49.6	36.7	52.5
24.	Unit Forced Dutage Rate	.1	3.2	25.3
25.	Forced Outage Hours	.2	38.2	19,498.0
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):
27	If Currently Shutdown Est	imated Star	tup Date:	N/A







APRIL 1988

Report	Period Al	PR 19	88		UN	IT	SHU	TDOW	NS / R	E D U C T I O N S × SALEM 1 × ×××××××××××××××××××××××××××××××××	
No.	Date	Type	Hours	Reason	Method	LER	Number	System	Component	Cause & Corrective Action to Prevent Recurrence	1
0032	03/31/88	s	349.1	в	4			CB	HTEXCH	NUCLEAR STEAM GENERATOR TUBE LEAK	
0040	04/30/88	F	0.2	2	3			CC	VESSEL	LOSS OF PRESSURIZ'R PRESSURE.	

Type	Reason		Method	System & Component
i-Forced S-Sched	A-Equip failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

STATE.....NEW JERSEY

DIST AND DIRECTION FROM NEAREST POPULATION CTR...20 MI S OF WILMINGTON, DEL

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...DECEMBER 11, 1976

DATE ELEC ENER 1ST GENER... DECEMBER 25, 1976

DATE COMMERCIAL OPERATE....JUNE 30, 1977

CONDENSER COOLING METHOD ... ONCE THRU

CONDENSER COOLING WATER ... DELAWARE RIVER

ELECTRIC RELIABILITY

COUNCILMID-ATLANTIC AREA COUNCIL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE PUBLIC SERVICE ELECTRIC & GAS

CONTRACTOR

ARCHITECT/ENGINEER.....PUBLIC SERVICES & GAS CO.

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

TURBINE SUPPLIER......WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....T. LINVILLE

LICENSE & DATE ISSUANCE.... DPR-70, DECEMBER 1, 1976

PUBLIC DOCUMENT ROOM......SALEM FREE PUBLIC LIDRARY 112 WEST BROADWAY SALEM, NEW JERSEY 08079

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS: NO INPUT PROVIDED. FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATES.

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICEMSEE

*********	**********	**********	************	
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT	
NO INPUT	PROVIDED.			
	*********	**********		

1.	Docket: <u>50-311</u>	OPERAT	ING S	TATUS								
2.	Reporting Period: _04/01/	88 Outage	+ An-line	Hrs: 719.0								
3.	Utility Contact: BRYAN W	GORMAN (6	09) 339-34	0.0								
4.	Licensed Thermal Power (M	Wt):	_	3411								
5.	Nameplate Rating (Gross MWe):1162											
6.	Design Electrical Rating	1115										
7.	Maximum Dependable Capaci	ty (Gross M	(Ne):	1149								
8.	Maximum Dependable Capaci	ty (Net MWe	.):	1106								
9.	If Changes Occur Above Si	nce Last Re	port, Give	Reasons:								
-	NONE											
10.	Power Level To Which Rest	ricted, If	Any (Net M	He):								
11.	Reasons for Restrictions,	If Any:										
_	NONE	den deservice and second										
12.	Report Period Hrs	MCNTH 719.0	YEAR 2,903.0	CUMULATIVE								
13.	Hours Reactor Critical	689.3	2,873.3									
14.	Rx Reserve Shtdwn Hrs		0	3,533.6								
15.	Hrs Generator On-Line	664.0	2,844.3	34,141.4								
16.	Unit Reserve Shtdwn Hrs		0									
17.	Gross Therm Ener (MWH)	2,249,256	9,570,418	106,336,147								
18.	Gross Elec Ener (MWH)	750-550	3,190,470	34,819,940								
19.	Net Elec Ener (MWH)	719,576	3,062,440	33,081,908								
20.	Unit Service Factor	92.4	98.0	59.5								
21.	Unit Avail Factor	92.4	98.0	59.5								
22.	Unit Cap Factor (MLC Net)	90.5	95.4	52.1								
23.	Unit Cap Factor (DER Net)	89.8	94.6	51.7								
24.	Unit Forced Outage Rate	7.6	2.0									
25.	Forced Dutage Hours	55.0	58.7	15,576.6								
26.	Shutdowns Sched Over Next	6 Months (Type, Date, I	Duration):								
	REFUELING - 9/1/88 - 52 D	AY DURATION										
27.	If Currently Shutdown Est	imated Star	tup Date:	N/A								



SALEM 2



APRIL 1988

Report	Period Al	PR 19	88		UN	ΙT	SHU	TDOP	1 N	s /	R	ED	U (: 1	I	0	N	NANANANANANANANANANANANANANANANANANANA
No.	Date	Type	Hours	Reason	Method	LER	Number	System	c Co	omponen	Ŧ			Ca	use	0 8	C	orrective Action to Prevent Recurrence
0078	04/21/88	F	22.7	Α	3			CB	1	INSTRU		REAG	TOP	2 0	001	AN	1T	FLOW INDICATION.
0079	04/22/88	F	32.3	Α	3			CB		HTEXCH		STE	M (GEN	IERI	ATO	R	LEVEL.

*********** SALEM 2 EXPERIENCED 2 FORCED OUTAGES IN APRIL FOR REASONS * SUMMARY * MENTIONED ABOVE. *********

1

Type	Reason		Method	System & Component			
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Rest E-Operator Traini & License Exam	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)			

4

PAGE 2-359

\$

********** SALEM 2 **************************** FACILITY DESCRIPTION LOCATION STATE.....NEW JERSEY DIST AND DIRECTION FROM NEAREST POPULATION CTR...20 MI S OF WILMINGTON, DEL TYPE OF REACTOR PWR DATE INITIAL CRITICALITY...AUGUST 8, 1980 DATE ELEC ENER 1ST GENER...JUNE 3, 1981 DATE COMMERCIAL OPERATE....OCTOBER 13, 1981 CONDENSER COOLING METHOD... ONCE THRU CONDENSER COOLING WATER....DELAWARE RIVER ELECTRIC RELIABILITY AREA COUNCIL

FACILITY DATA

Report Period APR 1988

. .

UTILITY & CONTRACTOR INFORMA UTILITY NEWARK, NEW JERSEY 07101 CONTRACTOR ARCHITECT/ENGINEER...... PUBLIC SERVICES & GAS CO. NUC STEAM SYS SUPPLIER...WESTINGHOUSE CONSTRUCTOR......UNITED ENG. & CONSTRUCTORS TURBINE SUPPLIER.....WESTINGHOUSE REGULATORY INFORMATION IE REGION RES & BLC.....I LICENSING PR., AANAGER.....D. FISCHER LICENSE & DATE ISSUANCE.... DPR-75, MAY 20, 1981 PUBLIC DOCUME .. ROOM SALEM FREE PUBLIC LIBRARY **112 WEST BROADWAY** SALEM, NEW JERSEY 08079

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT_SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS: NO INPUT PROVIDED. FACILITY ITEMS (PLANS AND PROCEDURES): NO INPUT PROVIDED. 60

Report Period APR 1988

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INFUT PROVIDED.

REPORTS FROM LICENSEE

		*********	***************	 	*********	***************	******************	
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT					
	DEQUIDED							
NU INPUI	PROVIDED.			 			*****************	

1.	Docket: _50-2060	PERAT	INGS	TATUS						
2.	. Reporting Period: 04/01/88 Outage + On-line Hrs: 719.0									
3.	. Utility Contact: E. R. SIACOR (714) 368-6223									
4.	Licensed Thermal Power (MWt): 1347									
5.	Nameplate Rating (Gross MW	e):	500 X	0.9 = 450						
6.	Design Electrical Rating (Net MWe):		436						
7.	Maximum Dependable Capacit	y (Gross M	1We):	456						
8.	Maximum Dependable Capacit	y (Net MWe	.):	436						
9.	If Changes Occur Above Sin NONE	ce Last Re	eport, Give	Reasons:						
10.	Power Level To Which Restr	icted, If	Any (Net M	we): 390						
11.	Reasons for Restrictions,	If Any:		the second delayer						
	SELF-IMPOSED TO CONTROL S.	G. TUBE CO	RROSION.							
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 183,007.0						
13.	Hours Reactor Critical	. 0	1,068.7	107,540.1						
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	. 0						
15.	Hrs Generator On-Line	. 0	1,063.1	103,493.5						
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	. 0						
17.	Gross Therm Ener (MWH)	0	1,304,993	130,434,853						
18.	Gross Elec Ener (MWH)	0	430,200	44,107,926						
19.	Net Elec Ener (MWH)	-2,004	402,290	41,645,555						
20.	Unit Service Factor	. 0	36.6	56.6						
21.	Unit Avail Factor	. 0		56.6						
22.	Unit Cap Factor (MDC Net)	. 0	31.8	52.2						
23.	Unit Cap Factor (DER Net)	. 0	31.8	52.2						
24.	Unit Forced Outage Rate	. 0	.0	19.9						
25.	Forced Outage Hours	, 0	. 0	13,140.4						



SAN ONOFRE 1



APRIL 1988

********** SAN ONOFRE REMAINED SHUTDOWN IN APRIL FOR REASONS STATED ABOVE.

0

.

1...

.

Туре	Reason	Method	System & Component		
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Yest G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report		

PAGE 2-363

đ

xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx	ACILITY DATA Rep
FACILITY DESCRIPTION	UTILITY & CONTRACTOR INFORMATION
LOCATION STATECALIFORNIA	UTILITY LICENSEESOUTHERN CALIFORNIA ED
COUNTYSAN DIEGO	CORPORATE ADDRESS2244 WALNUT GROVE AVEN ROSEMEAD, CALIFORNIA
DIST AND DIRECTION FROM NEAREST POPULATION CTR5 MI S OF SAN CLEMENTE, CA	CONTRACTOR ARCHITECT/ENGINEERBECHTEL
TYPE OF REACTORPWR	NUC STEAM SYS SUPPLIERWESTINGHOUSE
DATE INITIAL CRITICALITYJUNE 14, 1967	CONSTRUCTORBECHTEL
DATE ELEC ENER 1ST GENERJULY 16, 1967	TURBINE SUPPLIERWESTINGHOUSE
DATE COMMERCIAL OPERATEJANUARY 1, 1968	REGULATORY INFORMATION
CONDENSER COOLING METHODONCE THRU	IE REGION RESPONSIBLEV
CONDENSER COOLING WATERPACIFIC OCEAN	IE RESIDENT INSPECTORR. HUEY
ELECTRIC RELIABILITY COUNCIL	LICENSING PROJ MANAGERC. TRAMMELL DOCKET NUMBER50-206
COORDINATING COUNC	CIL LICENSE & DATE ISSUANCE DPR-13. MARCH 27, 1967

Report Period APR 1988

EDISON VENUE NIA 91770

PUBLIC DOCUMENT ROOM......UNIVERSITY OF CALIFORNIA GENERAL LIBRARY IRVINE, CA. 92713

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION ON JANUARY 10 - FEBRUARY 27, 1988 (REPORT NO. 50-206/88-03) AREAS INSPECTED: ROUTINE RESIDENT INSPECTION OF UNIT 1 OPERATIONS PROGRAM INCLUDING THE FOLLOWING AREAS: OPERATIONAL SAFETY VERIFICATION, RADIOLOGICAL PROTECTION, SECURITY, EVALUATION OF PLANT TRIPS AND EVENTS, MONTHLY SURVEILLANCE ACTIVITIES, MONTHLY MAINTENANCE ACTIVITIE INDEPENDENT INSPECTION, REVIEW OF LICENSEE EVENT REPORTS, AND FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

PESULTS: ONE VIOLATION WAS IDENTIFIED: FAILURE TO COMPLY WITH TECHNICAL SPECIFICATION AND SURVEILLANCE PROCEDURE REQUIREMENTS FOR SURVEILLANCE TESTING OF THE SAFETY-REALTED BACKUP NITROGEN SYSTEM. NUMEROUS EXAMPLES OF INADEQUATE ENVIRONMENTAL QUALIFICATION OF SAFETY EQUIPMENT WERE IDENTIFIED DURING THIS INSPECTION. THE LICENSEE WAS REQUESTED TO ADDRESS THE ROOT CAUSE OF THESE PROBLEMS AND IDENTIFY WARRANTED CORRECTIVE ACTIONS PRIOR TO RESTART FROM THE CURRENT MID-CYCLE OUTAGE.

+ INSPECTION ON MARCH & -11, 1988 (REPORT NO. 50-206/88-07) AREAS INSPECTED: UNANNOUNCED, ROUTINE EMERGENCY PREPAREDNESS INSPECTION IN THE AREA OF OPERATIONAL STATUS OF THE EMERGENCY PREPAREDNESS PROGRAM. DURING THIS INSPECTION, ONE INSPECTION PROCEDURE WAS UTILIZED.

RESULTS: OF THE AREAS INSPECTED, ONE VIOLATION OF NRC REQUIREMENTS WAS IDENTIFIED FOR FAILURE TO CONDUCT AN INDEPENDENT REVIEW OF THE EMERGENCY PREPAREDNESS PROGRAM AT LEAST EVERY 12 MONTH.

+ INSPECTION JN FEBRUARY 28 - APRIL 9, 1988 (REPORT NO. 50-206/88-08) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

PAGE 2-364

2

Report Period APR 1988

INSPECTION STATUS - (CONTINUED)

INSPECTION SUMMARY

+ INSPECTION ON MARCH 14 - APRIL 8, 1988 (REPORT NO. 50-206/88-09) AREAS INSPECTED: A ROUTINE, UNANNOUNCED INSPECTION OF ACTIVITIES RELATING TO A CONTAINMENT INTEGRATED 'EAK RATE TEST AND FOLLOWUP ON OPEN ITEMS. THE INTEGRATED LEAK RATE TEST INSPECTION INCLUDED REVIEW OF PROCEDURES AND RECORDS, INTERVIEWS WITH PERSONNEL, WITNESSING PORTIONS OF THE INTEGRATED LEAK RATE TEST, INSPECTION OF THE CONTAINMENT BUILDING, ASSOCIATED PENETRATIONS AND PIPING SYSTEM. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON FEBRUARY 25 - MARCH 25, 1988 (REPORT NO. 50-206/88-10) AREAS INSPECTED: THIS WAS A SPECIAL INSPECTION CONDUCTED FOLLOWING THE IDENTIFICATION OF ENVIRONMENTAL QUALIFICATION DEFERICIENCIES.

RESULTS: SEVERAL EXAMPLES OF LACK OF PROPER ENVIRONMENTAL QUALIFICATION OF UNIT 1 SAFETY EQUIPMENT WERE IDENTIFIED DURING THIS INSPECTION. A REVIEW CONDUCTED BY THE LICENSEE IN RESPONSE TO THE INSPECTOR'S FINDINGS IDENTIFIED NUMEROUS ADDITIONAL EXAMPLES. THE NATURE AND LARGE NUMBER OF DEFICIENCIES IDENTIFIED INDICATES & PROGRAMMATIC BREAKDOWN OF LICENSEE IMPLEMENTATION OF ENVIRONMENTAL QUALIFICATION CONTROL, AS REQUIRED BY NRC REGULATIONS. THE LICENSEE WAS REQUESTED TO ADDRESS THE ROOT CAUSE OF THIS PROGRAM BREAKDOWN AND IDENTIFY WARRANTED CORRECTIVE ACTIONS FRIOR TO RESTART OF UNIT 1 FROM THE CURRENT MID-CYCLE OUTAGE.

+ INSPECTION ON APRIL 5 - 8, 1988 (REPORT NO. 50-206/88-12) AREAS INSPECTED: ROUTINE, UNANNOUNCED REGIONAL INSPECTION OF MAINTENANCE PROGRAM IMPLEMENTATION, INSPECTOR FOLLOWUP ITEMS, AND FOLLOWUP ON ITEMS OF NON-COMPLIANCE. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON APRIL 10 - MAY 14, 1988 (REPORT NO. 50-206/88-13) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

ON FEBRUARY 25, 1988, SOUTHERN CALIFORNIA EDISON IDENTIFIED TO THE NRC THAT THEY HAD IDENTIFIED SOME ENVIRONMENTAL QUALIFICATION (EQ) PROBLEMS WITH VARIOUS COMPONENTS. THESE COMPONENTS WERE PRIMARILY SOLENOID VALVES IN THE AUXILIARY FEEDWATER, CHEMICAL AND VOLUME CONTROL, SAFETY INJECTION, AND CONTAINMENT ISOLATION SYSTEMS. IN A POSTULATED HARSH ENVIRONMENT, THESE COMPONENTS COULD BECOME INOPERABLE OR CAUSE SECONDARY ELECTRICAL PROBLEMS. THE LICENSEE IDENTIFIED THAT THESE DEFICIENCIES WOULD BE CORRECTED PRIOR TO STARTUP OR JUSTIFICATION WOULD BE PROVIDED FOR CONTINUED OPERATION.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

OTHER ITEMS

PLANT STATUS:

+ THE UNIT HAS REMAINED SHUT DOWN SINCE FEBRUARY 13, 1988, FOR A 45-DAY PLANNED MAINTENANCE OUTAGE (NO REFUELING). THE OUTAGE WAS EXTENDED TO RESOLVE THE ENVIRONMENTAL QUALIFIC/ ION DEFICIENCIES IDENTIFIED ABOVE.

LAST IE SITE INSPECTION DATE: 04/10 - 05/14/8/ +

INSPECTION REPORT NO: 50-206/8

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-01-L0	01-18-88	02-17-88	MISSED CTMT PURGE SAMPLE LOSED BY JET C
88-03-50	04-06-88	04-05-88	10 CFR 73.71 (C) RPT RE: NALARMED VA PORTAL (SAFEGUARDS EVENT) U

THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docket: 50-361 OPERATING STATUS										
2.	Reporting Period: 04/01/88 Outage + On-line Hrs: 719.0										
3.	Utility Contact: E. R. SIACOR (714) 368-6223										
4.	Licensed Thermal Power (M		3390								
5.	Nameplate Rating (Gross M	le):		1127							
6.	Design Electrical Rating	(Net MWe):		1070							
7.	Maximum Dependable Capacit	ty (Gross M	We):	1127							
8.	Maximum Dependable Capacit	ty (Net MWe):	1070							
9.	If Changes Occur Above Since Last Report, Give Reasons:										
10. 11.	Power Level To Which Restr Reasons for Restrictions,	ricted, If If Any:	Any (Net MW	le) :							
	NUNC	MONTH	YEAR								
12.	Report Period Hrs	719.0	2,903.0	41,472.0							
13.	Hours Reactor Critical	627.7	2,453.6	28,246,1							
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	(
15.	Hrs Generator On-Line	603.9	2,116 0	27,601.7							
16.	Unit Reserve Shtdwn Hrs	. 0	0	(
17.	Gross Therm Ener (MWH)	2,057,911	7,993,161	88,959,584							
18.	Gross Elec Ener (MWH)	673,082	2,749,039	30,011,613							
19.	Net Elec Ener (MWH)	637,840	2,611,684	28,400,564							
20.	Unit Service Factor	84.0	83.2	66.6							
21.	Unit Avail Factor	84.0	83.2	66.6							
22.	Unit Cap Factor (MDC Net)	82.9	84.1	64.0							
23.	Unit Cap Factor (DER Net)	82.9	84.1	64.0							
24.	Unit Forced Outage Rate		.0	4,1							
25.	Forced Outage Hours		. 0	1,183.5							
26.	Shutdowns Sched Over Next	6 Months (Type, Date, I	Duration):							
27	If Currently Shutdown Est	imated Star	tup Date:	N/A							

.

.

SAN ONOFRE 2



Report	Period A	PR 19	88		UN	τī	SHU	тром	N S	/ R	E	D U	ст	1 0	N	s	**************************************
No.	Date	Type	Hours	Reason	Method	LER	Number	System	Comp	onent	=		Ca	use	8 (Corre	ective Action to Prevent Recurrence
42	03/17/88	S	115.1	В	4				SG		UN RE	IT S PAIR	HUT S T	DOWN		ROM M GE	100% POWER FOR INSPECTION AND NERATOR 2-088 TUBE LEAKS.

.

Туре	Reason		Method	System & Component	
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)	

PAGE 2-369

8

.

FACILITY DESCRIPTION

LOCATION STATE.....CALIFORNIA

COUNTY......SAN DIEGO

DIST AND DIRECTION FROM NEAREST POPULATION CTR...5 MI S OF SAN CLEMENTE, CA

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY ... JULY 26, 1982

DATE ELEC ENER 1ST GENER...SEPTEMBER 20, 1982

DATE COMMERCIAL OPERATE.... AUGUST 8, 1983

CONDENSER COOLING METHOD ... ONCE THR"

CONDENSER JLING WATER PACIFIC OCEAN

ELECTRIC RELIABILITY COUNCIL......WESTERN SYSTEMS COORDINATING COUNCIL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE......SGUTHERN CALIFORNIA EDISON

CORPORATE ADDRESS......P.O. BOX 800 ROSEMEAD, CALIFORNIA 91770

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

ARGHITEGTIEHOTHEERTITTTTTTTTTTT

NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER......GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V

IE RESIDENT INSPECTOR R. HUEY

LICENSE & DATE ISSUANCE....NPF-10, SEPTEMBER 7, 1982

PUBLIC DOCUMENT ROOM......UNIVERSITY OF CALIFORNIA GENERAL LIBRARY IRVINE, CA. 92713

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION ON JANUARY 17 - FEBRUARY 27, 1988 (REPORT NO. 50-361/88-03) AREAS INSPECTED: ROUTINE RESIDENT INSPECTION OF UNIT 2 OPERATIONS PROGRAM INCLUDING THE FOLLOWING AREAS: OPERATIONAL SAFETY VERIFICATION, RADIOLOGICAL PROTECTION, SECURITY, EVALUATION OF PLANT TRIPS AND EVENTS, MONTHLY SURVEILLANCE ACTIVITIES, MONTHLY MAINTENANCE ACTIVITIES, INDEPENDANT INSPECTION, REVIEW OF LICENSEE EVENT REPORTS, AND FOLLOW-UP OF PREVIOUSLY IDENTIFIED ITEMS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: OF THE AREAS INSPECTED TWO VIOLATIONS WERE IDENTIFIED. FAILURE TO PROPERLY SET MAIN STEAM LINE SAFETY VALVES IN ACCORDANCE WITH TECHNICAL SPECIFICATION REQUIREMENTS; IMPROPER DOCUMENTATION AND EVALUATION OF NONCONFORMING CONDITIONS OBSERVED DURING MAINTENANCE ON SAFETY-RELATED EQUIPMENT.

+ INSPECTION ON MARCH 8 - 11, 1988 (REPORT NO. 50-361/88-07) AREAS INSPECTED: UNANNOUNCED, ROUTINE EMERGENCY PREPAREDNESS INSPECTION IN THE AREA OF OPERATIONAL STATUS OF THE EMERGENCY PREPAREDNESS PROGRAM. DURING THIS INSPECTION, ONE INSPECTION PROCEDURE WAS UTILIZED.

RESULTS: OF THE AREAS INSPECTED, ONE VIOLATION WAS IDFATIFIED FOR FAILURE TO CONDUCT AN INDEPENDENT REVIEW OF THE EMERGENCY PREPAREDNESS PROGRAM AT LEAST EVERY 12 MONTH.

+ INSPECTION ON FEBRUARY 28 - APRIL 9, 1988 (REPORT NO 50-361/88-08) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

Report Period APR 1988

INSPECTION STATUS - (CONTINUED)

INSPECTION SUMMARY

. INSPECTION ON APRIL 5 - 8, 1988 (REPORT NO. 50-361/88-09) AREAS INSPECTED: ROUTINE, UNANNOUNCED REGIONAL INSPECTION OF FOLLOWUP ON VENDOR-RELATED MODIFICATIONS FOR REACTOR TRIP BREAKERS, SURVEILLNACE TESTING AND CALIBRATION PROGRAM, INSPECTOR FOLLOWUP ITEMS, AND FOLLOWUP ON ITEMS OF NON-COMPLIANCE. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MAY 6 - 10, 1988 (REPORT NO. 50-361/88-10) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 10 - MAY 14, 1988 (REPORT NO. 50-361/88-11) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ UNIT 2 WAS RESTARTED ON APRIL 5, 1988, FROM THE MAINTENANCE OUTAGE CONDUCTED IN MARCH 1988. DURING THAT OUTAGE, THE LICENSEE REPLACED SEVERAL STEAM GENERATOR TUBE PLUGS THAT WERE MISSING FROM TUBES THAT HAD BEEN PREVIOUSLY PLUGGED. THE UNIT WAS OPERATED AT FULL POWER OR THE REMAINDER OF THE MONTH OF APRIL.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ UNIT 2 OPERATED AT FULL POWER UNTIL MARCH 17, 1988, WHEN IT WAS SHUT DOWN TO CORRECT STEAM GENERATOR TUBE LEAKAGE (SEE ABOVE). THE UNIT REMAINED SHUT DOWN FOR THE REMAINDER OF THE MONTH.

LAST IE SITE INSPECTION DATE: 04/10 - 05/14/88+

INSPECTION REPORT NO: 50-361/88-11+

Report Period APR 1988 REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	PTE OF REPORT	SUBJECT
88-01-L0	01-8-88	02-05-88	SPURIOUS CRIS ACTUATION DUE TO CORROSION ON ELECTRICAL CONNECTORS
88-06-10			SPURIOUS CRIS ACTUATION DUE TO CONNECTOR PINS BEING BACKED OUT OF MODULE

PAGE 2-372

ŝ,

.

. 8 é. PAGE 2-373 . THIS PAGE INTENTIONALLY LEFT BLANK .

1.	Docket: _50-362	OPERAT	ING S	TATUS							
2.	Reporting Period: 04/01/88 Outage + On-line Hrs: 719.0										
3.	. Utility Contact: E. R. SIACOR (714) 368-6223										
4.	Licensed Thermal Power (M	· · · · · · · · · · · · · · · · · · ·	3390								
5.	Nameplate Rating (Gross M	We):		1127							
6.	Design Electrical Rating	(Net MWe):		1080							
7.	Maximum Dependable Capaci	ty (Gross M	lkie) :	1127							
8.	Maximum Dependable Capaci	ty (Net MWe):	1080							
9.	If Changes Occur Above Si	nce Last Re	port, Give	Reasons:							
	NONE										
10.	Power Level To which Rest	ricted, If	Any (Net Mk	le):							
11.	Reasons for Restrictions,	If Any:									
-	NONE										
12	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 35.783.0							
13.	Hours Reactor Critical	696.6	2.632.3	26.354.8							
14.	Rx Reserve Shtdwn Hrs	.0	. 0	. 0							
15.	Hrs Generator On-Line	696.6	2,580.8	25,454.7							
16.	Unit Reserve Shtdwn Hrs	. 0	, 0	. 0							
17.	Gross Therm Ener (MWH)	2,323,149	8,593,478	78,049,239							
18.	Gross Elec Ener (MWH)	797,392	2,952,875	26,430,769							
19.	Net Elec Ener (MWH)	757,487	2,796,561	24,884,227							
20.	Unit Service Factor	96.9	88.7	71.1							
21.	Unit Avail Factor	96.9	88.9	71,1							
22.	Unit Cap Factor (MDC Net)	97.5	89.2	64,4							
23.	Unit Cap Factor (DER Net)	97.5	89.2	64.4							
24.	Unit Forced Outage Rate	. 0	10.4	9.6							
25.	Forced Outage Hours	. 0	299.8	2,708.6							
26.	Shutdowns Sched Over Next	6 Months (Type, Date, D	uration):							
	NONE										

· ··· ,

27. If Currently Shutdown Estimated Startup Date: _____07/16/88



SAN ONOFRE 3



APRIL 1988

Report	Period APR 1988	UNIT SHUT	TDOWNS / REDUCTIONS * SAN ONOFRE 3 * *********************************
No.	Date Type Hours Re	eason Method LER Number	System Component Cause & Corrective Action to Prevent Recurrence
61	06/30/88 5 22.4	C 1	CYCLE 4 REFUELING DUTAGE.

Туре	Reason		Method	System & Component		
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161		

FACILITY DESCRIPTION

LOCATION STATE.....CALIFORNIA

DIST AND DIRECTION FROM NEAREST POPULATION CTR...5 MI S OF SAN CLEMENTE, CA

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... AUGUST 27 1983

DATE ELEC ENER 1ST GENER...SEPTEMBER 25, 1983

DATE COMMERCIAL OPERATE.... APRIL 1, 1984

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER.... PACIFIC OCEAN

ELECTRIC RELIABILITY COUNCIL......WESTERN SYSTEMS COORDINATING COUNCIL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE......SOUTHERN CALIFORNIA EDISON

CORPORATE ADDRESS......P.O. BOX 800 ROSEMEAD, CALIFORNIA 91770

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER ... COMBUSTION ENGINEERING

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER......GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V

IE RESIDENT INSPECTOR.....R. HUEY

LICENSE & DATE ISSUANCE....NPF-15, NOVEMBER 15, 1982

PUBLIC DOCUMENT ROOM.....UNIVERSITY OF CALIFORNIA GENERAL LIBRARY IRVINE, CA. 92713 IN SPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION ON JANUARY 17 - FEBRUARY 27, 1988 (REPORT NO. 50-362/88-03) AREAS INSPECTED: ROUTINE RESIDENT INSPECTION OF UNIT 3 OPERATIONS PROGRAMS INCLUDING THE FOLLOWING AREAS: OPERATIONAL SAFETY VERIFICATION, RADIOLOGICAL PROTECTION, SECURITY, EVALUATION OF PLANT TRIPS AND EVENTS, MONTHLY SURVEILLANCE ACTIVITIES, MONTHLY MAINTENANCE ACTIVITIES, INDEPENDENT INSPECTION, REVIEW OF LICENSEE EVENT REPORTS, AND FOLLOW-UP OF PREVIOUSLY IDENTIFIED ITEMS. DURING THIS INSPECTIONS, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: TWO VIOLATIONS WERE IDF' IFIED INVOLVING FAILURE TO PROPERLY SET MAIN STEAM LINE SAFETY VALVES IN ALCORDANCE WITH TECHNICAL SPECIFICATION REQUIREM, S; IMPROPER DOCUMENTATION AND EVALUATION OF NONCONFORMING CONDITIONS OBSERVED DURING MAINTENANCE ON SAFETY-RELATED EQU MENT.

+ INSPECTION ON MARCH 8 - 11, 1988 (REPORT NO. 50-362/88-07) AREAS INSPECTED: UNANNOUNCED, ROUTINE EMERGENCY PREPAREDNESS INSPECTION IN THE AREA OF OPERATIONAL STATUS OF THE EMERGENCY PREPAREDNESS PROGRAM. DURING THIS INSPECTION ONE INSPECTION PROCEDURE WAS UTILIZED.

RESULTS: OF THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED FOR FAILURE TO CONDUCT AN INDEPENDENT REVIEW OF THE EMRGENCY PREPAREDNESS PROGRAM AT LEAST EVERY 12 MONTH.

+ IMSPECTION ON FEBRUARY 28 - APRIL 9, 1988 (REPORT NO. 50-362/88-08) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
INSPECTION SUMMARY

+ INSPECTION ON APRIL 5 - 8, 1988 (REPORT NO. 50-362/88-09) AREAS INSPECTED: ROUTINE, UNANNOUNCED REGIONAL INSPECTION OF FOLLOWUP ON VENDOR-RELATED MODIFICATIONS FOR REACTOR TRIP BREAKERS, SURVEILLANCE TESTING AND CALIBRATION PROGRAM, INSPECTOR FOLLOWUP ITEMS, AND FOLLOWUP ON ITEMS OF NONCOMPLIANCE. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MAY 6 - 10, 1988 (REPORT NO. 50-362/88-10) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 11 - MAY 14, 1988 (REPORT NO. 50-362/88-11) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ THE UNIT OPERATED AT FULL POWER UNTIL APRIL 29, 1988, WHEN IT WAS SHUT DOWN FOR THE CYCLE 4 REFUELING. THE LICENSEE EXPECTS TO RETURN THE UNIT TO SERVICE IN EARLY JULY.

LAST IE SITE INSPECTION DATE: 04/11 - 05/14/88+

INSPECTION REPORT NO: 50-362/88-11+

REPORTS FROM LICENSEE

NUMBER	DATE OF	DATE OF	SUBJECT
	EVENT	REPORT	

NONE

1.	Docket: 50-327 0	PERAT	INGS	TATUS
2.	Reporting Period: 04/01/8	Hrs: 719.0		
3.	Utility Contact: DAVID DU	PREE (615)	870-6722	
4.	Licensed Thermal Power (MM	3411		
5.	Nameplate Rating (Gross MM	le):	· · · · · · · · · · · · · · · · · · ·	1220
6.	Design Electrical Rating (Net MWe):	_	1148
7.	Maximum Dependable Capacit	y (Gross M	We):	1183
8.	Maximum Dependable Capacit	y (Net MWe):	1148
9.	If Changes Occur Above S: NONE	v Last Re	port, Give	Reasons:
10.	Power Level To Nhich Restr	icted, If	Any (Net Mk	le):
11.	Reasons for Restrictions,	If Any:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE
13.	Hours Reactor Critical	. 0	. 0	24,444.7
14.	R× Reserve Shtdwn Hrs	. 0	. 0	
15.	Hrs Generator On-Line	. 0	. 0	23,871.0
16.	Unit Reserve Shtdwn Hrs	. 0		
17.	Gross Therm Ener (MWH)	Q	0	77,060,921
18.	Gross Elec Ener (MWH)	0	0	25,978,386
19.	Net Elec Ener (MWH)	-4,239	-23,140	24,831,183
20.	Unit Service Factor	. 0		39.8
21.	Unit Avail Factor	. 0		39.8
		. 0	. 0	36.1
22.	Unit Cap Factor (MDC Net)			the second s
22. 23.	Unit Cap Factor (MDC Net) Unit Cap Factor (DER Net)	. 0		36.1
22. 23. 24.	Unit Cap Factor (MDC Net) Unit Cap Factor (DER Net) Unit Forced Outage Rate	.0	<u>.0</u> 100.0	36.1
22. 23. 24. 25.	Unit Cap Factor (MDC Net) Unit Cap Factor (DER Net) Unit Forced Outage Rate Forced Outage Hours	.0 100.0 719.0	<u>.0</u> <u>100.0</u> 2,903.0	<u> </u>



SEQUOYAH 1



APRIL 1988

.

UNIT SHUTDOWNS / REDUCTIONS

******** SEQUOYAH 1 × ********

Ma	Data	Tunn	Hours	Passo	Method	LER Number	System	Component		Cause &	Corrective	Acti	on to	Prev	ent	Recurrence
NO.	hate	TAbé	nour s	Nedadii	THE XING M	hart manus st	N.L.M. S. S.M.	State States								
1	12/20/85	F	719.0	F	4				DESIGN	CONTROL,	CONFIGURAT	ION	UPDATI	ING,	AND	EMPLOYEE

SEQUOYAH 1 REMAINED SHUTDOWN IN APRIL BECAUSE OF DESIGN CONTROL, CONFIGURATION UPDATING AND EMPLOYEE CONCERNS. ******

.

* SUMMARY * ********

Type	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

PAGE 2-379

1

V.

FACILITY DESCRIPTION
LOCATION STATETENNESSEE
COUNTY
DIST AND DIRECTION FROM NEAREST POPULATION CTR9.5 MI NE OF CHATTANOOGA, TN
TYPE OF REACTORPWR
DATE INITIAL CRITICALITYJULY 5, 1980
DATE ELEC ENER 1ST GENERJULY 22, 1980
DATE COMMERCIAL OPERATE ULLY 1, 1981

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....CHICKAMAUGA LAKE

ELECTRIC RELIABILITY

RELIABILITY COUNCIL

FACILITY DATA

Report Period APR 1988

TILITY & CONTRACTOR INFORMATION
UTILITY LICENSEETENNESSEE VALLEY AUTHORITY
CORPORATE ADDRESS NORTH 38A LOOKOUT PLACE CHATTANOOGA, TENNESSEE 37401
CONTRACTOR ARCHITECT/ENGINEERTENNESSEE VALLEY AUTHORITY
NUC STEAM SYS SUPPLIERWESTINGHOUSE
CONSTRUCTORTENNESSEE VALLEY AUTHORITY
TURBINE SUPPLIERWESTINGHOUSE
EGULATORY INFORMATION
IE REGION RESPONSIBLEII
IE RESIDENT INSPECTORE. FORD
LICENSING PROJ MANAGERE. MCKENNA DOCKET NUMBER
LICENSE & DATE ISSUANCEDPR-77, TEMBER 17, 1980
PUBLIC DOCUMENT ROOMCHATTANOUGA - HAMILTON BICENTENNIAL LIBRARY 1001 BROAD STREET

CHATTANOOGA, TENNESSEE 37402 STATUS

INSPECTION SUMMARY

+ INSPECTION AUGUST 17-21 (87-57): ANNOUNCED INSPECTION TO COMPLETE THE REVIEW OF TVA'S IMPLEMENTATION OF A PROGRAM PER THE REQUIREMENTS OF 10 CFR 50.49 FOR ESTABLISHING AND MAINTAINING THE QUALIFICATION OF ELECTRIC EQUIPMENT WITHIN THE SCOPE OF 10 CFR 50.49. THE INSPECTION IDENTIFIED NO DEFICIENCIES IN THE SQN IMPLEMENTATION OF A PROGRAM TO MEET THE REQUIREMENTS OF 50.49. BASED ON THE INSPECTORS REVIEWS AND EVALUATIONS, INSPECTION FOLLOW-UP ITEMS 50-327, 328/87-22-02 AND -03 WERE CLOSED. WHILE NO DEFICIENCIES WERE IDENTIFIED IN EQUIPMENT QUALIFICATION PROGRAM IMPLEMENTATION, SQN NEEDS TO COMPLETE THE REPLACEMENT ITEMS PROJECT (RIP) BEFORE SQN IS IN COMPLIANCE WITH 10 CFR 50.49. THIS PROJECT IS THE SUBJECT OF A SEPARATE NRC INSPECTION (INSPECTION 50-327.328/87-40, JULY 13-24, 1987); THEREFORE, COMPLETION OF RIP IS NOT IDENTIFIED FOR FOLLOW-UP IN THIS INSPECTION REPORT.

INSPECTION

INSPECTION DECEMBER 6 - FEBRUARY 5 (87-76): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF OPERATIONAL SAFETY VERIFICATION (INCLUDING OPERATIONS PERFORMANCE, SYSTEM LINEUPS, RADIATION PROTECTION, SAFEGUARDS AND HOUSEKEEPING INSPECTIONS); MAINTENANCE OBSERVATIONS; REVIEW OF PREVIOUS INSPECTION FINDINGS; FOLLOWUP OF EVENTS; REVIEW OF LICENSEE IDENTIFIED ITEMS: REVIEW OF IE INFORMATION NOTICES; AND REVIEW OF INSPECTOR FOLLOWUP ITEMS. THO VIOLATIONS (VIOS) WERE IDENTIFIED. FAILURE TO PERFORM ADEQUATE POST MAINTENANCE TESTING. FAILURE TO FOLLOW PROCEDURE, TWO EXAMPLES. ONE UNRESOLVED ITEM (URI) WAS IDENTIFIED DURING THIS INSPECTION. URIS ARE MATTERS ABOUT WHICH MORE INFORMATION IS REQUIRED TO DETERMINE WHETHER THEY ARE ACCEPTABLE GR MAY INVOLVE VIOLATIONS OR DEVIATIONS. FITH VITAL BATTERY CONCERNS. TWO INSPECTOR FOLLOWUP ITEMS (IFIS) WERE IDENTIFIED. ANUBAR FLOW INSTRUMENTS AND VERIFICATION OF HEAT EXCHANGER DIFFERENTIAL PRESSURE. CABLE ROUTING DEFICIENCIES ON UNIT 1 CABLES 1V1936A AND 1V1881A.

INSPECTION JANUARY 6-13 (88-01): THIS ANNOUNCED SPECIAL INSPECTION WAS CONLUCTED IN THE CORPORATE OFFICES IN CHATTANOOGA TO

INSPECTION STATUS - (CONTINUED)

INSPECTION SUMMARY

REVIEW THE LICENSEE'S CORRECCTIVE MEASURES IN RESPONSE TO UNRESOLVED ITEM NO. 50-259,260 AND 296/86-37-01 AND 50-327 AND 328/86-58-01. THE UNRESOLVED ITEM IS CLOSED.

INSPECTION FEBRUARY 8-12 (88-14): THIS SPECIAL ANNOUNCED INSPECTION WAS CONDUCTED TO EVALUATE LICENSEE RESOLUTIONS OF INSPECTOR FOLLOWUP ITEMS RELATED TO EMERGENCY OPERATING PROCEDURES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MARCH 7-18 (88-18): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED REVIEW AND EVALUATION OF THE LICENSEE'S EMERGENCY PREPAREDNESS PROGRAM. ONE VIOLATION WAS IDENTIFIED - FAILURE TO PROVIDE REQUIRED EMERGENCY RESPONSE TRAINING FOR AN INDIVIDUAL DESIGNATED AS TECHNICAL SUPPORT CENTER COMMUNICATOR.

INSPECTION MARCH 19 - APRIL 2 (88-22) THIS ANNOUNCED INSPECTION INVOLVED ONSHIFT AND ONSITE INSPECTIONS BY THE NRC RESTART TASK FORCE. THE M AJORITY OF EXPENDED INSPECTION EFFORT WAS IN THE AREAS OF EXTENDED CONTROL ROOM OBSERVATION AND OPERATIONAL SAFETY VERIFICATION INCLUDING OPERATIONS PERFORMANCE, SYSTEM LINEUPS, RADIATION PROTECTION, AND SAFEGUARDS AND HOUSEKEEPING INSPECTIONS. OTHER AREAS INSPECTED INCLUDED MAINTENANCE OBSERVATIONS, REVIEW OF PREVIOUS INSPECTION FINDINGS FOLLOW-UP OF EVENTS, REVIEW OF LICENSEE IDENTIFIED ITEMS, AND REVIEW OF INSPECTOR FOLLOW-UP ITEMS. DURING THIS PERIOD THERE WAS EXTENSIVE CONTROL ROOM AND PLANT ACTIVITY COVERAGE BY NRC INSPECTORS AND MANAGERS. NO VIOLATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION II, CRITERION V, CRITERION XVII, QA TOPICAL REPORT TABLE 17E-1, NUCLEAR QUALITY ASSURANCE MANUAL (NQAM), PART 1, SECTION 2.17, AND NUCLEAR ENGINEERING PROCEDURE 1.2, REV. 1, AS OF OCTOBER 1987, DNE TRAINING AND DOCUMENTATION FAILED TO MEET THE FOLLOWING REQUIREMENTS OF NEP-1.2: (1) THE ASSISTANT CHIEF MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 30 OF 40 REQUIRED TRAINING SUBJECTS. A LEAD MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 35 OF 40 REQUIRED TRAINING SUBJECTS. (2) WATTS BAR SITE-SPECIFIED TRAINING REQUIREMENTS WERE LESS THAN THE TRAINING PROGRAM SPECIFIED BY NEP-1.2. A TYPICAL EXAMPLE CONCERNS A WATTS BAR ASSISTANT PROJECT ENGINEER (APE), WHOSE SITE-SPECIFIED TRAINING REQUIREMENTS DID NOT INCLUDE SEVEN AREAS REQUIRED BY NEP-1.2. (3) THE LICENSEE WAS UNABLE TO CONFIRM THAT REQUIREMENTS OF THE TRAINING MATRIX HAD BEEN ACCOMPLISHED FOR FIVE MECHANICAL ENGINEERING BRANCH (MEB) PERSONNEL AND TWO WATTS BAR APES. SINCE AN ADDITIONAL OPPORTUNITY TO CONFIRM THE ABOVE TRAINING WAS AFFORDED SUBSEQUENT TO THE EXIT INTERVIEW AND THE TRAINING WAS NOT CONFIRMED, THE NRC CONCLUDES THAT THE TRAINING WAS NOT CONDUCTED.

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION XVIII, CRITERION XVI. AND NQAM, PART 1, SECTION 2.18, REV. 0, 10 AUDITS FROM 1985 TO JANUARY 1987 IDENTIFIED TRAINING DEFICIENCIES WHICH, AT THE TIME OF THE INSPECTION, HAD NOT BEEN CORRECTED. (8706 4)

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION V, AND NEP 1.3, REV. 0, CORRECTIONS WERE MADE TO NUMEROUS DOCUMENTS IN A MANNER NOT IN CONFORMANCE WITH THE ONE LINE, INITIAL, AND DATE METHOD. (8706 5)

CONTRARY TO TECHNICAL SPECIFICATION (TS) 6.8.1, FROM FEBRUARY TO NOVEMBER, 1987, THE OVERTIME LIMITS SPECIFIED IN AI-30 WERE EXCEEDED ON NUMEROUS OCCASIONS WITHOUT PLANT MANAGER OR PLANT SUPERINTENDENT AUTHORIZATION. IN ADDITION, THE FORM DOCUMENTING DEVIATION FROM PLANT STAFF OVERTIME LIMITS WAS NOT ALWAYS FORWARDED TO THE PLANT MANAGER WITHIN THE REQUIRED TIME PERIOD. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, PRIOR TO DECEMBER 14, 1987, THE LICENSEF FAILED TO PRESCRIBE IN INSTRUCTIONS OR PROCEDURES THE TRAINING AND QUALIFICATION REQUIREMENTS FOR COMPOSITE CREWS, IN THAT COMPOSITE CREWS WERE IMPLEMENTED PRIOR TO HAVING ESTABLISHED TRAINING AND QUALIFICATION REQUIREMENTS FOR FOREMEN AND GENERAL FOREMAN SUPERVISING PERSONNEL IN OTHER CRAFTS, FOR CRAFTSMEN PERFORMING WORK OUTSIDE OF THEIR CRAFT, AND FOR CRAFTSMEN PERFORMING INDEPENDENT VERIFICATION OUTSIDE OF THEIR CRAFT.

(8707 4)

CONTRARY TO TS 6.8.1, REGULATORY GUIDE 1.33, SYSTEM OPERATING INSTRUCTION (SOI)-1.1, MAIN STEAM, ADMINISTRATIVE INSTRUCTION

INSPECTION STATUS - (CONTINUED)

ENFORCEMENT SUMMARY

(AI)-25, (PART I), REV. 23, "DRAWING CONTROL AFTER LICENSING", AND SURVEILLANCE INSTRUCTION (SI)-187, CONTAINMENT INSPECTION: (1) ON FEBRUARY 7, 1988, SOI-1.1 WAS NOT COMPLIED WITH DURING STARTUP OF THE UNIT 2 MAIN STEAM SYSTEM IN THAT RCS TAVE WAS NOT BETWEEN 300 DEGREES FAHRENHEIT AND 350 DEGREES FAHRENHEIT PRIOR TO WARMING THE MAIN STEAM LINES AND PLACING MAIN STEAM IN SERVICE. THIS NONCOMPLIANCE CONTRIBUTED TO A HIGH STEAM FLOW INDICATION WHICH RESULTED IN A MSIV ISOLATION, GENERATION OF A REACTOR TRIP SIGNAL, AND A FEEDMATER ISOLATION. (2) DURING RECOVERY FROM THIS EVENT LATER ON FEBRUARY 7, 1988, ONLY THE #4 STEAM GENERATOR MSIV WAS OPENED TO EQUALIZE PRESSURE IN THE MAIN STEAM HEADER. THIS NONCOMPLIANCE RESULTED IN A STEAM GENERATOR SWELL CONDITION AND RESULTANT FEEDWATER ISOLATION. (3) ON JANUARY 31, 1988, A PORTION OF AN UNIDENTIFIED DRAWING MARKED "INFORMATION ONLY" WAS USED TO PERFORM WORK ON CONTAINMENT SPRAY SYSTEM FLOW INDICATOR 2-FI-72-34. (4) ON FEBRUARY 1, 1983, FOLLOWING THE LICENSEE'S PERFORMANCE OF SI-187, PORTIONS OF THE CONTAINMENT ICE CONDENSER WERE FOUND TO BE INADEQUATE TO SUPPORT PLANT RESTART DUE TO VARIOUS DEBRIS AND FOREIGN MATERIAL BEING PRESENT WITHIN THE ICE CONDENSER. ON FEBRUARY 2, 1988, FOLLOWING CLEANUP OF THE AREA, THE LICENSEE STATED THAT THE CONTAINMENT ICF CONDENSER WAS AGAIN READY TO SUPPORT RESTART, BUT UPON REINSPECTION THE ICE CONDENSER CONDITION WAS STILL FOUND TO BE DEFICIENT. CONTRARY TO TS 6.8.1 AND APPENDIX A OF REGULATORY GUIDE 1.33, REVISION 2, PRIOR TO JANUARY 4, 1983, THE LICENSEE FAILED TO ADEQUATELY ESTABLISH, IMPLEMENT, AND MAINTAIN PROCEDURES FO? CONFIGURATION CONTROL AS FOLLOWS: (1) THE LICENSEE FAILED TO SPECIFY THE MINIMUM QUALIFICATION LEVEL FOR INDIVIDUALS PERFORIING INDEPENDENT VERIFICATION OF SOI CHECKLISTS AS REQUIRED BY AI-37. THIS RESULTED IN A FAILURE TO PERFORM AND DOCUMENT ADEQUAT : TRAINING FOR ALL INDIVIDUALS PERFORMING SOI CHECKLIST VERIFICATIONS. (2) THE LICENSEE FAILED TO IMPLEMENT THE REQUIREMENTS IN A .- 58 FOR MAINTAINING CONFIGURATION CONTROL AFTER SOI CHECKLIST COMPLETION, IN THAT THE DOCUMENTED POSITIONS IN THE CONFIGURATION CONTROL SYSTEM FOR INSTRUMENT ROOT VALVE 1-268A, AND THE BREAKERS FOR POST ACCIDENT SAMPLING VALVES ON 120 V VITAL INSTRUMENT POWER BOARDS 2-III AND 2-IV (BREAKER 17 ON EACH BOARD) DISAGREED WITH THE ACTUAL POSITIONS. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XVI, PRIOR TO JANUARY 4, 1988, THE LICENSEE FAILED TO ADEQUATELY IDENTIFY AND CORRECT SOI CHECKLIST DEFICIENCIES IN THAT NUMEROUS SOI CHECKLISTS WERE FOUND TO HAVE SIGNIFICANT DEFICIENCIES AFTER THE LICENSEE HAD COMPLETED CORRECTIVE ACTION FOR SIMILAR DEFICIENCIES AND HAD RESTARTED THE SYSTEM ALIGNMENT PROGRAM USING THOSE CHECKLISTS. AS A RESULT, THE STATUS OF NUMEROUS PIECES OF EQUIPMENT HAD TO BE REVERIFIED TO ENSURE THAT THEIR POSITIONS WERE ADEQUATE FOR MODE CHANGE. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, PRIOR TO JANUARY 6, 1988, THE LICENSEE FAILED TO ESTABLISH OR IMPLEMENT INSTRUCTIONS, PROCEDURES, OR DRAWINGS THAT WOULD HAVE PREVENTED THE STORAGE OF LOOSE CONDUCTIVE MATERIAL WITHIN SAFETY RELATED ELECTRICAL BOARDS. SPECIFICALLY, LOOSE SPARE FUSES WERE FOUND STORED WITHIN 480 VOLT SAFFTY-RELATED DIESEL GENERATOR AUXILIARY BOARD 2A1-A WHICH COULD HAVE RENDERED THE PANEL INOPERABLE DURING A SEISMIC EVENT. SUBSEQUENT ELECTRICAL BOARD INSPECTIONS BY THE LICENSEE IDENTIFIED NUMEROUS ADDITIONAL SIGNIFICANT EXAMPLES OF LOOSE CONDUCTIVE MATERIAL STOKAGE WITHIN SAFETY-RELATED ELECTRICAL BOARDS. (8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROPIEMS:

ENVIRONMENTAL QUALIFICATION OF EQUIPMENT.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

MODE 5.

INSPECTION STATUS - (CONTINUED)

ENFORCEMENT SUMMARY

(AI)-25, (PART I), REV. 23, "DRAWING CONTROL AFTER LICENSING", AND SURVEILLANCE INSTRUCTION (SI)-187, CONTAINMENT INSPECTION: (1) ON FEBRUARY 7, 1988, SOI-1.1 WAS NOT COMPLIED WITH DURING STARTUP OF THE UNIT 2 MAIN STEAM SYSTEM IN THAT RCS TAVE WAS NOT BETWEEN 300 DEGREES FAHRENHEIT AND 350 DEGREES FAHRENHEIT PRIOR TO WARMING THE MAIN STEAM LINES AND PLACING MAIN STEAM IN SERVICE. THIS NONCOMPLIANCE CONTRIBUTED TO A HIGH STEAM FLOW INDICATION WHICH RESULTED IN A MSIV ISOLATION, GENERATION OF A REACTOR TRIP SIGNAL, AND A FEEDNATER ISOLATION. (2) DURING RECOVERY FROM THIS EVENT LATER ON FEBRUARY 7. 1988, ONLY THE \$4 STEAM GENERATOR MSIV WAS OPENED TO EQUALIZE PRESSURE IN THE MAIN STEAM HEADER. THIS NONCOMPLIANCE RESULTED IN A STEAM GENERATOR SWELL CONDITION AND RESULTANT FEEDWATER ISOLATION. (3) ON JANUARY 31, 1988, A PORTION OF AN UNIDENTIFIED DRAWING MARKED "INFORMATION ONLY" WAS USED TO PERFORM WORK ON CONTAINMENT SPRAY SYSTEM FLOW INDICATOR 2-FI-72-34. (4) ON FEBRUARY 1, 1988, FOLLOWING THE LICENSEE'S PERFORMANCE OF SI-187, PORTIONS OF THE CONTAINMENT ICE CONDENSER WERE FOUND TO BE INADEQUATE TO SUPPORT PLANT RESTART DUE TO VARIOUS DEBRIS AND FOREIGN MATERIAL BEING PRESENT WITHIN THE ICE CONDENSER. ON FEBRUARY 2, 1988, FOLLOMING CLEANUP OF THE AREA. THE LICENSEE STATED THAT THE CONTAINMENT ICE CONDENSER WAS AGAIN READY TO SUPPORT RESTART, BUT UPON REINSPECTION THE ICE CONDENSER CONDITION WAS STILL FOUND TO BE DEFICIENT. CONTRARY TO TS 6.8.1 AND APPENDIX A OF REGULATORY GUIDE 1.33, REVISION 2, PRIOR TO JANUARY 4, 1988, THE LICENSEE FAILED TO ADEQUATELY ESTABLISH, IMTLEMENT, AND MAINTAIN PROCEDURES FOR CONFIGURATION CONTROL AS FOLLOWS: (1) THE LICENSEE FAILED TO SPECIFY THE MINIMUM QUALIFICATION LEVEL FOR INDIVIDUALS PERFORMING INDEPENDENT VERIFICATION OF SOI CHECKLISTS AS REQUIRED BY AI-37. THIS RESULTED IN A FAILURE TO PERFORM AND DOCUMENT ADEQUATE TRAINING FOR ALL INDIVIDUALS PERFORMING SOI CHECKLIST VERIFICATIONS. (2) THE LICENSEE FAILED TO IMPLEMENT THE REQUIREMENTS IN AI-58 FOR MAINTAINING CONFIGURATION CONTROL AFTER SOI CHECKLIST COMPLETION, IN THAT THE DOCUMENTED POSITIONS IN THE CONFIGURATION CONTROL SYSTEM FOR INSTRUMENT ROOT VALVE 1-268A, AND THE BREAKERS FOR POST ACCIDENT SAMPLING VALVES ON 120 V VITAL INSTRUMENT POWER BOARDS 2-III AND 2-IV (BREAKER 17 ON EACH BOARD) DISAGREED WITH THE ACTUAL POSITIONS. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XVI, PRIOR TO JANUARY 4, 1988, THE LICENSEE FAILED TO ADEQUATELY IDENTIFY AND CORRECT SOI CHECKLIST DEFICIENCIES IN THAT NUMEROUS SOI CHECKLISTS WERE FOUND TO HAVE SIGNIFICANT DEFICIENCIES AFTER THE LICENSEE HAD COMPLETED CORRECTIVE ACTION FOR SIMILAR DEFICIENCIES AND HAD RESTARTED THE SYSTEM ALIGNMENT PROGRAM USING THOSE CHECKLISTS. AS A RESULT, THE STATUS OF NUMEROUS PIECES OF EQUIPMENT HAD TO BE REVERIFIED TO ENSURE THAT THEIR POSITIONS WERE ADEQUATE FOR MODE CHANGE. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, PRIOR TO JANUARY 6, 1988, THE LICENSEE FAILED TO ESTABLISH OR IMPLEMENT INSTRUCTIONS, PROCEDURES, OR DRAWINGS THAT WOULD HAVE PREVENTED THE STORAGE OF LOOSE CONDUCTIVE MATERIAL WITHIN SAFETY RELATED ELECTRICAL BOARDS. SPECIFICALLY, LOOSE SPARE FUSES WERE FOUND STORED WITHIN 480 VOLT SAFETY-RELATED DIESEL GENERATOR AUXILIARY BOARD 2A1-A WHICH COULD HAVE RENDERED THE PANEL INOPERABLE DURING A SEISMIC EVENT. SUBSEQUENT ELECTRICAL BOARD INSPECTIONS BY THE LICENSEE IDENTIFIED NUMEROUS ADDITIONAL SIGNIFICANT EXAMPLES OF LOOSE CONDUCTIVE MATERIAL STORAGE WITHIN SAFETY-RELATED ELECTRICAL BOARDS. (8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

ENVIRONMENTAL QUALIFICATION OF EQUIPMENT.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

MODE 5.

Report Period	d APR 1988	I	NSPEC	TION	STA	דטג -	(CONTINUED)	**************************************
OTHER ITEMS								
LAST IE SI	TE INSPECTIO	DN DATE: M	IARCH 19 - A	PRIL 2, 1	988 +			
INSPECTION	REPORT NO:	50-327/88	-22 +					
				REPOR	TS F	ROM	LICENSEE	

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT					
88-013	03/14/88	04/01/88	RADIATION OVERSIGHT	MONITOR	TCH SPEC	SURVEILL	ANCE REQUIREMENT	OMMITTED FROM SURVEILLANCE PROGRAM DUE TO AN
===========						*********		

1.	Docket: 50-328 0	PERAT	INGS	TATUS
2.	Reporting Period: 04/01/8	8_ Outage	+ On-line	Hes: 719.0
3.	Utility Contact: DAVID DU	PREF. (615)	870-6722	
4.	Licensed Thermal Power (MW	3411		
5.	Nameplate Rating (Gross MW	e):		1226
6.	Design Electrical Rating (Net MWo):		1148
7.	Maximum Dependable Capacit	y (Gross M	Weigt	1183
δ.	Maximum Dependable Capacit	y (Net MHe):	1148
9.	If Changes Occur Above Sin	ce Last Re	port, Give	Reasons:
	NONE			
10.	Power Level To Which Restr	icted, If	Any (Net Mk	le):
11.	Reasons for Restrictions,	If Any:		
-	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE
13.	Hours Reactor Critical	. 0	. 0	21,984.5
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	. 0
15.	Hrs Generator On-Line	. 0		
16.	Unit Reserve Shtdwn Hrs	. 0		. 0
17.	Gross Therm Ener (MWH)	0	0	69,127,974
18.	Gross Elec Ener (MWH)	0	0	23,536,780
19.	Net Elec Ener (MWH)	-9,153		22,456,395
20.	Unit Service Factor	. 0	. 0	41.4
21.	Unit Avail Factor	. 0		41.4
22.	Unit Cap Factor (MDC Net)	. 0	. 0	37.7
23.	Unit Cap Factor (DER Net)	. 0	. 0	37.7
24.	Unit Forced Outage Rate	100.0	100.0	54.3
25.	Forced Outage Hours	719.0	2,903.0	25,546.3
26.	Shutdowns Sched Over Next (6 Months (1	lype,Date,D	uration):
27	If Curcently Shutdown Entir	nated Star	Data:	05/01/88

.

SEQUOYAH 2

5



PAGE 2-384

. 6

UNIT SHUTDOWNS / REDUCTIONS *

No.	Date	Туре	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	08/21/27	F	185.0	F	4				DESIGN CONTROL, CONFIGURATION UPDATING, AND EMPLOYEE CONCERNS.
2	04/07/88	F	513.2	F	9				REPAIR NO. 3 S/G TUBE LEAK.
3	04/30/88	F	20.8	F	9				MAINTENANCE OF THE PRESSURIZER SAFETY VALVES.

Report Period APR 1988

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE.....TENNESSEE

DIST AND DIRECTION FROM NEAREST POPULATION CTR...9.5 MI NE OF CHATTANODGA, TN

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...NOVEMBER 5, 1981

DATE ELEC ENER 1ST GENER...DECEMBER 23, 1981

DATE COMMERCIAL OPERATE....JUNE 1, 1982

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER....CHICKAMAUGA LAKE

ELECTRIC RELIABILITY

COUNCIL......SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE.....TENNESSEE VALLEY AUTHORITY

CORPORATE ADDRESS...... NORTH 38A LOOKOUT PLACE CHATTANOOGA, TENNESSEE 37401

CONTRACTOR

ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....E. FORD

LICENSE & DATE ISSUANCE.... DPR-79, SEPTEMBER 15, 1981

PUBLIC DOCUMENT ROOM.....CHATTANOOGA - HAMILTON BICENTENNIAL LIBRARY 1001 BROAD STREET CHATTANOOGA, TENNESSEE 37402

INSPECTION SUMMARY

* INSPECTION AUGUST 17-21 (87-57): ANNOUNCED INSPECTION TO COMPLETE THE REVIEW OF TVA'S IMPLEMENTATION OF A PROGRAM PER THE REQUIREMENTS OF 10 CFR 50.49 FOR ESTABLISHING AND MAINTAINING THE QUALIFICATION OF ELECTRIC EQUIPMENT WITHIN THE SCOPE OF 10 CFR 50.49. THE INSPECTION IDENTIFIED NO DEFICIENCIES IN THE SQN IMPLEMENTATION OF A PROGRAM TO MEET THE REQUIREMENTS OF 50.49. BASED ON THE INSPECTORS REVIEWS AND EVALUATIONS, INSPECTION FOLLOW-UP ITEMS 50-327,328/87-22-02 AND -03 WERE CLOSED. WHILE NO DEFICIENCIES WERE IDENTIFIED IN EQUIPMENT QUALIFICATION PROGRAM IMPLEMENTATION, SQN NEEDS TO COMPLETE THE REPLACEMENT ITEMS PROJECT (RIP) BEFORE SQN IS IN COMPLIANCE WITH 10 CFR 50.49. THIS PROJECT IS THE SUBJECT OF A SEPARATE NRC INSPECTION (INSPECTION 50-327,328/87-40, JULY 13-24, 1987); THEREFORE, COMPLETION OF RIP IS NUT IDENTIFIED FOR FOLLOW-UP IN THIS INSPECTION REPORT.

INSPECTION DECEMBER 6 - FEBRUARY 5 (87-76): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF OPERATIONAL SAFETY VERIFICATION (INCLUDING OPERATIONS PERFORMANCE, SYSTEM LINEUPS, RADIATION PROTECTION, SAFEGUARDS AND HOUSEKEEPING INSPECTIONS); MAINTENANCE OBSERVATIONS; REVIEW OF PREVIOUS INSPECTION FINDINGS; FOLLOWUP OF EVENTS; REVIEW OF LICENSEE IDENTIFIED ITEMS; REVIEW OF IE INFORMATION NOTICES; AND REVIEW OF INSPECTOR FOLLOWUP ITEMS. TWO VIOLATIONS (VIOS) WERE IDENTIFIED. FAILURE TO PERFORM ADEQUATE POST MAINTENANCE TESTING. FAILURE TO FOLLOW PROCEDURE, TWO EXAMPLES. ONE UNRESOLVED ITEM (URI) WAS IDENTIFIED DURING THIS INSPECTION. URIS ARE MATTERS ABOUT WHICH MORE INFORMATION IS REQUIRED TO DETERMINE WHETHER THEY ARE ACCEPTABLE OR MAY INVOLVE VIOLATIONS GR DEVIATIONS. FITH VITAL BATTERY CONCERNS. TWO INSPECTOR FOLLOWUP ITEMS (IFIS) WERE IDENTIFIED. ANUGAR FLOW INSTRUMENTS AND VERIFICATION OF HEAT EXCHANGER DIFFERENTIAL PRESSURE. CABLE ROUTING DEFICIENCIES ON UNIT 1 CABLES 1V1936A AND 1V1881A.

INSPECTION JANUARY 6-13 (88-01): THIS ANNOUNCED SPECIAL INSPECTION WAS CONDUCTED IN THE CORPORATE OFFICES IN CHATTANOOGA TO

PAGE 2-386

Report Period APR 1988

INSPECTION STATUS - (CONTINUED)

INSPECTION SUMMARY

REVIEW THE LICENSEE'S CORRECCTIVE MEASURES IN RESPONSE TO UNRESOLVED ITEM NO. 50-259,260 AND 296/86-37-01 AND 50-327 AND 328/86-58-01. THE UNRESOLVED ITEM IS CLOSED.

INSPECTION FEBRUARY 8-12 (88-14): THIS SPECIAL ANNOUNCED INSPECTION WAS CONDUCTED TO EVALUATE LICENSEE RESOLUTIONS OF INSPECTOR FOLLOWUP ITEMS RELATED TO EMERGENCY OPERATING PROCEDURES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MARCH 7-18 (88-18): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED REVIEW AND EVALUATION OF THE LICENSEE'S EMERGENCY PREPAREDNESS PROGRAM. ONE VIOLATION WAS IDENTIFIED - FAILURE TO PROVIDE REQUIRED EMERGENCY RESPONSE TRAINING FOR AN INDIVIDUAL DESIGNATED AS TECHNICAL SUPPORT CENTER COMMUNICATOR.

INSPECTION MARCH 19 - APRIL 2 (88-22): THIS ANNOUNCED INSPECTION INVOLVED ONSHIFT AND ONSITE INSPECTIONS BY THE NRC RESTART TASK FORCE. THE M AJORITY OF EXPENDED INSPECTION EFFORT HAS IN THE AREAS OF EXTENDED CONTROL ROOM OBSERVATION AND OPERATIONAL SAFETY VERIFICATION INCLUDING OPERATIONS PERFORMANCE, SYSTEM LINEUPS, RADIATION PROTECTION, AND SAFEGUARDS AND HOUSEKEEPING INSPECTIONS. OTHER AREAS INSPECTED INCLUDED MAINTENANCE OBSERVATIONS, REVIEW OF PREVIOUS INSPECTION FINDINGS FOLLOW-UP OF EVENTS, REVIEW OF LICENSEE IDENTIFIED ITEMS, AND REVIEW OF INSPECTOR FOLLOW-UP ITEMS. DURING THIS PERIOD THERE WAS EXTENSIVE CONTROL ROOM AND PLANT ACTIVITY COVERAGE BY NRC INSPECTORS AND MANAGERS. 40 VIOLATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION II, CRITERION V, CRITERION XVII, QA TOPICAL REPORT TABLE 17E-1. NUCLEAR QUALITY ASSURANCE MANUAL (NQAM), PART 1, SECTION 2.17, AND NUCLEAR ENGINEERING PROCEDURE 1.2, REV. 1, AS OF OCTOBER 1987, DNE TRAINING AND DOCUMENTATION FAILED TO MEET THE FOLLOWING REQUIREMENTS OF NEP-1.2: (1) THE ASSISTANT CHIEF MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 3 OF 40 REQUIRED TRAINING SUBJECTS. A LEAD MECHANICAL ENGINEER'S TRAINING COULD NOT BE CONFIRMED FOR 3 OF 40 REQUIRED TRAINING SUBJECTS. (2) WATTS BAR SITE-SPECIFIED TRAINING REQUIREMENTS WERE LESS THAN THE TRAINING PROGRAM SPECIFIED BY NEP-1.2. A TYPICAL EXAMPLE CONCERNS A WATTS BAR ASSISTANT PROJECT ENGINEER (APE), WHOSE SITE-SPECIFIED TRAINING REQUIREMENTS DID NOT INCLUDE SEVEN AREAS REQUIRED BY NEP-1.2. (3) THE LICENSEE WAS UNABLE TO CONFIRM THAT REQUIREMENTS OF THE TRAINING MATRIX HAD BEEN ACCOMPLISHED FOR FIVE MECHANICAL ENGINEERING BRANCH (MEB) PERSONNEL AND TWO WATTS BAR APES. SINCE AN ADDITIONAL OPPORTUNITY TO CONFIRM THE ABOVE TRAINING WAS AFFORDED SUBSEQUENT TO THE EXIT INTERVIEW AND THE TRAINING WAS NOT CONFIRMED. THE NRC CONCLUDES THAT THE TRAINING WAS NOT CONDUCTED.

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION XVIII, CRITERION XVI, AND NQAM, PART 1, SECTION 2.18, REV. 0, 10 AUDITS FROM 1985 TO JANUARY 1987 IDENTIFIED TRAINING DEFICIENCIES WHICH, AT THE TIME OF THE INSPECTION, HAD NOT BEEN CORRECTED. (8706 4)

CONTRARY TO 10 CFR PART 50, APPENDIX B, CRITERION V, AND NEP 1.3, REV. 0, CORRECTIONS WERE MADE TO NUMEROUS DOCUMENTS IN A MANNER NOT IN CONFORMANCE WITH THE ONE LINE, INITIAL, AND DATE METHOD. (8706 5)

CONTRARY TO TECHNICAL SPECIFICATION (TS) 6.8.1, FROM FEBRUARY TO NOVEMBER, 1987, THE OVERTIME LIMITS SPECIFIED IN AI-30 WERE EXCEEDED ON NUMEROUS OCCASIONS WITHOUT PLANT MANAGER OR PLANT SUPERINTENDENT AUTHORIZATION. IN ADDITION, THE FORM DOCUMENTING DEVIATION FROM PLANT STAFF OVERTIME LIMITS WAS NOT ALWAYS FORWARDED TO THE PLANT MANAGER WITHIN THE REQUIRED TIME PERIOD. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, PRIOR TO DECEMBER 14, 1987, THE LICENSEE FAILED TO PRESCRIBE IN INSTRUCTIONS OR PROCEDURES THE TRAINING AND QUALIFICATION REQUIREMENTS FOR COMPOSITE CREWS, IN THAT COMPOSITE CREWS WERE IMPLEMENTED PRIOR TO HAVING ESTABLISHED TRAINING AND QUALIFICATION REQUIREMENTS FOR FOREMEN AND GENERAL FOREMAN SUPERVISING PERSONNEL IN OTHER CRAFTS, FOR CRAFTSMEN PERFORMING WORK OUTSIDE OF THEIR CRAFT, AND FOR CRAFTSMEN PERFORMING INDEPENDENT VERIFICATION OUTSIDE OF THEIR CRAFT.

(8707 4)

CONTRARY TO TS 6.8.1, REGULATORY GUIDE 1.33, SYSTEM OPERATING INSTRUCTION (SOI)-1.1, MAIN STEAM, ADMINISTRATIVE INSTRUCTION

INSPECTION STATUS - (CONTINUED)

ENFORCEMENT SUMMARY

(AI)-25, (PART I), REV. 23, "DRAWING CONTROL AFTER LICENSING", AND SURVEILLANCE INSTRUCTION (SI)-187, CONTAINMENT INSPECTION: (1) ON FEBRUARY 7, 1988, SOI-1.1 WAS NOT COMPLIED WITH DURING STARTUP OF THE UNIT 2 MAIN STEAM SYSTEM IN THAT RCS TAVE WAS NOT BETWEEN 300 DEGREES FAHRENHEIT AND 350 DEGREES FAHRENHEIT PRIOR TO WARMING THE MAIN STEAM LINES AND PLACING MAIN STEAM IN SERVICE. THIS NONCOMPLIANCE CONTRIBUTED TO A HIGH STEAM FLOW INDICATION WHICH RESULTED IN A MSIV ISOLATION. GENERATION OF A REACTOR TRIP SIGNAL, AND A FEEDWATER ISOLATION. (2) DURING RECOVERY FROM THIS EVENT LATER ON FEBRUARY 7, 1988, ONLY THE #4 STEAM GENERATOR MSIV WAS OPENED TO EQUALIZE PRESSURT IN THE MAIN STEAM HEADER. THIS NONCOMPLIANCE RESULTED IN A STEAM GENERATOR SWELL CONDITION AND RESULTANT FEEDWATER ISOLATION. (3) ON JANUARY 31, 1988, A PORTION OF AN UNIDENTIFIED DRAWING MARKED "INFORMATION ONLY" WAS USED TO PERFORM WORK ON CONTAINMENT SPRAY SYSTEM FLOW INDICATOR 2-FI-72-34. (4) ON FEBRUARY 1, 1988, FOLLOWING THE LICENSEE'S PERFORMANCE OF SI-187, PORTIONS OF THE CONTAINMENT ICE CONDENSER WERE FOUND TO BE INADEQUATE TO SUPPORT PLANT RESTART DUE TO VARIOUS DEBRIS AND FOREIGN MATERIAL BEING PRESENT WITHIN THE ICE CONDENSER. ON FEBRUARY 2, 1988, FOLLOWING CLEANUP OF THE AREA, THE LICENSEE STATED THAT THE CONTAINMENT ICE CONDENSER WAS AGAIN READY TO SUPPORT RESTART, BUT UPON REINSPECTION THE ICE CONDENSER CONDITION WAS STILL FOUND TO BE DEFICIENT. CONTRARY TO TS 6.8.1 AND APPENDIX A OF REGULATORY GUIDE 1.33, REVISION 2, PRIOR TO JANUARY 4, 1988, THE LICENSEE FAILED TO ADEQUATELY ESTABLISH, IMPLEMENT, AND MAINTAIN PROCEDURES FOR CONFIGURATION CONTROL AS FOLLOWS: (1) THE LICENSEE FAILED TO SPECIFY THE MINIMUM QUALIFICATION LEVEL FOR INDIVIDUALS PERFORMING INDEPENDENT VERIFICATION OF SOI CHECKLISTS AS REQUIRED BY AI-37. THIS RESULTED IN A FAILURE TO PERFORM AND DOCUMENT ADEQUATE TRAINING FOR ALL INDIVIDUALS PERFORMING SOI CHECKLIST VERIFICATIONS. (2) THE LICENSEE FAILED TO IMPLEMENT THE REQUIREMENTS IN AI-58 FOR MAINTAINING CONFIGURATION CONTROL AFTER SOI CHECKLIST COMPLETION. IN THAT THE DOCUMENTED POSITIONS IN THE CONFIGURATION CONTROL SYSTEM FOR INSTRUMENT ROOT VALVE 1-268A, AND THE BREAKERS FOR POST ACCIDENT SAMPLING VALVES ON 120 V VITAL INSTRUMENT POWER BOARDS 2-III AND 2-IV (BREAKER 17 ON EACH BOARD) DISAGREED WITH THE ACTUAL POSITIONS. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XVI, PRIOR TO JANUARY 4, 1988, THE LICENSEE FAILED TO ADEQUATELY IDENTIFY AND CORRECT SOI CHECKLIST DEFICIENCIES IN THAT NUMEROUS SOI CHECKLISTS WERE FOUND TO HAVE SIGNIFICANT DEFICIENCIES AFTER THE LICENSEE HAD COMPLETED CORRECTIVE ACTION FOR SIMILAR DEFICIENCIES AND HAD RESTARTED THE SYSTEM ALIGNMENT PROGRAM USING THOSE CHECKLISTS. AS A RESULT, THE STATUS OF NUMEROUS PIECES OF EQUIPMENT HAD TO BE REVERIFIED TO ENSUCE THAT THEIR POSITIONS WERE ADEQUATE FOR MODE CHANGE. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, PRIOR TO JANUARY 6, 1988, THE LICENSEE FAILED TO ESTABLISH OR IMPLEMENT INSTRUCTIONS, PROCEDURES, OR DRAWINGS THAT HOULD HAVE PREVENTED THE STORAGE OF LOOSE CONDUCTIVE MATERIAL WITHIN SAFETY RELATED ELECTRICAL BOARDS. SPECIFICALLY, LOOSE SPARE FUSES WERE FOUND STORED WITHIN 480 VOLT SAFETY-RELATED DIESEL GENERATOR AUXILIARY 80ARD 2A1-A WHICH COULD HAVE RENDERED THE PANEL INOPERABLE DURING A SEISMIC EVENT. SUBSEQUENT ELECTRICAL BOARD INSPECTIONS BY THE LICENSEE IDENTIFIED NUMEROUS ADDITIONAL SIGNIFICANT EXAMPLES OF LOOSE CONDUCTIVE MATERIAL STORAGE WITHIN SAFETY-RELATED ELECTRICAL BOARDS. CONTRARY TO TECHNICAL SPECIFICATION 6.4, DETAILED WRITTEN PROCEDURES WERE NOT FOLLOWED BY EITHER COMPLYING WITH THE STEPS OR IMPLEMENTING A CHANGE PRIOR TO PROCEEDING. THIS RESULTED IN THE FAILURE TO PROPERLY ESTABLISH THE INITIAL CONDITIONS LISTED BELOW: (1) ON JANUARY 9, 1988, TEST PROCEDURE 1-PT-29.1, "TURBINE INLET VALVE TEST", WAS PERFORMED WITHOUT MEETING INITIAL CONDITION 3.5 OF THE TEST, MHICH REQUIRES THE ROD CONTROL SYSTEM TO BE IN THE AUTOMATIC CONTROL MODE. THE TEST WAS PERFORMED WITH THE ROD CONTROL SYSTEM IN THE MANUAL MODE. (2) ON JANUARY 9 AND 23, 1988, UNIT 1 AND UNIT 2 RESPECTIVELY, WERE RAMPED DOWN FROM 100% TO LESS THAN 75% POWER IN ACCORDANCE WITH OPERATIONS PROCEDURE OP-2.1.2, "DECREASING POWER FROM EXISTING POWER LEVEL TO 22", WITHOUT MEETING INITIAL CONDITION 3.4 OF THE PROCEDURE, WHICH REQUIRED THE PORTABLE NARROW RANGE STEAM GENERATOR LEVEL INDICATORS TO BE IN PLACE AND OPERATING. (3) ON JANUARY 9, 1988, UNIT 1 WAS RAMPED DOWN FROM 100% TO LESS THAN 75% POWER IN ACCORDANCE WITH OPERATIONS PROCEEDIRE OF-2.1.2. "DECREASING POWER FROM EXISTING POWER LEVEL TO 22", WITHOUT PERFORMING STEP, 3.7.1 THROUGH 3.7.4 OF THE PROCEDURE, WHICH REQUIRED THAT JUMPERS BE INSTALLED TO REMOVE THE SEAL-IN FUNCTION FROM CONTROLLERS OF MOISTURE SEPARATOR REHEATER STEAM SUPPLY ISCLATION VALVES. CONTRARY TO TS 6.4J. ON FEBRUARY 23. 1988, FIRE PROTECTION EQUIPMENT REQUIRED TO BE MAINTAINED IN SITE FIRE HOSE HOUSES WAS REMOVED AND USED FOR NON-FIRE PROTECTION PURPOSES WITHOUT THE WRITTEN PERMISSION OF THE LOSS PREVENTION COORDINATOR. REVIEW OF TWELVE SURVEILLANCES OF HOSE HOUSES PERFORMED BY THE LICENSE IN 1987 AND 1988 IDENTIFIED TEN ADDITIONAL CASES WHERE EQUIPMENT HAD BEEN REMOVED WITHOUT WRITTEN PERMISSION OF THE LOSS PREVENTION COORDINATOR.

(8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INSPECTION STATUS ~ (CONTINUED)

OTHER ITEMS

12

.....

.

NONE.			
ENVIRONMEN	TAL QUALIFI	CATION OF E	QUIPMENT.
FACILITY I	TEMS (PLANS	AND PROCEDU	JR2S):
NONE.			
MANAGERIAL	ITEMS:		
NONE			
PLANT STAT	'US:		
MODE 5.			
LAST IE SI	TE INSPECTI	ON DATE: M	ARCH 19 - APRIL 2, 1988 +
INSPECTION	REPORT NO:	50-328/88	-22 *
			REPORTS FROM LICENSEE
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-011	03/06/88	04/01/88	SURVEILLANCE REQUIREMENT USED TO VERIFY BORON CONCENTRATION IN THE COLD LEG ACCUMULATORS WAS NOT PER." WITHIN APPL TIME
88-012	03/05/88	04/01/88	IMPROPER OPERABILITY DETERMINATIONS RELATING TO LEVEL CONTROL VALVE RESULTED IN NOT ENTERING THE APPL LCO IN A TIMELY MAN

PAGE 2-389

.....

8

1. Docket: _50-498	OPERAT	ING S	TATES
2. Reporting Period:	88_ Outage	+ On-line	Hrs: 719.0
3. Utility Contact: C.A. AY	ALA (512)	972-8628	
4. Licensed Thermal Power (M		3800	
5. Nameplate Rating (Gross M	We):		
6. Design Electrical Rating	(Net MWe):		1250
7. Maximum Dependable Capacit	ty (Gross M	Ne):	1250
8. Maximum Dependable Capacit	ty (Net MWe):	1250
9. If Changes Occur Above Sin	nce Last Rej	port, Give	Reasons:
 Power Level To Which Restrictions, NONE 	ricted, If If Any:	Any (Net Mk	le):
12. Report Period Hrs	MONTH 719.0	YEAR 758.1	CUMULATIVE
3. Hours Reactor Critical	666.0	678.3	678.3
4. R× Reserve Shtdwn Hrs	.0	. 0	
5. Hrs Generator On-Line	602.0	602.6	602.6
6. Unit Reserve Shtdwn Hrs	. 0		. 0
7. Gross Therm Ener (MWH)	663,115	666,554	666,554
8. Gross Elec Ener (MWH)	167,270	167,313	167,313
9. Net Elec Ener (MWH)	120,786	119,415	119,415
20. Unit Service Factor			
21. Unit Avail Factor		NOT IN	
22. Unit Cap Factor (MDC Net)		COMMERCIA	LL.
23. Unit Cap Factor (DER Net)		OPERATION	e
24. Unit Forced Dutage Rate			
25. Forced Outage Hours	74.6	113.1	113.1
26. Shutdowns Sched Over Next	6 Months (Type,Date,I	Duration):
MAINTENANCE - 5/1/88 - 16	DAT DUKATI	UN.	Net

IJ

34

1

.







APRIL 1988

************ SOUTH TEXAS 1 UNIT SHUTDOWNS / REDUCTIONS × Report Period APR 1988 ***** No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence REACTOR TRIP DUE TO SERIES OF MAIN GENERATOR LOCKOUT 88-01 03/30/88 F 69.4 B 4 88-026 EL RLY-86 AND MAIN TRANSFORMER LOCKOUT RELAYS TRIPPING WHEN A TEST SIGNAL WAS INCORRECTLY INSERTED INTO THE GENERATOR CONTROL CIRCUITS. TURBINE OVERSPEED TEST (RX CRITICAL). TA TRB 88-02 04/04/88 5 8.9 B 9 TTURBINE OVERSPEED TEST (RX CRITICAL). 4.6 9 TA TER 88-03 04/05/88 S B TURBINE OVERSPEED TEST (RX CRITICAL). TRB 88-04 04/05/88 S 1.1 B 9 TA STEAM LEAK REPAIR (RX CRITICAL). 9 TA TRB 88-05 04/06/88 S 27.8 B SHUTDOWN DUE TO TWO CONTROL ROOM HVAC MAKEUP AND 88-06 04/07/88 F VI TRB 5.2 D 9

112

ONE STANDBY DIESEL GENERATOR INOPERAABLE. TECH SPEC SHUTDOWN REQUIREMENT (RX CRITICAL).

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure F-A B-Maint or Test G-O C-Refueling H-O D-Regulatory Restric E-Operator Training & License Examina	dmin lper Error ther tion	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

**************************************	ILITY DATA
FACILITY DESCRIPTION	UTILITY & CONTRACTOR INFORMATION
LOCATION STATETEXAS	UTILITY LICENSEEHOU
COUNTYMATAGORDA	CORPORATE ADDRESSP.O
DIST AND DIRECTION FROM NEAREST POPULATION CTR12 MI SSW OF BAY CITY, TEX	CONTRACTOR ARCHITECT/ENGINEERBEC
TYPE OF REACTORPWR	NUC STEAM SYS SUPPLIERWES
DATE INITIAL CRITICALITYMARCH 8, 1988	CONSTRUCTOR EBA
DATE ELEC ENER 1ST GENERMARCH 30, 1988	TURBINE SUPPLIERWES
DATE COMMERCIAL OPERATE******************	REGULATORY INFORMATION
CONDENSER COOLING METHODCC	IE REGION RESPONSIBLEIV
CONDENSER COOLING WATERCOLORADO RIVER	IE RESIDENT INSPECTORC.
ELECTRIC RELIABILITY COUNCILELECTRIC RELIABILITY	LICENSING PROJ MANAGERN. DOCKET NUMBER
COUNCIL OF TEXAS	LICENSE & DATE ISSUANCE NPE

HOUSTON LIGHTING & POWER COMPANY P.O. BOX 1700 HOUSTON, TEXAS 77001 BECHTEL WESTINGHOUSE EBASCO WESTINGHOUSE VI C. JOHNSON N. KADAMBI 50-498 NPF-76, MARCH 22, 1988 PUBLIC DOCUMENT ROOM.....GLEN ROSE-SOMERVELL LIBRARY BERNARD AND HIGHWAY 144 P.O. BOX 417 GLEN ROSE, TX. 76043

INSPECTION STATUS

INSPECTION SUMMARY

INFO. NOT SUPPLIED BY REGION

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INFO. NOT SUPPLIED BY REGION

FACILITY ITEMS (PLANS AND PROCEDURES):

INFO. NOT SUPPLIED BY REGION

MANAGERIAL ITEMS:

INFO. NOT SUPPLIED BY REGION

Report Period APR 1988 INSPECTION STATUS - (CONTINUED)

******** SOUTH TEXAS 1 * *********************************

PLANT STATUS:

INFO. NOT SUPPLIED BY REGION

LAST IE SITE INSPECTIOM DATE: INFO. NOT SUPPLIED BY REGION

INSPECTION REPORT NO: INFO. NOT SUPPLIED BY REGION

REPORTS FROM LICENSEE

DATE OF DATE OF SUBJECT NUMBER EVENT

REPORT

INFO. NOT SUPPLIED BY REGION

1.	Docket: _50-3350	PERAT	INGS	TATUS				
2.	Reporting Period: 04/01/8	0utage	+ On-line	Hrs: 719.0				
3.	Utility Contact: N. W. GR	ANT (305)	694-4432					
4.	Licensed Thermal Power (MWt): 2700							
5.	Nameplate Rating (Gross M	(e):	1000 X	0.89 = 890				
6.	Design Electrical Rating (Net MWe):		830				
7.	Maximum Dependable Capacit	ty (Gross M	We):	872				
8.	Maximum Dependable Capacit	ty (Net MWe):	839				
9.	If Changes Occur Above Sir NONE	nce Last Re	port, Give	Reasons:				
10.	Power Level To Which Restr	icted, If	Any (Net Mb	le):				
11.	Reasons for Restrictions,	If Any:						
	NONE							
12.	Report Pe.iod Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 99,575.0				
13.	Hours Reactor Critical	719.0	2,882.1	75,433.9				
14.	Rx Reserve Shtdwn Hrs	. 0	.0	205.3				
15.	Hrs Generator On-Line	719.0	2,876.0	73,846.5				
16.	Unit Reserva Shtdwn Hrs	. 0	. 0	39.3				
17.	Gross Therm Ener (MWH)	1,941,214	7,729,126	189,074,763				
18.	Gross Elec Ener (MKH)	651,900	2,601,330	62,124,915				
19.	Net Elec Ener (MWH)	619,590	2,471,385	58,662,974				
20.	Unit Service Factor	100.0	99.1	74.2				
21.	Unit Avail Factor	100.0	99.1	74.2				
22.	Unit Cap Factor (MDC Net)	102.7	101.5	70.2				
23.	Unit Cap Factor (DER Net)	103.8	102.6	71.0				
24.	Unit Forced Outage Rate	. 0	.9	3.5				
25.	Forced Outage Hours	. 0	27.0	2,967.9				
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):				



ST LUCIE 1



APRIL 1988

UNIT SHUTDOWNS / REDUCTIONS

No.	Date	Type Hours	Reason Method	LER Number	System Component	Cause & Corrective Action to	Prevent Recurrence
-----	------	------------	---------------	------------	------------------	------------------------------	--------------------

NONE

.

********* ST. LUCIE 1 OPERATED ROUTINELY IN APRIL WITH NO OUTAGES * SUMMARY * OR SIGNIFICANT POWER REDUCTIONS.

Type	Reason	and the second second	Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161

PAGE 2-395

A

.

xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx	FACILITY DATA	Report Pariod APR 1988
CACILITY DESCRIPTION	UTILITY & CONTRACTOR INFORMATION	그는 것 같은 것 같은 것 같아요.
LOCATION STATEFLORIDA	UTILITY LICENSEEFLORIDA P	POWER & LIGHT
COUNTYST LUCIE	CORPORATE ADDRESS9250 WEST MIAMI,	FLAGLER STREET P.O. BOX 529100 FLORIDA 33152
DIST AND DIRECTION FROM NEAREST POPULATION CTR12 MI SE OF FT. PIERCE, FLA	CONTRACTOR ARCHITECT/ENGINEEREBASCO	
TYPE OF REACTORPWR	NUC STEAM SYS SUPPLIERCOMBUSTIC	DN ENGINEERING
DATE INITIAL CRITICALITY APRIL 22, 1976	CONSTRUCTOREBASCO	
DATE ELEC ENER 1ST GENER MAY 7, 1976	TURBINE SUPPLIERWESTINGHO	DUSE
DATE COMMERCIAL OPERATEDECEMBER 21, 19	76 REGULATORY INFORMATION	
CONDENSER COOLING METHODONCE THRU	IE REGIOM RESPONSIBLEII	
CONDENSER COOLING WATERATLANTIC OCEAN	IE RESIDENT INSPECTORR. CRLEN.	JAK
ELECTRIC RELIABILITY COUNCIL	ECTRIC LICENSING PROJ MANAGERE. TOURIG	GNY
RELIABILITY C	DUNCIL LICENSE & DATE ISSUANCEDPR-67, 1	MARCH 1, 1976

PUBLIC DOCUMENT ROOM......INDIAN RIVER COMMUNITY COLLEGE LIBRARY 3209 VIRGINIA AVENUE FT. PIERCE, FLORIDA 33450

INSPECTION STATUS

INSPECTION SUMPARY

+ INSPECTION FEBRUARY 8-12 (88-02): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED A REVIEW OF THE FOLLOWING AREAS: SECURITY PLAN AND IMPLENTING PROCEDURES; MANAGEMENT EFFECTIVENESS - SECURITY PROGRAM; SECURITY ORGANIZATION; RECORDS AND REPORTS; TESTING AND MAINTEPANCE; PHYSICAL BARRIERS - PROTECTED AREAS; PHYSICAL BARRIERS - VITAL AREAS; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL - PACKAGES; DETECTION AIDS - VITAL AREAS; AND ALARM STATIONS. TWO VIOLATIONS OF REGULATORY REQUIREMENTS AND ONE INSPECTOR FOLLOWUP ITEM WERE IDENTIFIED WITHIN THE AREAS INSPECTED.

1 (SPECTION MARCH 14-18 (88-04): THIS SPECIAL, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF LIQUID AND GASEOUS RADWASTE SYSTEMS, OFFSITE DOSE CALCULATION METHODOLOGY, AND EFFLUENT MONITORING AND SAMPLING. NO VIOLAITONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

· · ·

ł

OTHER ITEMS

Ceport Period APK 1988	INSPECTION	STATUS - (CUNIINUED)	* ST LUCIE 1 *
THER ITEMS			
SYSTEMS AND COMPONENT PRO	BLEMS:		
NONE.			
FACILITY ITEMS (PLANS AND	PROCEDURES):		
NONE.			
MANAGERIAL ITEMS:			
NONE .			
PLANT STATUS:			
NORMAL OPERATIONS.			
LAST IE SITE INSPECTION DA	ATE: MARCH 14-18, 1988 +		
INSPECTION REPORT NO: 50	-335/88-04 +		
	REPOR	TS FROM LICENSEE	
NUMBER DATE OF DAT EVENT R	TE OF SUBJEC1 EPORT		
NONE.			

PAGE 2-397

.

1.	Docket: 50-389 0	PERAT	ING S	TATUS
2.	Reporting Period: 04/01/8	0utage	+ On-line	Hrs: 719.0
3.	Utility Contact: N. W. GR	ANT (305)	694-4432	
4.	Licensed Thermal Power (MM	it):		2700
5.	Nameplate Rating (Gross MM	le):		850
6.	Design Electrical Rating (Net MWe):		830
7.	Maximum Dependable Capacit	y (Gross M	le):	882
8.	Maximum Dependable Capacit	ty (Net MWe):	839
9.	If Changes Occur Above Sir	nce Last Re	port, Give	Reasons:
	NONE			
10.	Power Level To Which Restr	icted, If	Any (Net MW	e):
11.	Reasons for Restrictions,	If Any:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 41,472.0
13.	Hours Reactor Critical	719.0	2,903.0	35,660.9
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	. 0
15.	Hrs Generator On-Line	719.0	2,903 0	34,940.4
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	. 0
17.	Gross Therm Ener (MWH)	1,903,973	7,791,237	90,787,879
18.	Gross Elec Ener (MWH)	637,660	2,622,680	30, 321, 340
19.	Net Elec Ener (MWH)	604,897	2,490,584	28,658,372
20.	Unit Service Factor	100.0	100.0	84.3
21.	Unit Avail Factor	100.0	100.0	84.3
22.	Unit Cap Factor (MDC Net)	100.3	102.3	82.4
23.	Unit Cap Factor (DER Net)	101.4	103.4	83.3
24.	Unit Forced Outage Rate	. 0		6.7
25.	Forced Outage Hours	. 0	. 0	2,511.7
26.	Shutdowns Sched Over Next	6 Months (Type, Date, I	Duration):
	NONE		the Determined	NZA







PAGE 2-398

*

Report	Period A	PR 19	88		U N	ΙT	SHU	тром	NSZI	EDUCTIONS STLUCIE 2
No.	Date	Type	Hours	Reason	Method	LER	Number	System	Componen	Cause & Corrective Action to Prevent Recurrence
01	04/26/88	F	0.0	A	5			нс	HTEXCH	UNIT NO. 2 WAS AT 100% POWER WHEN HIGH CONDUCTIVITY WAS OBSERVED IN THE STEAM GENERATORS. POWER WAS REDUCED TO 30%. A LEAKING CONDENSER TUBE WAS DISCOVERED AND PLUGGED AND THE UNIT RETURNED TO FULL POWER OPERATION

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Rest E-Operator Traini & License Exam	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

PAGE 2-399

4

xxxxxxxxxxxxxxxxxxxxxxxxxxxxx x ST LUCIE 2 X xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx	F
FACILITY DESCRIPTION	
LOCATION STATEFLORIDA	
COURTYST LUCIE	
DIST AND DIRECTION FROM NEAREST POPULATION CTR12 MI SE OF FT. PIERCE, FLA	
TYPE OF REACTORPWR	
DATE INITIAL CRITICALITYJUNE 2, 1983	
DATE ELEC ENER 1ST GENERJUNE 13, 1983	
DATE COMMERCIAL OPERATEAUGUST 8, 1983	
CONDENSER COOLING METHODONCE THRU	
CONDENSER COOLING WATERATLANTIC OCEAN	
ELECTRIC RELIABILITY COUNCIL	TRIC

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

ILITI & CONTRACTOR INFORMATION

UTILITY LICENSEE.....FLORIDA POWER & LIGHT

CORPORATE ADDRESS......9250 WEST FLAGLER ST., P.O. BOX 529100 MIAMI, FLORIDA 33152

CONTRACTOR

ARCHITECT/ENGINEER.....EBASCO

NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING

CONSTRUCTOR.....EBASCO

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR..... R. CRLENJAK

LICENSING PROJ MANAGER....E. TOURIGNY DOCKET NUMBER......50-389

LICENSE & DATE ISSUANCE....NPF-16, JUNE 10, 1983

PUBLIC DOCUMENT ROOM......INDIAN RIVER COMMUNITY COLLEGE LIBRARY 3209 VIRGINIA AVENUE FT. PIERCE, FLORIDA 33450 INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 8-12 (88-02): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED A REVIEW OF THE FOLLOWING AREAS: SECURITY PLAN AND IMPLENTING PROCEDURES; MANAGEMENT EFFECTIVENESS - SECURITY PROGRAM; SECURITY ORGANIZATION; RECORDS AND REPORTS; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AREAS; PHYSICAL BARRIERS - VITAL AREAS; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS COPTROL - PACKAGES; DETECTION AIDS - VITAL AREAS; AND ALARM STATIONS. TWO VIOLATIONS OF REGULATORY REQUIREMENTS AND ONE INSPECTOR FOLLOWUP ITEM WERE IDENTIFIED WITHIN THE AREAS INSPECTED.

INSPECTION MARCH 14-18 (88-04): THIS SPECIAL, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF LIQUID AND GASEOUS RADWASTE SYSTEMS, OFFSITE DOSE CALCULATION METHODOLOGY, AND EFFLUENT MONITORING AND SAMPLING. NO VIOLAITONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

INSPECTION	STATUS	- (CONTINUED)
------------	--------	---------------

*******	***	*******	****
×	ST	LUCIE 2	×
*********	***	********	*********

0.7	1.0	E 25	 Chief
13.1	н	P 16	 EPPO-
× 1		Sec. 7.5	 Sec. 1.96

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (FLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: MARCH 14-18, 1988 +

INSPECTION REPORT NO: 50-389/88-04 +

REPORTS FROM LICENSEE

1.	Docket: _50-395_	OPERAT	INGS	TATUS							
Ζ.	Reporting Period: 04/01/88 Outage + On-line Hrs: 719.0										
3.	Utility Contact: J. W. HALTIWANGER (803) 345-5209										
4.	Licensed Thermal Power (MWt):2775										
5.	Nameplate Rating (Gross M	We):		900							
6.	Design Electrical Rating	(Net MWe):		900							
7.	Maximum Dependable Capacit	ty (Gross M	We):	900							
8.	Maximum Dependable Capaci	ty (Net MWe):	885							
9.	If Changes Occur Above Sin	nce Last Re	port, Give	Reasons:							
10. 11.	Power Level To Which Rest Reasons for Restrictions, NONE	ricted, If If Any:	Any (Net MW	le):							
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE							
13.	Hours Reactor Critical	719.0	2,868.1	29,537.0							
14.	Rx Reserve Shtdwn Hrs	. 0		. 0							
15.	Hrs Generator On-Line	719.0	2,859.9	28,988.0							
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	. 0							
5.	Gross Therm Ener (MWH)	1,993,177	7,900,658	76,684,338							
18.	Gross Elec Ener (MWH)	666,540	2,641,660	25, 471, 073							
19.	Net Elec Ener (MWH)	640,345	2,534,558	24,274,141							
20.	Unit Service Factor	100.0	98.5	76.4							
21.	Unit Avail Factor	100.0	98.5	76.4							
22.	Unit Cap Factor (MDC Net)	100.6	98.7	72.2							
23.	Unit Cap Factor (DER Net)	99.0	97.0	71.0							
24.	Unit Forced Outage Rate	. 0	1.5	6.0							
25.	Forced Outage Hours		43.1	1,866.2							
26.	Shutdowns Sched Over Next	6 Months (Type,Date,I	Ouration):							
	REFUELING, SEPTEMBER 16,	1988, 85 DA	Y DURATION.								
27	If Currently Shutdown Fet	imated Star	tun Data:	N/A							



SUMMER 1



APRIL 1988

PAGE 2-402

-

Report Period	APR 1988	UNIT	SHUT	TDOWNS / R	EDUCTIONS	* SUMMER 1 *
No. Date	Type Hours	Reason Method LE	R Number	System Component	Cause & Cor	rective Action to Prevent Recurrence

NONE

*********** * SUMMARY * ******** SUMMER 1 OPERATED AT APPROXIMATELY 100 PERCENT POWER FOR THE ENTIRE MONTH OF APRIL.

Type	Reason	Method	System & Component		
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)		

PAGE 2-403

,

0

.

FACILITY DESCRIPTION

LOCATION STATE.....SOUTH CAROLINA

COUNTY......FAIRFIELD

DIST AND DIRECTION FROM NEAREST POPULATION CTR...26 MI NW OF COLUMBIA, SC

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY...OCTOBER 22, 1982

DATE ELEC ENER 1ST GENER...NOVEMBER 16, 1982

DATE COMMERCIAL OPERATE.... JANUARY 1, 1984

CONDENSER COOLING METHOD ... ONCE THRU

CONDENSER COOLING WATER....MONTICELLO RESERVOIR

ELECTRIC RELIABILITY

COUNCIL.....SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS......P.O. BOX 764 COLUMBIA, SOUTH CAROLINA 29202

CONTRACTOR

ARCHITECT/ENGINEER.....GILBERT ASSOCIATES

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR...... DANIEL INTERNATIONAL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....R. PREVATTE

LICENSE & DATE ISSUANCE..., NPF-12, NOVEMBER 12, 1982

PUBLIC DOCUMENT ROOM......FAIRFIELD COUNTY LIBRARY GARDEN & WASHINGTON STREETS WINNSBORD, SOUTH CAROLINA 29180

INSPECTION SUMMARY

+ INSPECTION MARCH 1-31 (88-08): THIS ROUTINE, ANNOUNCED INSPECTION WAS CONDUCTED BY THE RESIDENT INSPECTORS ONSITE, IN THE AREAS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, MONTHLY SURVEILLANCE OBSERVATIONS, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, ENGINEERED SAFETY FEATURES SYSTEM WALKDOWN, RADIOLOGICAL PROTECTION, PHYSICAL SECURITY, CNSITE FOLLOWUP OF EVENTS AND SUBSEQUENT WRITTEN REPORTS, AND OTHER AREAS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MARCH 14-18 (88-09): THIS ROUTINE, UNANNOUNCED PHYSICAL SECURITY INSPECTION INCLUED A REVIEW AND INSPECTION OF THE FOLLOWING AREAS: SECURITY PROGRAM AUDIT; RECORDS AND REPORTS; TESTING AND MAINTENANCE; SECURITY SYSTEM POWER SUPPLY; LIGHTING; ASSESSMENT AIDS; DETECTION AIDS - VITAL AREAS; ALARM STATIONS; SAFEGUARDS CONTINGENCY PLAN IMPLEMENTATION REVIEW, AND PHYSICAL PROTECTION SAFEGUARDS INFORMATION. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH REGULATORY REQUIREMENTS WITHIN THE TEN AREAS INSPECTED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS: NONE. FACILITY ITEMS (PLANS AND PROCEDURES): NONE . MANAGERIAL ITEMS: NONE. PLANT STATUS: NORMAL OPERATION. LAST IE SITE INSPECTION DATE: MARCH 14-18, 1988 + INSPECTION REPORT NO: 50-395/88-09 + REPORTS FROM LICENSEE DATE OF NUMBER DATE OF SUB. ECT REPORT EVENT 05/26/81 04/22/88 TWO 2 INCH CORE DRILLS FOUND UNSEALED 88-004

		T 8 0 5	TATUS						
1. Docket: _50-280	OPERAT	INGS	1 4 1 0 5						
2. Reporting Period: _0	Reporting Period: 04/01/83 Outage + On-line Hrs: 719.0								
3. Utility Contact:	A. WARREN (804)	357-3184							
4. Licensed Thermal Powe	Licensed Thermal Power (MWt):2441								
5. Nameplate Rating (Gro	oss MWe):	942 X 0	.9 = 848						
6. Design Electrical Rat	ting (Net MWe):		788						
7. Maximum Dependable C	apacity (Gross M	We):	820						
8. Maximum Dependable C	apacity (Net MWe):	781						
9. If Changes Occur Abo	ve Since Last Re	port, Give	Reasons:						
NONE									
10. Power Level To Which	Restricted, If	Any (Net Mk	le):						
11. Reasons for Restrict	ions, If Any:								
NONE									
	MONTH	YEAR	CUMULATIVE						
12. Report Period Hrs	719.0	2,903.0	134,615.0						
13. Hours Reactor Critic	al <u>193.6</u>	2,312.6	87,052.2						
14. Rx Reserve Shtdwn Hr	s0		3,774.5						
15. Hrs Generator On-Lin	e <u>192.8</u>	2,297.6	85,268.4						
16. Unit Reserve Shtdwn	Hrs0	.0	3,736.2						
17. Gross Therm Ener (MW	H)	5,322,810	197,550,076						
18. Gross Elec Ener (MWH	120,255	1,794,685	64,169,858						
19. Net Elec Ener (MWH)	112,948	1,705,504	60,857,666						
20. Unit Service Factor	26.8	79.1	63.3						
21. Unit Avail Factor	26.8	79.1	66.1						
22. Unit Cap Factor (MDC	Net)20.1	75.2	57.5						
23. Unit Cap Factor (DER	Nec) 19.9	74.6	57.4						
24. Unit Forced Outage R	ate0	3.3	17.6						
25. Forced Outage Hours	. 0	79.2	14,499.5						
26 Shutdowns Sched Over	Next 6 Months (Type, Date,	Duration):						
NONE									
	. Estimated Star	tup Date:	06/08/8						





Report	Period AF	PR 198	88		UN	тI	S H	υT	D	0 м	N	s		εE	D	U	ст	I	0 1	s	xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx
No.	Date	Туре	Hours	Reason	Method	LER	Numbe	<u> </u>	Sys	item	Co	mpoi	nent	E _			Ca	use	8	Cori	rective Action to Prevent Recurrence
88-04	04/09/88	5	526.2	С	1									U	NI	ти	AS	SHU	TDO) WN	FOR REFUELING OUTAGE.

.

SURRY 1 SHUTDOWN FOR SCHEDULED REFUELING OUTAGE IN APRIL.

* SUMMARY *

9

0

Туре	Reason	Method	System & Component		
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 9-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-016)		

PAGE 2-407

.

LUCATION STATE.....VIRGINIA

COUNTY.....SURRY

DIST AND DIRECTION FROM NEAREST POPULATION CTR...17 MI NW OF NEWPORT NEWS, VA

DATE INITIAL CRITICALITY...JULY 1, 1972

DATE ELEC ENER 1ST GENER...JULY 4, 1972

DATE COMMERCIAL OPERATE.... DECEMBER 22, 1972

CONDENSER COOLING METHOD. .. ONCE THRU

CONDENSER COOLING WATER....JAMES RIVER

ELECTRIC RELIABILITY

COUNCIL......SOUTHEASTERN ELECTRIC RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE.....VIRGINIA POWER

CORPORATE ADDRESS.....P.O. BOX 26666 RICHMOND, VIRGINIA 23261

CONTRACTOR

AFCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR......STONE & WEDSTER

TURBINE SUPPLIER......WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.D. BURKE

LICENSE & DATE ISSUANCE.... DPR-32, MAY 25, 1972

PUBLIC DOCUMENT ROOM.....SWEM LIBRARY COLLEGE OF WILLIAM AND MARY WILLIAMSBURG, VIRGINIA 23185

INSPECTION SUMMARY

+ INSPECTION MARCH 7-11 (88-08): THIS ROUTINE, UNANNOUNCED SECURITY INSPECTION INVOLVED A REVIEW OF THE FOLLOWING AREAS: RECORDS AND REPORTS; TESTING AND MAINTENANCE; LOCKS, KEYS, AND COMBINATIONS; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL OF PERSONNEL, PACKAGES, AND VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS. NO VIOLATIONS OF REGULATORY REQUIREMENTS WERE IDENTIFIED.

INSPECTION FEBRUARY 28 - APRIL 2 (88-09): THIS ROUTINE, RESIDENT INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF PLANT OPERATIONS, PLANT MAINTENANCE, PLANT SURVEILLANCE, AND LICENSEE EVENT REPORT REVIEW. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN THIS INSPECTION REPORT.

INSPECTION MARCH 3-11 (88-10): THIS SPECIAL, ANNOUNCED INSPECTION WAS CONDUCTED TO REVIEW POTENTIAL RADIATION EXPOSURES IN EXCESS OF NRC LIMITS ASSOCIATED WITH THE FREEING OF AN INCORE DETECTOR WHICH HAD BECOME LODGED IN A THIMBLE TUBE IN THE CORE OF THE UNIT 2 REACTOR. THREE VIOLATIONS WERE IDENTIFIED - FASCURE TO ADEQUATELY EVALUATE THE RADIATION HAZARDS PRESENT DURING WORK ON AN INCORE DETECTOR, INADEQUATE PROCEDURES FOR FREEING THE INCORE DETECTOR AND FOR BRIEFING THOSE INVOLVED IN THE WORK AND FAILURE TO CONDUCT OPERATIONS IN ACCORDANCE WITH APPROVED PROCEDURES.

ENFORCEMENT SUMMARY

PAGE 2-408

Report Period APR 1988

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50 APPENDIX B, CRITERION V AS IMPLEMENTED BY THE LICENSEE'S ACCEPTED QUALITY ASSURANCE PROGRAM (VIRGINIA POWER TOPICAL REPORT VEP-1-5A, SECTION 17.2.5), AS OF JANUARY 3, 1988, MEASURES FOR THE SELECTION AND REVIEW FOR SUITABILITY OF APPLICATION OF MATERIALS, PARTS, AND EQUIPMENT THAT ARE ESSENTIAL TO THE SAFETY-RELATED FUNCTIONS OF COMPONENTS WERE NOT ADEQUATELY PRESCRIBED BY PROCEDURES. THIS CONDITION CONTRIBUTED TO THE FAILURE MECHANISM, WHICH WAS IDENTIFIED IN DECEMBER, 1987, OF SAFETY-RELATED VALVE 2-CH-MOV-2289B. (8800 5)

```
OTHER ITEMS
```

SYSTEMS AND COMPANENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

NONE .

LAST IE SITE INSPECTION DATE: MARCH 5-11, 1988 +

INSPECTION REPORT NO: 50-280/88-10 +

REPORTS FROM LICENSEE

 NUMBER
 DATE OF EVENT
 DATE OF REPORT
 SUBJECT

 88-008
 03/09/88
 04/08/88
 LOW HEAD SAFETY INJECTION PUMP INOPERABLE DUE TO FAILED MOTOR LEADS

 88-009
 03/11/88
 06/05/86
 IODINE SPIKE DUE TO DEFECTIVE FUEL ELEMENT

	B			and the last second
1.	Docket: _50-281	OPERAT	ING S	TATUS
2.	Reporting Period: _04/01.	/88_ Outage	+ On-ling	Hrs: 719.
3.	Utility Contact: L. A.	WARREN (804)	357-3184	
4.	Licensed Thermal Power (MWt):	_	2441
5.	Nameplate Rating (Gross)	MWe):	942 X	0.9 = 848
6.	Design Electrical Rating	(Net MWe):		788
7.	Maximum Dependable Capac	ity (Gross M	1Ne):	020
8.	Maximum Dependable Capac	ity (Net MWa):	781
9.	If Changes Occur Above S NONE	ince Last Re	eport, Give	Reasons:
10.	Power Level To Which Res	tricted, If	Any (Net M	He):
11.	Reasons for Restrictions	, If Any:		
-	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVI 131,495.0
13.	Hours Reactor Critical	604.4	2,684.8	87,353.
14.	Rx Reserve Shtdwn Hrs		. 0	23.1
15.	Hrs Generator On-Line	576.5	2,656.9	85,955.
16.	Unit Reserve Shtdwn Hrs			
17.	Gross Therm Ener (MWH)	1,391,180	6,428,995	201,599,344
18.	Gross Elec Ener (MWH)	464,035	2,143,685	65,511,50
19.	Net Elec Ener (MWH)	441,794	2,040,475	62,119,250

 21. Unit Avail Factor
 80.2
 91.5
 65.4

 22. Unit Cap Factor (MDC Net)
 78.7
 90.0
 60.5

 23. Unit Cap Factor (DER Net)
 78.0
 89.2
 60.0

 24. Unit Forced Outage Rate
 19.8
 8.5
 13.8

 25. Forced Outage Hours
 142.5
 246.1
 11,195.2

 26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
 142.5
 142.5

80.2 91.5 65.4

REFUELING - 8/19/88, 48 DAY DURATION.

20. Unit Service Factor

SURRY 2



APRIL 1988

Report	Period APR 1988	UNIT SHUTDOWNS / R	EDUCTIONS NAMEXANA ANALANA SURRY 2 A A A A A A A A A A A A A A A A A A
<u>No.</u> 88-06	Date Type Hours Reason 03/27/88 F 142.5 A	Method LER Number System Component 4 88-004	Cause & Corrective Action to Prevent Recurrence UNIT WAS MANUALLY TRIPPED DUE TO VITAL BUS 2-III INVERTER FAILURE, UNIT WAS KEPT DOWN TO INSPECT AFW SYSTEM FOR BLOCKAGE, NONE FOUND.

SURRY 2 ENTERED APRIL IN A FORCED OUTAGE. SUBSEQUENTLY, RETURNED TO POWER AND OPERATED ROUTINELY THE REMAINDER OF THE MONTH.

Type	Reason	Method	System & Component		
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)		
******* SURRY 2 *****

FACILITY DESCRIPTION

LOCATION STATE.....VIRGINIA

COUNTY.....SURRY

DIST AND DIRECTION FROM NEAREST POPULATION CTR...17 MI NW OF NEWPORT NEWS, VA

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY...MARCH 7, 1973

DATE ELEC ENER 1ST GENER ... MARCH 10, 1973

DATE COMMERCIAL OPERATE....MAY 1, 1973

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER....JAMES RIVER

ELECTRIC RELIABILITY

RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS......P.O. BOX 26666 RICHMOND, VIRGINIA 23261

CONTRACTOR

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....STONE & WEBSTER

REGULATORY INFORMATION

COLLEGE OF WILLIAM AND MARY WILLIAMSBURG, VIRGINIA 23185 INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION MARCH 7-11 (88-08): THIS ROUTINE, UNANNOUNCED SECURITY INSPECTION INVOLVED A RC"IEW OF THE FOLLOWING AREAS: RECORDS AND REPORTS: TESTING AND MAINTENANCE; LOCKS, KEYS, AND COMBINATIONS; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL OF PERSONNEL, PACKAGES, AND VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS. NO VIOLATIONS OF REGULATORY REQUIREMENTS WERE IDENTIFIED.

INSPECTION FEBRUARY 28 - APRIL 2 (88-09): THIS ROUTINE, RESIDENT INSPECTION WAS CONDUCTED ON SITE IN THE AREAS OF PLANT OPERATIONS, PLANT MAINTENANCE, PLANT SURVEILLANCE, AND LICENSEE EVENT REPORT REVIEW. NG VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN THIS INSPECTION REPORT.

INSPECTION MARCH 5-11 (88-10): THIS SPECIAL, ANNOUNCED INSPECTION WAS CONDUCTED TO REVIEW POTENTIAL RADIATION EXPOSURES IN EXCESS OF NRC LIMITS ASSOCIATED WITH THE FREEING OF AN INCORE DETECTOR WHICH HAD BECOME LODGED IN A THIMBLE TUBE IN THE CORE OF THE UNIT 2 REACTOR. THREE VIOLATIONS WERE IDENTIFIED - FAILURE TO ADEQUATELY EVALUATE THE RADIATION HAZARDS PRESENT DURING WORK ON AN INCORE DETECTOR, INADEQUATE PROCEDURES FOR FREEING THE INCORE DETECTOR AND FOR BRIEFING THOSE INVOLVED IN THE WORK AND FAILURE TO CONDUCT OPERATIONS IN ACCORDANCE WITH APPROVED PROCEDURES.

ENFORCEMENT SUMMARY

PAGE 2-412

TURBINE SUPPLIER.....WESTINGHOUSE

IE RESIDENT INSPECTOR.....D. BURKE

LICENSING PROJ MANAGER.....C. PATEL DOCKET NUMBER 50-281

LICENSE & DATE ISSUANCE.... DPR-37, JANUARY 29, 1973

PUBLIC DOCUMENT ROOM......SWEM LIBRARY

Report Period APR 1988

ENFORCEMENT SUMMARY

CONTRARY 19 TECHNICAL SPECIFICATION 6.4, DETAILED WRITTEN PROCEDURES WERE NOT FOLLOWED BY EITHER COMPLYING WITH THE STEPS OR IMPLEMENTING A CHANGE PRIOR TO PROCEEDING. THIS RESULTED IN THE FAILURE TO PROPERLY ESTABLISH THE INITIAL CONDITIONS LISTED ELOW: (1) ON JANUARY 9, 1988, TEST PROCEDURE 1-PT-29.1, "TURBINE INLET VALVE TEST", WAS PERFORMED WITHOUT MEETING INITIAL CONDITION 3.5 OF THE TEST, WHICH REQUIRES THE ROD CONTROL SYSTEM TO BE IN THE AUTOMATIC CONTROL MODE. THE TEST WAS PERFORMED WITH CONDITION 3.5 OF THE TEST, WHICH REQUIRES THE ROD CONTROL SYSTEM TO BE IN THE AUTOMATIC CONTROL MODE. THE TEST WAS PERFORMED WITH CONDITION 3.5 OF THE TEST, WHICH REQUIRES THE ROD CONTROL SYSTEM TO BE IN THE AUTOMATIC CONTROL MODE. THE TEST WAS PERFORMED WITH CONDITION 5.5 OF THE TEST, WHICH REQUIRES THE ROD CONTROL SYSTEM TO BE IN THE AUTOMATIC CONTROL MODE. THE TEST WAS PERFORMED WITH CONDITION 5.5 OF THE TEST, WHICH REQUIRES THE ROD CONTROL SYSTEM TO BE IN THE AUTOMATIC CONTROL MODE. THE TEST WAS PERFORMED WITH CONDITION 5.5 OF THE TEST, WHICH REQUIRES THE ROD CONTROL SYSTEM TO PERFORMED WITH AND UNIT 1 AND UNIT 1 RESPECTIVELY, WERE RAMPED DOWN FROM THE ROD CONTROL SYSTEM IN THE MANUAL MODE. (2) ON JANUARY 9 AND 23, 1988, UNIT 1 AND UNIT 1 AND UNIT 1 RESPECTIVELY, WERE RAMPED DOWN FROM TO LESS THAN 752 POWER IN ACCORDANCE WITH OPERATIONS PROCEDURE OP-2.1.2, "DECREASING POWER LEVEL TO 22", WITHOUT MEETING INITIAL CONDITION 5.4 OF THE PROCEDURE, WHICH REQUIRED THE PORTABLE NARROW RANGE STEAM GENERATOR LEVEL INDICATORS WITHOUT MEETING INITIAL CONDITION 5.4 OF THE PROCEDURE, WHICH REQUIRED THE PORTABLE NARROW RANGE STEAM GENERATOR LEVEL INDICATORS WITHOUT MEETING OP-2.1.2, "DECREASING POWER FROM EXISTING POWER LEVEL TO 22", WITHOUT PERFORMING STEPS 3.7.1 THROUGH 3.7.4 OF THE PROCEDURE, WHICH REQUIRED THAT JUMPERS BE INSTALLLD TO REMOVE THE SEAL-IN FUNCTION FROM CONTROLLERS OF MOISTURE SEPARATOR REHEATER STEAM SUPPLY ISOLATION VALVES. CONTRARY TO TS 6.4.J, ON FEBRUARY 23, 1988, FIRE PROTECTION EQUIPMENT REQUIRED TO BE REH

(8800 4)

CONTRARY TO 10 CFR 50 APPENDIX B, CRITERION V AS IMPLEMENTED BY THE LICENSEE'S ACCEPTED QUALITY ASSURANCE PROGRAM (VIRGINIA POWER TOPICAL REPORT VEP-1-5A, SECTION 17.2.5), AS OF JANUARY 3, 1988, MEASURES FOR THE SELECTION AND REVIEW FOR SUITABILITY OF APPLICATION OF MATERIALS, PARTS, AND EQUIPMENT THAT ARE ESSENTIAL TO THE SAFETY-RELATED FUNCTIONS OF COMPONENTS WERE NOT ADEQUATELY PRESCRIBED BY PROCEDURES. THIS CONDITION CONTRIBUTED TO THE FAILURE MECHANISM, WHICH WAS IDENTIFIED IN DECEMBER, 1987, OF SAFETY-RELATED VALVE 2-CH-MOV-2289B. (8800 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION. +

LAST IE SITE INSPECTION DATE: MARCH 5-11, 1988 +

INSPECTION REPORT NO: 50-281/88-10 +

Report Period A	PC 1988		REPORTS FROM LICENSEE N SURRY 2 N NORMANNEE NEEDENSEE	
NUMBER D	ATE OF EVENT	DATE OF REPORT	SUBJEC?	
88-004 0	3/27/88	04/26/88	MANUAL REACTOR TRIP DUE TO LOSS OF VITAL BUS CAUSED BY FAILED INVERTER	
88-006 0	3/10/88	04/08/88	FAILURE TO COMPLY WITH TECHNICAL SPECIFICATION DUE TO PERSONNEL SAFETY CONSIDERATIONS	

PAGE 2-415 THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docke : 50-387	DPERAT	ING S	TATUS					
2.	Reporting Period: 04/01/88 Outage + On-line Hrs: 719.0								
3.	Utility Contact:								
4.	Licensed Thermal Power (MWt):								
5.	Namoplate Rating (Gross MWe): 1280 X 0.9 = 1152								
6.	Design Electrical Rating	(Net MWe):		1065					
7.	Maximum Dependable Capacit	ty (Gross M	We):	1068					
8.	Maximum Dependable Capacit	ty (Net MWe):	1032					
9.	If Changes Occur Above Sin	nce Last Re	port, Give	Reasons:					
10.	Power Level To Which Rest Reasons for Restrictions, NONE	ricted, If If Any:	Any (Net Mk	le):					
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 42,536.0					
13.	Hours Reactor Critical	719.0	2,628.0	31,282.0					
14.	Rx Reserve Shtdwn Hrs	. 0		773.2					
15.	Hrs Generator On-Line	719.0	2,584.4	30,533.2					
6.	Unit Reserve Shtdwn Hrs		0	. 0					
17.	Gross Therm Ener (MWH)	2,356,635	8,254,661	94,301,086					
18.	Gross Elec Ener (MWH)		2,726,112	30,736,711					
19.	Net Elec Ener (MWH)	751,003	2,630,162	29,477,558					
20.	Unit Service Factor	100.0	89.0	71.1					
21.	Unit Avail Factor	100.0	89.0	71.1					
22.	Unit Cap Factor (MDC Net)	101.2	87.8	66.5					
23.	Unit Cap Factor (DER Net)	98.1	85.1	64.5					
24.	Unit Forced Outage Rate	.0	5.5	10.5					
25.	Forced Outage Hours	0	149.0	3,565.6					
26.	Shutdowns Sched Over Next	6 Months (Type,Date,I	Duration):					
27	If Currently Shutdown Est	imated Star	tup Date:	N/A					



AVERAGE DAILY POWER LEVEL (MWe) PLOT

SUSQUEHANNA 1



PAGE 2-416

13

Report	Period Al	PR 19	88		UN	тт сни	TDOW	NS / R	EDUCTIONS SUSQUEHANNA 1 X XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
No.	Date	Type	Hours	Reason	Method	IER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
4	04/30/88	S	0.0	В	5		JD	ZZZZZZ	ON APRIL 30, 1988, AT APPROXIMATELY 0600 HOURS, OPERATIONS PERSONNEL BEGAN DECREASING REACTOR POWER TO PERFORM A CONTROL ROD SEQUENCE EXCHANGE AND TO SCRAM TIME 19 CONTROL RODS. FOLLOWING COMPLETION OF THESE ACTIVITIES, OPERATIONS PERSONNEL INCREASED REACTOR POWER. FULL POWER OPERATION WAS RESTORED ON MAY 1, 1988, AT APPROXIMATELY 1900 HOURS.

SUSQUEHANNA 1 INCURRED 1 POWER REDUCTION IN AFRIL FOR REASONS STATED ABOVE. ********

* SUMMARY * *********

Туре	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE.....PENNSYLVANIA COUNTY.....LUZERNE DIST AND DIRECTION FROM NEAREST POPULATION CTR...7 MI NE OF BERWICK, PA TYPE OF REACTOR.....BWR DATE INITIAL CRITICALITY...SEPTEMBER 10, 1982 DATE ELEC ENER 1ST GENER...NOVEMBER 16, 1982 DATE COMMERCIAL OFERATE....JUNE 8, 1983 CONDENSER COOLING METHOD...CC, HNDCT CONDENSER COOLING MATER....SUSQUEHANNA RIVER ELECTRIC RELIABILITY COUNCIL......MID-ATLANTIC AREA COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS......2 NORTH NINTH STREET ALLENTOWN, PENNSYLVANIA 18101

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE RECION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....F. YOUNG

LICENSE & DATE ISSUANCE....NPF-14, NOVEMBER 12, 1982

PUBLIC DOCUMENT ROOM.....OSTERHOUT FREE LIBRARY 71 SOUTH FRANKLIN STREET WILKES-BARRE, PENNSYLVANIA 18701 INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

PAGE 2-418

Report Period APR 1988

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

*********	**********			====
NUMBER	DATE OF EVENT	DATE OF REPORT	UBJECT	
NO INPUT	PROVIDED.			

1.	Docket: <u>50-388</u> 0	PERAT	INGS	TATUS					
2.	Reporting Period: <u>04/01/88</u> Outage + On-line Hrs: <u>719.0</u>								
3.	Utility Contact: J. A. HIRT (717) 542-3917								
4.	Licensed Thermal Power (MW		3293						
5.	Nameplate Rating (Gross MW	le):		1152					
6	Design Electrical Rating (Net MWe)		1065					
7.	Maximum Dependable Capacit	y (Gross M	We):	1068					
8.	Maximum Dependable Capacit	y (Not MWe):	1032					
9.	If Changes Occur Above Sin	ce Last Re	port, Give	Reasons:					
10.	Power Level To Which Restr Ressons for Restrictions, NONE	icted, If If Any ¹	Any (Net MA	le):					
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE					
13.	Hours Reactor Critical	. 0	1.560.0	23.111.8					
4.	Rx Reserve Shtdwn Hrs	. 0	.0	693.9					
15.	Hrs Generator On-Line	.0	1,536.5	22,697.4					
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	.0					
7.	Gross Therm Ener (MWH)	0	4,798,980	71, 424, 698					
8.	Gross Elec Ener (MWH)	0	1,572,662	23, 379, 424					
19.	Net Elec Ener (MWH)	-6,209	1,511,685	22, 512, 649					
20.	Unit Service Factor	.0	52.9	80.6					
21.	Unit Avail Factor	.0	52.9	80.6					
22.	Unit Cap Factor (MDC Net)	.0	50.5	77.4					
23.	Unit Cap Factor (DER Net)	.0	48.9	75.0					
24.	Unit Forced Outage Rate	.0	.0	8.6					
25.	Forced Outage Hours	.0	.0	2,149.0					
26.	Shutdowns Sched Over Next	6 Months (Type, Date, I	Ouration):					
	NUNE	and the second second	the second second second						

SUSQUEHANNA 2



Report Period APR 1988 UNIT SHUTDOWNS / REDUCTIONS

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	u3/05/88	S	719.0	С	4		ZZZ	ZZZZZZ	ON MARCH 5, 1988, AT 0200 HOURS, OPERATIONS PERSONNEL PLACED THE REACTOR MODE SWITCH IN THE "SHUTDOWN" POSITION TO COMMENCE THE UNIT'S SECOND REFUELING OUTAGE.

********* SUSQUEHANNA 2 REMAINED SHUTDOWN IN APRIL FOR SCHEDULED * SUMMARY * REFUELING OUTAGE.

×.,	2	9	6.9		~	~			~	
××	×	×	×	×	×	×	×	×	×	

Туре	Reason	Method	System & Component	
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Err C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual or 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)	

FACILITY DESCRIPTION

LOCATION STATE.....PENNSYLVANIA COUNTY.....LUZERNE DIST AND DIRECTION FROM NEAREST POPULATION CTR...7 MI NE OF BERWICK, PA TYPE OF PEACTOR.....BWR DATE INITIAL CRITICALITY...MAY 8, 1984 DATE ELEC ENER 1ST GENER...JULY 3, 1984 DATE COMMERCIAL OPERATE....FEBRUARY 12, 1985 CONDENSER COOLING METHOD...CC, HNDCT CONDENSER COULING WATER....SUSQUEHANNA RIVER ELECTRIC RELIABILITY COUNCIL......MID-ATLANTIC

AREA COUNCIL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS......2 NURTH NINTH STREET ALLENTOWN, PENNSYLVANIA 18101

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER. . . GENERAL ELECTRIC

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....F. YOUNG

LICENSE & DATE ISSUANCE....NPF-22, JUNE 27, 1984

PUBLIC DOCUMENT ROOM.....OSTERHOUT FREE LIBRARY 71 SOUTH FRANKLIN STREET WILKES-BARRE, PENNSYLVANIA 18701

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

INPUT PROVIDED.

E SITE INSPECTION DATE: NO INPUT PROVIDED.

INS CTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

	*********	*********		 	 	***********	******
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT				
NO INPUT	PROVIDED.						

1. Docket: _5	0-289	OPERA	TINGS	TATUS
2. Reporting I	Period: 04/01/	188 Outag	e + On-line	Hrs: 719.0
3. Utility Con	ntact: <u>C. W.</u>	SMYTH (717)	948-8551	
4. Licensed Th	nermal Power (M	Wt):		2535
5. Nameplate #	Rating (Gross M	1We):	968 X	0.9 = 871
6. Design Elec	trical Rating	(Net MWe):		819
7. Maximum Dep	endable Capaci	ity (Gross 1	MWe):	824
8. Maximum Dep	endable Capaci	ty (Net MW	e):	776
9. If Changes NONE	Occur Above Si	nce Last Re	eport, Give	Reasons:
10. Power Level	To Which Rest	ricted, If	Any (Net M	We):
11. Reasons for	Restrictions,	If Any:		
NONE				
12. Report Peri	od Hrs	MONTH 719.0	2,903.0	CUMULATIVE 119,760.0
13. Hours React	or Critical	719.0	2,841,4	49,361.8
14. Rx Reserve	Shtdwn Hrs	. 0	61.6	1,947.8
15. Hrs Generat	or On-Line	719.0	2,839.4	48,439.2
16. Unit Reserv	e Shtdwn Hrs	.0	. 0	. 0
17. Gross Therm	Ener (MWH)	1,819,116	7,160,868	117,648,568
18. Gross Elec	Ener (MWH)	625,079	2,467,22	39, 335, 441
19. Net Elec En	er (MWH)		2,330,095	36,834,378
20. Unit Service	e Factor	100.0	97.8	40.4
21. Unit Avail	Factor	100.0	97.8	40.4
22. Unit Cap Fac	ctor (MDC Net)	105.9	103.4	39.4*
23. Unit Cap Fac	ctor (DER Net)	100,4	98.0	37.6
24. Unit Forced	Outage Rate		2.2	55.1
25. Forced Outag	ge Hours	. 0	63.6	59,376.5
26. Shutdowns So	ched Over Next	6 Months (Type, Date, D	Duration):
REFUELING -	JUNE 17, 1988	- 64 DAY D	URATION.	
27. If Currently	Shutdown Esti	imated Star	tup Date:	NZA



THREE MILE ISLAND 1



APRIL 1988

* Item calculated with a Weighted Average

UNIT SHUTDOWNS / REDUCTIONS * THREE M

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

Туре	Reason	Method	System & Component	
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Munual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)	

FACILITY DESCRIPTION

LOCATION

- STATE.....PENNSYLVANIA
- COUNTY......DAUPHIN

DIST AND DIRECTION FROM NEAREST POPULATION CTR...10 MI SE OF HARRISBURG, PA

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...JUNE 5, 1974

DATE ELEC ENER 1ST GENER...JUNE 19, 1974

DATE COMMERCIAL OPERATE....SEPTEMBER 2, 1974

CONDENSER COOLING METHOD... COOLING TOWERS

CONDENSER COOLING WATER....SUSQUEHANNA RIVER

ELECTRIC RELIABILITY COUNCIL.....MID-ATLANTIC AREA COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE......GPU NUCLEAR CORP.

CORPORATE ADDRESS......P.O. BOX 480 MIDDLETOWN, PENNSYLVANIA 17057

CONTRACTOR

ARCHITECT/ENGINEER.....GILBERT ASSOCIATES

NUC STEAM SYS SUPPLIER... BABCOCK & WILCOX

CONSTRUCTOR......UNITED ENG. & CONSTRUCTORS

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....R. CONTE

LICENSE & DATE ISSUANCE.... DPR-50, APRIL 19, 1974

PUBLIC DOCUMENT ROOM......GOVERNMENT PUBLICATIONS SECTION STATE LIBRARY OF PENNSYLVANIA FORUM BUILDING COMMONWEALTH AND WALNUT STREET HARRISBURG, PENNSYLVANIA 17105

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period APR 1988

OTHER ITEMS

NO INPUT PROVIDED.
MANAGERIAL ITEMS:
NO INPUT PROVIDED.
PLANT STATUS:
NO INPUT PROVIDED.
LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.
INSPECTION REPORT NO: NO INPUT PROVIDED.
REPORTS FROM LICENSEE
NUMBER DATE OF DATE OF SUBJECT EVENT REPORT
NO INPUT PROVIDED.

1.	Docket: 50-344 0	PERAT	ING S	TATUS
2.	Reporting Period: 04/01/8	8_ Outage	+ On-line	Hrs: 719.0
3.	Utility Contact: F. J. UH	MER (503)	556-3713 X	495
4.	Licensed Thermal Power (MW	t):		3411
5.	Nameplate Rating (Gross MW	e):	1280 X	0.95 = 1216
6.	Design Electrical Rating (Net MWe):		1130
7.	Maximum Dependable Capacit	y (Gross M	We):	1153
8.	Maximum Dependable Capacit	y (Net MWe):	1095
9.	If Changes Occur Above Sin	ce Last Re	port, Give	Reasons:
	MDC RATINGS DUE TO IMPROVE	D PLANT PE	RFORMANCE	FROM UPGRADE
10.	Power Level To Which Restr	icted, If	Any (Net M	Ne):
11.	Reasons for Restrictions,	If Any:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,913.0	CUMULATIVE 102,239.0
13.	Hours Reactor Critical	287.3	2,344.6	64,689.6
14.	Rx Reserve Shtdwn Hrs	.0	. 0	3,875.4
15.	Hrs Generator On-Line	287.3	2,342.2	63,013.4
16.	Unit Reserve Shtdwn Hrs	. 0	.0	3,237.0
17.	Gross Therm Ener (MWH)	969,061	7,955,428	201,300,792
18.	Gross Elec Ener (MWH)	324,855	2,692,463	65,580,534
19.	Net Elec Ener (MWH)	307,012	2,568,357	62,067,634
20.	Unit Service Factor	40.0	80.7	61.6
21.	Unit Avail Factor	40.0	80.7	64.8
22.	Unit Cap Factor (MDC Net)	39.0	80.8	55.4
23.	Unit Cap Factor (DER Net)	37.8	78.3	53.7
24.	Unit Forced Outage Rate	. Q	5.2	13.6
25.	Forced Outage Hours	. 0	129.1	9,932.6
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):
27	If Currently Shutdawn Enti	matod Star	tun Data:	05/31/88



TROJAN



APRIL 1988

Report Period APR 1988 UNIT SHUTDOWNS / REDUCTIONS * TROJAN

***************************** *******************************

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence 88-02 04/13/88 S 431.7 C 1 ANNUAL REFUEL/MAINTENANCE OUTAGE.

*********** TROJAN COMMENCED SCHEDULED REFUELING OUTAGE IN APRIL.

* SUMMARY * *********

Type	Reason	Method	System & Compos ort
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE....OREGON

DIST AND DIRECTION FROM NEAREST POPULATION CTR...32 MI N OF PORTLAND, ORE

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...DECEMBER 15, 1975

DATE ELEC ENER 1ST GENER...DECEMBER 23, 1975

DATE COMMERCIAL OPERATE....MAY 20, 1976

CONDENSER COOLING METHOD...COOLING TOWERS

CONDENSER COOLING WATER....COOLING TOWER

ELECTRIC RELIABILITY

COUNCIL......WESTERN SYSTEMS COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE......PORTLAND GENERAL ELECTRIC

CORPORATE ADDRESS......121 S.W. SALMON STREET PORTLAND, OREGON 97204

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

COI STRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V

IE RESIDENT INSPECTOR.....R. BARR

ICENSING PROJ MANAGER....T. CHAN DOCKET NUMBER.....50-344

LICENSE & DATE ISSUANCE....NPF-1, NOVEMBER 21, 1975

PUBLIC DOCUMENT ROOM.....LIBRARY ASSOCIATION OF PORTLAND SOCIAL SCIENCES & SCIENCE DEPARTMENT 801 SW 10TH AVENUE PORTLAND, OREGON 97207

INSPECTION SUMMARY

INSPECTION STATUS

+ INSPECTION ON FEBRUARY 14 - MARCH 26, 1988 (REPORT NO. 50-344/88-08) AREAS INSPECTED: ROUTINE INSPECTION OF OPERATIONAL SAFETY VERIFICATION, MAINTENANCE, SURVEILLANCE, AND OPEN ITEM FOLLOWUP. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MARCH 28 - APRIL 1, 1988 (REPORT NO. 50-344/88-09) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S EMERGENCY PREPAREDNESS PROGRAM. THIS INSPECTION INCLUDED FOLLOWUP ON PREVIOUS INSPECTION FINDINGS, AND EXAMINATIONS OF CHANGES TO THE EMERGENCY PLAN AND PROCEDURES, ORGANIZATION AND MANAGEMENT CONTROL OF THE EMERGENCY PLANNING PROGRAM, TRAINING OF EMERGENCY RESPONSE PERSONNEL, AND INDEPENDENT REVIEWS/AUDITS OF THE EMERGENCY PREPAREDNESS PROGRAM. DURING THIS INSPECTION, ONE INSPECTION PROCEDURE WAS UTILIZED.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MARCH 14 - 18, 1988 (REPORT NO. 50-344/88-10) AREAS INSPECTED: THIS ROUTINE, UNANNOUNCED INSPECTION BY THE PROJECT INSPECTOR INVOLVED THE ANNUAL REVIEW OF THE LICENSSE'S PROGRAM TO HANDLE INFORMATION NOTICES, REVIEW OF PROCEDURES, AND ONSITE FOLLOWUP OF WRITTEN REPORTS OF NONROUTINE EVENTS. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

PAGE 2-430

Report Period APR 1988

INSPECTION SUMMARY

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MARCH 29 - 31, 1988 (REPORT NO. 50-344/88-11) AREAS INSTECTED: ROUTINE, UNANNOUNCED INSPECTION OF PLANT WATER CHEMISTRY CONTROL AND CHEMICAL ANALYSIS, RADIOCHEMICAL ANALYSIS, POST-ACTIVENT SAMPLING, AND QUALITY ASSURANCE OF PLANT CHEMISTRY ACTIVITIES. DURING THIS INSPECTION, TWO INSPECTION PROCEDURES WERE UTILI.ED.

RESULTS: NO ITEMS OF NOCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ MANAGEMENT MEETING ON MARCH 25, 1988 (REPORT NO. 50-344/88-12) A MANAGEMENT MEETING WAS HELD ON THE ABOVE DATE TO DISCUSS ISSUES OF CURRENT INTEREST RELATING TO THE TROJAN NUCLEAR GENERATING STATION.

+ INSPECTION ON MARCH 27 - MAY 7, 1988 (REPORT NO. 50-344/88-13) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON MARCH 27 - APRIL 30, 1988 (REPORT NO. 50-344/88-14) REPORT CANCELLED.

+ INSPECTION ON APRIL 25 - 29, 1988 (REPORT NO. 50-344/88-15) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 21 - 29, 1988 (REPORT NO. 50-344/88-16) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 18 - 22, 1988 (REPORT NO. 50-344/88-17) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 25 - 29, 1988 (REPORT NO. 50-344/88-18) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

POWER LEVEL 100%.

LAST IE SITE INSPECTION DATE: 03/27 - 05/07/88+

****** ****** TROJAN × *****************************

INSPECTION REPORT NO: 50-344/88-13+

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT					
NO	NE			 		 		
				 	 	 	 	===

THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docket 50-250	OPERAT	INGS	TATUS
2.	Reporting Period:04/01/1	88 Outage	+ On-line	Hrs: 719.0
3.	Utility Contact: N. W. G	RANT (305)	694-4432	
4.	Licensed Thermal Power (M	Wt):		2200
5.	Nameplate Rating (Gross M	We):	894 X 1	0.85 = 760
6.	Design Electrical Rating	(Net MWe):		693
7.	Maximum Dependable Capacit	ty (Gross M	lWe):	700
8.	Maximum Dependable Capacit	666		
9.	If Changes Occur Above Sin	nce Last Re	port, Give	Reasons:
	NONE			
10.	Power Level To Which Rest	ricted, If	Any (Net M	de):
11.	Reasons for Restrictions,	If Any:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 135,032.6
13.	Hours Reactor Critical	719.0	1,714.4	91,409.1
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	844.3
15.	Hrs Generator On-Line	719.0	1,629.0	88,424.2
16.	Unit Reserve Shtdwn Hrs		. 0	121.8
17.	Gross Therm Ener (MWH)	1,557,749	3,335,672	183,139,937
18.	Gross Elec Ener (MWH)	509,845	1,082,775	58,680,776
19.	Net Elec Ener (MWH)	486,141	1,012,364	55,491,150
20.	Unit Service Factor	100.0	56.*	65.5
21.	Unit Avail Factor	100.0	56.1	65.6
22.	Unit Can Factor (MDC Net)	101.5	52.4	<u>63.1</u> ×
23.	Unit Cap Factor (DER Net)	97.6	50.3	59.3
24.	Unit Forced Outage Rate	. 0	43.6	11.1
25.	Forced Outage Hours	.0	1,258.1	10,505.4
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):
27	If Currently Shutdown Est	imated Star	tup Date:	NZA

AVERAGE DAILY POWER LEVEL (MWe) PLOT

TURKEY POINT 3



APRIL 1988

* Item calculated with a Weighted Average

Report	Period AF	PR 19	88		UN	IТ	SHU	TDOP	IN	s /	R	E	DU	с	т	10) N	s	**************************************
<u>No.</u> 05	Date 04/29/88	Type S	<u>Hours</u> 0.0	<u>Reason</u> B	Method 5	LER	Number	<u>System</u> HA	V	mpon ALVO	ent P	UN PE PO RO	HIT ERFO DWER DD P	3 IRM A	Cau MAS T HO ITI	RE URE LD ON	8 EDU BIN WA IN	Cer E V S E DIC	rective Action to Prevent Recurrence TO APPROXIMATELY 40% POWER TO ALVE TESTING. WHILE RETURNING TO FULL XPERIENCED TO MAKE ADJUSTMENTS IN ATION.

EXXXXXXXXXX E SUMMARY X	TURKEY POINT 3 PEASONS STATED	INCURRED ABOVE.	1	SCHEDULED	POWER	REDUCTION	IN	APRIL	FOR

Type	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161

******* * TURKEY POINT 3 * ******

FACILITY DESCRIPTION

LOCATION

COUNTY DADE

DIST AND DIRECTION FROM NEAREST POPULATION CTR. .. 25 MI S OF MIAMI, FLA

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... OCTOBER 20, 1972

DATE ELEC ENER 1ST GENER. .. NOVEMBER 2, 1972

DATE COMMERCIAL OPERATE.... DECEMBER 14, 1972

CONDENSER COOLING METHOD. .. CLOSED CANAL

CONDENSER COOLING WATER CLOSED CYCLE CANAL

ELECTRIC RELIABILITY

RELIABILITY COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

MIAMI, FLORIDA 33174

CONTRACTOR

ARCHITECT/ENGINEER......BECHTEL

NUC STEAM SYS SUPPLIER ... WESTINGHOUSE

CONSTRUCTOR..... BECHTEL

REGULATORY INFORMATION

IE REGION RESPONSIBLE......II

IE RESIDENT INSPECTOR R. BREWER

LICENSING PROJ MANAGER.....G. EDISON

LICENSE & DATE ISSUANCE..., DPR-31, JULY 19, 1972

PUBLIC DOCUMENT ROOM ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY FLORTDA INTERNATIONAL UNIVERSITY MIAME, FIORIDA 33199 INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 22-25 (88-01): THIS SPECIAL, ANNOUNCED INSPECTION WAS AN EMERGENCY RESPONSE FACILITIES (ERF) APPRAISAL. AREAS EXAMINED DURING THE APPRAISAL INCLUDED A REVIEW OF SELECTED PROCEDURES AND REPRESENTATIVE RECORDS. THE ERES AND RELATED EQUIPMENT, AND INTERVIEWS WITH LICENSEE PERSONNEL. SELECTED ACTIVITIES WERE OBSERVED DURING THE 1988 ANNUAL EXERCISE TO DETERMINE THE ADEQUACY OF THE ERFS AND RELATED EQUIPMENT. THO VIOLATIONS WERE IDENTIFIED, NAMELY: FAILURE TO PROVIDE ADEQUATE MENTODS, SYSTEMS AND EQUIPMENT FOR ASSESSING AND MONITORING ACTUAL OR POTENTIAL OFFSITE CONSEQUENCES OF A RADIOLOGICAL EMERGENCY CONDITION, FAILURE TO TO PROVIDE WRITTEN PROCEDURES AND ADMINISTRATIVE POLICIES TO CONTROL THE COMPUTER BASED DOSE CALCULATION MODEL.

INSPECTION JANUARY 18 - FEBRUARY 25 (88-02): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED DIRECT INSPECTION AT THE SITE, INCLUDING BACKSHIFT INSPECTION, IN THE AREAS OF ANNUAL AND MONTHLY SURVEILLANCE, MAINTENANCE OBSERVATIONS AND REVIEWS, ENGINEERED SAFETY FEATURES, OPERATIONAL SAFETY, FACILITY MODIFICATIONS AND "LANT EVENTS. ONE VIOLATION WITH THREE EXAMPLES FOR FAILURE TO MEET THE REQUIREMENTS OF TECHINCAL SPECIFICATION (TS) 6.8.1 WAS IDENTIFIED.

INSPECTION MARCH 21-25 (88-05): THIS ROUTINE, UNAMNOUNCED INSPECTION WAS CONDUCTED IN THE AKEAS OF LIQUID AND GASEOUS WASTE PROCESSING, LIQUID AND GASEOUS EFFLUENTS, EFFLUENT MONITORING, POST ACCIDENT SAMPLING, CONFIRMATORY MEASUREMENTS AND ENVIRONMENTAL MONITORING. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 25 - MARCH 25 (88-07): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED DIRECT INSPECTION AT THE SITE, INCLUDING BACKSHIFT INSPECTION, IN THE AREAS OF ANNUAL AND MONTHLY SURVEILLANCE, MAINTENANCE OBSERVATIONS AND REVIEWS, ENGINEERED SAFETY FEATURES, OPERATIONAL SAFETY, FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS AND PLANT EVENTS. ONE VIOLATION WITH THREE EXAMPLES FOR

PAGE 2-436

Report Period APR 1988

INSPECTION SUMMARY

FAILURE TO MEET THE REQUIREMENTS OF TS 6.8.1 WAS IDENTIFIED.

ENFORCEMENT SUMMARY

TS 6.8.1 REQUIRES THAT WRITTEN | ROCEDURES AND ADMINISTRATIVE POLICIES SHALL BE ESTABLISHED, IMPLEMENTED AND MAINTAINED THAT MEET OR EXCEED THE REQUIREMENTS AND RECOMMENDATIONS OF APPENDIX A OF USNRC REGULATORY GUIDE 1.33 AND SECTION 5.1 AND 5.3 OF ANSI N18-7-1972. CONTRARY TO THE ABOVE: (1) ON JANUARY 6, 1988, PROCEDURES 3/4-0SP-075.3 FAILED TO ESTABLISH ADMINISTRATIVE REQUIREMENTS TO INDEPENDENTLY VERIFY AFW NITROGEN VALVE POSITIONS, WHICH RESULTED IN A FAILURE TO IMPLEMENT STEP 7.2.20 OF PROCEDURE 4-OSP-75.3 IN THAT A VALVE WAS NOT OPENED AS REQUIRED. CONSEQUENTLY, ONLY TWO OF THREE NITROGEN BOTTLES WERE RESTORED TO THEIR NORMAL ALIGNMENT FOLLOWING SURVEILLANCE TESTING. (2) ON JANUARY 12, 1988, THE CONTINUOUS FIRE WATCH POSTED AT FIRE DOOR 108A-1 TO COMPENSATE FOR AN IMPAIRED HALON SYSTEM WAS FOUND ASLEEP. CONSEQUENTLY, THE EFFECTIVENESS OF THE HALON SYSTEM MIGHT NOT HAVE BEEN RE-ESTABLISHED (THROUGH DOOR CLOSURE) WITHIN THE REQUIRED 60 SECOND TIME INTERVAL. (3) ON JANUARY 13, 1988, MAINTENANCE WAS PERFORMED ON THE UNIT 3 ROD CONTROL SYSTEM WITHOUT DOCUMENTED INSTRUCTIONS OR DRAWINGS APPROPRIATE TO THE CIRCUMSTANCES. FUSES WERE REMOVED FROM THE SYSTEM WITHOUT A COMPLETE UNDERSTANDING OF WHAT CIRCUITRY THE FUSES SUPPLIED. CONSEQUENTLY, PORTIONS OF THE ROD CONTROL CIRCUITRY FOR 3 RODS WERE DE-ENERGIZED WHILE ONLY ONE ROD WAS THOUGHT TO BE AFFECTED. DURING A UNIT 3 REACTOR SHUTDOWN, THIS UNEXPECTEDLY RESULTED IN MULTIPLE RODS DROPPING INTO THE CORE, REQUIRING AS MANUAL REACTOR TRIP. (4) ON JANUARY 10, 1988, OTSC 5676 WAS APPROVED TO ONOP 0208.11, AN ANNUNCIATOR RESPONSE PROCEDURE, AND AS OF JANUARY 13, 1988, IT HAD NOT BEEN ENTERED INTO THE ONOP. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION III, AS IMPLEMENTED BY THE APPROVED FLORIDA PURER AND LIGHT COMPANY TOPICAL QUALITY ASSURANCE REPORT (FPLTQAR) 1-76A, REVISION 10, TOPICAL QUALITY REQUIREMENT (TQR) 3.0, REVISION 5, IN JANUARY 1988, INSPECTIONS IDENTIFIED THAT DESIGN INPUTS CONTAINED INPLANT CHANGE MODIFICATIONS (PCMS) 85-175 AND 85-176, HAD NOT BEEN CORRECTLY TRANSLATED INTO OPERATING PROCEDURES AND THE SYSTEM DESCRIPTION. (8705 4)

UNDERGROUND PA BARRIER. UNALARMED PA BARRIER. INADEQUATE ALARM TES?. (8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

SELECT SAFETY SYSTEM OPERABILITY REVIEW IN PROGRESS.

FACILITY ITEMS (PLANS AND PROCEDURES):

PROCEDURE UPGRADE PROGRAM (PUP) IN PROGRESS.

MANAGERIAL ITEMS:

PEP IN PROGRESS.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: FEBRUARY 25 - MARCH 25, 1988 +

INSPECTION REPORT NO: 50-250/88-07 +

Report Period APR 1988 INSPECTION STATUS - (CONTINUED)

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-003	03/04/88	04/07/88	CONTAINMENT VENTILATION AND CONTROL ROOM VENTILATION ISOLAT WHILE CONTAIN PARTICULATE RAD MONITOR SETPOINT WAS BEING CHECK
88-004	03/18/88	04/15/88	AUXILIARY FEEDWATER INITIATION ON LOW S/G LEVEL DUE TO INADEQUATE MONITORING OF STEAM GENERATOR LEVEL; PERSONNEL ERROR

THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docket: 50-251	OPERAT	TINGS	TATUS
2.	Reporting Period: _04/01/	88 Outage	e + On-line	Hrs: 719.0
3.	Utility Contact: <u>N. W. G</u>	RANT (305)	694-4432	
4.	Licensed Thermal Power (M	Wt):		2200
5.	Nameplate Rating (Gross M	We):	894 X	0.85 = 760
6.	Design Electrical Rating	(Net MWe):	-	693
7.	Maximum Dependable Capaci	ty (Gross M	1We):	700
8.	Maximum Dependable Capaci	ty (Net MWa		666
9.	If Changes Occur Above Si	nce Last Re	eport, Give	Reasons:
	NONE			
10.	Power Level To Which Rest	ricted, If	Any (Net M	We):
11.	Reasons for Restrictions,	If Any:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 128,760.0
13.	Mours Reactor Critical	647.5	2,427.8	87,614.5
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	166.6
15.	Hrs Generator On-Line	613,1	2,383.6	84,597.0
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	31.2
17.	Gross Therm Ener (MWH)	1,322,618	5,088,425	178,553,048
18.	Gross Elec Ener (MWH)	433,190	1,676,500	56,976,324
19.	Net Elec Ener (MWH)	411,689	1,593,687	53,915,518
20.	Unit Service Factor	85.3	82.1	65.7
21.	Unit Avail Factor	85.3	82.1	65.7
22.	Unit Cap Factor (MDC Net)	86.0	82.4	64.3×
23.	Unit Cap Factor (DER Net)	82.6	79.2	60.4
24.	Unit Forced Outage Rate	.4.7	17.9	11.0
25.	Forced Outage Hours	105.9	518.2	10,099.1
26.	Shutdowns Sched Over Next NONE	6 Months (Type,Date,I	Duration):
1.1	street out the second of the last of the second			

AVERAGE DAILY POWER LEVEL (MWe) PLOT

TURKEY POINT 4





* Item calculated with a Weighted Average

Report	Period A	PR 19	88		UN	тт сни	тром	NS / R	E D U C T I O N S REXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
07	04/06/88	F	33.8	A	1		на	PIPEXX	UNIT 4 WAS SHUTDOWN TO INVESTIGATE AND REPAIR A LEAK IN THE TURBINE CONTROL OIL SYSTEM. WHILE RETURNING TO FULL POWER FOLLOWING REPAIR OF THE OIL LEAK, HOLDS WERE EXPERIENCED FOR SECONDARY CHEMISTRY, ADJUSTMENT OF ROD POSITION INDICATION AND TO REPAIR THE BACKUP FEEDWATER PUMP WHICH WAS FOUND TO HAVE WATER IN THE OIL.
08	04/27/88	F	72.1	A	1		PC	VALVEX	THE UNIT WAS SHUTDOWN TO INVESTIGATE AND REPAIR A LEAKING PRESSURIZER CONTROL SPRAY VALVE. THE UNIT WAS-SHUTDOWN FOR THE REMAINDER OF THE PERIOD.

TypeReasonMethodSystem & ComponentF-Forced
S-SchedA-Equip Failure
B-Maint or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training
& License Examination1-Manual
1-Manual
2-Manual Scram
3-Auto Scram
4-Continued
9-OtherExhibit F & H
Instructions for
D-Reparation of
Data Entry Sheet
License Event Report
(LER) File (NUREG-0161)

FACILITY DESCRIPTION

RELIABILITY COUNCIL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS......9250 WEST FLAGLER STREET P.O. BOX 013100 MIAMI, FLORIDA 33174

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER. .. WESTINGHOUSE

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....R. BREWER

LICENSE & DATE ISSUANCE.... DPR-41, APRIL 10, 1973

PUBLIC DOCUMENT ROOM......ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY FLORIDA INTERNATIONAL UNIVERSITY MIAMI, FLORIDA 33199

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 22-25 (88-01): THIS SPECIAL, ANNOUNCED INSPECTION WAS AN EMERGENCY RESPONSE FACILITIES (ERF) APPRAISAL. AREAS EXAMINED DURING THE APPRAISAL INCLUDED A REVIEW OF SELECTED PROCEDURES AND REPRESENTATIVE RECORDS, THE ERFS AND RELATED EQUIPMENT, AND INTERVIEWS WITH LICENSEE PERSONNEL. SELECTED ACTIVITIES WERE OBSERVED DURING THE 1988 ANNUAL EXERCISE 1: DETERMINE THE ADEQUACY OF THE ERFS AND RELATED EQUIPMENT. TWO VIOLATIONS WERE IDENTIFIED, NAMELY: FAILURE TO PROVIDE ADEQUATE MEHTODS, SYSTEMS AND EQUIPMENT FOR ASSESSING AND MONITORING ACTUAL OR POTENTIAL OFFSITE CONSEQUENCES OF A RADIOLOGICAL EMERGENCY CONDITION, FAILURE TO TO PROVIDE WRITTEN PROCEDURES AND ADMINISTRATIVE POLICIES TO CONTROL THE COMPUTER BASED DOSE CALCULATION MODEL.

INSPECTION JANUARY 18 - FEBRUARY 25 (88-02): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED DIRECT INSPECTION AT THE SITE, INCLUDING BACKSHIFT INSPECTION, IN THE AREAS OF ANNUAL AND MONTHLY SURVEILLANCE, MAINTENANCE OBSERVATIONS AND REVIEWS, ENGINEERED SAFETY FEATURES, OPERATIONAL SAFETY, FACILITY MODIFICATIONS AND PLANT EVENTS. ONE VIOLATION WITH THREE EXAMPLES FOR FAILURE TO MEET THE REQUIREMENTS OF TECHINCAL SPECIFICATION (TS) 6.8.1 WAS IDENTIFIED.

INSPECTION MARCH 21-25 (88-05): THIS ROUTINE, UNANNOUNCED INSPECTION WAS CONDUCTED IN THE AREAS OF LIQUID AND GASEOUS WASTE PROCESSING, LIQUID AND GASEOUS EFFLUENTS, EFFLUENT MONITORING, POST ACCIDENT SAMPLING, CONFIRMATORY MEASUREMENTS AND ENVIRONMENTAL MONITORING. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 25 - MARCH 25 (88-07): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED DIRECT INSPECTION AT THE SITE, INCLUDING BACKSHIFT INSPECTION, IN THE AREAS OF ANNUAL AND MONTHLY SURVEILLANCE, MAINTENANCE OBSERVATIONS AND REVIEWS, ENGINEERED SAFETY FEATURES, OPERATIONAL SAFETY, FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS AND PLANT EVENTS. ONE VIOLATION WITH THREE EXAMPLES FOR PAGE 2-442

INSPECTION STATUS - (CONTINUED)

INSPECTION SUMMARY

FAILURE TO MEET THE REQUIREMENTS OF TS 6.8.1 WAS IDENTIFIED.

ENFORCEMENT SUMMARY

TS 6.8.1 REQUIRES THAT WRITTEN PROCEDURES AND ADMINISTRATIVE POLICIES SYALL BE ESTABLISHED, IMPLEMENTED AND MAINTAINED THAT MEET OR EXCEED THE REQUIREMENTS AND RECOMMENDATIONS OF APPENDIX A OF USNRC REGULATORY GUIDE 1.33 AND SECTION 5.1 AND 5.3 OF ANSI N18-7-1972. CONTRARY TO THE ABOVE: (1) ON JANUARY 6, 1988, PROCEDURES 3/4-0SP-075.3 FAILED TO ESTABLISH ADMINISTRATIVE REQUIREMENTS TO INDEPENDENTLY VERIFY AFW NITROGEN VALVE POSITIONS, WHICH RESULTED IN A FAILURE TO IMPLEMENT STEP 7.2.20 OF REQUIREMENTS TO INDEPENDENTLY VERIFY AFW NITROGEN VALVE POSITIONS, WHICH RESULTED IN A FAILURE TO IMPLEMENT STEP 7.2.20 OF REQUIREMENTS TO INDEPENDENTLY VERIFY AFW NITROGEN VALVE POSITIONS, WHICH RESULTED IN A FAILURE TO IMPLEMENT STEP 7.2.20 OF REQUIREMENTS TO INDEPENDENTLY VERIFY AFW NITROGEN VALVE POSITIONS, WHICH RESULTED IN A FAILURE TO IMPLEMENT STEP 7.2.20 OF TO THEIR NORMAL ALIGNMENT FOLLOWING SURVEILLANCE TESTING. (2) ON JANUARY 12, 1988, THE CONTINUOUS FIRE WATCH POSTED AT FIRE DOOR TO THEIR NORMAL ALIGNMENT FOLLOWING SURVEILLANCE TESTING. (2) ON JANUARY 12, 1988, THE CONTINUOUS FIRE WATCH POSTED AT FIRE DOOR NAVE BEEN RE-ESTABLISHED (THROUGH DOOR CLOSURE) WITHIN THE REQUIRED 60 SECOND TIME INTERVAL. (3) ON JANUARY 13, 1988, MAINTENANCE NAS PERFORMED ON THE UNIT 3 ROD CONTROL SYSTEM WAS FOUND ASLEEP. CONSEQUENTLY, THE EFFECTIVENESS OF THE HALON SYSTEM MICHT NOT OF THE ROD CONTROL CIRCUITRY FOR 3 RODS WERE DE-ENERGIZED WHILE ONLY ONE ROD WAS THOUGHT TO BE AFFECTED. DURING A UNIT 3 REACTOR FUSES WERE REMOVED FROM THE SYSTEM WITHOUT A COMPLETE UNDERSTANDING OF WHAT CIRCUITRY THE FUSES SUPPLIED. CONSEQUENTLY, PORTIONS SHUTDOWN, THIS UNEXPECTEDLY RESULTED IN MULTIPLE RODS DROPPING INTO THE CORE, REQUIRE AND AS OF JANUARY 13, 1988, IT AD NOT BEEN OF THE ROD CONTROL CIRCUITRY FOR 3 RODS WERE DE-ENERGIZED WHILE ONLY ONE ROD WAS THOUGHT TO BE AFFECTED. DURING A UNIT 3 REACTOR SHUTDOWN, THIS UNEXPECTEDLY RESULTED IN MULTIPLE REDS DROPPING INTO THE CORE, REQUIRE AND AL REACTOR TRIP. (4) ON JANUARY ON 1985, OTSC 5676 WAS APPROV

UNDERGROUND PA BARRIER. UNALARMED PA BARRIER. INADEQUATE ALARM TEST. (8800 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

SELECT SAFETY SYSTEM OPERABILITY REVIEW IN PROGRESS.

FACILITY ITEMS (PLANS AND PROCEDURES):

PROCEDURE UPGRADE PROGRAM (PU.) IN PROGRESS.

MANAGERIAL ITEMS:

PEP IN PROGRESS.

PLANT STATUS:

REFUELING OUTAGE. PLANT IN COLD SHUTDOWN.

LAST IE SITE INSPECTION DATE: FEBRUARY 25 - MARCH 25, 1988 +

INSPECTION REPORT NO: 50-251/88-07 +

INSPECTION STATUS - (CONTINUED)

REPORTS FROM LICENSEE

- 11		1	
H		1	
11			
H		1	
41			
18		i	
11		1	
i ii		1	
一县		1	
H.		1	
н		1	
11		1	
- 8		- 1	
		- 1	
1		- 1	
- 11		1	
- 11		i	
H		1	
- 11			
11		- i	
H		1	
1		1	
18		- 1	
H		1	
10		1	
11		- 1	
H		1	
iii		-	
11		. i	
H		1	
H		1	
11		1	
-11		1	
H		1	
H		1	
H		1	
11			
ñ.		- 1	
11		1	
11		1	
11		1	
11		1	
12		1	
11		1	
11		1	
11		1	
88		i	
11		1	
11		1	
82		i	
H		1	
11		1	
25		i	
53		1	
11		1	
H		i	
H. 11		1	
11		1	
H		1	
11		1	
ii .		1	
H.		1	
11		1	
11		1	
11		1	
1		1	
H	jue .	1	
	2	1	
1.1	30	1	
18	100	1	
8	80	-	
	10B	1	
8 1 4 1 a	SUB	1	
5 1 4 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5	SUB	-	
4 日日	SUB		
(1) (1) (1) (1) (1) (1) (1) (1) (1) (1)	E SUB		
经财产过程费用方法资产	OF SUB		
· · · · · · · · · · · · · · · · · · ·	ORT SUB		
经过资源法律方法过率建立法	FE OF SUB		
经财政财法法定法律律法	ATE OF SUB REPORT		
经财经财富保证资金建立支援	DATE OF SUB REPORT		
经间接通过法律法律法律法	DATE OF SUB REPORT		
经同时间期利用的公司付款金属资源	DATE OF SUB REPORT		
植材料 机拉拉拉口的 植物 机合成分子	DATE OF SUB REPORT		
经回转回转通过公司传递承达了法法事实来来。	IF DATE OF SUB REPORT		
经回外间接通过计算中达有关的现在分词	OF DATE OF SUB VI REPORT SUB		
建铜铁铁铁铁石的复数建筑建筑建筑建筑	E OF DATE OF SUB ENT REPORT SUB		
建铜铁铺铺建设设设建建筑建成委员等等的复数	VENT REPORT SUB		
建建造法有意义的学校教育的成功的专家的专家	EVENT REPORT SUB		
建建烧过油油过去过度建筑发展出来来来来来来来来来来。	BATE OF DATE OF SUB EVENT REPORT		
经初经财物经济经济建筑成学校成本学校学校学校学校	BATE OF DATE OF SUB EVENT REPORT		
韩国县国际部门团团和部时间和市场市场建立主要主要支援	BATE OF DATE OF SUB EVENT REPORT		
经经济利益保持保持保持保持资源资源资源资源资源资源资源	E BATE OF DATE OF SUB EVENT REPORT		
经经济利益保持的保证保持资源资源资源资源资源资源资源	ER DATE OF DATE OF SUB EVENT REPORT		
韩国映到韩韩国的神秘和我们和希望这些主义主义是主义。	BER VATE OF DATE OF SUB EVENT REPORT		
韩国联邦新研科局部的研研研研研研研研研研研研研研研研研研研研研研研研研研研研研研研研研研研	IMBER DATE OF DATE OF SUB EVENT REPORT	建合金 医子宫炎 医尿管 化化学学 医外外的 医外外的 化化化学 化化化学	
韩毅毅刘颢静静静静静静静静静静静静静静静静静静静静静静静静静静静静静静静静静静静	NUMBER DATE OF DATE OF SUB EVENT REPORT	建合金 医子宫炎 医尿管炎 医外外的 医外外的 医外外的 医外外的 医外外的	
韩拉顿到林廷村让你把他放弃和我们的你们你的你们的你们的你们的你们的你们的你们	NUMBER DATE OF DATE OF SUB EVENT REPORT		

NONE.

1

ð

THIS PAGE INTENTIONALLY LEFT BLANK

1.	Docket: _50-271	OPERA	TINGS	TATUS				
2.	Reporting Period: 04/01/88 Outage + On-line Hrs: 719.0							
3.	Utility Contact: G. A. M	ALLIN (802	257-7711	X2272				
4.	Licensed Thermal Power (MWt): 1593							
5.	Nameplat > Rating (Gross M	0.9 = 563						
6.	Design Electrical Rating	514						
7.	Maximum Dependable Capaci	535						
8.	Maximum Dependable Capacity (Net MWe):504							
9.	If Changes Occur Above Since Last Report, Give Reasons: NONE							
10.	Power Level To Which Rest	ricted, If	Any (Net M	We):				
11.	Reasons for Restrictions,	If Any:						
	NONE							
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE				
13.	Hours Reactor Critical	719.0	2,903.0	107,748.1				
14.	R× Reserve Shtdwn Hrs	. 0	. 0					
15.	Hrs Generator On-Line	719.0	2,903.0	105,193.0				
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	. 0				
17.	Gross Therm Ener (MWH)	1,130,656	4,569,658	154,310,356				
18.	Gross Elec Ener (MWH)	381,815	1,545,698	51,385,642				
19.	Net Elec Ener (MWH)	365,556	1,482,362	48,777,449				
20.	Unit Service Factor	100.0	100.0	76.9				
21.	Unit Avail Factor	100.0	100.0	76.9				
22.	Unit Cap Factor (MDC Net)	100.9	101.3	70.7				
23.	Unit Cap Factor (DER Net)	98.9	99.3	69.4				
24.	Unit Forced Outage Rate		. 0	6.1				
25.	Forced Outage Hours		. 0	5,593.4				
26.	Shutdowns Sched Over Next	6 Months (Type,Date,I	Duration):				
27	If Currently Shutdown Est	imated Star	tun Date:	N/A				

.

VERMONT YANKEE 1



APRIL 1988

PAGE 2-446

...

Report	Period Al	PR 19	88		UN	тт сни	тром	NS / R	EDUCTIONS ************************************	
No.	Date	Туре	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recorrence SINGLE ROD SCRAM TESTING; CONTROL ROD AND TURBINE	
88-04	04/30/88	S	0.0	5	2		RD	COMOD	BYPASS VALVE TESTING; WEEKLY TURBINE SURVEILLANCE AND A ROD PATTERN EXCHANGE.	
88-041	04/30/88	s	0.0	В	5		CB	XXXXXX	AT AND 'B' RECIRCULATION MG SETS REMOVED FROM SERVICE	

********** * SUMMARY * ********

Туре	Reason	Method	System & Component	
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper I C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual Error 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensec Event Report (LER) File (NUREG-0161)	
***** VERMONT YANKEE 1 *****

FACILITY DESCRIPTION

LOCATION STATE.....VERMONT

DIST AND DIRECTION FROM NEAREST POPULATION CTR...5 MI S OF BRATTLEBORO, VT

TYPE OF REACTOR BWR

DATE INITIAL CRITICALITY... MARCH 24, 1972

DATE ELEC ENER 1ST GENER... SEPTEMBER 20, 1972

DATE COMMERCIAL OPERATE.... NOVEMBER 30, 1972

CONDENSER COOLING METHOD. .. COOLING TOWER

CONDENSER COOLING WATER CONNECTICUT RIVER

ELECTRIC RELIABILITY

COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS......RD #5, BOX 169, FERRY ROAD BRATTLEBORO, VERMONT 05301

CONTRACTOR

ARCHITECT/ENGINEER.....EBASCO

NUC STEAM SYS SUPPLIER. .. GENERAL ELECTRIC

CONSTRUCTOR......EBASCO

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

JE RESIDENT INSPECTOR.....W. RAYMOND

LICENSING PROJ MANAGER V. ROONEY

LICENSE & DATE ISSUANCE.... DPR-28, FEBRUARY 28, 1973

224 MAIN STREET BRATTLEBORD, VERMONT 05301 INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

10 CFR 50.49 PARA (F) AND (G), AND PARA (K) (FOR DOR GUIDELINE PROVISION) REQUIRE THAT EACH ITEM OF ELECTRICAL EQUIPMENT IMPORTANT TO SAFETY BE QUALIFIED AND THAT QUALIFICATIONS MUST BE COMPLETED NO LATER THAN NOVEMBER 30, 1985. CONTRARY TOTHE ABOVE, ON OCTOBER 23, 1987, QUALIFICATION OF THE EP/HYPALON CABLES WAS NOT ESTABLISHED AT THE TIME OF THE INSPECTION IN THAT THE QUALIFICATION TEST REPORT WAS INVALID BECAUSE OF PROBLEMS IDENTIFIED IN IEIN 84-44 (INADEQUATE QA PROGRAM, TEST EQUIPMENT NOT PROPERLY CALIBRATED, TEST DEFICIENCIES AND TEST ANOMALIES IMPROPERLY DOCUMENTED, AND TEST DOCUMENTS IMPROPERLY CONTROLLED). 10 CFR 50.49 PARA (F) AND (G), AND PARA (K) (FOR DOR GUIDELINE PROVISION) REQUIRE THAT EACH ITEM OF ELECTRICAL EQUIPMENT IMPORTANT TO SAFETY BE QUALIFIED AND THAT QUALIFICATIONS MUST BE COMPLETED NO LATER THAN NOVEMBER 30, 1985. CONTRARY TOTHE ABOVE, ON OCTOBER 23, 1987, QUALIFICATION OF3M TAPE SPLICE WAS NOT ESTABLISHED AT THE TIME OF THE INSPECTION IN TAHT NO TYPE TEST REPORT NOR ADEQUATE SIMILARITY ANALYSIS WAS ABAILABLE IN THE EQ FILE TO SUPPORT THE TAPE SPLICES QUALIFICATION.

10 CFR 50,49 PARA (F) AND (G), AND PARA (K) (FOR DOR GUIDELINE PROVISION) REQUIRE THAT EACH ITEM OF ELECTRICAL EQUIPMENT INPORTANT TO SAFETY BE QUALIFIED AND THAT QUALIFICATIONS MUST BE COMPLETED NO LATER THAN NOVEMBER 30, 1985. CONTRARY TOTHE ABOVE, ON OCTOBER 23, 1987, QUALIFICATION OFDINGS BRAKES IN THE LINITORQUE VALVE OPERATOR WAS NOT ESTABLISHED AT THE TIME OF THE INSPECTION

PAGE 2-448

Report Period APR 1988

PUBLIC DOCUMENT ROOM...... BROOKS MEMORIAL LIBRARY

Report Period APR 1988

ENFOLCEMENT SUMMARY

IN THAT THE EQ FILE DID NOT CONTAIN EVIDENCE TO DEMONSTRATE THE RADIATION QUALIFICATION OF THE DINGS BRAKES FOR APPLICATION INSIDE THE DRYWELL. 10 CFR 50.69 PARA (F) AND (G), AND PARA (K) (FOR DOR GUIDELINE PROVISION) REQUIRE THAT EACH ITEM OF ELECTRICAL EQUIPMENT IMPORTANT TO SAFETY BE QUALIFIED AND THAT QUALIFICATIONS MUST BE COMPLETED NO LATER THAN NOVEMBER 30, 1985. CONTRARY TOTHE ABOVE, ON OCTOBER 23, 1987, QUALIFIED AND THAT QUALIFICATIONS MUST BE COMPLETED NO LATER THAN NOVEMBER 30, 1985. CONTRARY (1) THE TYPE TEST REPORT DID NOT DEMONSTRATE THAT THIS TERMINAL BLOCK WAS NOT ESTABLISHED AT THE TIME OF THE INSPECTION IN THAT RESISTANCE VALUES WERE OBSERVED DURING THE TEST; (2) NO SIMILARITY ANALYSIS WAS AVAILABLE IN THE THAT EACH ITEM OF ELECTRICAL EQUIPMENT IMPORTANT TO SAFETY BE QUALIFIED AND THAT QUALIFICATIONS MUST BE COMPLETED NO LATER THAN NOVEMBER 30, 1985. ELECTRICAL EQUIPMENT IMPORTANT TO SAFETY BE QUALIFIED AND THAT QUALIFICATIONS MUST BE COMPLETED NO LATER THAN NOVEMBER 30, 1985. CONTRARY TOTHE ABOVE, ON OCTOBER 23, 1987, QUALIFIED AND THAT QUALIFIED SERVICE CONDITIONS (303 DEG F FOR FOUR HOURS VS. 325 DEG F FOR THEE IN THAT THE TEST CONDITIONS DID NOT 4NVELOPE THE REQUIRED SERVICE CONDITIONS (303 DEG F FOR FOUR HOURS VS. 325 DEG F FOR THREE HOURS). 10 CFR 50.49 PARA (F) AND (G), AND PARA (K) (FOR DOR GUIDELINE PROVISION) REQUIRE THAT EACH ITEM OF THE INSPECTION N THAT THE TEST CONDITIONS DID NOT 4NVELOPE THE REQUIRED SERVICE CONDITIONS (303 DEG F FOR FOUR HOURS VS. 325 DEG F FOR THREE IN THAT THE TEST CONDITIONS DID NOT HAVELOPE THE REQUIRED SERVICE CONDITIONS NEED NOT HAT EACH ITEM OF ELECTRICAL EQUIPMENT HOURS). 10 CFR 50.49 PARA (F) AND (G), AND PARA (K) (FOR DOR GUIDELINE PROVISION) REQUIRE THAT EACH ITEM OF THE INSPECTION N THAT THE TEST CONDITIONS DID NOT HAVELOPE THE REQUIRED SERVICE CONDITIONS (303 DEG F FOR FOUR HOURS VS. 325 DEG F FOR THREE HOURS). 10 CFR 50.49 PARA (F) AND (G), AND PARA (K) (FOR DOR GUIDELINE PROVISION) REQUIRE THAT EACH ITEM OF THE INSPECTION IN THAT HOURS). 10 CFR

(8701 4)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

REPORTS FROM LICENSEE

*********	**********	================		
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT	
NO INPUT	PROVIDED.			

1.	Docket: _50-424	OPERAT	TING S	TATUS
2.	Reporting Period: _04/01	/88 Outage	+ On-line	Hrs: 719.
3.	Utility Contact: <u>S. C.</u>	DILWORTH (40)4) 724-8114	¥ X3870
4.	Licensed Thermal Power (MWt):		3411
5.	Nameplate Rating (Grcss		1157	
6.	Design Electrical Rating	(Net MWe):		1101
7.	Maximum Dependable Capac	ity (Gross M	1We) :	1133
8.	Maximum Dependable Capac		1079	
9.	If Changes Occur Above S NONE	ince Last Re	eport, Give	Reasons:
10.	Power Level To Which Res	tricted, If	Any (Net Mk	le):
11.	Reasons for Restrictions	, If Any:		
_	NONE	Second Second		
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIV 8,040.
13.	Hours Reactor Critical	604.6	_2,224.9	6,273.
14.	Rx Reserve Shtdwn Hrs	. 0	. 0	
15.	Hrs Generator On-Line	578.5	2,158.6	6,079.
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	
17.	Gross Therm Ener (MWH)	1,907,244	7,116,241	19,777,17
18.	Gross Elec Ener (MWH)	635,710	2,371,050	6,554,94
19.	Net Elec Ener (MWH)	598,280	2,224,740	6,146,26



80.5

74.4

75.6

REFUELING - SEPTEMBER 18, 1988 - 50 DAY DURATION.

20. Unit Service Factor



VOGTLE 1



APRIL 1988

Report	Report Period APR 1988			UNIT SHUTDOWN:		NS / R	E D U C T I O N S		
No.	Date	Туре	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
88-7	04/07/88	F	50.3	Α	3		LΊ	TCV	FAILURE OF A LINKAGE SHAFT ON STATOR COOLING VALVE (1TCV-6800) TEMPERATURE CONTROLLER. VIBRATION OF UNDERLYING EQUIPMENT SKID LED THE UNDERSIZED LINKAGE SHAFT TO STRIP THE ENGAGED THREADS AND DROP OUT OF NYLON THUMB NUT, GIVING A SIGNAL FOR 1TCV-6800 TO CLOSE. REPLACED THE UNDERSIZED LINKAGE SHAFT WITH THE CORRECT SIZE SHAFT.
88-8	04/24/88	F	90.2	A	2		SJ	ISV	REACTOR OPERATOR MANUALLY TRIPPED THE REACTOR IN ANTICIPATION OF AN AUTOMATIC TRIP DUE TO STEAM GENERATOR NO. 4 LEVEL AT 42%. OPERATORS WERE MANUALLY UNABLE TO OPEN LOOP NO. 4 MAIN FEEDWATER ISOLATION VALVE. THE VALVE WOULD NOT RESPOND TO AN OPEN SIGNAL. REPLACED THOSE COMPONENTS WHICH ACTIVATE THE LOOP NO. 4 MAIN FEEDWATER ISOLATION VALVE.

********* VOGTLE 1 INCURRED 2 FORCED POWER OUTAGES IN APRIL FOR REASONS * SUMMARY * STATED ABOVE.

Type	Reason	Method	System & Component
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

******* VOGTLE 1 ******** FACILITY DESCRIPTION LOCATION STATE.....GEORGIA COUNTY.....BURKE DIST AND DIRECTION FROM NEAREST POPULATION CTR...25 MI SSE OF AUGUSTA, GA TYPE OF REACTOR PWR DATE INITIAL CRITICALITY...MARCH 9, 1987 DATE ELEC ENER 1ST GENER...MARCH 27, 1987 DATE COMMERCIAL OPERATE....JUNE 1, 1987 CONDENSER COOLING METHOD...CCCT CONDENSER COOLING WATER....SAVANNAH RIVER ELECTRIC RELIABILITY RELIABILITY COUNCIL

FACILITY DATA

Report Period APP. 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE.....GEORGIA POWER

CONTRACTOR

ARCHITECT/ENGINEER.....SOUTHERN SERVICES & BECHTEL

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR......GEORGIA POWER CO.

T"RBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....J. ROGGE

LICENSE & DATE ISSUANCE....NPF-68, MARCH 16, 1987

PUBLIC DOCUMENT ROOM.....BURKE COUNTY LIBRARY 412 FOURTH ST. WAYNESBORD, GA. 30830 INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 27 - MARCH 25 (88-15): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED RESIDENT INSPECTION IN THE FOLLOWING AREAS: PLANT OPERATIONS, RADIOLOGICAL CONTROLS, MAINTENANCE, SURVEILLANCE, FIRE PROTECTION, SECURITY, AND QUALITY PROGRAMS AND ADMINISTRATIVE CONTROLS AFFECTING QUALITY. NO VIGLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION MARCH 7-10 (88-16): THIS SPECIAL, ANNOUNCED INSPECTION WAS IN THE AREAS OF SAFE SHUTDOWN OF THE UNIT 1 WITH LIMITED STAFF IN THE EVENT OF A MAIN CONTROL ROO™ FIRE AND EQUIPMENT ACTUATIONS DUE TO FIRE INDUCED SPURIOUS SIGNALS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTERS AND COMPONENT PROBLEMS:

Report Period APS 1988

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES): NONE. MANAGERIAL ITEMS: NONE. PLANT STATUS: + NORMAL OPERATION. LAST IE SITE INSPECTION DATE: MARCH 7-10, 1988 + INSPECTION REPORT NO: 50-424/88-16 + REPORTS FROM LICENSEE DATE OF SUBJECT NUMBER DATE OF EVENT REPORT 03/22/88 04/21/88 PERSONNEL ERROR LEADS TO MISSED TECHNICAL SPECIFICATION SURVEILLANCE 88-007

1.	Docket: _50-397_	OPERAT	TING S	TATUS						
Ζ.	Reporting Period: 04/01/	88 Outage	+ On-line	Hrs: 719.0						
3.	Utility Contact: LEONARD	HUTCHISON	(509) 377-2	2486						
ą.,	Licensed Thermal Power (M	Wt):		3323						
5.	Nameplate Rating (Gross M	Nameplate Rating (Gross MWe):								
6.	Design Electrical Rating	(Net MWe):	-	1100						
7.	Maximum Dependable Capaci	y (Gross M	1We):	1140						
8.	Maximum Dependable Capaci	ty (Net MWe):	1095						
9.	If Changes Occur Above Since Last Report, Give Reasons:									
10.	Power Level To Which Rest	ricted, If	Any (Net Mk	le):						
11.	Reasons for Restrictions,	If Any:								
_	NONE									
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE						
13.	Hours Reactor Critical	703.0	2,223.2							
14.	R× Reserve Shtdwn Hrs		0	340,4						
15.	Hrs Generator On-Line	701.4	2,176.2	21,318.1						
16.	Unit Reserve Shtdwn Hrs		0	381.7						
17.	Gross Therm Ener (MWH)	2,280,000	6,719,698	57,102,465						
18.	Cross Elec Lner (MWH)	746,710	2,244,320	19,061,460						
19.	Net Elec Ener (MWH)	721,055	2,166,352	18,334,304						
20.	Unit Service Factor	97.6	75.0	72.0						
21.	Unit Avail Factor		75.0	73.3						
22.	Unit Cap Factor (MDC Net)	91.6	68.2	56.5						
23.	Unit Cap Factor (DER Net)	91.2	67.8	56.3						
24.	Unit Forced Outage Rate		24.6	9.9						
	Forced Outage Hours	.0	709.2	_ 2,354.3						
25.	and the second strength the second strength stre									





APRIL 1988

Report	Period AF	R 19	88		UN	ΙT	SHU	TDOW	NS / I	REDU	CTIO	NS	* WASHINGTON NUCLEAR 2 *
No.	Date	Type	Hours	Reason	Method	LER	Number	System	Component	ŧ	1 YUSE 8	§ Corr	ective Action to Prevent Recurrence
88-07	04/30/88	s	17.6	с	1			RC	FUELXX	PLANT	SHUTDOWN	N AS S	SCHEDULED FOR REFUELING OUTAGE.

********** * SUMMARY * ********* ASHINGTON NUCLEAR 2 OPERATED ROUTINELY IN APRIL. SHUTDOWN OF. SUTH FOR SCHEDULED REFUELING OUTAGE.

Type	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

PAGE 2-455

***************************** WASHINGTON NUCLEAR 2 * *******

FACILITY DESCRIPTION

10CA3 (0N

STATE......WASHINGTON

COUNTY.....BENTON

DIST AND DIRECTION FROM NEAREST POPULATION CTR...12 MI. NW OF RICHLAND, WASH.

TYPE OF REACTOR BWR

DATE INITIAL CRITICALITY... JANUARY 19, 1984

DATE ELEC ENER 1ST GENER...MAY 27, 1984

DATE COMMERCIAL OPERATE.... DECEMBER 13, 1984

CONDENSER COOLING METHOD...COOLING TOWERS

CONDENSER COOLING WATER....MECHANICAL TOWERS

ELECTRIC RELIABILITY

COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

RICHLAND, WASHINGTON 99352

CONTRACTOR ARCHITECT/ENGINEER...... BURNS & ROE

NUC STEAM SYS SUPPLIER ... GENERAL ELECTRIC

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V

IE RESIDENT INSPECTOR.....C. BOSTED

LICENSING PROJ MANAGER.....R. SAMWORTH DOCKET NUMBER 50-397

LICENSE & DATE ISSUANCE..., NPF-21, APRIL 13, 1984

PUBLIC DOCUMENT ROOM RICHLAND PUBLIC LIBRARY SWIFT AND NORTHGATE STREETS RICHLAND, WA 99352 INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION ON JANUARY 21 - MARCH 10, 1988 (REPORT NO. 50-397/88-02) AREAS INSPECTED: ROUTINE INSPECTION BY THE RESIDENT INSPECTORS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, CONTROL ROOM OPERATIONS, ENGINEERED SAFETY FEATURE STATUS, SURVEILLANCE PROGRAM, MAINTENANCE PROGRAM, PLANT SECURITY, RADIOLOGICAL PROTECTION PRACTICES, DESIGN REVIEW DEFICIENCIES, GENERAL EMPLOYEE AND LICENSED OPERATOR SIMULATOR TRAINING, REACTOR BUILDING ROOF FAILURE, LICENSEE EVENT REPORTS, AND SPECIAL REPORTS REVIEW. DURING THIS INSPECTION, VARIOUS INSPECTION PROCEDURES WERE UTILIZED.

RESULTS: IN THE AREAS INSPECTED, TWO VIOLATIONS WERE IDENTIFIED INVOLVING INEFFECTIVE CORRECTIVE ACTION IN REMOVING FOAM FILTERS FROM THE CLASS 1E SWITCHGEAR CABINET, AND FAILURE TO PERFORM AN ADEQUATE DESIGN REVIEW OF DESIGN CHANGE PACKAGES ASSOCIATED WITH ANTICIPATED TRANSIENT WITHOUT SCRAM MODIFICATIONS.

+ INSPECTION ON APRIL 26-29, 1988 (REPORT NO. 50-397/88-06) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JUNE 1, 1987 - MAY 31, 1988 (REPORT NO. 50-397/88-08) YEARLY SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE.

+ INSPECTION ON MARCH 11 - APRIL 8, 1988 (REPORT NO. 50-397/88-10) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 25 - MAY 13, 1988 (REPORT NO. 50-397/88-12) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON APRIL 5 - 13, 1988 (REPORT NO. 50-397/28-13) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

PAGE 2-456

Report Period APR 1988

Report Period APR 1988

INSPECTION STATUS - (CONTINUED)

INSPECTION SUMMARY

+ INSPECTION ON APRIL 9 - MAY 12, 1988 (REPORT NO. 50-397/88-14) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ EXAMINATIONS ON MARCH 22-23, 1988 (REPORT NO. 50-397/0L-88-01) THE WRITTEN EXAMINATION WAS ADMINISTERED TO ONE SENIOR REACTOR OPERATOR CANDIDATE AND ONE REACTOR OPERATOR CANDIDATE. BOTH OF THESE CANDIDATES PASSED THE OPERATING PORTION OF THE EXAMINATION, AND SUBSEQUENTLY PASSED OVERALL. THE OTHER CANDIDATE FAILED THE SIMULATOR PORTION OF THE EXAMINATION. THE CANDIDATE PASSED OVERALL.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

+ NONE

FACILITY ITEMS (PLANS AND PROCEDURES)

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

+ THE PLANT OPERATED AT FULL POWER UNTIL APRIL 29, 1988, WHEN IT WAS SHUT DOWN FOR THE CYCLE 4 REFUELING OUTAGE. THE LICENSEE EXPECTS TO RETURN THE UNIT TO SERVICE IN MIDDLE JUNE.

LAST IE SITE INSPECTION DATE: 06/01/1987 - 05/31/1988+

INSPECTION REPORT NO: 50-397/88-08+

REPORTS FROM LICENSEE

NUMBER DATE OF DATE OF SUBJECT EVENT REPORT

NONE

۴.	Docket: <u>50-382</u>	DPERAT	ING S	TATUS
2.	Repor Period: _ 04/01/8	0utage	+ On-line	Hrs: 719.0
3.	Utility Contact:	MILLER (504) 467-8211	
4.	Licensed Thermal Power (M)	(t):		3390
5.	Nameplate Rating (Gross M	le):		1153
6.	Design Electrical Rating ((Net MWe):	· · · · · · · · · · · · · · · · · · ·	1104
7.	Maximum Dependable Capacit	ty (Gross M	1We):	1120
8.	Maximum Dependable Capacit	ty (Net MWe):	1075
9.	If Changes Occur Above Sir NONE	nce Last Re	port, Give	Reasons:
10.	Power Level To Which Restr	icted. If	Any (Net Mk	le) :
11.	Reasons for Restrictions.	If Anv:		
	NONE			
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE
13.	Hours Reactor Critical	23.6	2,107.7	18,212,3
14,	R× Reserve Shtdwn Hrs	. 0	. 0	. 0
15.	Hrs Generator On-Line	23.5	2,053.0	17,867.4
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	. 0
17.	Gross Therm Ener (MWH)	76,267	6,857,785	58,318,757
18.	Gross Elec Ener (MWH)	26,160	2,324,390	19,705,200
19.	Net Elec Ener (MWH)	17,858	2,216,633	18,749,091
20.	Unit Service Factor		70.7	78.4
21.	Unit Avail Factor	3.3	70.7	78.4
22.	Unit Cap Factor (MDC Net)	2.3	71.0	76.5
23,	Unit Cap Factor (DER Net)	2.2	69.2	74.5
24.	Unit Forced Outage Rate	0	5.1	9.3
25.	Forced Outage Hours	. 0		1,840.1
26.	Shutdowns Sched Over Next NONE	6 Months (Type,Date,D)uration):
27.	If Currently Shutdown Esti	imated Star	tup Date:	05/30/88



1500 -



Report Period APR 1988	UNIT	SHUTDOWNS	<pre>/ REDUCTIONS</pre>	xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx
The second s				

No.	Date	Type	Hours	Reason	Method	LEK Number	System	Component	Cause & Cor: ac	tive Act	100 10	rievent Record	ence
88-03	04/01/88	s	695.5	с	1				REFUELING/MAINTENANCE	OUTAGE	NO. 2.		

********** WATERFORD 3 SHUTDOWN FOR SCHEDULED REFUELING IN APRIL.

* SUMMARY *

Туре	Reason		Method	System & Component
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Res E-Operator Train & License Exa	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION STATE......DUISIANA COUNTY.....ST CHARLES DIST AND DIRECTION FROM NEAREST POPULATION CTR...20 MI W OF NEW ORLEANS, LA TYPE OF REACTOR.....PWR DATE INITIAL CRITICALITY...MARCH 4, 1985 DATE ELEC ENER 1ST GENER...MARCH 18, 1985 DATE COMMERCIAL OPERATE...SEPTEMBER 24, 1985 CONDENSER COOLING METHOD...ONCE THRU CONDENSER COOLING MATER....MISSISSIPPI RIVER ELECTRIC RELIABILITY COUNCIL.....SOUTHWEST POWER POOL

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

LICENSEE.....LOUISIANA POWER & LIGHT

CORPORATE ADDRESS......142 DELARONDE STREET NEW ORLEANS, LOUISIANA 70174

CONTRACTOR ARCHITECT/ENGINEER.....EBASCO

NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING

CONSTRUCTOR.....EBASCO

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV

IE RESIDENT INSPECTOR.....T. STAKER

LICENSING PROJ MANAGER....D. WIGGINTON DOCKET NUMBER.....50-382

LICENSE & DATE ISSUANCE....NPF-38, MARCH 16, 1985

PUBLIC DOCUMENT ROOM.....HEAD LIBRARIAN LOUISIANA COLLECTION EARL K. LONG LIBRARY UNIVERSITY OF NEW ORLEANS LAKEFRONT DRIVE NEW GRLEANS, LOUISIANA 70148

INSPECTION SUMMARY

INSPECTION CONDUCTED MARCH 7-11, 1988 (88-05) ROUTINE, UNANNOUNCED INSPECTION CONSISTING OF: (1) OPERATIONAL SAFETY ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S CHEMISTRY/RADIOCHEMISTRY PROGRAM AND WATER CHEMISTRY AND RADIOCHEMISTRY CONFIRMATORY MEASUREMENTS. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED. ONE PREVIOUSLY IDENTFIED VIOLATION AND ONE UNRESOLVED ITEM WERE CLOSED.

INSPECTION CONDUCTED FEB. 29 - MARCH 4, 1988 (88-06) NONROUTINE, ANNOUNCED INSPECTION OF DIESEL GENERATOR RELIABILITY/ OPERABILITY AND TECHNICAL SPECIFICATIONS REPORTABILITY. WITHIN THE TWO AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period APR 1988

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

RCP 28 EXPERIENCING EXCESSIVE UPPER MOTOR BEARING TEMPERATURES DUE TO CLOGGING LUBE OIL STRAINER. MAY REQUIRE A BRIEF FORCED OUTAGE PRIOR TO SHUTDOWN FOR RFD-2 TO CLEAN THE STRAINER.

FACILITY ITEMS (PLANS AND PROCEDURES):

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

OPERATING AT FULL POWER

LAST IE SITE INSPECTION DATE: MARCH 11, 1988

INSPECTION REPORT NO: 30-382/88-05

REPORTS FROM LICENSEE

		***********		2
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT	
NONE				

1.	Docket: 50-482	OPERAT	ING S	TATUS							
2.	Reporting Period: 04/01/88 Outage + On-line Hrs: 719.0										
3.	Utility Contact: M. WILL	IAMS (316)	364-8831								
4.	Licensed Thermal Power (M	· · · · · · · · · · · · · · · · · · ·	3411								
5.	Nameplate Rating (Gross M	We):		1250							
6.	Design Electrical Rating	(Net MWe):		1170							
7.	Maximum Dependable Capaci	ty (Gross M	1We):	1170							
8.	Maximum Dependable Capacit	ty (Net MWe	.):	1128							
9.	If Changes Occur Above Sin	nce Last Re	port, Give	Reasons:							
10.	Power Level To Which Rest	ricted, If	Any (Net Mk	le):							
11.	Reasons for Restrictions,	If Any:									
	NONE										
12.	Report Period Hrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE 23,302.7							
13.	Hours Reactor Critical	719.0	2,299.6	17,766.1							
14.	Rx Reserve Shtdwn Hrs	. 0	89.5	339.8							
15.	Hrs Generator On-Line	719.0	2,146.4	17,349.5							
16.	Unit Reserve Shtdwn Hrs	. 0	. 0	19.0							
17.	Gross Therm Ener (MWH)	2,452,604	7,152,708	56, 579, 092							
18.	Gross Elec Ener (MWH)	859,975	2,508,235	19,697,126							
19.	Net Elec Ener (MWH)	827,320	2,390,129	18,802,437							
20.	Unit Service Factor	100.0	73.9	74.5							
21.	Unit Avail Factor	100.0	73.9	74.5							
22.	Unit Cap Factor (MDC Net)	102.0	73.0	54.7×							
23.	Unit Cap Factor (DER Net)	98.3	70.4	69.0							
24.	Unit Forced Outage Rate	. 0	23.0	8.0							
25.	Forced Outage Hours	. 0	640.7	1,517.0							
26.	Shutdowns Sched Over Next	6 Months (Type, Date, D	Juration):							
_	REFUELING, OCTOBER 1, 1988	8, 60 DAY D	URATION.								
27.	If Currently Shutdown Est	imated Star	tup Date:	N/A							







* Item calculated with a Weighted Average

Report Period APR 1988	U N	ΙT	SHU	тром	NS / R	EDUCTIONS	xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx
No. Date Type Hours Reason M	ethod	LER	Number	System	7.mponent	Cause & Corr	ective Action to Prevent Recurrence

NONE

Type	Reason		Method	System & Component		
F-Forced S-Sched	A-Equip Failure B-Maint or Test C-Refueling D-Regulatory Rest E-Operator Traini & License Exam	F-Admin G-Oper Error H-Other triction ing mination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161		

FACILITY DESCRIPTION

LOCATION STATEKA	NSAS
COUNTY	FFEY
DIST AND DIRECTION FROM NEAREST POPULATION CTR3. BU	5 MI NE OF RLINGTON, KAN
TYPE OF REACTORPW	R
DATE INITIAL CRITICALITY MA	Y 22, 1985
DATE ELEC ENER 1ST GENERJU	NE 12, 1985
DATE COMMERCIAL OPERATESE	PTEMBER 3, 1985
CONDENSER COOLING METHOD CO	OLING LAKE
CONDENSER COOLING WATER CO	OLING LAKE
ELECTRIC RELIABILITY CCUNCIL	UTHWEST POWER POOL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS......P.O. BOX 208 WICHITA, KANSAS 67201

CONTRACTOR ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER. .. WESTINGHOUSE

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV

IE RESIDENT INSPECTOR.....J. CUMMINS

LICENSE & DATE ISSUANCE....NPF-42, JUNE 4, 1985

PUBLIC DOCUMENT ROOM......WILLIAM ALLAN WHITE LIBRARY GOVERNMENT DOCUMENTS DIVISION EMPORIA STATE UNIVERSITY 1200 COMMERCIAL STREET EMPORIA, KANSAS 66801

INSPECTION SUMMARY

INSPECTION CONDUCTED MARCH 14-18, 1988 (88-09) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S SOLID RADWASTE AND TRANSPORTATION PROGRAM. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

INSPECTION CONDUCTED MARCH 7-11, 188 (88-12) ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S EMER "CY PLAN FACILITIES AND TRAINING. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED.

ENFORCEMENT CUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

PAGE 2-464

Report Period APR 1988

*********	************	***
×	WOLF CREEK 1	*
******	*****	关系关系关系关系关系关系

OTHER ITEMS

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

PLANT STATUS:

LAST IE SITE INSPECTION DATE: MARCH 18, 1988

INSPECTION REPORT NO: 50-482/88-09

REPORTS FROM LICENSEE

*********	**********	**************	***************************************	 	 SEESSERIASSICCLORE	-
NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT		 	
NONE						
				 **************	 ***************************************	122

1.	Docket: _50-029 0	DPERAT	ING S	TATUS							
2.	Reporting Period:	0utage	+ On-line	Hrs: 719.0							
3.	Utility Contact: <u>S. WHIPP</u>	PLE (617) 8	872-8100								
4.	Licensed Thermal Power (MWt): 600										
5.	Nameplate Rating (Gross M	(e):	185 X	1.0 = 185							
6.	Design Electrical Rating ((Net MWe):		175							
7.	Maximum Dependable Capacit	ty (Gross M	1We):	180							
8.	Maximum Dependable Capacit	ty (Net MWa):	167							
9.	If Changes Occur Above Sir	ice Last Re	port, Give	Reasons:							
	NUNC										
10.	rower Level To Which Restr	icted, If	Any (Net M	Ne):							
	NONE	If Any:									
12.	Report Period Mrs	MONTH 719.0	YEAR 2,903.0	CUMULATIVE _240,668.0							
13.	Hours Reactor Critical	705.4	2,822.5	193,935.4							
4.	R× Reserve Shtdwn Hrs	. 0	. 0								
15.	Hrs Generator On-Line	696.4	2,791.0	188,872.4							
6.	Unit Reserve Shtdwn Hrs	. 0	0								
17.	Gross Therm Ener (MWH)	402,314	1,583,828	103,196,853							
8.	Gross Elec Ener (MWH)	122,664		31,266,470							
9.	Net Elec Ener (MWH)	114,864	450,292	29,254,836							
20.	Unit Service Factor	96.9	96.1	78.5							
21.	Unit Avail Factor	96.9	96.1	78.5							
22.	Unit Cap Factor (MDC Net)	95.7	92.9	74.6*							
23.	Unit Cap Factor (DER Net)	91.3	88.6	71.1*							
24.	Unit Forced Outage Rate	1.0	3.3	5.1							
25.	Forced Outage Hours	7.1	96.5	9,000.4							
26.	Shutdowns Sched Over Next	6 Months (Type,Date,	Duration):							



15 20 DAYS

25

APRIL 1988

10

HOO OPIN BE EXDERIDED UNDER OPYTHEL CONDITIONS

* Item calculated with a Weighted Average

5

0

ò

PAGE 2-466

100

0

30

Report	Period Af	PR 19	88		UN	IТ	SHU	T D	0 W	N	s /	R	E	DU	J C	τ	I	0	N 5	**************************************
No.	Date	Type	Hours	Reason	Method	LER	Number	Sys	stem	Co	mpon	ent	-		_	Cai	use	8	Co	prrective Action to Prevent Recurrence
88-10	04/06/88	F	7.1	н	2								IN CO FO	ISPE	FCT DSI D.	ION	N O DU	F	THE	E ISOLATION VALVE BOLTING FOR POSSIBLE BORON ACCUMULATION. NO CORROSION WAS
88-11	04/30/88	s	15.5	н	1								SH	UTI	оон	IN F	PLA	NT	T	CHANGE BATTERY NO. 3.

********** YANKEE ROWE INCURRED 2 OUTAGES DURING APRIL AS DISCUSSED ABOVE. * SUMMARY *

Туре	Reason	Method	System & Component		
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Err C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual ror 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)		

FACILITY DESCRIPTION

LOCATION

STATE.....MASSACHUSETTS

COUNTY FRANKLIN

DIST AND DIRECTION FROM NEAREST POPULATION CTR...25 MI NE OF PITTSFIELD, MASS

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY ... AUGUST 19, 1960

DATE ELEC ENER 1ST GENER...NOVEMBER 10, 1960

DATE COMMERCIAL OPERATE JULY 1, 1961

CONDENSER COOLING METHOD... ONCE THRU

CONDENSER COOLING WATER....DEERFIELD RIVER

ELECTRIC RELIABILITY COUNCIL.....NORTHEAST POWER

COORDINATING COUNCIL

FACILITY DATA

UTILITY & CONTRACTOR INFORMATION

UTILITY LICENSEE......YANKEE ATOMIC ELECTRIC

CORPORATE ADDRESS......1671 WORCESTER RD. FRAMINGHAM, MASSACHUSETTS 01701

CONTRACTOR

ARCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....STONE & WEBSTER

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I

IE RESIDENT INSPECTOR.....H. EICHENHOLZ

LICENSE & DATE ISSUANCE.... DPR-3, DECEMBER 24, 1963

PUBLIC DOCUMENT ROOM.....GREENFIELD COMMUNITY COLLEGE 1 COLLEGE DRIVE GREENFIELD, MASSACHUSETTS 01301

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

10 CFR 50, PART 50.72(B)(I)(A) REQUIRES THE LICENSEE TO NOTIFY THE NRC OPERATIONS CENTER VIA THE EMERGENCY NOTIFICATION SYSTEM AS SOON AS PRACTICAL AND IN ALL CASES WITHIN ONE HOUR OF THE OCCURENCE OF THE INITIATION OF ANY NUCLEAR PLANT SHUTDOWN REQUIRED BY THE PLANT'S TS. CONTRARY TO THE ABOVE, THE REQUIERMENT OF 10 CFR 50.72(B)(I)(A) WAS NOT MET ON DECEMBER 3, 1987, IN THAT THE NRC WAS NOT NOTIFIED WITHIN ONE HOUR OF THE INITIATION OF PLANT SHUTDOWN AS REQUIRED BY TS 3.0.3. SPECIFICALLY, THE CHANNEL 1 MAIN STEAM LINE PRESSURE SWITCH ON THE NO 3 STEAM LINE WAS DECLARED INOPERABLE AT 10:40 A.M. TS TABLE 3.3.2 ACTION STATEMENT 6 REQUIRES THAT THE INOPERABLE CHANNEL BE PLACES IN THE TRIPPED CONDITION WITHIN ONE HOUR; IF NOT, PLANT SHUTDOWN IS TO BE INITIATED IN ACCORDANCE WITH TS 3.0.3. PLANT SHUTDOWN WAS INITIATED AT 11:40 A.M. AS REQUIRED BY TS; HOWEVER, THE REQUIRED ENS NOTIFICATION TO (8701 5)

OTHER ITEMS

PAGE 2-468

Report Period APR 1988

*******	**********************	*
*	YANKEE-ROWE 1	×
******	******	×

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLAN' STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INP" PROVIDED.

REPORTS FROM LICENSEE

NUMBER	DATE OF	DATE OF	SUBJECT
	EVENT	REPORT	
	a an air in to be be at the set		

NO INPUT PROVIDED.

1.	Docket: 58-295	PERA	TING S	TATUS							
z.	. Reporting Period: <u>04/01/88</u> Outage + On-line Hrs: <u>719.0</u>										
3.	Utility Contact: GERRI AL	STIN (312	746-2084								
4.	Licensed Thermal Power (MM	3250									
5.	Nameplate Rating (Gross Mk	le):	1220 X	0.9 = 1098							
6.	Design Electrical Rating (Net MHe):		1040							
7.	Maximum Dependable Capacit	y (Gross !	We):	1085							
8.	Maximum Dependable Capacit	y (Net Mid	»):	1040							
9.	If Changes Occur Above Sin	ce Last Re	eport, Give	Reasons:							
	NONE	<u></u>									
10.	Power Level To Which Restr	icted, If	Any (Net M	We):							
11.	Reasons for Restrictions,	If Any:									
-	NONE										
12	Percent Percind New	MONTH	YEAR	CUMULATIVE							
**	Report Period nrs	/19.0	2,903.0	125,639.0							
13.	Hours Reactor Critical	.0	_1,306.2								
	Kx Reserve Shtdwn Hrs		0	2,621.8							
15.	Hrs Generator On-Line		1,306.2	84,846.7							
16.	Unit Reserve Shtdwn Hrs	. 0	.0								
17.	Gross Therm Ener (MWH)	0	3,999,310	245,225,637							
18.	Gross Elec Ener (MWH)	0	1,362,469	78,578,098							
19.	Net Elec Ener (MWH)	-7,071	1,292,975	74,665,368							
20.	Unit Service Factor	. 0	45.0	67.5							
21.	Unit Avail Factor	. 0	45.0	67.5							
22.	Unit Cap Factor (MDC Net)		42.8	57.1							
23.	Unit Cap Factor (DER Net)	. 0	42.8	57.1							
24.	Unit Forced Outage Rate	. 0		12.7							
25.	Forced Outage Hours	. 0	12.0	11,680.2							
26.	Shetdowns Sched Over Next (NONE	6 Months (Type,Date,,	Juration):							
-	which the second day is supported by the second day.										

******	*****	*****	******	*****	****	
×		ZION 1	1		*	
******	*****	*****	(XXXXXX)	*****	*****	
AVERAGE	DAILY	POWER	LEVEL	(Mixie)	PLOT	

ZION 1



APRIL 1988

Report	Period Al	PR 19	85		UN	IТ	S H U	тD	0.	IN S	1	R	ED	U	ст	I	0 1	N S	
No.	Date	Type	Hours	Reason	Method	LER	Number	- Sy	ster	Com	pone	nt			Ca	use	8	Ć¢.	rrective Action to Prevent Recurrence
1 .	02/24/88	s	719.0	С	4								CON	TIN	UED	CY	CLI	E 1	0-11 REFUELING OUTAGE.

********* ZION 1 REMAINED SHUTDOWN IN APRIL FOR SCHEDULED REFUELING OUTAGE.

Type	Reason	Method	System & Component		
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)		

xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx	ILIT
FACILITY DESCRIPTION	UT
LOCATION STATETLLINOIS	
COUNTYLAKE	
DIST AND DIRECTION FROM NEAREST POPULATION CTR40 MI N OF CHICAGO, ILL	1
TYPE OF REACTORPWR	
DATE INITIAL CRITICALITYJUNE 19, 1973	
DATE ELEC ENER 1ST GENERJUNE 28, 1973	
DATE COMMERCIAL OPERATE DECEMBER 31, 1973	REC
CONDENSER COOLING METHODONCE THRU	
CONDENSER COOLING WATERLAKE MICHIGAN	1
ELECTRIC RELIABILITY COUNCILMID-AMERICA INTERPOOL NETWORK	1

FACILITY DATA

Report Period APR 1988

UTILIN' & CONTRACTOR INFORMATION

LICENSEE......COMMONWEALTH EDISON

CORPORATE ADDRESS......P.0. BOX 767 CHICAGO, ILLINOIS 60690

CONTRACTOR

ARCHITECT/ENGINEER.....SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR......COMMONWEALTH EDISON

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

JE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....M. HOLZMER

LICENSING PROJ MANAGER....J. NORRIS DOCKET NUMBER.....50-295

LICENSE & DATE ISSUANCE....DPR-39, OCTOBER 19, 1973

PUBLIC DOCUMENT ROOM......WAUKEGAN PUBLIC LIBRARY 128 N. COUNTY STREET WAUKEGAN, ILLINOIS 60085 INSPECTION STATUS

INSPECTI_N SUMMARY

INSPECTION ON MARCH 2-4, 1988 (88007; 88008): ROUTINE, ANNOUNCED INSPECTION by Region based inspector of the containment leak rate test (CILRT) procedure; CILRT performance witnessing; review of CILRT results; review of the Unit 2 CILRT report dated March 31, 1986; and review of licensee action on previous inspection findings. NRC modules utilized during this inspection include 70307, 70313, 70323, 90713 and 92701. No violations or deviations were identified.

INSPECTION FROM JANUARY 15 THROUGH FEBRUARY 24, 1988 (87005; 87006): ROUTINE unannounced resident inspection of licensee action on previous inspection findings, summary of operations; operational safety verification and engineered safety feature (ESF) system walkdown; surveillance observation; maintenance observation; licensee event reports (LERs); training; cold weather preparations; IE Bulletin 84-02; IEN 87-04; IEN 87-08; IEN 87-47; IEN 87-34; IEN 87-24; IEN 87-42; and site visit by Section Chief. Of the 17 areas inspected, no violations or deviations were identified.

INSPECTION CONDUCTED DURING THE PERIOD OF NOVEMBER 16, 1987 THROUGH MARCH 14, 1988 (87034; 87035): Special, announced safety inspection conducted to assess compliance with 10 CFR 50, Appendix R, and review Fire Protection Program requirements. The following inspection modules were utilized by the inspectors: 2515-62 and 64704. Of the areas inspected, four violations were identified (failure to adequa ely establish, implement and maintain procedures; failure to update and comply with technical surveillance requirements for fire walls; failure to provide adequate emergency lighting, and failure to meet a license condition to install a Fire Pump Controller).

*****	******************	******
×	ZION 1	*
*****	*****	*****

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

Nº JE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT OPERATED FOR THE ENTIRE PERIOD IN MODE 1 AT POWER LEVELS UP TO 100% POWER.

LAST IE SITE INSPECTION DATE: 04/13/88

INSPECTION REPORT NO: 88009

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
88-03	030288	033188	QUARTERLY COMPOSITE SAMPLE UNABLE TO MEET LOWER LIMIT OF DETECTION REQUIREMENTS
88-06	032588	062288	SERVICE WATER PUMP FLOWRATE BELOW REQUIRED DILUTION FLOW DURING A RADIOACTIVE LIQUID WASTE RELEASE
88-07	032688	042588	FAILURE OF HYDRAULIC STEAM GENERATOR SNUBBERS DUE TO CONTAMINATED HYDRAULIC FLUID

1.	Docket: _50-304	OPERAT	ING S	TATUS
2.	Reporting Period: 04/01/	88 Outage	+ On-line	Hrs: 719.0
3.	Utility Contact:GERRI A	USTIN (312)	746-2084	
4.	Licensed Thermal Power (M	Wt):		3250
5.	Nameplate Rating (Gross M	We):	1220 X	0.9 = 1098
6.	Design Electrical Rating	(Net MWe):		1040
7.	Maximum Dependable Capaci	ty (Gross M	1We):	1985
8.	Maximum Dependable Capaci	;):	1040	
9.	If Changes Occur Above Sin NONE	nce Last Re	eport, Give	Reasons:
10.	Power Level To Which Rest	ricted, If	Any (Net M	He):
11.	Reasons for Restric' ms,	(f Any:		
	NONE			
١	Report Period Hrs	MONTH 719.0	YEAR 2.903.0	CUMULATIVE
13.	Hours Reactor Critical	719.0	2,903.0	87,675.6
14.	R× Reserve Shtdwn Hrs		, 0	226,1
15.	Mrs Generator On-Line	719.0	2,903.0	85,267.3
16.	Jnit Reserve Shtdwn Hrs	. 0	. 0	. 0
17.	Gross Therm Ener (MWH)	2,092,971	8,776,147	253,469,914
18.	Gross Elec Ener (MWH)	702,773	2,954,369	89,296,502
19.	Net Elec Ener (MWH)	672,339	2,831,315	76,457,135
20.	Unit Service Factor	100.0	100.0	71.4
21.	Unit Avail Factor	100.0	100.0	71.4
22.	Unit Cap Factor (MDC Net)	89.9	93.8	61.6
23.	Unit Cap Factor (DER Net)	89.9	93.8	61.6
24.	Unit Forced Outage Rate		. 0	13.9
25.	Forced Outage Hours		. 0	13,795.9
24	Shuddana Cabad O	(Manhhar /	Tune Bata	Dum ation):

*****	*****	ZION 2	****** 2	*****	*****
******	*****	*****	******	******	*****
VERAGE	DAILY	POWER	LEVEL	(MWe)	PLOT
		ZION	2		



APRIL 1988

Report	Period Al	PR 198	88		UN	ΙT	S H P	тD	00	I N	s	/ F	E	D	UC	ст	I	0	N S	**************************************
No.	Date	Туре	Hours	Reason	Method	LER	Number	Sy	ster	ī	ompo	onent	=			Ca	use	8	Cor	rrective Action to Prevent Recurrence
5	04/05/88	s	0.0	В	5								RS	EDU	CEI	VA	OWE	R S.	TO S	50% FOR TESTING OF THE MAIN STEAM

Туре	Reason	Method	System & Component		
F-Forced S-Sched	A-Equip Failure F-Admin B-Maint or Test G-Oper Error C-Refueling H-Other D-Regulatory Restriction E-Operator Training & License Examination	1-Manual 2-Manual Scram 3-Auto Scram 4-Continued 5-Reduced Load 9-Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)		

FACILITY DESCRIPTION

LOCATION

STATE.....ILLINDIS

COUNTY.....LAKE

DIST AND DIRECTION FROM NEAREST POPULATION CTR...40 MI N OF CHICAGO, ILL

TYPE OF REACTOR PWR

DATE INITIAL CRITICALITY... DECEMBER 24, 1973

DATE ELEC ENER 1ST GENER...DECEMBER 26, 1973

DATE COMMERCIAL OPERATE ... SEPTEMBER 17, 1974

CONDENSER COOLING METHOD ... ONCE THRU

CONDENSER COOLING WATER....LAKE MICHIGAN

ELECTRIC RELIABILITY

COUNCIL.....MID-AMERICA INTERPOOL NETWORK

FACILITY DATA

Report Period APR 1988

UTILITY & CONTRACTOR INFORMATION

UTILITY

CORPORATE ADDRESS.P.O. BOX 767 CHICAGO, ALLINOIS 60690

CONTRACTOR

ARCHITECT/ENGINEER..... SARGENT & LUNDY

NUC STEAM SYS SUPPLIER. .. WESTINGHOUSE

TURBINE SUPPLIER......WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR M. HOLZMER

LICENSE & DATE ISSUANCE.... DPR-48, NOVEMBER 14, 1973

PUBLIC DOCUMENT ROOM......WAUKEGAN PUBLIC LIBRARY 128 N. COUNTY STREET WAUKEGAN, ILLINDIS 60085

INSPECTION SUMMARY

INSPECTION ON MARCH 2-4, 1988 ((88007; 88008(): ROUTINE, (ANNOUNCED INSPECTION by Region based inspector of the containment leak rate test (CILRT) procedure; CILRT performance witnessing; review of CILRT results; review of the Unit 2 CILRT report dated March 31, 1986; and review of licensee action on previous inspection findings. NRC modules utilized during this inspection include 70307, 70313, 70323, 90713 and 92701. No violations or deviations were identified.

INSPECTION FROM JANUARY 15 THROUGH FEBRUARY 24, 1988 (87005; 87006): ROUTINE, unannounced resident inspection of licensee action on previous inspection findings; summary of operations; operational safety verification and engineered safety feature (ESF) system walkdown; surveillance observation; maintenance observation; licensee event eports (LERs); training; cold weather preparations; IE Bulletin 84-02; IEN 87-04; IEN 87-08; IEN 87-47; IEN 87-34; IEN 87-24; IEN 87-42; and site visit by Section Chief. Of the 17 areas inspected, no violations or deviations were identified.

INSPECTION CONDUCTED DURING THE PERIOD OF NOVEMBER 16, 1987 THROUGH MARCH 14, 1988 (87034; 87035): Special, announced safety inspection conducted to assess compliance with 10 CFR 50, Appendix R, and review Fire Protection Program requirements. The identified (failure to adequately establish, implement and maintain procedures; failure to update and comply with technical surveillance requirements for fire walls; failure to provide adequate emergency lighting, and failure to meet a license condition

Report Period APR 1988

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT OPERATED AT POWER LEVELS UP TO 100% UNTIL OCTOBER 2, 1987, WHEN THE UNIT WAS SHUT DOWN TO REPAIR A PACKING LEAKS ON BOTH PRESSURIZER SPRAY VALVES. FOLLOWING OCTOBER 6, 1987. THE UNIT WAS HOLDING AT 50% POWER FOR STEAM GENERATOR CHEMISTRY AT THE END OF THE PERIOD.

LAST IE SITE INSPECTION DATE: 04/12/88

INSPECTION REPORT NO: 88010

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT									
88-04	022488	032588	FAILURE OF 2 DIESEL GENERATIKS WHILE UNIT IS IN HOT SHUTDOWN									
88-02	031288	041188	UNIT 2 STEAM GENERATOR SAFETIES INOPERABLE									



***********	×						
* PRESSURIZED	* STAT	US OF SP	ENT F	UEL STORAC	GE CAPABIL	ITY	
* MATER 9	¥						
* REACTORS	¥ (a)				REMAINING CAPACITY		
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX	A CODE STOE	PRESENT AUTH	NO DE		TE DENDINO DEGUEST		(1)
***********	A CONC SILL	CTODACE DOOL CAD	ACCEMPLIES	DEMATHTHE CADACTICY	IF FERDING REQUEST	NEXT DECUEL	UTLL ETLL PRECENT
FACTLETY	INU. OF	STURAGE FUGL CAP.	ASSEMBLIES	REMAINING CAPACITE	AFFRUVED	NEXT REFUEL	WILL FILL PRESENT
FACILITY	ASSEMBLIES)	(FUEL ASSEMBLIES)	STURED	(NU. OF ASSEMBLIES)	(NU. UF ASSEMBLIES)	SCHED, DATE	AUTH. CAPACITY
*******	*********	***********	********	*************	*************	********	***********
Latin Contract of the							
ARKANSAS 1	177	968	488	480		09-88	1997
ARKANSAS 2	177	988	289	699		02-88	1999
BEAVER VALLEY	1 157	833	284	549		12-87	1995
BEAVER VALLEY	2					N/S	
BRAIDWOOD 1	193	1050	0	1050		N/S	
BYRON 1	193	1050	0	1050		NZS	1005
BYPON 2	103	1050	0	1050		NZS	
CALLAMAY 1	107	1740	180	11/0		07-90	2005
CALVEDT CLIER	C 4 247	1340	100	1160		0.5-0.9	2005
CALVERI CLIFFS	217	1020(C)	1120(C)	692(C)		04-88	1991
CALVERT CLIFFS	5 2 217	and the second se				04-89	1991
CATAWBA 1	193	1418	132	1286		12-88	2011
CATAWBA 2	193	1418	0	1418		12-87	2013
COOK 1	193	2050(c)	866(c)	1184(c)		N/S	1994
C00K 2	193					N/S	1994
CRYSTAL RIVER	3 177	1163	328	829		09-87	1997
DAVIS-BESSE 1	177	735	206	531		03-88	1003
DIARLO CANYON	1 107	1600	204	1600		07 00	1007
DIADLO CANYON	1 195	1400	0	1400		03-00	1995
DIABLU CANTUN	2 195	1400	0.7.7	1400		N/S	1001
FARLEY 1	157	1407	213	1134		03-88	1991
FARLEY 2	157	1407	240	1167		10-87	1994
FORT CALHOUN 1	1 133	729	393	336		09-88	1996
GINNA	121	1016	420	596		02-88	1993
HADDAM NECK	157	1168	653	515		07-87	1996
HARRIS 1	157		0			N/S	
INDIAN POINT 1	1(d) 0	288	160	128		N/S	
INDIAN POINT 2	2 193	980	460	520		10-87	1003
INDIAN POINT 3	3 103	860	202	568		NZS	1003
VENALINCE	121	000	276	(16(-)		07-99	1993
MATHE VANKEE	217	990	721	014(11)		05-00	1773
MAINE TANKEE	217	1470	121	/ 55		N/S	1987
MCGUIKE 1	195	1463	293	11/0(n)		11-88	2010
MCGUIRE 2	193	1463	424	1039		05-88	2010
MILLSTONE 2	217	1277	512	765		01-88	1994
MILLSTONE 3	193	756	84	672		06-89	1996
NORTH ANNA 1	157	1737(c)	520(c)	1217		04-87	1993
NORTH ANNA 2	157					10-87	1993
DCONEE 1	177	1312(1)	874	438(1)(n)		02-89	1991
OCONFE 2	177					02-88	1991
OCONFE 3	177	875	513	362		07-88	1991
PALTSADES	206	708	677	301		N/S	2002
PALISADES	264	1720	977	1260		10-87	2002
PALO VERDE 1	241	1329	00	1249		10-67	2006
FALU VERDE 2	291	1329	0	1329		02-88	2006
PALO VERDE 3	241	1329	0	0		02-89	2007
POINT BEACH 1	121	1502(c)	875(c)	626(c)		04-88	1995
POINT BEACH 2	121					N/S	1995
PRAIRIE ISLAND	0 1 121	1586(c)	781(c)	805(c)(m)		N/S	1993
PRAIRIE ISLAND	0 2 121					01-88	1993
RANCHO SECO 1	177	1080	316	764		03-89	2001
and a start of the							

Report Period APR 1988

ile:

PAGE 3-2

-

************************ * PRESSURIZED* * WATER * * REACTORS * ***********************************	S T (a) CORE (NO. SSEMBI XXXXX	A T (SIZE OF LIES)	USOFSP PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) **********	ENT F NJ. OF ASSEMBLIES STORED ******	UEL STORA(REMAINING CAPACITY (NO. OF ASSEMBLIES) *****	GE CAPABIL REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) XXXXXXXXXXXXXXXXXXXX	I T Y NEXT REFUEL SCHED. DATE ********	(b) WILL FILL PRESENT AUTH. CAPACITY ******
				074	2444-2	\$70	NZS	1988(0)
ROBINSON 2		157	541	279	200(e)	3/9	03-80	2001
SALEM 1		193	1170	464	706		00-88	2003
SALEM 2		193	1170	224	946		07-00	1028
SAN ONOFRE 1		157	216	146	70		07-00	1007
SAN ONOFRE 2		217	800	268	532		08-89	1997
SAN ONOFRE 3		217	800	160	640		04-88	1997
SEQUOYAH 1		193	1386	348	1033		N/S	1994
SEQUOYAH 2		193					N/S	1994
SOUTH TEXAS 1		0	0	0	0			
ST LUCIE 1		217	728	372	356		N/S	1993
ST LUCIE 2		217	1076	152	924		N/S	1993
SUMMER 1		157	1276	96	1180		N/S	2008
SUPPY 1		157	104((c)	901(c)	143(c)		N/S	1987
SURAL 2		157					N/S	1987
THREE MILE TSLA	ND 1	177	752	284	468		07-88	1991
THDEE MILE ISLA	ND 2	177	442	0	442		N/S	
TDO IAN	in c	103	1608	425	983		04-88	1993
TUDKEY DOTNE T		157	1606	665	959(m)		N/S	1993
TURKET FUIRT 5		157	1606	482	922		N/S	1993
TURKET FUINT 4		1.57	1404	0	0		N/S	
VUGILE I		217	1088	0	1088		N/S	1993
MATEKFURD S		107	1360	0	1340		04-83	
NULF CREEK I		74	724	325	396		N/S	1993
TANKEE-RUWE 1		10	2112(0)	1168603	966(c)		02-88	1995
ZION 1 ZION 2		193	2112(0)	1146(C)	204(6)		10-88	1995

INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(h)

MORRIS OPERATIONS	750 MTU(j) 315	385 MTU(j)	1490 MTU(j)
NES(i)	250 MTU 170 MTU	80 MTU	

(a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a BWR core is off-loaded.

(b) Some of these dates have been adjusted by staff assumptions.

(c) This is the total for both units.

(d) Plant not in commercial operation.

(e) Some spent fuel stored at Brunswick.

(f) Authorized a total 2772 BWR and 1232 PWRassamblies for both pools.

(g) Robinson 2 assemblies being shipped to Brunswick for storage.
(h) Capacity is in metric tons of uranium; 1 MTU = 2 PWR assemblies or 5 BWR assemblies.

(i) No longer accepting spent fuel.

(j) Racked for 700 MTU.

(k) Reserved.

5

8

(1) This is the station total.

(m) Installed capacity is less than that authorized.

(n) McGuire 1 authorized to accept Oconee fuel assemblies.

Report Period APR 1988

N/S = Not Scheduled

PAGE 3-3

**	**	**	**	**	**	**

* BOILING *	STATU	US OF SPI	ENT FU	UEL STORAG	E CAPABIL	ITY	
* WAIEK *	1.3				DEMAINING CADACITY		
* REACTORS *	CORE SIZE	PRESENT AUTH. STORAGE POOL CAP.	NO. OF ASSEMBLIES	REMAINING CAPACITY	IF PENDING REQUEST APPROVED	NEXT REFUEL	(b) WILL FILL PRESENT
FACILITY	ASSEMBLIES)	(FUEL ASSEMBLIES)	STORED	(NO. OF ASSEMBLIES)	(NO. OF ASSEMBLIES)	SCHED. DATE	AUTH. CAPACITY
*******	********	***********	********	***********	******	********	*************
BIG ROCK POINT	1 84	441	212	229		04-88	1995
BROWNS FERRY 1	764	3471	1288	2183		N/S	1993
BROWNS FERRY 2	764	3471	1161	2310(m)	1819	N/S	1993
BROWNS FERRY 3	764	3471	1004	2467(m)		N/S	1993
BRUNSWICK 1	560	1803	160PWR+11	016BWR 787		11-88	1990
BRUMSWICK 2	560	1839	144PWR+94	40BWR 899		01-88	1991
CLINTON 1	624	2672	0	2672		12-89	2010
COOPER STATION	548	2366	790	1576		03-88	1996
DRESDEN 1 (d)	464	672	221	451		N/S	1990
DRESDEN 2	7.24	3537	1413	2124		N/S	1993
DRESDEN 3	724	3537	1271	2266		03-88	1993
DUANE ARNOLD FERMI Z	368	2050	824	1226		10-88 N/S	1998
FITZPATRICK	560	2244	1200	484		08-88	1992
GRAND GULF 1	800	1440	0	1440		11-87	1993
HATCH 1	560	6026	1580	4446		N/S	1999
HATCH 2	560			1325		03-88	1999
HOPE CREEK 1						02-88	
HUMBOLDT BAY(d) 172	487	251	236		N/S	
LA CROSSE (d)	72	440	261	179		N/S	1992
LASALLE 1	764	2162	191	1971		03-88	1928
LASALLE 2	764					N/S	1988
LIMERICK 1	764	2040	0	2040		N/S	1993
MILLSTONE 1	580	2184	1732	452		03-89	1987

....

.

0

赛美美美美美美美美美美美美美																																
* BOILING * * WATER *	S	TA	ΤU	S	0 F	SP	EN	T	1	FU	E	L	S	TI	OR	A	GE	E	1	CA	P	AI	3 I	L	II	Y						
* REACTORS *	(.	a)															F	REM	IAI	NIN	GC	CAPI	/CI	ΓY								
*********	CORE	SIZ	E	PRES	ENT A	UTH.		NO	. OF		in las		1				1	IFI	PE	NDI	NG	RE	UE:	ST						(b)		
	(NO	. OF		STORAG	E POO	L CAP	. A:	SSE	MBLI	ES	REM	AIN	ING	CAI	PAC	ITY			1	APP	ROV	ED			NEX	11	LEFUI	EL	WILL F	ILL P	RESE	NI
FACILITY A	SSEM	BLIE	S)	(FUEL	ASSEM	BLIES)	ST	ORED	(NO.	OF	AS	SEM	BLI	ES)	CN	.CN	0	FA	SSE	MBI	.IE:	\$2	SCH	ED.	DA	TE	AUTH	. CAP	ACII	Y
*******	****	****	×	****	*****	****	×	(XX	****	¥Ж	***	***	***	***	***	××		кжж	EXX:	×××	<u>ж</u> жэ	(**)	(* *)	×.	***	**)	EXXXI	**	*****	*****	****	**
MONTICELLO		48	4		2237			82	2					141	5											12.	-87		1	999		
NINE MILE POINT	1	53	2		2776		1	137	7					139	9					17	88					03-	-88		1	996		
NINE MILE POINT	2		÷		~																					N	S					
DYSTER CREEK 1	-	56	0		2600		1	39	2					120	8											N	'S		1	994		
PEACH BOTTOM 2		76	4		3819			46	2					235	7											03-	-87		1	995		
PEACH BOITOM 3		76	4		3819		1	49	6					232	3											03	-87		1	996		
PERRY 1			0		0				0						0											N	15					
PILGRIM 1		58	0		2320		1	132	0					100	0											09.	-89		1	990		
QUAD CITIES 1		72	4		3657		1	177	3					188	4											06.	-89		2	800		
QUAD CITIES 2		72	4		3897		1	131	1					258	6											04	-88		2	800		
RIVER BEND 1																										09-	-87					
SUSQUEHANNA 1		76	4		2840			38	2					245	8											N	15		1	997		
SUSQUEHANNA 2		76	6		2840				0					284	0											03	-88		1	997		
VERMONT YANKEE	1	36	8		2000			129	6					70	4											N	'S		1	992		
WASHINGTON NUCL	EAR×	76	4		2658			27	2					238	6											04	-88		1	995		

INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(h)

MORRIS OPERATIONS	750 MTU(j)) 315	385 MTU(j)	1490 MTU(j)
NES(1)	250 MTU	170 MTU	80 MTU	

(a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a PWR core is off-loaded.

(b) Some of these dates have been adjusted by staff assumptions.

(c) This is the total for both units.

(d) Plant not in commercial operation.

(e) Some spent fuel stored at Brunswick.
(f) Authorized a total 2772 BWR and 1232 PWRassemblies for both prols.

(g) Robinson 2 assemblies being shipped to Brunswick for storage.
(h) Capacity is in metric tons of uranium; 1 MTU = 2 PWR assemblies or 5 BWR assemblies.

(i) No longer accepting spent fuel.(j) Racked for 700 MIU.

(k) Reserved.

(1) This is the station total.

(m) Installed capacity is less than that authorized.

(n) McGuire 1 authorized to accept Oconee fuel assemblies.

Report Period APR 1988

N/S = Not Scheduled

PAGE 3-5

(INCLUDES BOTH LICENSED REACTOR YEARS OF EXPERIENCE AND NON-LICENSED UNITS)

.

	YEARS	1ST ELEC GENERATE	UNIT	YEARS	1ST ELEC GENERATE	UNIT	YEARS	IST ELEC GENERATE	UNIT
XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX	13 75	08/01/74	ARKANSAS 1	9.35	12/26/78	ARKANSAS 2	11.88	06/14/76	BEAVER VALLEY 1
* OPERATING *	71	08/17/87	BEAVER VALLEY 2	25.40	12/08/62	BIG ROCK POINT	1 .80	07/12/87	BRAIDWOOD 1
* FLECTRICAL *	14.54	10/15/73	BROWNS FERRY 1	13.68	08/28/74	BROWNS FERRY 2	11.63	09/12/76	BROWNS FERRY 3
* PRODUCING *	11 41	12/04/76	BRUNSWICK 1	13.01	04/29/75	BRUNSWICK 2	3.17	03/01/85	BYRON 1
* UNITS *	1 23	02/06/87	BYRON 2	3.52	10/24/84	CALLAWAY 1	13.33	01/03/75	CALVERT CLIFFS 1
*****	11 40	12/07/76	CALVERT CLIFFS 2	3.27	01/22/85	САТАНВА 1	1.95	05/18/86	CATAWBA 2
	1 02	04/24/87	CLINTON 1	13.22	02/10/75	C00K 1	10.11	03/22/78	COOK 2
	13.98	05/10/74	COOPER STATION	11.25	01/30/77	CRYSTAL RIVER 3	10.67	08/28/77	DAVIS-BESSE 1
	3.47	11/11/84	DIABLO CANYON 1	2.53	10/20/85	DIABLO CANYON 2	18.05	04/13/70	DRESDEN 2
	16.78	87/22/71	DRESDEN 3	13.95	05/19/74	DUANE ARNOLD	10.70	08/18/77	FARLEY 1
	6.93	05/25/81	FARLEY 2	1.61	09/21/86	FERMI 2	13.25	02/01/75	FITZPATRICK
	14.68	08/25/73	FORT CALHOUN 1	11.39	12/11/76	FORT ST VRAIN	18.41	12/02/69	GINNA
	3.53	10/20/84	GRAND GULF 1	20.73	08/07/67	HADDAM NECK	1.28	01/19/87	HARRIS 1
	13.47	11/11/74	HATCH 1	9.61	09/22/78	HATCH 2	1.75	08/01/86	HOPE CREEK 1
	14.85	06/26/73	INDIAN POINT 2	12.01	04/27/76	INDIAN POINT 3	14.06	04/08/74	KEWAUNEE
	5.66	09/04/82	LASALLE 1	4.03	04/20/84	LASALLE 2	3.05	04/13/85	LIMERICK 1
	15.48	11/08/72	MAINE YANKEE	6.84	06/30/81	MCGUIRE 1	4.94	05/23/83	MCGUIRE 2
	17.42	11/29/70	MILLSTONE 1	12.48	11/09/75	MILLSTONE 2	2.21	02/12/86	MILLSTONE 3
	17.16	03/05/71	MONTICELLO	18.48	11/09/69	NINE MILE POINT	1 .73	08/08/87	NINE MILE POINT 2
	10.04	04/17/78	NORTH ANNA 1	7.68	08/25/80	NORTH ANNA 2	14.99	05/06/73	OCONEE 1
	14.40	12/05/73	OCONEE 2	13.66	09/01/74	OCONEE 3	18.60	09/23/69	OYSTER CREEK 1
	16.33	12/31/71	PALISADES	2.89	06/10/85	PALO VERDE 1	1.95	05/20/86	PALO VERDE 2
	.42	11/28/87	PALO VERDE 3	14.20	02/18/74	PEACH BOTTOM 2	13.66	09/01/74	PEACH BOTTOM 3
	1.37	12/19/86	PERRY 1	15.78	07/19/72	PILGRIM 1	17.48	11/06/70	POINT BEACH 1
	15.75	08/02/72	POINT BEACH 2	14.41	12/04/73	PRAIRIE ISLAND	1 13.36	12/21/74	PRAIRIE ISLAND 2
	16.05	04/12/72	QUAD CITIES 1	15.94	05/23/72	QUAD CITIES 2	13.55	10/13/74	RANCHO SECO 1
	2.41	12/03/85	RIVER BEND 1	17.60	09/26/70	ROBINSON 2	11.35	12/25/76	SALEM 1
	6.91	06/03/81	SALEM 2	20.79	07/16/67	SAN ONOFRE 1	5.61	09/20/82	SAN ONOFRE 2
	4.60	09/25/83	SAN ONOFRE 3	7.78	07/22/80	SEQUOYAH 1	6.35	12/23/81	SEQUOYAH 2
	.09	03/30/88	SOUTH TEXAS 1	11.98	05/07/76	ST LUCIE 1	4.88	06/13/83	ST LUCIE 2
	5.46	11/16/82	SUMMER 1	15.82	07/04/72	SURRY 1	15.14	03/10/73	SURRY 2
	5.46	11/16/82	SUSQUEHANNA 1	3.83	07/03/84	SUSQUEHANNA 2	13.87	06/19/74	THREE MILE ISLAND 1
	12.36	12/23/75	TROJAN	15.49	11/02/72	TURKEY POINT 3	14.86	06/21/73	TURKEY POINT 4
	15.61	09/20/72	VERMONT YANKEE 1	1.10	03/27/87	VOGTLE 1	3.93	05/27/84	WASHINGTON NUCLEAR 2
	3.12	03/18/85	WATERFORD 3	2.89	06/12/85	WGLF CREEK 1	27.47	11/10/60	YANKEE-ROWE 1
	14.84	06/28/73	ZION 1	14.35	12/26/73	ZION 2			
TOTAL 1094.26 Y	RS								

	YEARS	1ST ELEC GENERATE	SHUTDOWN	UNIT	YEARS	1ST ELEC GENERATE	SHUTDOWN DATE	UNIT	
******				The set of the set				100 H 1 100 H	
* PERMANENTLY *	3 80	08/14/64	06/01/68	BONUS	3.04	12/18/63	01/01/67	CVTR	
× np ¥	18 56	04/15/60	10/31/78	DRESDEN 1	4.44	08/24/63	02/01/68	ELK RIVER	
X UN X	10.34	09/05/66	11/20/72	CEDMI 1	1 26	05/29/63	09/01/64	HALLAM	
* INDEPINITELT*	0.32	00/00/00	11/27/16	FERMI I	12 12	00/16/62	10/31/74	INDIAN POINT	1
* SHUTDOWN *	13.21	04/18/63	0//02/16	HUMBULDI DAT	12.12	07/25/66	10/01/67	PATHEINDER	1
* UNITS *	19.01	04/26/68	04/30/87	LA CROSSE	1.19	01/25/00	10/01/07	PATHFINDER	
************	7.76	01/27/67	11/01/74	PEACH BOTTOM 1	2.16	11/04/65	01/01/66	PIQUA	
	.93	04/21/78	03/28/79	THREE MILE ISLAND 2					
TOTAL 93.78 YI	RS								

* RESEARCH * REACTORS * *****

NON-POWER REACTORS IN THE U.S.

******					LICENSE	DATE OL	AUTHORIZED
STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	NUMBER	ISSUED	LEVEL (KW)
ALABAMA	TUSKEGEE	TUSKEGEE INSTITUTE	AGN-201 #102	50-406	R-122	08-30-74	0.0001
ARIZONA	TUCSON	UNIVERSITY OF ARIZONA	TRIGA MARK I	50-113	R-52	12-05-58	100.0
CALIFORNIA	BERKELEY CANOGA PARK HAWTHORNE IRVINE LOS ANGELES SAN DIEGO SAN DIEGO SAN JOSE SAN LUIS OBISPO SAN RAMON SANTA BARBARA	UNIVERSITY OF CALIFORNIA, BERKELEY COLLEGE ROCKWELL INTERNATIONAL CORP. NORTHROP CORP. LABORATORIES UNIVERSITY OF CALIFORNIA, IRVINE UNIVERSITY OF CALIFORNIA, L.A. GENERAL ATOMIC COMPANY GENERAL ATOMIC COMPANY GENERAL ELECTRIC COMPANY CALIFORNIA STATE POLYTECHNIC COLLEGE AEROTEST OPERATIONS, INC. UNIVERSITY OF CALIFORNIA, SANTA BARBARA	TRIGA MK. III L-85 TRIGA MARK F TRIGA MARK I ARGONAUT TRIGA MARK F TRIGA MARK F TRIGA MARK I NTR AGN-201 #100 TRIGA (INDUS) L-77	50-224 50-375 50-187 50-326 50-142 50-163 50-089 50-073 50-394 50-228 50-433	R-101 R-188 R-90 R-116 R-71 R-67 R-38 R-33 R-121 R-98 R-124	$\begin{array}{c} 08-10-66\\ 01-05-72\\ 03-04-63\\ 11-24-69\\ 10-03-60\\ 07-01-60\\ 05-03-58\\ 10-31-57\\ 05-16-73\\ 07-02-65\\ 12-93-74 \end{array}$	$\begin{array}{c} 1000.0\\ 0.003\\ 1000.0\\ 250.0\\ 100.0\\ 250.0\\ 250.0\\ 100.0\\ 0.0001\\ 250.0\\ 0.01 \end{array}$
COLORADO	DENVER	U.S. GEOLOGICAL SURVEY DEPARTMENT	TRIGA MARK I	50-274	R-113	02-24-69	1000.0
DELAWARE	NEWARK	UNIVERSITY OF DELAWARE	AGN-201 #113	50-098	R-43	07-03-58	0.0001
DIST OF COLUMBIA	WASHINGTON	THE CATHOLIC UNIVERSITY OF AMERICA	AGN-201 #101	50-077	R-31	11-15-67	0.0001
FLORIDA	GAINESVILLE	UNIVERSITY OF FLORIDA	ARGONAUT	50-083	R-56	05-21-59	100.0
GEORGIA	ATLANTA	GEORGIA INSTITUTE OF TECHNOLOGY	HEAVY WATER	50-160	R-97	12-29-64	5000.0
IDAHO	POCATELLO	IDAHO STATE UNIVERSITY	AGN-201 #103	50-284	R-110	10-11-67	0.0001
ILLINOIS	URBANA URBANA ZION	UNIVERSITY OF ILLINOIS UNIVERSITY OF ILLINOIS WESTINGHOUSE ELECTRIC CORP.	LOPRA TRIGA NTR	50-356 50-151 50-087	R-117 R-115 R-119	12-27-71 07-22-69 01-28-72	10.0 1500.0 10.0
INDIANA	LAFAYETTE	PURDUE UNIVERSITY	LOCKHEED	50-182	R-87	08-16-62	10.0
IONA	AMES	IOWA STATE UNIVERSITY	UTR-10	50-116	R-59	10-16-59	10.0
KANSAS	LAWRENCE MANHATTAN	UNIVERSITY OF KANSAS KANSAS STATE UNIVERSITY	LOCKHEED TRIGA	50-148 50-188	R-78 R-88	06-23-61 10-16-62	250.0 250.0
MARYLAND	BETHESDA COLLEGE PARK	ARMED FORCES RADIOBIOLOGY RESEARCH INSTITUTE UNIVERSITY OF MARYLAND	TRIGA TRIGA	50-170 50-166	R-84 R-70	06-26-62 10-14-60	1000.0 250.0
MASSACHUSETTS	CAMBRIDGE	MASSACHUSETTS INSTITUTE OF TECHNOLOGY	HWR REFLECTED	50-020	R-37	06-09-58	5000.0

*********** * RESEARCH * * REACTORS * *****

.

0

NON-POWER REACTORS IN THE U.S.

*********					LICENSE	DATE 01	AUTHORIZED
STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	NUMBER	ISSUED	LEVEL (KW)
MASSACHUSETTS	LOWELL WORCESTER	UNIVERSITY OF LOWELL WORCESTER POLYTECHNIC INSTITUTE	GE GE	50-223 50-134	R-125 R-61	12-24-74 12-16-59	1000.0
MICHIGAN	ANN ARBOR EAST LANSING MIDLAND	UNIVERSITY OF MICHIGAN MICHIGAN STATE UNIVERSITY DOW CHEMICAL COMPANY	POOL TRIGA MARK I TRIGA	50-002 50-294 50-264	R-28 R-114 R-108	09-13-57 03-21-69 07-03-67	2000.0 250.0 100.0
MISSOURI	COLUMBIA ROLLA	UNIVERSITY OF MISSOURI, COLUMBIA UNIVERSITY OF MISSOURI	TANK POOL	50-186 50-123	R-103 R-79	10-11-66 11-21-61	10000.0 200.0
NEBRASKA	OMAHA	THE VETERANS ADMINISTRATION HOSPITAL	TRIGA	50-131	R~57	06-26-59	18.0
NEW MEXICO	ALBUQUERQUE	UNIVERSITY OF NEW MEXICO	AGN-201M #112	50-252	R-102	09-17-66	0.005
NEW YORK	BRONX BUFFALO ITHACA ITHACA NEW YORK TUXEDO	MANHATTAN COLLEGE - PYHSICS DEPT. STATE UNIVERSITY OF NEW YORK CORNELL UNIVERSITY CORNELL UNIVERSITY COLUMBIA UNIVERSITY IN THE CITY OF NEW YORK CINTICHEM INC.	TANK PULSTAR TRIGA MARK II ZPR TRIGA MARK II POOL	50-199 50-057 50-157 50-097 50-208 50-054	R-94 R-77 R-80 R-89 R-128 R-81	$\begin{array}{c} 03-24-64\\ 03-24-61\\ 01-11-62\\ 12-11-62\\ 04-14-77\\ 09-07-61 \end{array}$	0.0001 .000.0 100.0 0.1 250.0 5000.0
NORTH CAROLINA	RALEIGH	NORTH CAROLINA STATE UNIVERSITY AT RALEIGH	PULSTAR	50-297	R-120	08-25-72	1000.0
0110	COLUMBUS	OHIO STATE UNIVERSITY	POOL	50-150	R-75	02-24-61	10.0
OKLAHOMA	NORMAN	THE UNIVERSITY OF OKLAHOMA	AGN-211 #102	50-112	R-53	12-29-58	0.015
OREGON	CORVALLIS	OREGON STATE UNIVERSITY REED COLLEGE	TRIGA MARK II TRIGA MARK I	50-243 50-288	R-106 R-112	03-07-67 07-02-68	1000.0 250.0
PENNSYLVANIA	UNIVERSITY PARK	PENNSYLVANIA STATE UNIVERSITY	TRIGA MK. III	50-005	R-2	07-08-55	1000.0
RHODE ISLAND	NARRAGANSETT	RHODE ISLAND NUCLEAR SCIENCE CENTER	GE POOL	50-193	R-95	07-21-64	2000.0
TENNESSEE	MEMPHIS	MEMPHIS STATE UNIVERSITY	AGN-201 #108	50-538	R-127	12-10-76	0.0001
TEXAS	AUSTIN COLLEGE STATION COLLEGE STATION	UNIVERSITY OF TEXAS TEXAS A&M UNIVERSITY TEXAS A&M UNIVERSITY	TRIGA MARK I AGN-201M #106 TRIGA	50-192 50-059 50-128	R-92 R-23 R-83	08-26-63 08-26-57 12-07-61	250.0 0.005 1000.0
UTAH	PROVO SALT LAKE CITY	BRIGHAM YOUNG UNIVERSITY THE UNIVERSITY OF UTAH	L-77 TRIGA MARK I	50-262 50-407	R-109 R-126	09-07-67 09-30-75	0.01

PAGE 3-8

4

************ * RESEARCH * * REACTORS * *******

.

NON-POWER REACTORS IN THE U.S.

۰.

STATE	CITY		REACTOR TYPE	DOCKET	LICFNSE NUMBER	DATE OL ISSUED	POWER LEVEL (KW)
UTAH	SALT LAKE CITY	UNIVERSITY OF UTAH	AGN-201M #107	50-072	R-25	09-12-57	0.005
VIRGINIA	BLACKSBURG CHARLOTTESVILLE CHARLOTTESVILLE LYNCHBURG	VIRGINIA POLYTECHNIC INSTITUTE UNIVERSITY OF VIRGINIA UNIVERSITY OF VIRGINIA BABCOCK & WILCOX COMPANY	UTR-10 CAVALIER POOL LPR	50-124 50-396 50-062 50-099	R-62 R-123 R-66 R-47	12-18-59 09-24-74 06-27-60 09-05-58	100.0 0.1 2000.0 1000.0
WASHINGTON	PULLMAN SEATTLE	WASHINGTON STATE UNIVERSITY UNIVERSITY OF WASHINGTON	TRIGA ARGONAUT	50-027 50-139	R-76 R-73	03-06-61 03-31-61	1000.0 100.0
WISCONSIN	MADISON	UNIVERSITY OF WISCONSIN	TRIGA	50-156	R-74	11-23-60	1000.0
**************************************	xxxxxxxxxxxxxxxxxx ID TEST REACTORS * xxxxxxxxxxxxxxxxxx						
CALIFORNIA	SAN JOSE	GENERAL ELECTRIC COMPANY	GETR	50-070	TR-1	01-07-59	50.0
DIST OF COLUMBIA	WASHINGTON	NATIONAL BUREAU OF STANDARDS	TEST	50-184	TR-5	06-30-70	10.0
**************** * CRITICAL EXPERI	**************** MENT FACILITIES * ******						
NEW YORK	TROY	REWSSELAER POLSTECHNIC INSTITUTE		50-22.	CX-22	07-03-64	0.0
WASHINGTON	RICHLAND	BATTELLE MEMORIAL INSTITUTE		50-360	CX-26	11-29-71	0.0

PAGE 3-9

NRC FORM 336 U.S. NUCLEAR REGULATORY COMMISSION	I REPORT NUN TER AMIN	aned by TIDC add Vol No , I any)
BIBLIOGRAPHIC DATA SHEET	NUREG-0020,	Volume 12, No. 5
SEE INSTRUCTIONS ON THE RELATE		
2 TITLE AND SUBTITLE	J LEAVE BLANK	/
Licensed Operating Reactors	12 W. L. L. L. A	1
Status Summary Report	4 DATE	REPORT COMPLETED
	MONTH	YEAR
5 AUTHORISI	June	1988
Instruments	6 DA	TE REPORT ISSUED
Indeconwartz	June	1988
PERFORMING ORGANIZATION NAME AND WAICHG ADDRESS TIRCUP Zo Coord Division of Computer and Telecommunications Services/IRM Office of Administration and Resources Management U. S. Nuclear Regulatory Commission Washington, D. C. 20555	E PROFECTITASKIWORK	UNIT NUMEER
Division of Computer and Telecommunication Services/IRM	ELA TYPE OF REPORT	
Office of Administration and Resources Management		and dates
U. S. Nuclear Regulatory Commission	5 PERIOD COVERED Incl	urive datesi
Washington, D. C. 20555	April	1988
12 SUPPLEMENTARY NOTES Status Summary Report		
The OPERATING UNITS STATUS REPORT - LICEASED OPERATING Re- on the operation of nuclear units as timely and accurated information is collected by the Office of Administration Management from the Headquarters staff of NRC's Office of from NRC's Regional Offices, and from utilities. The thr report are: monthly highlights and statistics for commer and errata from previously reported data; a compilation of on each unit, provided by NRC's Regional Offices, OE Head utilities; and an appendix for miscellaneous information storage capability, reactor-years of experience and non-p U. S. It is hoped the report is helpful to all agencies interested in maintaining an awareness of the U. S. energy	ACTORS provide y as possible and Resources Enforcement ree sections of cial operating of detailed in quarters and such as spent ower reactors and individually situation as	es data . This (OE), f the g units, formation the fuel in the als s a whole.
Licensed Operating Peactors Commercial Operating Units		15 AVAILABILITY STATEMENT 16 SECURITY CLASSIFICATION (This pege)
	1	(This report)
	1	17 NUMBER OF PAGES
	1	18 PRICE
	and the second sec	and the second sec

DISTRIBUTION LIST - NRC

INTERNAL DISTRIBUTION

Office of the Commissioners	2
Atomic Safety and Licensing Appeal Panel	3
Advisory Committee on Reactor Safeguards	0
Office of Inspector and Auditor	1
Office of Policy Evaluation	1
Office of the General Counsel	1
Office of Public Affairs	21
Office of Congressional Affairs	3
Office of the Executive Director for Operations	1
Office of Administration	2
Office of the Executive Legal Director	2
Office of Analysis and Evaluation of Operational Data	2
Office of International Programs	3
Office of State Programs	1
Office of Information Resources Management	19
Office of Nuclear Material Safety and Safeguards	2
- Division of Fuel Cycle and Material Safety	3
- Division of Safequards	2
Office of Nuclear Reactor Regulation	138
- Division of Engineering	
Division of Safety Jechnology	
- Division of Licensing	
- Division of Systems Integration	
- Division of Human Factors Safety	
Office of Nuclear Reculatory Research	4
office of hocidation and Enforcement	7
preice of inspection and children and	11
	10
- Region II	10
- Region IV	10
- Region V	7
- Kegion V	281

EXTERNAL DISTRIBUTION

SPECIAL REQUESTS

ir Force	
ongress	
lepartment of Energy	
overnment Accounting Office	
nvironmental Protection Agency	
lectric Power Research Institute	
coope National Laboratory	
Minor	
ureau of mnes	
epartment of Agriculture	
pepartment of the Commerce	
Department of the Interior	
apper constraints and	

1 53

OTHER

GPO Depository	440
GPO Stores National Technical Information Service	25
Subscriptions (NTIS) Colleges and Libraries (including Public Document Rooms)	128
Itilities and Other Requests	1145

UNITED STATES NUCLEAR REGULATORY COMMISSION

 OFFICIAL BUSINESS
 120555078877
 1 1AN1NU

 OFFICIAL BUSINESS
 120555078877
 1 1AN1NU

 OFFICIAL BUSINESS
 DIV OF PUB SVCS

 PENALTY FOR PRIVATE USE, \$300
 POLICY & PUB MGT BR-PDR NUREG

 WASHINGTON
 DC 20555

00 20555

FIRST CLASS MAIL POSTAGE & FEES PAID USNRC PERMIT No. G-67

PENALTY FOR PRIVATE USE, \$300

