

Docket No. 50-423

Attachment 1

Proposed Revision to Technical Specifications
Steam Generator Low Low Level Reactor Trip Setpoint

June, 1988

8806230275 880615
PDR ADOCK 05000269
P DCD

TABLE 3.3-4 (Continued)

ENGINEERING SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIPS SETPOINTS

<u>FUNCTIONAL UNIT</u>		<u>TOTAL ALLOWANCE (TA) Z</u>		<u>SENSOR ERROR (S)</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
5.	Turbine Trip and Feedwater Isolation					
a.	Automatic Actuation Logic Actuation Relays	N.A.	N.A.	N.A.	N.A.	N.A.
b.	Steam Generator Water Level--High-High (P-14)	3.7	2.33	1.75	$\leq 82.0\%$ of narrow range instrument span.	$\leq 82.8\%$ of narrow range instrument span.
c.	Safety Injection Actuation Logic	See Item 1. above for all Safety Injection Trip Setpoints and Allowable Valves.				
d.	Low Coincident with Reactor Trip (P-4)					
	1) Four Loops Operating	N.A.	N.A.	N.A.	$\geq 564^{\circ}\text{F}$	$\geq 560.6^{\circ}\text{F}$
	2) Three Loops Operating	N.A.	N.A.	N.A.	$\geq 564^{\circ}\text{F}$	$\geq 560.6^{\circ}\text{F}$
6.	Auxiliary Feedwater					
a.	Manual Initiation	N.A.	N.A.	N.A.	N.A.	N.A.
b.	Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	N.A.
c.	Steam Generator Water Level--Low-Low					
	1) Start Motor-Driven Pumps	18.10	16.64	1.50	$\geq 18.10\%$ of narrow range instrument span.	$\geq 17.11\%$ of narrow range instrument span.

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

FUNCTIONAL UNIT	TOTAL ALLOWANCE (TA) Z	SENSOR ERROR (S)		TRIP SETPOINT	ALLOWABLE VALUE
6. Auxiliary Feedwater (Continued)					
2) Start Turbine-Driven Pumps	18.10	16.64	1.50	$\geq 18.10\%$ of narrow range instrument span.	$\geq 17.11\%$ of narrow range instrument span.
d. Safety Injection	See Item 1. above for all Safety Injection Trip Setpoints and Allowable Values.				
e. Loss-of-Offsite Power Start Motor-Driven Pumps	N.A.	N.A.	N.A.	$\geq 2800V$	$\geq 2720V$
f. Containment Depressurization Actuation (CDA) Start Motor-Driven Pumps	See Item 2. above for all CDA Trip Setpoints and Allowable Values.				
7. Control Building Isolation					
a. Manual Actuation	N.A.	N.A.	N.A.	N.A.	N.A.
b. Manual Safety Injection Actuation	N.A.	N.A.	N.A.	N.A.	N.A.
c. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	N.A.
d. Containment Pressure--High 1	3.3	1.01	1.75	≤ 3.0 psig	≤ 3.8 psig
e. Control Building Inlet Ventilation Radiation	N.A.	N.A.	N.A.	$\leq 1.5 \times 10^{-5}$ μ c/cc	$\leq 1.5 \times 10^{-5}$ μ c/cc

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

FUNCTIONAL UNIT	TOTAL ALLOWANCE (TA)	Z	SENSOR ERROR (S)	TRIP SETPOINT	ALLOWABLE VALUE
9. Pressurizer Pressure-Low	5.0	1.77	3.3	≥ 1900 psia	≥ 1890 psia
10. Pressurizer Pressure-High	5.0	1.77	3.3	≤ 2385 psia	≤ 2395 psia
11. Pressurizer Water Level-High	8.0	5.13	2.7	$\leq 89\%$ of instrument span	$\leq 90.7\%$ of instrument span
12. Reactor Coolant Flow-Low	2.5	1.52	0.78	$\geq 90\%$ of loop design flow*	$\geq 89.1\%$ of loop design flow*
13. Steam Generator Water Level Low-Low	18.10	16.64	1.50	$\geq 18.10\%$ of narrow range instrument span	$\geq 17.11\%$ of narrow range instrument span
14. General Warning Alarm	N.A.	N.A.	N.A.	N.A.	N.A.
15. Low Shaft Speed - Reactor Coolant Pumps	3.8	0.5	0	$\geq 97.8\%$ of rated speed	$\geq 94.6\%$ of rated speed
16. Turbine Trip					
a. Low Fluid Oil Pressure	N.A.	N.A.	N.A.	≥ 500 psig	≥ 450 psig
b. Turbine Stop Valve Closure	N.A.	N.A.	N.A.	$\geq 1\%$ open	$\geq 1\%$ open
17. Safety Injection Input from ESF	N.A.	N.A.	N.A.	N.A.	N.A.

 **RTP = RATED THERMAL POWER