



Point Beach Nuclear Plant
6610 Nuclear Rd., Two Rivers, WI 54241

(920) 755-2321

NPL 98-0959

November 12, 1998

Document Control Desk
U.S. NUCLEAR REGULATORY COMMISSION
Mail Station P1-137
Washington, D.C. 20555

10 CFR 50.73

Ladies/Gentlemen:

DOCKETS 50-266 AND 50-301
LICENSEE EVENT REPORT 1998-027-00
INADEQUATE TECHNICAL SPECIFICATION SURVEILLANCE
TESTING OF NON-ESSENTIAL SERVICE WATER ISOLATION LOGIC
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

Enclosed is Licensee Event Report 1998-027-00 for Point Beach Nuclear Plant, Units 1 and 2. This report is provided in accordance with 10 CFR 50.73(a)(2)(i)(B), as "Any operation or condition prohibited by the plant's Technical Specifications." This report describes the discovery of a deficiency in the surveillance testing of the logic matrix for isolation of non-essential service water system heat loads and the discovery that the overlap between the auxiliary contacts on the service water pump breakers that provide the input to this service water isolation matrix were not being adequately verified.

New commitments within this report are indicated in italics.

Please contact us if you require additional information.

Sincerely,

A handwritten signature in cursive script, appearing to read 'Vito A. Kaminskas'.

Vito A. Kaminskas
Manager,
Regulatory Services & Licensing

Enclosure

CWK/tja

9811180224 981112
PDR ADOCK 05000266
S PDR

cc: NRC Resident Inspector
NRC Regional Administrator
PSCW
INPO Support Services

A subsidiary of Wisconsin Energy Corporation

1/1
IE 22