



May 30, 1986

Public Service of New Hampshire

SBN- 1078

T.F. B4.2.7

NEW HAMPSHIRE YANKEE DIVISION

United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

Attention: Mr. Edward C. Wenzinger, Chief Projects Branch 3
Division of Reactor Projects

References: (a) Construction Permits CPPR-135 and CPPR-136,
Docket Nos. 50-443 and 50-444
(b) USNRC Letter, dated April 29, 1986, "Inspection
Report No. 50-443/86-12", E. C. Wenzinger to
R. J. Harrison

Subject: Response to Inspection Report No. 50-443/86-12

Dear Sir:

Our response to the violations reported in the subject inspection is provided in Attachment 1, included herewith. The corrective action was completed during the week of May 12, 1986.

Very truly yours,

John DeVincentis
Director of Engineering

Attachment

cc: Atomic Safety and Licensing Board Service List

8606090082 860530
PDR ADOCK 05000443
A PDR

Diane Curran, Esquire
Harmon & Weiss
2001 S. Street, N.W.
Suite 430
Washington, D.C. 20009 -

Sherwin E. Turk, Esq.
Office of the Executive Legal Director
U.S. Nuclear Regulatory Commission
Tenth Floor
Washington, DC 20555

Robert A. Backus, Esquire
116 Lowell Street
P.O. Box 516
Manchester, NH 03105

Philip Ahrens, Esquire
Assistant Attorney General
Department of The Attorney General
Statehouse Station #6
Augusta, ME 04333

Mrs. Sandra Cavutis
Chairman, Board of Selectmen
RFD 1 - Box 1154
Kensington, NH 03827

Carol S. Snider, Esquire
Assistant Attorney General
Department of the Attorney General
One Ashburton Place, 19th Floor
Boston, MA 02108

Senator Gordon J. Humphrey
U.S. Senate
Washington, DC 20510
(ATTN: Tom Burack)

Richard A. Hampe, Esq.
Hampe and McNicholas
35 Pleasant Street
Concord, NH 03301

Donald E. Chick
Town Manager
Town of Exeter
10 Front Street
Exeter, NH 03833

Brentwood Board of Selectmen
RFD Dalton Road
Brentwood, NH 03833

Peter J. Mathews, Mayor
City Hall
Newburyport, MA 01950

Calvin A. Canney
City Manager
City Hall
126 Daniel Street
Portsmouth, NH 03801

Stephen E. Merrill, Esquire
Attorney General
George Dana Bisbee, Esquire
Assistant Attorney General
Office of the Attorney General
25 Capitol Street
Concord, NH 03301-6397

Mr. J. P. Wadeau
Selectmen's Office
10 Central Road
Rye, NH 03870

Mr. Angie Machiros
Chairman of the Board of Selectmen
Town of Newbury
Newbury, MA 01950

Mr. William S. Lord
Board of Selectmen
Town Hall - Friend Street
Amesbury, MA 01913

Senator Gordon J. Humphrey
1 Pillsbury Street
Concord, NH 03301
(ATTN: Herb Boynton)

H. Joseph Flynn, Esquire
Office of General Counsel
Federal Emergency Management Agency,
500 C Street, SW
Washington, DC 20472

Paul McEachern, Esquire
Matthew T. Brock, Esquire
Shaines & McEachern
25 Maplewood Avenue
P.O. Box 360
Portsmouth, NH 03801

Gary W. Holmes, Esq.
Holmes & Ellis
47 Winnacunnet Road
Hampton, NH 03841

Mr. Ed Thomas
FEMA Region I
442 John W. McCormack PO & Courthouse
Boston, MA 02109

Stanley W. Knowles, Chairman
Board of Selectmen
P.O. Box 710
North Hampton, NH 03862

ATTACHMENT 1NRC Notice of Violation (43/86-12-01)

10CFR50, Appendix B, Criterion III and the Seabrook Station FSAR, Section 17.1.1.3, require that measures be established to assure that applicable regulatory requirements and the design basis for safety-related structures, systems, and components are correctly translated into specifications, drawings, procedures, and instructions. FSAR Section 6.2.3 states that the Containment Enclosure Emergency Cleanup System "is capable of reducing the containment enclosure pressure to negative 0.25 inches (wc)" and of "processing the atmosphere of the containment enclosure space". It further states that the containment boundary welds of the main steam, feedwater, and steam generator blow-down lines are included within the containment enclosure. UE&C Specification 236-11 states, in part, that the Containment Enclosure Emergency Exhaust Units "serve to exhaust radioactively-contaminated air from the containment enclosure area during emergency conditions and to remove particulate material and radioactive iodine gas from the air prior to it being exhausted to the atmosphere". UE&C drawings F-805052 and 101453 and Foreign Prints 18032 and 18033 (P.O. 12-04/5) identify pressure seal plates in both the East and West Main Steam and Feedwater Chases as extensions of the containment enclosure.

Contrary to the above, as of February 3, 1986, no design document translated the requirement that the air space behind the pressure seal plate be made part of the containment enclosure. This design failure resulted in the construction of a space within the containment enclosure (as defined by the above UE&C drawings and foreign prints), which would not be reduced to a negative 0.25 inches (wc) pressure during emergency conditions and which would not be vented through the Containment Enclosure Emergency Exhaust Units. Thus, the inspector observed on February 19, 1986 the installation of the pressure seal plates in both steam and feedwater chases with no provision for venting the air space behind them so that their atmosphere would be processed by the Containment Enclosure Emergency Air Handling System.

This is a Severity Level IV Violation (Supplement II).

Response

We concur that, as of February 3, 1986, the subject areas had been constructed such that they could not be processed by the Containment Enclosure Emergency Air Handling System.

This violation is the result of an oversight between interfacing engineering disciplines in not detailing all of the required information in the installation details. The potential for similar unique containment enclosure volumes has been evaluated for similar circumstances. None were found to exist. This is considered an isolated occurrence. To preclude recurrence, an appropriate management directive was issued to emphasize the importance of the interdisciplinary review.

ATTACHMENT 1
(continued)

Corrective Action

In addition to the actions described in the response, ECAs have been issued to provide vent paths (i.e., core bores in walls) between the subject areas and the containment enclosure. As a result, the subject areas can now be reduced to a negative 0.25 inches (wc) pressure during emergency conditions and can be vented through the Containment Enclosure Emergency Exhaust Units.

Corrective action was completed during the week of May 12, 1986.