



nps industries, inc.

Maintenance & Inspection

NO. 2570
9-9-80

MI No. 3	Dated 9/26/80	Revision No. 0
-------------	------------------	-------------------

TITLE: PROCEDURE FOR CONFIRMING FULL THREAD
ENGAGEMENT VIA EYE ROD MEASUREMENT FOR
RIGID SWAY STRUTS

SCOPE OF:

INFORMATION
COPY

	APPROVAL SIGNATURES	Rev. 1	Rev. 2	Rev. 3
	Original Issue			
Prepared By:	R. P. Deubler 9/26/80			
Checked By:	Csaba Kertesz 9/30/80			
Approved By:	Leo Low 9/30/80			

nps

nps industries, inc.

4011
Pg. 10 of 28


Revision No. 0	Title: PROCEDURE FOR CONFIRMING FULL THREAD ENGAGEMENT VIA EYE ROD MEASUREMENT FOR RIGID SWAY STRUTS	Maintenance & Inspection No. MI 03
Date: 9/26/80		Page <u>1</u> of <u>2</u>

A. Forged Eye Rods:

1. Determine sway strut size by measurement of rod diameter or checking size code forged into the eye rod.
2. Verify design C-C equals or exceeds the minimum value listed in Table 1 or Measure L and determine if it equals or exceeds the minimum value listed in Table 1.
- 3A. If C-C or L equals or exceeds minimum value, verify DL and DR do not exceed maximum values listed.
- 3B. If C-C or L is less than the minimum value, unpin one end of strut and verify by unscrewing rod ends that the ends are upset and/or are fully engaged.

TABLE 1

ROD SIZE	STRUT SIZE	C-C MIN.	L MIN.	DL MAX.	DR MAX.
3/4	06	19-3/8	9-1/2	5-13/16	6-9/16
1	08	21-1/2	10	6-1/2	7-1/2
1-1/4	10	24-3/4	10-1/2	7-3/4	9
1-1/2	12	23-1/4	11	6-5/8	8-1/8
1-3/4	14	28-1/4	11-1/2	8-3/4	10-1/2



INFORMATION
COPY
 PPRV



Revision No. 0	Title: PROCEDURE FOR CONFIRMING FULL THREAD ENGAGEMENT VIA EYE ROD MEASUREMENT FOR RIGID SWAY STRUTS	Maintenance & Inspection No. MI #3
Date: 9/26/80		Page <u>2</u> of <u>2</u>

B. Fabricated Eye Rods:

1. Determine sway strut size by measurement of rod diameter.
2. If strut is Size 20, determine if it is long pattern or short pattern by measuring E.
3. Verify design C-C equals or exceeds the minimum value listed in Table 2 or measure L and determine if it equals or exceeds the minimum value listed in Table 2.
- 4A. If C-C or L equals or exceeds minimum value, verify FL and FR do not exceed maximum values listed.
- 4B. If C-C or L is less than the minimum value, unpin one end of strut and verify by unscrewing rod ends that the ends are upset and/or are fully engaged.





TABLE 2

ROD SIZE	E	STRUT SIZE	C-C MIN.	L MIN.	FL MAX.	FR MAX.
3/4	-	06	19-5/8	9-1/2	5-7/16	6-3/16
1	-	08	21-1/8	10	5-13/16	6-13/16
1-1/4	-	10	24-1/8	10-1/2	6-15/16	8-3/16
1-3/4	-	14	31	11-1/2	9-5/8	11-3/8
2-1/2	5-3/8	20 (short)	31-1/2	13	8-3/4	11-1/4
2-1/2	8-5/8	20 (long)	38	13	12	14-1/2
3	-	24	41-1/4	14	12-7/8	15-7/8
4-1/2	-	36	54-1/2	17	17-1/4	21-3/4





nps industries, inc.

one harmon plaza
secaucus, new Jersey 07094
201-865-6550 telex 14-1435

*NCR 11-557120
Pg. 12 of 28*

October 23, 1980
NPSI-12-1052

Texas Utilities Services, Inc.
P.O. Box 1002
Glen Rose, Texas 76043

Attention: J.T. Merritt, Jr./R.T. Wolantejus

Subject: Texas Utilities Gen. Co.
Comanche Peak Stm. Elec. Sta.
Units 1 and 2
Purchase Order No. CP0046 A.1

Subject: (PMI No. 3.1.2) Thread Upsetting
on Welded Sway Struts

Ref.: NPSI-12-1016, TWX-12,489

RECEIVED
NOV 3 1980
P & H STAINB

Gentlemen:

NPS Industries is transmitting to TUSI (PMI No. 3.1.2, Rev. 0)
Thread Upsetting on Welded Sway Struts procedure for your use.

If I can be of any further assistance, please do not hesitate
to contact me.

Very truly yours,

NPS INDUSTRIES, INC.

Herman W. D'Errico
Project Manager

HND:mg
Attachments: (1) 2 pages

cc: H.R. Rock, G&H 2L
D.C. Frankum, B&R 1L
J.T. Merritt, TUSI OL, 1L, 1A
R.E. Holloway, G&H 1L
J. Oliver, NPSI @ TUSI 1L

INFORMATION
COPY
PPRV



QA RECORD

ARMS
Brown & Root, Inc. INDEXED

QUALITY ASSURANCE DEPARTMENT
NONCONFORMANCE REPORT (NCR)

NCR No M-1889

PROJECT CPSES _____ JOB NO 35-1195 PAGE 1 OF 2

(2) UNIT	STRUCTURE SYSTEM	COMPONENT	TAG ID NUMBER	LOCATION OR ELEVATION	RIR NO
1	CT-1-013-004-032S	Pipe Support	N/A	elev. 921' Quadrant 0 ^o -270 ^o	N/A

(3) NONCONFORMING CONDITION
 (3) DOCUMENT VIOLATED: CPM 6.9 REV 0 PARA 3, 5, 28, 3 (4) TREND CATEGORY M-5

FW#9 has grinding under-cut in base metal approx. 4" long, width 1-1/2", depth 1/16" to 3/32".

- NOTE: 1. This hanger is N.P.S. furnished
 2. Hold Tag Applied

BROWN & ROOT, INC.
 RECEIVED
 FEB 4 1980
 QUALITY ASSURANCE

FOIA-85-59
 S/1

INFORMATION
 COPY
 PPRV

(5) REPORTED BY: B. Snellgrove	(6) DATE: 12 / 17 / 79	(9) REVIEW/APPROVAL: <i>[Signature]</i>	(10) DATE: 12 / 17 / 79
(7) PREPARED BY: B. Snellgrove	(8) DATE: 12 / 17 / 79	(11) ISSUED BY: <i>[Signature]</i>	(12) DATE: 12 / 17 / 79

(13) DISPOSITION ASSIGNED TO: D. C. Frankum	(14) DUE DATE: 12 / 31 / 79	(15) CORRECTIVE ACTION REQUEST: CAR NO. <input type="checkbox"/> Required <input checked="" type="checkbox"/> Not Required	(16) ASME CODE CLASS: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
--	--------------------------------	--	--

(17) DISPOSITION: Rework _____ Repair _____ Use as is Scrap _____

The extent of the grinding has not adversely affected the integrity of the fillet weld or the plate thickness. The hanger is acceptable as is.

SEE CPPA-3822 (Attached)

(18) CONSTRUCTION REVIEW/APPROVAL: <i>[Signature]</i>	(19) DATE: 1 / 17 / 80	(20) QA/QC REVIEW APPROVAL: <i>[Signature]</i>	(21) DATE: 1 / 19 / 80
(22) ENGR REVIEW/APPROVAL: <i>[Signature]</i>	(23) DATE: 1 / 9 / 80	(24) AM REVIEW APPROVAL: <i>[Signature]</i>	(25) DATE: 1 / 11 / 80

(26) VERIFICATION: <input checked="" type="checkbox"/> Satisfactory <input type="checkbox"/> Unsatisfactory <input type="checkbox"/> Not Req'd
(27) QA/QC ENGR/INSPE VERIFICATION: <i>[Signature]</i> (28) DATE: 1 / 11 / 80
(29) AM CONCURRENCE: <i>[Signature]</i> (30) DATE: 1 / 11 / 80
(31) QA REVIEW/CLOSURE: <i>[Signature]</i> (32) DATE: 1 / 11 / 80

(33) REMARKS:

QA RECORD

RTN.	QA REVIEW
L	CH 1-17-80
FILE NO.	15.1
SUBFILE NO.	M-1889

NCR M-1889
Pg. 2 of 2

Gibbs & Hill, Inc.

Interoffice Memorandum

CPPA-3822

TO: J. T. Merritt, Jr.

DATE: January 10, 1980

FROM: R. E. Heim


JOB NO: _____

SUBJECT: NCR- M-1889

REF. NO: _____

COMANCHE PEAK STEAM ELECTRIC STATION
1981-83 2300 MW INSTALLATION
NCR- M-1889

By copy of this letter we are advising Brown & Root that the "Use As Is" disposition on NCR No.M-1889 is acceptable.


R. E. Heim
Resident Engineer

DRH
REH/DRH/ JJR/jg
cc: ARMS

INFORMATION
COPY
PPRV



INDEXED

Brown & Root, Inc.

QUALITY ASSURANCE DEPARTMENT
NONCONFORMANCE REPORT (NCR)

(1) NCR No. M-2002

1A RECORD

PROJECT CPSES

JOB NO. 35-1195

PAGE 1 OF 8

(2) UNIT	STRUCTURE/SYSTEM	COMPONENT	TAG/ID NUMBER	LOCATION OR ELEVATION	RIR NO.
1	N/A	Pipe Hanger	CC-X-039-006-F43R	Elev. 823'9"	N/A

(3) NONCONFORMING CONDITION

(3) DOCUMENT VIOLATED: CPM 6.9G REV 0 PARA 3.1 (4) TREND CATEGORY G-2

Problem: CMC#16173 requires F.W. 4 & 5 to be added. These welds were made without a weld data card.

Cause: Subject CMC was marked void on 2-13-80 per CMC #16321. CMC #16173 was then reinstated on 2-14-80 by drawing a line thru the red "void" stamp. Simultaneously on 2-14-80 CMC #16321, rev. 5 to traveler, was marked "error", initialed and dated.

Note: The person (weld symbol BGN) that made welds 4 & 5 was not qualified to to make a single groove weld without a backing strip.

(5) REPORTED BY: Billy Snellgrove	(6) DATE: 2 / 19 / 80	(9) REVIEW/ APPROVAL: <i>R.M. Finist</i>	(10) DATE: 2 / 22 / 80
(7) PREPARED BY: Donald R. Vogt	(8) DATE: 2 / 19 / 80	(11) ISSUED BY: <i>Clara Halliday</i>	(12) DATE: 2 / 22 / 80

(13) DISPOSITION ASSIGNED TO: D.C. Frankum	(14) DUE DATE: 3 / 4 / 80	(15) CORRECTIVE ACTION REQUEST: CAR NO. <input type="checkbox"/> Required <input checked="" type="checkbox"/> Not Required	(16) ASME CODE <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	CLASS
---	------------------------------	---	---	-------

(17) DISPOSITION: REWORK REPAIR _____ USE AS IS _____ SCRAP _____

Issue a CMC to remove these welds.

FOIA-85-59

S/2

INFORMATION
COPY
PPRV

(18) CONSTRUCTION REVIEW/ APPROVAL: <i>Clara</i>	(19) DATE: 2/22/80	(20) QA/QC REVIEW/ APPROVAL: <i>R.M. Finist</i>	(21) DATE: 2/22/80
(22) ENG. REVIEW/ APPROVAL: N/A CH	(23) DATE: 2 / 22 / 80	(24) QA REVIEW/ APPROVAL: <i>Stephen R. Smith</i>	(25) DATE: 2/22/80

(26) VERIFICATION: <input checked="" type="checkbox"/> Satisfactory <input type="checkbox"/> Unsatisfactory <input type="checkbox"/> Not Req'd	
(27) QA/QC ENGR. INSPR. VERIFICATION: <i>Stephen R. Smith</i>	(28) DATE: 4 / 9 / 80
(29) APPROVAL CONCURRENCE: <i>Stephen R. Smith</i>	(30) DATE: 4 / 9 / 80
(31) QA REVIEW/ CLOSURE: <i>R.M. Finist</i>	(32) DATE: 4 / 9 / 80

(33) REMARKS	QA RECORD
	RTN. QA REVIEW L CH 4-14-80
	FILE NO. 15.1
	SUBFILE NO. M-2002

CONSTRUCTION OPERATION TRAVELER 35-1195

NCR-11-02
Pg. 2 of 8

① TRAVELER NO. <i>M-1-039-006-F33E</i>	② EQUIPMENT NO. SEE 1	③ UNIT NO.	④ QUANTITY	⑤ PAGE OF
⑥ ACTIVITY DESCRIPTION PIPE-SUPPORT FABRICATION AND INSTALLATION		⑦ REFERENCE DRAWINGS SEE 1 REV. 0		
⑧ SPEC./PROC./ENG. INSTR.	⑨ LOCATION <i>5E-4E; 4E-1E</i>	⑩ SYSTEM <i>CC</i>		
PREPARED BY <i>Thomas W. Lee</i>	DATE <i>8-24-79</i>	DEPT. Mech. Engr.		
REVIEWED BY <i>J. ...</i>	DATE <i>8-30-79</i>	QA/QC ENG ANI		
ANI REVIEW <i>XDD</i>	DATE <i>8-31-1979</i>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

OP. NO.	DEPT.	OPERATION	QA/QC ENG	ANI
1	IN	Verify material		
2	IN	Fabricate and/or install the pipe support assembly in accordance with the latest pipe support drawing, applicable CMC's, attached WDC's, and I.A.W. CPM6.9		
3	PD	Prepare surface, prime, and coat support assembly in accordance with CCP-30 in Containment Building and AS-30 for B.O.P.		
4	IN	Install Hilti-Kwik Bolts in accordance with CEI-20.		
5	BD	Install grout in accordance with CCP-16 and CCP-12.		
OBSERVE ALL QC/ANI HOLD POINTS ON REVERSE SIDE.				

REVISION RECORD				
<i>A</i>	<i>SM</i>	<i>INCORPORATE ABRPN-50470-8m</i>		
		<i>VOID PER CMC 16139</i>		
<i>A</i>	<i>SM</i>	<i>INCORPORATE CMC 16139</i>		
<i>A</i>	<i>PLH</i>	<i>INCORPORATE CMC 16157</i>		
<i>A</i>	<i>PLH</i>	<i>INCORPORATE CMC 16173</i>		
<i>A</i>	<i>SM</i>	<i>INCORPORATE CMC 16321</i>		

INFORMATION
COPY

NCR 11-27-79
Pg. 3 of 8

Drawing = 00-1-037-070-Form

MULTIPLE WELD DATA CARD

Line = 11A

11-27-79 SA-304L Wt. 11-27-79

ITEM NO.	NA	WPS NO.	REV.	ICN	WELD FILLER MATERIAL	WELD NOS.	P. NO.	FABRICATION CODE & CLASS/ACC STD.
		11032	1	0	ET01P	1-3	1-1	3 ASME III -

NOTES: 1) Applicable QC/ANI hold points shall be indicated by checkmark ✓.
 2) ANI inspection points indicated by (X).
 3) Denote Satisfactory inspections by an "S"; Unsatisfactory inspections by a "U".

OPERATION #	OPERATIONS
1	CLEANED
2	ALIGNMENT
3	FINAL VT
4	
5	
6	

PRODUCTION RELEASE

WELD NO.	OPERATION	HOLDPOINTS			CONST.	SAT. or UNSAT.	INSPECTION RESULTS (SIGN & DATE)			NDEP/ REV.	MTSE # / CALIB. DUE DATE
		WT	QC	ANI			QC or WT	NDE CERT. LEVEL	ANI		
1	1	NA	✓	NC		SAT	R 12/17/79	II		260 10/9/79	
	2		✓			SAT	M 2/14/80	II			
	3		✓			* SAT					
2	1		✓			SAT	R 12/17/79	II			
	2		✓			SAT	M 2/14/80	IF			
	3		✓								
3	1		✓			SAT.	R 12/17/79	II			
	2		✓			SAT	M 2/14/80	II			
	3	NA	✓	↓							

Reviewed: B. P. ... 11-27-79

JUL 23 1979 MOD AUG 31 1979

* Signed in error. PPRV 2-17-80

INFORMATION
COPY
PPRV

WE QC ANI

Approval signatures shall be affixed on the line immediately below the last step in each sequence.

Hanger III

WDC Serial # 03083

MULTIPLE WELD DATA CARD

Drawing # CC-X-039-006-F931

NCR M 2000
Pg. 7 of 8

Line # NA

ITEM NO.	WPS NO	REV.	ICN	WELD FILLER MATERIAL	WELD NOS.	P.NO.	FABRICATION CODE & CLASS/ACC STD.
NA	11032	6	D	E7018	6-7	1-1	3 ASME III -

NOTES: 1) Applicable QC/ANI hold points shall be indicated by checkmark ✓.
 2) ANI inspection points indicated by (X).
 3) Denote Satisfactory inspections by an "S"; Unsatisfactory inspection by a "U".

OPERATION #	OPERATIONS
1	VERIFY WELD CUT
2	CLEANED
3	Fit-up
4	FINAL VT
5	
6	

WELD NO.	OPERATION	HOLDPOINTS			CONST	SAT. or UNSAT.	INSPECTION RESULTS (SIGN & DATE)			NDEP/REV.	MT# #/ CALIB. DUE DATE
		WT	QC	ANI			QC or WT	NDE CERT. LEVEL	ANI		
6	1	✓	NA		*	S	DRV 3-20-80	II		200	10-8-79
	2	NA	✓			S	R 7/2/80	II			
	3	NA	✓			S	K 7/2/80	II			
	4	NA	✓			S	DRV 3-20-80	II			
7	1	✓	NA		*	S	DRV 3-20-80	II			
	2	NA	✓			S	R 7/2/80	II			
	3	NA	✓			S	R 7/2/80	II			
	4	NA	✓			S	DRV 3-20-80	II			

* Signed in error 3-20-80

Reviewed: B.P. 3-19-80 JOK 3-19-80

INFORMATION
COPY
PPRV



Brown & Root, Inc.

INSPECTION REPORT

PAGE ____ OF ____

N/A	CC	N/A
PLANT CODE	SYSTEM CODE	COMPONENT CODE
14	5-10	11-16

TAG/SPIN/IDENT NO						DRAWING/SPECIFICATION NO.			SERIAL NO		
A	B	C	D	E	F	G (Units)		H (Units)		J (Units)	
						17 55					

N/A	N/A
PURCHASE ORDER NUMBER	VEND CODE
56-69	70-73

N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
MRR NUMBER	RIR NUMBER	VENDOR'S HEAT/LOT/BATCH NO.	COUNT	UNITS	PURCH'S OR NO.	RLS/HOLD NO.	CODE	INPUT DATE
74 79	80-85	86-95	96-106		106-111	112-121		122-127

PURPOSE AND TYPE OF INSPECTION/SURVEILLANCE: *The purpose of this inspection is to close out NCR M-2002.*

RESULTS OF INSPECTION/SURVEILLANCE: *All welds were cut satisfactorily per the WT and pieces were rewelded and found satisfactory visually to NDEP 200. All requirements of the disposition have been completed and Red tag has been removed, on hanger # CC-X-039-006-F43R.*



NCR NO. *M-2002*

Don R. Vogt
QC ENGINEER/INSPECTOR

4/13/80
DATE

Figure 16.1-1

QA RECORD

BROWN & ROOT, INC.
Quality Assurance Department
Nonconformance Report (NCR)
CPSES-35-1195

NCR NO. M-2374

PAGE 1 OF 9

DRAWING/IDENTIFICATION AF-1-037-002-S33R	TAG/ID NUMBER AF-1-037-002-S33R	LOCATION OR ELEVATION 15' 10" S. 4-S & 5'9" W. E-S SG. # 1 805'4"	RIR NO. N/A
---	------------------------------------	---	----------------

NONCONFORMING CONDITION

DOCUMENT VIOLATED: CP-CPM-6.9D REV. 0 PARA. 2.5.3 TREND CATEGORY M-10
2.5.4 M

Item number 2, North piece of component support, AF-1-037-002-S33R, does not have any traceability mark stamped or etched on it. Material cannot be verified. Material is thus rendered indeterminate.

FOIA-85-59
5/3

Hold tag applied

REPORTED BY: Sam Bell	DATE: 6/20/80	REVIEW/ APPROVAL <i>[Signature]</i>	DATE: 6-25-80	TIME: 9:00 a.m.
DISPOSITION RESPONSIBILITY: D. C. Frankum	DISPOSITION ASSIGNED TO:	CAR NO.:	ASME CODE ITEM: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

DISPOSITION:
REWORK XX REPAIR USE AS IS SCRAP RETURN TO VENDOR

Remove nonconforming material (North piece of item number 2) and replace with verified SA-36 steel.

Rework in accordance with CMC-34851, R. 3 (attached).

ARMS INDEXED

DATE: _____

QA RECORD

RTN.	QA REVIEW
L	CH 10-8-80
FILE NO. 15.1	
SUBFILE NO. M-2374	

CON. REVIEW/APPROVAL: <i>[Signature]</i>	DATE: 7/28/80	QA/QC REVIEW: <i>[Signature]</i>	DATE: 7-28-80
ENG. REVIEW/APPROVAL: N/A C#	DATE: 7/24/80	ANI REVIEW: <i>[Signature]</i>	DATE: 7/28/80
QA/QC ENG/INSBR. VERIFICATION: <i>[Signature]</i>	DATE: 10-7-80		
ANI CONCURRENCE: <i>[Signature]</i>	DATE: 10/7/80		
QA REVIEW/CLOSURE: <i>[Signature]</i>	DATE: 10/7/80		

INFORMATION COPY
PPRV

ITEM NO.	MATERIALS & OPERATIONS	QUAN	SHIP	PAS	L	CSS	PAV	SEC	AISC
	SEISMIC PIPE RESTRAINT CONSISTING OF: MATERIAL EXISTS IN FIELD	ONE							
2	C5x6.7 (SA-36) 1'-7 1/2" Long, TW=2# C5x6.7 (SA-36) 0'-6 11/16" Long, TW=7#	2							
3	1/2" x 5 1/2" Hilti Kwik Bolt Concrete Anchors, TW=1# (11L41)	22	6-11-80						
4	per CMC 34851 Hilti 5-23-80 mt# 17773	2	KBK 5-23-80						
5	per CMC 34851 Hilti mt# 60216	1	KBK 5-31-80						
6	per CMC 34851 Hilti mt# 17773	1	KBK 5-31-80						
	SEISMIC ASSEMBLY SKETCH AND ENGINEERING BUNDLE AND TAG	1							
	MARK # AF-1-037-002-S33R	1							

Apply one coat of Galbo Zinc #11 to above work except this which shall be coated w/o rust preventative.

INFORMATION
COPY
 PPRV

Approved By: CEJ
 Date: 7-27-80

QUAN SHIP PAS L CSS PAV SEC AISC

FOR MATERIALS AND OPERATIONS SEE SKETCH NO. SHEET OF

Brown & Root, Inc.
ENGINEERS AND CONTRACTORS

REF. DRAWING NUMBERS



TYPE: MICRO-REU 1A ELECT: EL-0601-01S
 MODEL: 11-0602REU 1A H.V.A.C: AF-1-037-002-S33R

CONDITIONS	Fx	Fy	Fz	Mx	My	Mz
DESIGN						
NORMAL & UPSET	2558	21000				
EMERGENCY	21000	21420				
FAULTED						

DESCRIPTION	CUSTOMER
ISSUE FOR CONST	Texas Utilities Service
REVISIONS NOTED PER ITT REV 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78, 79, 80, 81, 82, 83, 84, 85, 86, 87, 88, 89, 90, 91, 92, 93, 94, 95, 96, 97, 98, 99, 100	ORDER OR CONT. NO.
REVD AS NOTED PER ITT REV 2	JOB NAME
REVD AS NOTED PER ITT REV 2	MARK NO. AF-1-037-002-S33R
	SKETCH NO.
	SHEET / OF


MAR 29 1980

INFORMATION
COPY
 PPRV



CONCRETE EXISTS

NOTE: 1/2\"/>



THIRD PARTY INSPECTION
 CODE CLASS: A-01-111-3

ITEM NO.	MATERIALS & OPERATIONS
1	SEISMIC PIPE RESTRAINT CONSISTING OF MATERIAL QUANTITY AS SHOWN
2	ANCHORS 1/2\"/>
3	SEISMIC ASSEMBLY SEE DETAIL FOR TYPICAL SECTION BUNDLE AND TAG
4	1/4\"/>

CONDITIONS	EX	BY	FR	MA	DATE
DESIGN					
EMERGENCY					
FAULTED					

PIPE: 15\"/>	STEEL: 1-01-111-3
REF. DRAWING NUMBERS	DESCRIPTION
ISSUE FOR CONST	REVISAS NOTED PER
REVISAS NOTED PER	REVISAS NOTED PER

MANCHE PEAK STEAM ELECTRIC STATION (CPSES)

COMPONENT MODIFICATION CARD (CMC)

2 100 6/2/80

SERIAL NO. N° 34851 REV. 3

1) APPLICATION: PIPE HANGER WELD MOD. Q NON-Q NA DESIGN CHANGE/DEVIATION

2) DWG. NO. AF-1-037-002-S33R BRH REV 2

4) REASON FOR CHANGE: TO UTILIZE EMBED PLATE HCR# M-2374
 TO INSTALL SHIM (DETAIL A)
 CHANGE WELD ITEM #2 TO ITEM #4


7) ORIGINATOR ARUN MAJUMDAR
 CPPE
 ORIGINAL DESIGNER

3) LINE NO./COMPONENT NO.

5) INSTRUCTIONS:

- REMOVE WELD # 1
- THRU # 4
- DELETE ITEM # 1
- DELETE - QUANTITY - 2
- ITEM # 3
- DELETE ITEM # 2, QUAN. 2

- ADD ITEM # (7) CS X 6'7 SA-36 2'-2 1/2" LONG QUANTITY - 2
- CS R 3/8" X 4" X 7" SA-36, DETAIL A
- CS R 1/4" X 4" X 7" SA-36, DETAIL A




8) APPROVED BY: 4/30/80
ARUN MAJUMDAR
DATE: 5/29/80
Arun Majumdar
DATE: 2/29/80
John P. Donnan
DATE: 7-10-80
R. W. Highsmith
DATE: _____

9) DISTRIBUTION	DCC CNTL NO.	QTY
THIS REVISION VOIDS AND SUPERSEDES DOCUMENT SERIAL NO. 34851 REV. 2		
CIARA Holiday		



CLIENT CMC # 34851 REV (3) JOB NO. _____
SUBJECT AF-1-037-002-S33R REV (2) DRAWING NO. _____
BASED ON _____
COMPUTER _____ CHK'D. BY _____ APP'D. BY _____ DATE 5/29 19 80



- ⑤ USE $\frac{3}{8}$ " THICK PLATE AT TOP
- ⑥ USE $\frac{1}{4}$ " THICK PLATE AT BOTTOM

TYP. EXCEPT THICKNESS OF THE SHIM PLATE AS PER ITEM # ⑤ AND ⑥

INFORMATION
COPY
PPRV



Brown & Root, Inc.

INSPECTION REPORT

NCR m-2374
10.6.80

PAGE ___ OF ___

PLANT CODE	SYSTEM CODE	COMPONENT CODE
1-1	5-10	11-16

TAG, SPIN/IDENT NO						DRAWING/SPECIFICATION NO			SERIAL NO		
A	B	C	D	E	F	G (Units)	H (Units)	I (Units)	J (Units)	K (Units)	L (Units)
						17-55					

AF-1-037-002-533R

PURCHASE ORDER NUMBER	VEND CODE
56-49	70-73

MRR NUMBER	RIR NUMBER	VENDOR'S HEAT LOT/BATCH NO.	COUNT QUANTITY	UNITS	PURCHS OR NO	RLS/HOLD NO CODE STATUS	INPUT DATE
74-79	80-85	86-95	96-105		106-111	112-121	122-127

PURPOSE AND TYPE OF INSPECTION/SURVEILLANCE: NCR # m-2374 Closure

RESULTS OF INSPECTION / SURVEILLANCE: Reviewed in accordance with CMC-34851 Rev. 3. Deleted Item #2 Added Item #8. Inspected satisfactorily per disposition of NCR # m-2374

Hold Tag, Removed

INFORMATION
COPY
PPRV

NCR NO m-2374
QA-15.1/1-0(4-1-77)

Betty A. Williams
QC ENGINEER/INSPECTOR

DATE 10/6/80

MULTIPLE WELD DATA SHEET

Weld No. 7019

SERIAL # AF-1-037-002-5
DRAWING # 6"-A-1-037-1

ITEM NO.	WPS NO.	REV.	ICN	WELD FILLER MATERIAL	WELD NOS.	P NO.	FABRICATION CODE & CLASS.
1/1	11032	6	0	E7018	N/A	1-1	ACC STD ASME III- 3

NOTES: 1. APPLICABLE QC/ANI HOLD POINTS SHALL BE INDICATED BY CHECKMARK.
 2. ANI INSPECTION POINTS INDICATED BY (X).
 3. DENOTE SATISFACTORY INSPECTIONS BY AN "S"; UNSATISFACTORY INSPECTIONS BY A "U".

OPERATION #	OPERATIONS
1	Support Number Identification
2	Size, Configuration, Tolerance/Dwg.
3	Material Correct/Dwg.
4	Fasteners Correct & Complete
5	Location & Elevation/Dwg.
6	Spring Can Stops Installed
7	Spherical Bearings
8	All Welds/Dwg. & WPS (V.T.)
9	Installation Complete
10	Final PT/MT (as required)
11	
12	

PRODUCTION RELEASE

WELD NO.	OPERATION	HOLDPOINTS			CONST	SAT OR UNSAT	INSPECTION RESULTS (SIGN & DATE)			NDEP/REV.	MISC CALIB DUE DATE
		WT	QC	ANI			QC OR WT	NDE CERT LEVEL	ANI		
NA	1	NA	✓	NC							
NA	2	NA	✓	NC							
NA	3	NA	✓	NC							
NA	4	NA	✓	NC							
NA	5	NA	✓	NC							
NA	6	NA	✓	NC							
NA	7	NA	✓	NC							
NA	8	NA	✓	NC							
NA	9	NA	NA	NC	✓						

Reviewed: [Signature]

INFORMATION COPY PPRV

APPROVAL SIGNATURES SHALL BE AFFIXED IN THE LINE IMMEDIATELY BELOW THE LAST STEP IN EACH SEQUENCE.

* Operations 1-8 are Final Inspections.

NER m-2394
Pg. 8 of 9

03350

WPS #
11032

Serial No. _____
Drawing No. AF-1-037-002-1331
Weld No. N/A

WELD FILLER MATERIAL LOG

5/20/80
10/10/80
10/10/80

WELD NO.	DATE	SIZE/CLASS	WELDER SYMBOL	WPS/ICH #	HEAT/LOT # or CODE #	AMT. ISS.	AMT. RT'D.	ISSUANCE APPROVAL
					AS2394		19	P-213
N/A	6/14/80	1/2	ART	11	AS2394	20	0	P-198
N/A	6/14/80	1/2	ART	11	AS2394	20	1	P-198
N/A	6/14/80	1/2	ART	11	AS2394	10	0	P-198
N/A	6/14/80	1/2	ART	11	AS2394	25	22	P-198
N/A	6/14/80	1/2	ART	11	AS2394	30	30	P-198
N/A	8/2/80	1/2	ART	11	643575	15	0	P-236

INFORMATION
COPY
PPRV

U.I. 2374
9019

ITEM NO.	MATERIALS & OPERATIONS	QUAN.	SNIP	PCS	L	CGS	PLM	...
	SEISMIC ASSEMBLY SKETCH AND ENGINEERING BUNDLE AND TAG	1						
	MARK # AF-1-037-002-8532							
1	...							
2	...							
3	1/2" x 5 1/2" HILTI ANCHOR BOLTS Concrete Anchors, TW-1# (W.L.A.)	32						
4	...	2						
5	...	1						
6	...	1						

Apply one coat of Galvalume 55 to above metal except where noted to be coated w/p rust preventative.

INFORMATION
COPY
PPRV

Approved By: _____
Date: _____

QUAN. SNIP

FOR MATERIALS AND OPERATIONS SEE SKETCH NO. _____ SHEET _____ OF _____



Brown & Root, Inc.
ENGINEERS AND ARCHITECTS

CONDITIONS	Fx	Fy	Fz	Mx	My	Mz
DESIGN						
NORMAL & UPSET	1058	1000				
EMERGENCY	1000	1000				
FAULTED						

REF. DRAWING NUMBERS

NOTE: MIP-0001-1-FG 1A ELECT: ...
ITEMEL: 1-060287-1-1 H.V.A.C.:

DATE	BY	DESCRIPTION
...	...	ISSUE FOR CONSTRUCTION
...	...	REVISED AS NOTED PER SET OF DRAWINGS

CUSTOMER: Texas Utilities Service, Inc.
OWNER OR COM. NO. _____
REV. _____

UNIT	STRUCTURE/SYSTEM	ITEM/COMPONENT	TAG/ID NUMBER	LOCATION OR ELEVATION	RIR NO.
1	SG #1/AF (3700)	Pipe Support	AF-1-035-029-S33A	805'4", 15'10" S. of 4S, 9'9" W. of DS	N/A

NONCONFORMING CONDITION

Paragraph 3.1.2.1 of CEI-20 states: that engineering approval is needed to drill through concrete reinforcing steel. The approval given for this drilling operation (memo page 3 of 4) allows drilling through probable template bar at 5 1/2" depth. However, craft drilled through rebar at 2 1/2" depth and notched rebar at 7" depth of same hole. This paragraph also states that carbide masonry bits be used for drilling concrete. Craft failed to change bits after cutting first rebar causing them to notch second rebar.

Changes direction from East to West

REFERENCE DOCUMENT: CEI-20 REV 5 PARA 3.1.2.1

REPORTED BY: J. McCommas DATE: 11/6/80

QE REVIEW/APPROVAL: *How J. T. Merritt* DATE: 11/18/80 10
ACTION ADDRESSEE: J. T. Merritt DEPARTMENT: Engineering

DISPOSITION: REWORK _____ REPAIR _____ USE AS IS X SCRAP _____

See DCA-9091 **FOIA-85-59** **ARMS INDEXED**

s/y
INFORMATION COPY

QA RECORD 1
PTN. L QA REVIEW ds
FILE NO. 15.1
SUBFILE NO. M-80-00161
2-29-80

ENG. REVIEW/APPROVAL: *Sustans J. Albe* PPRV DATE: 12/15/80

QE REVIEW APPROVAL: *SPR J. T. Merritt* DATE: 12/19/80

DISPOSITION VERIFICATION & CLOSURE: *J. T. Merritt* DATE: 12/19/80

COMMENTS:

REPORTING PERSONNEL

QE

ACTION ADDRESSEE



Brown & Root, Inc.

P.O. BOX 1001 GLEN ROSE, TEXAS 76043

MESSAGE

REPLY

To Don Sutton
REF. AEI-035-029-S33A
DATE 10-19-80

DATE 10/23/80
No structural repair
should be encountered
at these locations
and depths. The loss
encountered in probably
a construction "stiff"
"template" base and
as such may be
cut as requested.

THE REFERENCED HANGER
HAS 1 ANCHOR HOLE HITTING REBAR
AT 5 1/2" DEEP ON THE TOP
PLATE (BOTTOM RIGHT CORNER)
THE ORIENTATION SEEMS TO BE AT
A 45° ANGLE TO THE VERTICAL. PLEASE
CHECK THIS OUT FOR REBAR CUTTING
DUE TO THE IMPORTANCE OF THIS
ANCHOR

BY Rick Hankins EXT 560

SIGNED D. J. Sutton

INSTRUCTIONS TO SENDER:


- 1. SEND TO JOB. FILE.
- 2. SEND WHITE AND PINK COPIES WITH CARBON INTACT.

INSTRUCTIONS TO RECEIVER:

- 1. WRITE REPLY.
- 2. DETACH STUB, KEEP PINK COPY, RETURN WHITE COPY TO SENDER.

INFORMATION
COPY
PPRV







- 1) All dimensions in accordance with QSP #2A001 U.N.O.
- 2) Fob. Procedure is FH-1014-4
- 3) All products designed in accordance with EPL File No. 1 Rev. 13

G.S.I. Iao. MI-3206-29 R.K.
 ERP Iao. AF-1-38-02 RLEH
 Data Point. 1011/PROB. 24.510A
 Pipe Mat'l. SA106GR.B
 Invol. Pkg. CB

SPOOL #1



THIRD PARTY INSPECTION
 CODE CLASS: ASME III-3

MATERIALS & OPERATIONS		QUAN	SHIP
SEISMIC ANCHOR CONSISTING OF			
1	1/2" X 5" X 10" Structural Tubing (A307-76 GR. B) 1'-6 1/4" Long TW 144	2	
2	Special HS 63N "C" Carbon Steel (SA106 GR. B) Schedule 80 Stanchion 9 5/8" ID Tube 2'-1'-0" F-0'-8 1/2" Long Plus Flange 40#	2	
3	Carbon Steel (SA106 GR. B) 1/2" X 20" X 20 1/2" LG	1	
4	1" X 12" Supp. Hill (1146)	1	
5	1/2" X 1'-0 1/2" Carbon Steel Plate 1'-2 5/16" Long TW	1	
6	1/2" X 20" X 20 1/2" LG	1	
7	1/2" X 12" X 15 CS PLATE (SA106 GR. B)	1	
SEISMIC ASSEMBLY SKETCH AND ENGINEERING RUNDLE AND TAG MARK: AF-1-035-029 S33A			
Apply one coat of Carbo Line #1 to above Mat 1 except th'ds which sh'd be coated w/ rust preventative			
Date: 12-18-74		QUAN	SHIP

FOR MATERIALS AND OPERATIONS SEE SKETCH NO.		SHEET						
Brown & Root, Inc.		CONDITIONS	Fx	Fy	Fz	Mx	My	Mz
REF. DRAWING NUMBERS		DESIGN						
PIPE: MI-0604-R-14 ELECT: MI-0601-R-14		NORMAL & UPSET	1032	1265	1576	1700	1700	1700
STEEL: SI-0622-R-12 H.V.A.C: MI-0621-R-2		EMERGENCY	7055	1442	1700	1700	1700	1700
REV DATE DWN CHK APP		FAULTED						
DESCRIPTION		CUSTOMER						
ISSUE FOR CONSTRUCTION		ORDER OR CONT. NO. C-1046						
EVD APPROVED FOR CONSTRUCTION		JOB NAME						
MATERIALS & OPERATIONS		MARK NO. AF-1-035-029-S33A						
		SKETCH NO.						
		SHEET 1 OF 2 REV 1						

PAGE 4 of 4
 NCR NO. _____

#289

COMANCHE PEAK STEAM ELECTRIC STATION
DESIGN CHANGE AUTHORIZATION

~~(NCR)~~ (WILL NOT) BE INCORPORATED IN DESIGN DOCUMENTS

DCA NO. 9091

- 1. SAFETY RELATED DOCUMENT: XX YES NO
- 2. ORIGINATOR: CPPE XX ORIGINAL DESIGNER
- 3. DESCRIPTION:

A. APPLICABLE ~~SPR/DWG/DOCUMENT~~ 2323-S1-0628 REV. 13

B. DETAILS After drilling for installation of expansion bolts for pipe support, AF-1-035-029-S33A, the following problems have been revealed

1) One #8 vertical bar located in the wall face 14'-6" south of 4-S & located at 9'-3" west of D-S was accidently cut at elevation 805'- 11-1/2"

2) 8" typical embedded wall plate was drilled through at location in 1 above (detail A S-0786)

SOLUTION: The condition as described is acceptable.

4. SUPPORTING DOCUMENTATION:

NCR - M-80-161

INFORMATION
COPY
PPRV

5. APPROVAL SIGNATURES: DGS/bgf 11-17-80

A. ORIGINATOR: D. D. Sutton DATE 11/17/80

B. DESIGN REPRESENTATIVE: R.M. Kissinger DATE 11-18-80

6. VENDOR TRANSMITTAL REQUIRED: YES NO XX

7. STANDARD DISTRIBUTION:

- ARMS (Original) (1)
- Quality Engineering (1)
- TS for Orig. Design. (1)

JOB NO. 35-1195

E DCA FOR VIEW-88

NOV 19 1980

R RECEIVE **D**

QA RECORD

BROWN & ROOT, INC. DATE:
Quality Assurance Department
Nonconformance Report (NCR)
CPSES-35-1195

NCR NO. M-2507 R. 2

PAGE 1 OF 28

Table with 4 columns: DRAWING/IDENTIFICATION, TAG/ID NUMBER, LOCATION OR ELEVATION, RIR NO.
* See below * See below Fab Shop N/A

NONCONFORMING CONDITION

DOCUMENT VIOLATED: NF-3271.5(b) TREND NF-4711 REV. PARA. CATEGORY M-19

* CC-1-028-029-S33R, CC-1-126-015-F43R and SW-1-004-009-A33R

It was found that spherical bearing adjustable ends could be completely removed from the strut body. Threads on the adjustable ends were not upset in order to prevent ends from being removed. Also there are no sight holes in the strut bodies to determine thread engagement.

Revision 1:

Generic - Numerous struts installed without sight holes or upset threads. Thread engagement between body and eye rod assembly is indeterminate.

Revision 2: Final disposition.

Hold tag applied

REPORTED BY: L. W. Mansfield DATE: 9/18/80 REVIEW/APPROVAL: [Signature] DATE: 11/6/80 TIME: 1:00 P.M.
DISPOSITION RESPONSIBILITY: D. C. Frankum DISPOSITION ASSIGNED TO: CAR NO.: ASME CODE ITEM: XX Yes No

DISPOSITION: REWORK REPAIR XX* USE AS IS XX* SCRAP RETURN TO VENDOR

Partial disposition:

Verify all NPSI sway struts not yet installed in accordance with CP-CPM-9.11.

Supports already installed will be dispositioned shortly.

See attached for final disposition *

FOIA-85-59

S/S

QA RECORD

Table with 2 columns: RTN, QA REVIEW. Values: L, CH1-29-81, 15.1, M-2507R2

CON REVIEW/APPROVAL: Bob Stone DATE: 11/06/80 QA/QC REVIEW: [Signature] DATE: 11/6/80
ENG REVIEW/APPROVAL: [Signature] DATE: 11/6/80 ANI REVIEW: [Signature] DATE: 11/6/80
QA/QC ENG/INSPECTION VERIFICATION: [Signature] DATE: 1-29-81
ANI CONCURRENCE: [Signature] DATE: 1-29-81
QA REVIEW/CLOSURE: [Signature] DATE: 1-29-81

INFORMATION COPY PPRV

Final disposition to
NCR M-2507

NCR M-35712
B 2 of 3

* Verify and either "use as is" or repair as required.

Struts not installed - Verify per NPS Procedure MI-5, Revision 0, transmitted by NPSI-12-1053 dated 10/23/80.

Struts installed - Verify per NPS Procedure MI-3, Revision 0, transmitted by NPSI-12-1009 dated 10/2/80.

If threads are shown to be not upset they shall be upset as follows:

1. Coupling nut welded to pipe - upset per NPSI Procedure PMI-3.1.2 transmitted by NPSI-12-1052 dated 10/23/80.
2. Coupling nut not welded to pipe - upset per NPSI Procedure PMI-3.1.1 transmitted by NPSI-12-1055 dated 10/23/80.

Above to be performed by NPSI personnel at the CPSES site under the auspices of their QA program.

All sway struts shipped from NPSI facilities on or after 10/20/80 will be identified with a $\frac{1}{4}$ " five-pointed star stamp on each end to indicate verification of thread upset.

INFORMATION
COPY
PPRV



nps industries, inc.

one harmon plaza
secaucus, new jersey 07094
201-865-6550 telex 14-1435

NOV 1 2 50700
12-3 of 28

October 23, 1980
NPSI-12-1053

Texas Utilities Services, Inc.
P.O. Box 1002
Glen Rose, Texas 76043

Attention: J.T. Merritt, Jr./R.T. Wolantejus

Subject: Texas Utilities Gen. Co.
Comanche Peak Stm. Elec. Sta.
Units 1 and 2
Purchase Order No. CP0046 A.1

Subject: (MI No. 5) Procedure for Confirming
Upset Threads for Rigid Sway Struts
for TUSI Project (Struts not Installed)

Ref.: NPSI-12-1016, TWX-12,489
NPSI-12-1052, NPSI-12-0988

RECEIVED
NOV 3 1980
P. & H STATUS

Gentlemen:

NPS Industries is transmitting to TUSI (MI No. 5, Rev. 0) Procedure for Confirming Upset Threads for Rigid Sway Struts for TUSI Project (Struts not Installed) for your use.

If I can be of any further assistance, please do not hesitate to contact me.

Very truly yours,

NPS INDUSTRIES, INC.

Herman W. D'Errico
Project Manager

HWD:rmg
Attachments: (1) 4 pages

cc: H.R. Rock, G&H 2L
D.C. Frankum, E&R 1L
J.T. Merritt, TUSI OL, 1L, 1A
R.E. Holloway, G&H 1L
J. Oliver, NPSI @ TUSI 1L

INFORMATION
COPY
PPRV



nps industries, inc.

MAINTENANCE & INSPECTION

NCRP-5570?
Pg 4 of 28

MI No. 5	Dated 10/16/80	Revision No. 0
----------	----------------	----------------

TITLE: PROCEDURE FOR CONFIRMING UPSET THREADS FOR RIGID SWAY STRUTS FOR TUSI PROJECT (STRUTS NOT INSTALLED)

SCOPE OF:

INFORMATION
COPY
PPRV

APPROVAL SIGNATURES				
	Original Issue	Rev. 1	Rev. 2	Rev. 3
Author	<i>B. J. Dublin 10/20/80</i>			
Approved	<i>Leetown 10/22/80</i>			

nps

Industries, Inc.

Revision No. 0	Title: PROCEDURE FOR CONFIRMING UPSET THREADS FOR RIGID SWAY STRUTS FOR TSI PROJECT (STRUTS NOT INSTALLED)	Maintenance & Inspection No. MI #5
Date: 10/16/80		Page 1 of 1

*NCM-25722
Pg. 5 of 28*

1.0 PURPOSE

To verify that the sway strut threads are upset, and provide measurements for verification of MI #3.

2.0 SCOPE

This procedure is intended for use on TUCI CPSES Project Sway Struts shipped prior to October 20, 1980, which have not been installed. (Installed struts will be verified using MI #3.)

3.0 ATTACHMENTS

Table 1 - Sway Strut Eye Rod Size (Attachment 1)
MI #5 Worksheet (Attachment 2)

4.0 PROCEDURE

- 4.1 Locate support and record mark number, determine and record sway strut size by measuring eye rod and determine and record whether eye rod is forged or fabricated type. (See Table 1)
- 4.2 Attempt to back out the eye rod. If eye rod can be fully unscrewed, the eye rod thread is not upset. If not, it is upset. Record the condition, upset or not upset.
- 4.3 If the eye rod thread is not upset, prior to its reinsertion, measure and record the L dimension, left and right eye rod length, and E dimension (each side if fabricated). (See Table 1.) Record measurements on MI #5 worksheet.
 - 4.3.1 Upset the eye rod per PMI 3.1.1 (if coupling nut is not welded to the pipe) or PMI 3.1.2 (if coupling nut is welded to the pipe) and verify upset as described in 4.2 above.
- 4.4 After the eye rod upset is verified by attempted removal, stamp the eye rod with a 1/4" five-pointed star and record this fact.
- 4.5 Sign and date the record on MI #5 worksheet.

INFORMATION
COPY
PPRV


*NCA 11, 35, 145
 19. 6 of 28*

TABLE 1
SWAY STRUT EYE ROD SIZE


<u>STRUT SIZE</u>	<u>EYE ROD SIZE</u>	<u>TYPES</u>
06	3/4" - UNC	Forged and Fabricated
08	1" - UNC	Forged and Fabricated
10	1-1/8" - UNC	Forged and Fabricated
12	1-1/4" - UNC	Forged
14	1-3/4" - UNC	Forged and Fabricated
20	2-1/2" - UNC	Fabricated
24	3" - UNC	Fabricated
36	4-1/2" - 4UN	Fabricated

SWAY STRUT MEASUREMENTS

FORGED



FABRICATED



INFORMATION
COPY
 PPRV



nps industries, inc.

one harmon plaza
secaucus, new jersey 07094
201-865-6550 telex 14-1435

October 2, 1980
NPSI-12-1009

NCR n. 953702
Pg. 8 of 28

Texas Utilities Services, Inc.
P.O. Box 1002
Glen Rose, Texas 76043

Attention: J.T. Merritt, Jr./R.T. Wolantejus

Subject: Texas Utilities Gen. Co.
Comanche Peak Stm. Elec. Sta.
Units 1 and 2
P.O. No. CP0046A.1

Subject: Procedure for confirming Full Thread
Engagement via eyerod measurement for
Rigid Sway Struts

Ref.: TWX 12, 489

RECEIVED
OCT 10 1980
P & H DIVISION

Gentlemen:

We are transmitting herewith NPS Industries MI-3 Rev. 0
"Procedure for confirming full thread engagement via eye-
rod measurement for rigid sway struts".

This procedure provides means for confirming full engagement by
taking simple direct measurements. It is designed to be con-
servative in that it is based on an extra 1" for each forged
eyerod and 1½" for each fabricated eyerod (based upon nominal
dimensions) past full engagement for accepting a given condition.
These extra allowances allow for considerably more than the
tolerances in the parts and therefore make the procedure conserv-
ative.

It should be noted that if the procedure does not confirm full
engagement for a particular strut, there probably still is full
engagement and further inspection should be performed to deter-
mine its full engagement.

If NPSI can be of any further assistance, please do not hesitate
to contact us.

Very truly yours,
NPS Industries, Inc.

Herman W. D'Errico
Herman W. D'Errico
Project Manager

HWD:pmr
Attachments: 3 pages

cc: H.R. Rock, G&H 2L
D.C. Frankum, B&R 1L
J.T. Merritt, TUSI 0L, 1L, 2A
R.E. Holloway, G&H 1L

INFORMATION
COPY
PPRV