

SACRAMENTO MUNICIPAL UTILITY DISTRICT P. O. Box 15830, Sacramento CA 95852-1830, (916) 452-3211

AN ELECTRIC SYSTEM SERVING THE HEART OF CALIFORNIA

AGM/NPP 88-577

NOV 1 8 1988

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

Docket No. 50-312 Rancho Seco Nuclear Generating Station License No. DPR-54 PROPOSED AMENDMENT NO. 170, REVISION 1

Attention: George Knighton

By letter dated October 7, 1988, the District submitted Proposed Amendment No. 170 to better define the applicability requirements of Technical Specification 3.4 with respect to Auxiliary Feedwater (AFW) System flow paths.

The District hereby submits Revision 1 to Proposed Amendment No. 170. Revision 1 supersedes the original submittal in its entirety. Revision 1 modifies a surveillance requirement for the AFW System to reflect the in tallation of an alternate flow path for AFW pump testing. The deletion of the words "to the condenser" from Specification 4.8.1 (first paragraph) allows AFW pump test flow through either of the alternate flow paths.

Attachment I provides the insertion/removal instructions for and the Technical Specification pages affected by Proposed Amendment No. 170, Revision 1. Attachment II contains the revised Safety Analysis Report and No Significant Hazards Consideration for the proposed changes.

Pursuant to 10 CFR 50.91(b)(1), the Radiological Health Branch of the California State Department of Health Services has been informed of this proposed amendment by mailed copy of this submittal.

Since this is a revision to Proposed Amendment No. 170, no additional license fees are required.

It is requested that upon approval of this proposed amendment by the NRC, it be made effective no later than thirty days after receipt by the District.

8811220305 881118 PDR ADOCK 05000312 PDC PDC

Apol

Members of your staff with questions requiring additional information or clarification may contact Mr. Steve Crunk at (209) 333-2935, extension 4913.

State of California

SS

County of Sacramento

Russell B. DeWitt, being first duly sworn, deposes and says: that he is Acting Assistant General Manager, Nuclear Power Production of Sacramento Municipal Utility District (SMUD), the licensee herein; that he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute this document on behalf of said licensee.

essel B Russell B. DeWitt

Acting Assistant General Manager

Nuclear Power Production

Subscribed and affirmed to before me on this 18 day of Momenter. 1988.

FSTHER H. HUGHES ROTARY PUBLIC - CALIFORNIA SACRAMENTO COUNTY My Comm. Expires Oct. 21, 1989

Estner H. Hughes Notary Public

Attachments

cc w/atch: A. D'Angelo, NRC, Rancho Seco

J. B. Martin, NRC, Walnut Creek J. S. McGurk, State of California

INPO MIPC (2)