



Northeast Nuclear Energy

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385-0128  
(860) 447-1791  
Fax (860) 444-4277

The Northeast Utilities System

JUN - 8 1999

Docket No. 50-423

B17796

Re: 10 CFR 50.73(a)(2)(i)

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Millstone Nuclear Power Station Unit No. 3

Licensee Event Report 99-005-00

"Failure To Perform Surveillance On RCS Pressurizer Heater Penetration Breakers."

This letter forwards Licensee Event Report (LER) 99-005-00 (Attachment 2), documenting a condition that was determined reportable at Millstone Unit No. 3 on May 10, 1999. This LER is submitted pursuant to 10 CFR 50.73(a)(2)(i). Northeast Nuclear Energy Company's (NNECO) commitments in response to this event are contained within Attachment 1 to this letter.

Should you have any questions regarding this submittal, please contact Mr. David W. Dodson at (860) 447-1791, ext. 2346.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

C. J. Schwarz  
Unit Director, Millstone Unit No. 3

1/1  
IE22

9906150136 990608  
PDR ADOCK 05000423  
S PDR

U.S. Nuclear Regulatory Commission  
B17796/Page 2

Attachment: 1) NNECO's commitments in response to LER 99-005-00  
2) LER 99-005-00

cc: H. J. Miller, Region I Administrator  
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3  
J. A. Nakoski, NRC Project Manager, Millstone Unit No. 3  
Corrective Action Group Files (CR M3-99-1480)

RWF:rf

Docket No. 50-423  
B17796

Attachment 1

Millstone Nuclear Power Station, Unit No. 3  
NNECO's Commitments In Response To  
LER 99-005-00

June 1999

List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document. Please notify the Manager - Regulatory Compliance at the Millstone Nuclear Power Station Unit No. 3 of any questions regarding this document or any associated regulatory commitments.

Number	Commitment	Due
B17796-1	Adjust the Required Completion Date (RCD) within PMMS to reflect the date the surveillance will lapse for the containment penetration breaker surveillance.	January 1, 2000

Docket No. 50-423  
B17796

Attachment 2

Millstone Nuclear Power Station, Unit No. 3  
NNECO's Submittal of  
**LER 99-005-00**

June 1999