

CWNEP'S DATA REPORT

FOR

INSERVICE INSPECTION

EDWIN I. HATCH NUCLEAR PLANT

UNIT 2

JANUARY 1988 - MARCH 1988

8806280117 880621
PDR ADOCK 05000366
Q PDR

TABLE OF CONTENTS

PAGES

I.	ASME NIS-1 FORM AND SUPPLEMENTARY INFORMATION	1-7
II.	ABSTRACT	8-14
III.	EXAMINATION SUMMARY	
	A. CLASS 1 EXAMINATIONS	15-49
	B. CLASS 2 EXAMINATIONS	50-60
	C. PRESSURE TESTING	61-63
	D. COMPONENT SUPPORTS	64-74
	E. REACTOR PRESSURE VESSEL INTERNALS	75-104
	F. REPAIRS AND REPLACEMENTS	105-106

NOTE: Portions of this report are compiled from Southern Company Services issued report: "Nondestructive Examination Of Selected Class 1, 2, and 3 Components", for the Winter 1988 Refueling Outage at E.I. Hatch Nuclear Plant, Unit 2. This report will be available for review in the Records Management Department at the plant site.

LIST OF ABBREVIATIONS

ANI/ANII	Authorized Nuclear Inspector/Authorized Nuclear Inservice Inspector
ASME	American Society of Mechanical Engineers
ASNT	American Society for Nondestructive Testing
BC	Branch Connection
BWR	Boiling Water Reactor
CH	Closure Head
CONT	Containment
CPI	Containment Purge and Inerting System
CRD	Control Rod Drive System
CS	Core Spray System
CU	Cleanup
C&L	Cramer and Lindell Engineers
DCR	Design Change Request
ET	Eddy Current Examination
EPRI	Electric Power Research Institute
FB	Flange Bolting
FPC	Fuel Pool Cooling System
FW	Feedwater System
GE	General Electric
GPC	Georgia Power Company
HL	Hanger Lug
HPCI	High Pressure Coolant Injection System
INF	Indication Notification Form
IGSCC	Intergranular Stress Corrosion Cracking
ISI	Inservice Inspection
ITL	International Testing Laboratories
LD	Longitudinal Seam Weld Extending Downstream
LD-I	Longitudinal Weld Downstream on Inside of Elbow
LD-O	Longitudinal Weld Downstream on Outside of Elbow
LMT	Lambert, MacGill, and Thomas, Inc.
Lo	Zero Reference Location
LU	Longitudinal Seam Weld Extending Upstream
LU-I	Longitudinal Weld Upstream on Inside of Elbow
LU-O	Longitudinal Weld Upstream on Outside of Elbow

MSIV	Main Steam Isolation Valve
MS	Main Steam System
MSA	Main Steam Auxiliary System
MT	Magnetic Particle Examination
MWO	Maintenance Work Order
NDE	Nondestructive Examination
NI	No Indication
NRC	Nuclear Regulatory Commission
NRI	No Recordable Indication
OL	Overlay
PL	Pipe Lug
PLT	Plant
PR	Pipe Restraint
PROD	Product
PS	Pipe Support
PSW	Plant Service Water System
PT	Liquid Penetrant Examination
QC	Quality Control (GPC)
RC	Reactor Recirculation System
RCIC	Reactor Core Isolation Cooling System
RHR	Residual Heat Removal System
RI	Recordable Indication
RINTSA	Recirculation Inlet Nozzle Thermal Sleeve Attachment Welds
RL	Refracted Longitudinal
RL	Restraint Lug
RPV	Reactor Pressure Vessel
RX	Reactor
RWCU	Reactor Water Cleanup System
SBLC	Standby Liquid Control System
SCS	Southern Company Services
SER	Service
SRV	Safety Relief Valve
SWRI	Southwest Research Institute
TDP	Torus Drainage and Purification System
TSB	Turbine Steam Bypass System
UT	Ultrasonic Examination
VLV	Valve
VT	Visual Examination

This list is comprised of standard abbreviations used in Inservice Inspection Documentation. All of these abbreviations may not appear in this report.

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS
As Required By the Provisions Of The ASME Code Rules

1. Owner Georgia Power Company, 333 Piedmont Ave., NE P.O. Box 4545 Atlanta Georgia 30302
2. Plant Edwin I. Hatch Nuclear Plant, Route 1, Box 278, Baxley, Ga. 31513
3. Plant Unit 2 4. Owner Certificate of Authorization(if req.) N/A
5. Commercial Service Date 09/05/79 6. National Board No. for Unit N/A
7. Components Inspected:

Component or Appurtenance or System =====	Manufacturer or Installer =====	Manufacturer or Installer Serial No. =====	State or Province Number =====	National Board No. =====
<u>Rx. Pressure Vessel</u>	<u>Combustion Eng.</u>	<u>70101</u>	<u>N/A</u>	<u>11570</u>
<u>Rx. Pressure Vessel</u>	<u>Combustion Eng.</u>	<u>70201</u>	<u>N/A</u>	<u>11570</u>
<u>2B21 Main Steam</u>	<u>Pullman Power Prod.</u>	<u>*</u>	<u>N/A</u>	<u>*</u>
<u>2B21 Feedwater</u>	<u>Pullman Power Prod.</u>	<u>*</u>	<u>N/A</u>	<u>*</u>
<u>2B21 M.S. Relief</u>	<u>Pullman Power Prod.</u>	<u>*</u>	<u>N/A</u>	<u>*</u>
<u>2B31 Rx. Recirc</u>	<u>Pullman Power Prod.</u>	<u>*</u>	<u>N/A</u>	<u>*</u>
<u>2B31 Recirc Pump</u>	<u>Byron Jackson</u>	<u>*</u>	<u>N/A</u>	<u>*</u>
<u>2C11 CRD</u>	<u>Pullman Power Prod.</u>	<u>*</u>	<u>N/A</u>	<u>*</u>
<u>2C41 SBLC</u>	<u>Pullman Power Prod.</u>	<u>*</u>	<u>N/A</u>	<u>*</u>
<u>2E11 RHR</u>	<u>Pullman Power Prod.</u>	<u>*</u>	<u>N/A</u>	<u>*</u>
<u>2E21 Core Spray</u>	<u>Pullman Power Prod.</u>	<u>*</u>	<u>N/A</u>	<u>*</u>
<u>2E41 HPCI</u>	<u>Pullman Power Prod.</u>	<u>*</u>	<u>N/A</u>	<u>*</u>

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets are recorded at the top of this form. **

* - Spool piece or fitting numbers too numerous to list for each specific system. Material certifications for all piping, fittings, etc., are available for review in the Records Management Department at the plant site.

** Exception taken to note 2.

7. Components Inspected (continued):

FORM NIS-1 (Continued)

Component or Appurtenance or System =====	Manufacturer or Installer =====	Manufacturer or Installer Serial No. =====	State or Province Number =====	National Board No. =====
<u>2G31 RWCU</u>	<u>Pullman Power Prod.</u>	<u>*</u>	<u>N/A</u>	<u>*</u>
<u>2G41 FPC & CU</u>	<u>Pullman Power Prod.</u>	<u>*</u>	<u>N/A</u>	<u>*</u>
<u>2N11 M S Auxiliary</u>	<u>Pullman Power Prod.</u>	<u>*</u>	<u>N/A</u>	<u>*</u>
<u>2P41 Plt Serv Water</u>	<u>Pullman Power Prod.</u>	<u>*</u>	<u>N/A</u>	<u>*</u>

- * - Spool piece or fitting numbers too numerous to list for each specific system. Material certifications for all piping, fittings, etc., are available for review in the Records Management Department at the plant.

- 8. Examination Dates 01/04/88 to 03/23/88.
- 9. Inspection Interval from 01/86 to 01/96.
- 10. Abstract of Examinations. Include a list of examinations and a statement concerning status of work required for current interval. **
- 11. Abstract of Conditions Noted. **
- 12. Abstract of Corrective Measures Recommended and Taken. **

We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Date June 6 1988 Signed Georgia Power Company By D. Stead
Owner

Certificate of Authorization No. (if applicable) N/A Expiration Date N/A

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of GA. and employed by *** of Hartford, CT have inspected the components described in this Owners' Data Report during the period 01/88 to 03/88 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners' Data Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date June 6 19 88

Charles J. Seeger Jr.
Inspector's Signature

Commissions Georgia - 201
National Board, State, Province, & No.

** The following NIS-1 Form supplementary information and report includes the responses to NIS questions #10, #11, and #12.

*** Hartford Steam Boiler Insurance and Inspection Company.

NIS-1 Form Supplementary Information

Owner's Data Report
for
Inservice Inspection

Date: June 1, 1988

Owner Name & Address: Georgia Power Company
333 Piedmont Avenue, N.E.
P.O. Box 4545
Atlanta, Georgia 30302

Name & Address of Nuclear Generating Plant:

Edwin I. Hatch Nuclear Plant
Route 1, Box 278
Baxley, Georgia 31513

Name Assigned to Nuclear Plant Station:

Edwin I. Hatch Nuclear Plant
Unit 2

Commercial Service Date: September 5, 1979

Gross Generating Capability:

2436 MWt, 817.3 MWe

State, Province, or Municipality Assigned Number:

N/A

National Board Number Assigned by Manufacturer:

N/A

Name of Component or Part of Component ISI Involved:

Representative samples of the following components and areas were examined with nondestructive testing techniques.

Class 1

Reactor Pressure Vessel	Standby Liquid Control System
Reactor Pressure Vessel Closure Head	High Pressure Coolant Injection System
Main Steam Piping System	Reactor Core Isolation Cooling System
Feedwater Piping System	
Residual Heat Removal System	
Control Rod Drive System	
Reactor Recirculation System	
Core Spray System	
Reactor Water Cleanup System	
Valve Internal Surfaces	
Valve Bolting	

Class 2

RHF System

Core Spray System

HPCI System

Control Rod Drive System

Reactor Water Cleanup System

Main Steam Auxiliary Piping System

Hydrostatic Testing

Class 2

Residual Heat Removal System (ISI Hydros 2E11-HT-2, 2E11-HT-3, 2E11-HT-6, 2E11-HT-14, 2E11-HT-23, and 2E11-HT-24)

Class 3

Plant Service Water System (ISI Hydros 2P41-HT-13, 2P41-HT-28, and 2P41-HT-29)

System Pressure/Leakage Tests

<u>System</u>	<u>Class</u>	<u>Test Required</u>
Reactor Pressure Vessel and Associated Piping and Components	1	Leakage (2B21-LT-1)
Residual Heat Removal Service Water System	3	Inservice (2E11-IT-1)

Pipe Support & Hanger Examination

Class 1

Main Steam System

High Pressure Coolant Injection System

Reactor Recirculation System

Class 2

Core Spray System

High Pressure Coolant Injection System

Residual Heat Removal System

Main Steam Auxiliary System

Class 3

Main Steam Safety/Relief Valve Discharge System

RHR Service Water System

Plant Service Water System

Fuel Pool Cooling System

Name & Address of Manufacturer of Components:

1. Reactor Pressure Vessel and Closure Head:
Combustion Engineering, Inc.
Chattanooga, TN
2. Piping (Classes 1, 2, and 3)
 - a. Pullman Power Products
Division of Pullman-Kellogg
Williamsport, PA
 - b. General Electric Company
San Jose, CA

Note: Piping purchased by General Electric and Pullman and installed by Pullman. Material certifications and manufacturer information are available for review in the Records Management Department at the Hatch Plant Site.

3. Piping Supports and Hangers (Classes 1, 2, and 3)
 - a. Bergen-Paterson Pipe Support Corporation
Laconia, NH
 - b. ITT Grinnell Corporation
Providence, Rhode Island
 - c. Pacific Scientific
Anaheim, CA
4. Valves, Pumps, and Heat Exchangers
 - a. Byron-Jackson, Inc.
Los Angeles, CA
 - b. Crane
New York, NY
 - c. Wm. Powell Company
Cincinnati, OH
 - d. General Electric
San Jose, CA

Date of Inservice Inspection:

- January 1988 - March 1988

Completion Date of Inservice Inspection:

March 23, 1988 *

Name of Inspector: Charles F. Toegel, Jr. (ANI/ANII)

Name & Mailing Address of Inspector's Employer:

The Hartford Steam Boiler Inspection and Insurance Company
1117 Perimeter Center West
Suite E 301
Atlanta, Georgia 30338

* Small portion of pressure test 2E11-IT-1 was not completed until 05-03-88 due to required valve line up. Majority of test was completed prior to 03-23-88 and is being included in this report.

ABSTRACT

An Inservice Inspection of selected Class 1, 2, and 3 components of Georgia Power Company's Edwin I. Hatch Nuclear Plant Unit 2 was performed during the Winter 1988 Maintenance/Refueling Outage. The components were examined in accordance with the applicable outage plan, including any changes made during the ISI as approved by Georgia Power Company.

The nondestructive examinations were performed using VT, PT, MT, AND UT examination techniques. SCS personnel and their contractors; SWRI and EBASCO Services, Inc. performed NDE of the selected welds and components. In addition, CTS assisted SCS personnel with VT examinations of selected RPV internal components.

SCS, SWRI, and EBASCO personnel performed Class 1, 2, and 3 examinations. SCS and SWRI procedures were used to perform the NDE Examinations. EBASCO personnel were qualified to the applicable SCS procedures prior to performance of examinations. EPRI qualified inspectors were utilized for examinations involving IGSCC susceptible materials.

In addition to NDE testing of Class 1 and 2 welds and components, pressure testing, visual examination of Class 1 valve internal surfaces and visual examination of pipe supports and hangers were also performed. GPC QC Personnel performed the Class 1 Valve Internals Inspections and supplied copies of the examination reports to SCS for inclusion in the final report.

Third party review (e.g. an ANII) was utilized for the ISI.

Selected components were examined in accordance with the following documents:

- Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, "Rules for Inservice Inspection of Nuclear Power Plant Components," 1980 Edition with Addenda through Winter 1981.
- United States Nuclear Regulatory Commission, NUREG 0313, Revision 2, (Draft), "Technical Report on Material Selection and Processing Guidelines for BWR Coolant Pressure Boundary Piping".
- United States Nuclear Regulatory Commission, NUREG 0619, "BWR Feedwater Nozzle and Control Rod Drive Return Line Nozzle Cracking".
- United States Nuclear Regulatory Commission I&E Bulletin 80-13 Visual Examination of Core Spray Spargers.
- General Electric Company Service Information Letter-330, Jet Pump Beam Inspection.
- General Electric Company Service Information Letter-420, Inspection of Jet Pump Sensing Lines.
- General Electric Company Service Information Letter-433, Shroud Head Bolting Inspection.
- SCS "Second Ten-Year Examination Plan, Edwin I. Hatch Nuclear Plant, Unit 2", Rev. 1.
- SCS "Inservice Inspection Outage Plan, Edwin I. Hatch Nuclear Plant, Unit 2 1988 Winter Refueling Outage", Revision 1 and Deviation 001.

Representative samples of the following systems, comprised of selected Class 1, 2, and 3 components, were examined using various NDE techniques, in accordance with the above documents:

Class 1

Reactor Pressure Vessel (2B11)
Main Steam System (2B21)
Feedwater System (2B21)
Reactor Recirculation System (2B31)
Control Rod Drive System (2C11)
Standby Liquid Control System (2C41)
Residual Heat Removal System (2E11)
Core Spray System (2E21)
High Pressure Coolant Injection System (2E41)
Reactor Core Isolation Cooling System (2E51)
Reactor Water Cleanup System (2G31)
Valve Internals
Valve Bolting

Class 2

Residual Heat Removal System (2E11)
Core Spray System (2E21)
High Pressure Coolant Injection System (2E41)
Control Rod Drive System (2C11)
Reactor Water Cleanup System (2G31)
Main Steam Auxiliary System Piping (2N11)
Main Steam Relief Valve Discharge Piping (2B21)

Class 3

Service Water System (2E11) (2P41)
Fuel Pool Cooling System (2G41)
Main Steam Safety/Relief Valve Discharge System (2B21)

Other (Non-ASME Related)

UT thickness measurements were performed on selected components in the Extraction Steam, Auxiliary Vents and Drain, and Condensate Feedwater Piping Systems. A portion of these components were selected due to their similarity in design and operating conditions to components involved with the "Surry Pipe Break Incident". A separate report for these examinations was prepared by SCS and was submitted to GPC engineering.

CLASS 1 EXAMINATIONS

RPV Shell Welds (SWRI Mechanized UT)

Mechanized UT was utilized to examine four (4) circumferential welds and twelve (12) longitudinal welds. A minimum of 5% of each circumferential weld and 10% of each longitudinal weld was examined. These examination lengths meet the requirements of the ASME Section XI Code, 1974 Edition with Addenda through Summer 1975. No reportable indications were detected.

RPV Examinations (UT)

Five (5) nozzle-to-shell welds and four (4) nozzle inner radius welds were examined using manual UT techniques. No reportable indications were detected.

The RPV closure head-to-flange weld was examined due to indications detected during a previous outage. There was no significant change in the indications and they were deemed acceptable.

Nineteen (19) closure head studs and eighteen (18) vessel flange ligaments were examined. No reportable indications were detected.

RPV Examinations (MT & VT)

Nineteen (19) closure head nuts were MT examined and the corresponding nineteen (19) washers were VT examined. No reportable indications were detected.

RPV Internal Examinations (UT & VT)

All twenty (20) jet pump hold down beams were UT examined per GE SIL-330. Jet pump beam #20 was found to have a crack like indication and was removed and replaced. The replacement beam was UT examined and found to be acceptable.

All thirty-six (36) shroud head hold down bolts were UT examined per GE SIL-433. Eight (8) bolts were found to have crack like indications (#6, #10, #13, #17, #24, #32, #34, and #36). Six (6) bolts were replaced (#6, #10, #17, #24, #32, and #36). The remaining two (2) bolts were evaluated and deemed to be acceptable by GE.

Per IE Bulletin 80-13, the core spray sparger and associated piping was VT examined. No reportable indications were detected.

Per ASME Section XI, selected RPV internals were examined using remote visual examination techniques. VT of the steam dryer revealed forty-five (45) indications in the support ring, two (2) indications in the vertical vane welds and forty-five (45) indications in the steam dryer support brackets. Indications were evaluated and found to be acceptable by GE.

Visual examination of the jet pump mixing nozzles revealed evidence of erosion in the throat area. The erosion was evaluated by GE and deemed acceptable with recommendations for additional monitoring in future outages.

Other Class 1 Examinations (UT, MT, PT, & VT)

Sixty-three (63) welds were examined using volumetric and surface NDE techniques. One (1) of the welds was per NUREG-0619, fifty-six (56) welds were per NUPEG-0313 and the remaining six (6) were for ASME Section XI requirements. One (1) MT indication was reported to GPC. This indication was evaluated by UT and found to be acceptable. One (1) weld was being re-examined due to previous indications. There was no significant change in the indication and it was deemed acceptable.

Twenty-three (23) integral attachments were examined using surface NDE techniques. One (1) attachment had unacceptable indications and required surface conditioning to remove indications.

Five (5) RINTSA welds were UT examined per NUREG-0313 and all were found to be acceptable.

Bolting on recirculation pump 2B31-C001A was UT examined and no reportable indications were detected.

Thirteen (13) components were examined using VT for bolting and valve body examination requirements of ASME Section XI. No reportable indications were detected.

CLASS II EXAMINATIONS

Seventy-two (72) welds were examined using surface and volumetric NDE techniques. These examinations included piping welds and integral attachment welds. Three (3) of these were examined for GPC augmented commitments, three (3) were examined per NUREG-0619 and the remaining sixty-six (66) were examined for ASME Section XI requirements. Four (4) indications were reported to GPC. These indications were repaired and re-examined and found to be acceptable.

PRESSURE TESTING

Six (6) Class 2 and three (3) Class 3 hydrostatic test, one (1) Class 3 Inservice Tests and a Class 1 Leakage Test were performed during the Outage. See the Pressure Test Section of this report for specific information.

COMPONENT SUPPORT EXAMINATIONS (CLASS 1, 2, AND 3)

One hundred and sixty-five (165) component supports were VT examined during the outage. Twenty-three (23) examinations revealed unacceptable results. These supports were either repaired and re-examined or evaluated by engineering and found to be acceptable as is.

REPAIRS AND REPLACEMENTS (CLASS 1 AND 2)

No major repairs or replacements were performed during the outage. Some minor repairs to valves and component supports were performed due to ISI examinations, six shroud head hold down bolts, and one jet pump hold down beam were replaced. See Repair and Replacement Section of this report for specific information.

REPORTABLE INDICATIONS

Following is an itemized list of all welds and components which were reported to contain indications or were considered unacceptable due to ISI examinations. All of these items were either repaired or evaluated and then deemed acceptable.

RPV Internals

92 linear indications in steam dryer (VT)
Deficiency Card 2-88-0465

8 Moisture Separator Shroud Head Hold Down Bolts (UT)
Deficiency Card 2-88-0477 (Bolts 6, 10, 13, 17, 24, 32, 34, 36)
MWO 2-88-0065 (Bolts 6, 10, 17, 24, 32, 36)

Jet Pump Hold Down Beam #20 (UT)
Deficiency Card 2-88-0464
MWO 2-88-0659

Jet Pump Inlet Mixing Nozzles - all 20 (VT)
Deficiency Card 2-88-0583

Class 1 Welds

2E41-1HPCI-10-D-8 (MT)
Deficiency Card 2-88-0466
MWO 2-88-0565

2B21-IMS-24A-GPL-2 (MT)
Deficiency Card 2-88-0644
MWO 2-88-0727

Class 2 Welds

2E11-2RHR-8-FPS-8 (MT)
Deficiency Card 2-88-1058
MWO 2-88-1159

2E11-2RHR-20B-D-3 (MT)
Deficiency Card 2-88-1059
MWO 2-88-1160

2N11-2MSA-24B-IPS-1 (MT)
Deficiency Card 2-88-0942
MWO 2-88-1020

2N11-2MSA-24B-IPS-2 (MT)
Deficiency Card 2-88-0942
MWO 2-88-1020

Component Status (Class 1, 2, AND 3)

SUPPORT	DEFICIENCY CARD	MWO
2B21-MS-H3	2-88-0860	2-88-0970
2B21-MSRV-H7	2-88-0860	2-88-0970
2B21-MSRV-H26	2-88-0860	2-88-0970
2B21-MSRV-R55	2-88-0614	2-88-0703
2E11-RHR-A58	2-88-0817	2-88-0929
2E11-RHR-H57	2-88-0864	2-88-0975
2E11-RHR-H175	2-88-0864	2-88-0975
2E11-RHR-H181	2-88-0864	2-88-0975
2E11-RHR-H182	2-88-0864	2-88-0975
2E11-RHR-H183	2-88-0864	2-88-0975
2E11-RHR-H195	2-88-0864	2-88-0975
2E11-RHR-R298	2-88-0817	2-88-0930
2E11-RHR-R299	2-88-0817	2-88-0928
2E11-RHR-R300	2-88-0817	2-88-0931
2E11-RHR-H314	2-88-0864	2-88-0975
2E41-HPCI-H31	2-88-0227	2-88-0287
2E41-HPCI-H71	2-88-0887	2-88-1006
2E41-HPCI-H98	2-88-0835	2-88-1120
	2-88-0584	2-88-0672
2E41-HPCI-H108	2-88-0887	2-88-1006
2E41-HPCI-HR710	2-88-0835	2-88-1120
	2-88-0584	2-88-0672
2E41-HPCI-R102	2-88-0835	2-88-1120
2E41-HPCI-R104	2-88-0835	2-88-1120
	2-88-0584	2-88-0672
2P41-SW-H265	2-88-0888	2-88-1007

The following sections of this NIS-1 Report contain the summary of the NDE Examinations performed, provides additional information and gives results of those examinations.

SUMMARY
OF
CLASS 1 COMPONENTS

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 1 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>RPV EXAMINATIONS</u>									
B1.11 B-A	A-1/04	2C-2 Upper Shell-To- Upper Middle Shell	Mech	SwRI	Please see SwRI Report				PL-CSCL-5.875-62-H
B1.11 B-A	A-1/04	2C-3 Upper Middle Shell- To-Lower Middle Shell	Mech	SwRI	Please see SwRI Report				PL-CSCL-5.875-62-H
B1.11 B-A	A-1/04	2C-4 Lower Middle Shell- To-Lower Shell Weld	Mech	SwRI	Please see SwRI Report				PL-CSCL-5.875-62-H
B1.11 B-A	A-1/04	2C-5 Lower Shell-To- Bottom Head Torus	Mech	SwRI	Please see SwRI Report				PL-CSCL-5.875-62-H
B1.12 B-A	A-1/04	2C-1-A Longitudinal Weld on Upper Shell	Mech	SwRI	Please see SwRI Report				PL-CSCL-5.875-62-H
B1.12 B-A	A-1/04	2C-1-B Longitudinal Weld on Upper Shell	Mech	SwRI	Please see SwRI Report				PL-CSCL-5.875-62-H

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 2 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>RPV EXAMINATIONS (Cont'd)</u>									
B1.12 B-A	A-1/04	2C-1-C Longitudinal Weld on Upper Shell	Mech	SwRI	Please see SwRI Report				PL-CSCL-5.875-62-H
B1.12 B-A	A-1/04	2C-2-A Longitudinal Weld on Upper Mid Shell	Mech	SwRI	Please see SwRI Report				PL-CSCL-5.875-62-H
B1.12 B-A	A-1/04	2C-2-B Longitudinal Weld on Upper Mid Shell	Mech	SwRI	Please see SwRI Report				PL-CSCL-5.875-62-H
B1.12 B-A	A-1/04	2C-2-C Longitudinal Weld on Upper Mid Shell	Mech	SwRI	Please see SwRI Report				PL-CSCL-5.875-62-H
B1.12 B-A	A-1/04	2C-3-A Longitudinal Weld on Lower Mid Shell	Mech	SwRI	Please see SwRI Report				PL-CSCL-5.875-62-H
B1.12 B-A	A-1/04	2C-3-B Longitudinal Weld on Lower Mid Shell	Mech	SwRI	Please see SwRI Report				PL-CSCL-5.875-62-H
B1.12 B-A	A-1/04	2C-3-C Longitudinal Weld on Lower Mid Shell	Mech	SwRI	Please see SwRI Report				PL-CSCL-5.875-62-H

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 3 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>RPV EXAMINATIONS (Cont'd)</u>									
B1.12 B-A	A-1/04	2C-4-A Longitudinal Weld on Lower Shell	Mech	SwRI	Please see SwRI Report				PL-CSCL-6.875-61-H
B1.12 B-A	A-1/04	2C-4-B Longitudinal Weld on Lower Shell	Mech	SwRI	Please see SwRI Report				PL-CSCL-6.875-61-H
B1.12 B-A	A-1/04	2C-4-C Longitudinal Weld on Lower Shell	Mech	SwRI	Please see SwRI Report				PL-CSCL-6.875-61-H
B1.40 B-A	A-3/03	2HC-2 Closure Head-To-Flg Centerline Stud 1 to Stud 20 (CW)	MT UT	MT-H-500/2 UT-H-410/4	S88H2M048 S88H2U132 S88H2U143 S88H2U145 S88H2C041 S88H2C052 S88H2C053	x x		x x	PL-CS-4.5-64-H Indications detected during previous outage. See INF I86H2010. Acceptable per IWB-3510-1.
B1.10 B-D	A-1/04	2N2A B Loop Recirculation Inlet Nozzle To Shell	UT	UT-H-410/4	S88H2U169 S88H2U176 S88H2U177 S88H2C073 S88H2C074 S88H2C075	x x x		UT Cal. UT Cal. UT Cal.	PL-CSCL-6.875-61-H

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 4 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>RPV EXAMINATIONS (Cont'd)</u>									
B3.90 B-D	A-1/04	2N2D B Loop Recirculation Inlet Nozzle to Shell	UT	UT-H-410/4	S88H2U172 S88H2U175 S88H2U178 S88H2C073 S88H2C074 S88H2C075			x	PL-CSCL-6.875-61-H Laminar indication. Acceptable per IWB-3511-2.
B3.90 B-D	A-1/04	2N2G A Loop Recirculation Inlet Nozzle to Shell	UT	UT-H-410/4	S88H2U171 S88H2U173 S88H2U179 S88H2C073 S88H2C074 S88H2C075			x	PL-CSCL-6.875-61-H
B3.90 B-D	A-1/04	2N2K A Loop Recirculation Inlet Nozzle to Shell	UT	UT-H-410/4	S88H2U170 S88H2U174 S88H2U180 S88H2C073 S88H2C074 S88H2C075			x	PL-CSCL-6.875-61-H
B3.90 B-D	A-1/04	2N4D B-D Loop Feedwater Inlet Nozzle to Shell	UT	UT-H-410/4	S88H2U214 S88H2U215 S88H2U216 S88H2U217 S88H2C09G S88H2C09I S88H2C092			x	PL-CSCL-5.875-62-H

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 5 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>RPV EXAMINATIONS (Cont'd)</u>									
B3.100 B-D	A-1/04	2N2A B Loop Recirculation Inlet Nozzle IR	UT	UT-H-480/3	S88H2U188 S88H2C077		x	UT Cal.	PL-CSCL-6.875-61-H
B3.100 B-D	A-1/04	2N2D B Loop Recirculation Inlet Nozzle IR	UT	UT-H-480/3	S88H2U187 S88H2C077		x	UT Cal.	PL-CSCL-6.875-61-H
B3.100 B-D	A-1/04	2N2G A Loop Recirculation Inlet Nozzle IR	UT	UT-H-480/3	S88H2U186 S88H2C077		x	UT Cal.	PL-CSCL-6.875-61-H
B3.100 B-D	A-1/04	2N2K A Loop Recirculation Inlet Nozzle IR	UT	UT-H-480/3	S88H2U185 S88H2C077		x	UT Cal.	PL-CSCL-6.875-61-H
B6.10 B-G-1	A-33/01	2NUT-1 Closure Head Nuts	MT	MT-H-501/2	S88H2M063	x			
B6.10 B-G-1	A-33/01	2NUT-2 Closure Head Nuts	MT	MT-H-501/2	S88H2M063	x			
B6.10 B-G-1	A-33/01	2NUT-3 Closure Head Nuts	MT	MT-H-501/2	S88H2M063	x			
B6.10 B-G-1	A-33/01	2NUT-4 Closure Head Nuts	MT	MT-H-501/2	S88H2M063	x			

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 6 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>RPV EXAMINATIONS (Cont'd)</u>									
B6.10 B-G-1	A-33/01	2NUT-5 Closure Head Nuts	MT	MT-H-501/2	S88H2M063	x			
B6.10 B-G-1	A-33/01	2NUT-6 Closure Head Nuts	MT	MT-H-501/2	S88H2M063	x			
B6.10 B-G-1	A-33/01	2NUT-29 Closure Head Nuts	MT	MT-H-501/2	S88H2M063	x			
B6.10 B-G-1	A-33/01	2NUT-45 Closure Head Nuts	MT	MT-H-501/2	S88H2M064	x			
B6.10 B-G-1	A-33/01	2NUT-46 Closure Head Nuts	MT	MT-H-501/2	S88H2M064	x			
B6.10 B-G-1	A-33/01	2NUT-47 Closure Head Nuts	MT	MT-H-501/2	S88H2M064	x			
B6.10 B-G-1	A-33/01	2NUT-48 Closure Head Nuts	MT	MT-H-501/2	S88H2M063	x			
B6.10 B-G-1	A-33/01	2NUT-49 Closure Head Nuts	MT	MT-H-501/2	S88H2M062	x			
B6.10 B-G-1	A-33/01	2NUT-50 Closure Head Nuts	MT	MT-H-501/2	S88H2M064	x			

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 7 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>RPV EXAMINATIONS (Cont'd)</u>									
B6.10 B-G-1	A-33/01	2NUT-51 Closure Head Nuts	MT	MT-H-501/2	S88H2M064	x			
B6.10 B-G-1	A-33/01	2NUT-52 Closure Head Nuts	MT	MT-H-501/2	S88H2M062	x			
B6.10 B-G-1	A-33/01	2NUT-53 Closure Head Nuts	MT	MT-H-501/2	S88H2M062	x			
B6.10 B-G-1	A-33/01	2NUT-54 Closure Head Nuts	MT	MT-H-501/2	S88H2M062	x			
B6.10 B-G-1	A-33/01	2NUT-55 Closure Head Nuts	MT	MT-H-501/2	S88H2M064	x			
B6.10 B-G-1	A-33/01	2NUT-56 Closure Head Nuts	MT	MT-H-501/2	S88H2M064	x			
B6.30 B-G-1	A-33/01	2STUD-1 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-2 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-3 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 8 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>RPV EXAMINATIONS (Cont'd)</u>									
B6.30 B-G-1	A-33/01	2STUD-4 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-5 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-6 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-40 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-45 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-46 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-47 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-48 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-49 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H

Edwin I. Hatch Unit 2
1986 Winter Refueling Outage
Class 1 Components
Page 9 of 34

<u>ASME SECTION XI CAT. NO.</u>	<u>EXAM FIG. NO.</u>	<u>EXAMINATION/AREA</u>	<u>EXAM METHOD</u>	<u>NDE PROCEDURE</u>	<u>EXAM/CAL. SHEET NO.</u>	<u>NI</u>	<u>NRI</u>	<u>RI GEOM/OTHER</u>	<u>REMARKS/BASIC CALIBRATION BLOCK</u>
<u>RPV EXAMINATIONS (Cont'd)</u>									
B6.30 B-G-1	A-33/01	2STUD-50 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-51 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-52 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-53 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-54 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-55 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.30 B-G-1	A-33/01	2STUD-56 Closure Head Studs	UT	UT-H-421/2	S88H2U227 S88H2C099		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-1 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 10 of 34

<u>ASME SECTION XI CAT. NO.</u>	<u>EXAM FIG. NO.</u>	<u>EXAMINATION/AREA</u>	<u>EXAM METHOD</u>	<u>NDE PROCEDURE</u>	<u>EXAM/CAL. SHEET NO.</u>	<u>NI</u>	<u>NRI</u>	<u>RI GEOM/OTHER</u>	<u>REMARKS/BASIC CALIBRATION BLOCK</u>
<u>RPV EXAMINATIONS (Cont'd)</u>									
B6.40 B-G-1	A-33/01	2LIG-2 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-41 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-42 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-43 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-44 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-45 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-46 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-47 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-48 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 11 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>RPV EXAMINATIONS (Cont'd)</u>									
B6.40 B-G-1	A-33/01	2LIG-49 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-50 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-51 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-52 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-53 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-54 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-55 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.40 B-G-1	A-33/01	2LIG-56 Flange Ligaments	UT	UT-H-419/0	S88H2U226 S88H2C098		x	UT Cal.	23-H
B6.50 B-G-1	A-33/01	2WASHER-1 Closure Head Washers	VT	VT-H-710/2	S88H2V183			Satisfactory	

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 12 of 34

<u>ASME SECTION XI CAT. NO.</u>	<u>EXAM FIG. NO.</u>	<u>EXAMINATION/AREA</u>	<u>EXAM METHOD</u>	<u>NDE PROCEDURE</u>	<u>EXAM/CAL. SHEET NO.</u>	<u>NI</u>	<u>NRI</u>	<u>RI GEOM/OTHER</u>	<u>REMARKS/BASIC CALIBRATION BLOCK</u>
<u>RPV EXAMINATIONS (Cont'd)</u>									
B6.50 B-G-1	A-33/01	2WASHER-2 Closure Head Washers	VT	VT-H-710/2	S88H2V183				Satisfactory
B6.50 B-G-1	A-33/01	2WASHER-3 Closure Head Washers	VT	VT-H-710/2	S88H2V183				Satisfactory
B6.50 B-G-1	A-33/01	2WASHER-4 Closure Head Washers	VT	VT-H-710/2	S88H2V183				Satisfactory
B6.50 B-G-1	A-33/01	2WASHER-5 Closure Head Washers	VT	VT-H-710/2	S88H2V183				Satisfactory
B6.50 B-G-1	A-33/01	2WASHER-6 Closure Head Washers	VT	VT-H-710/2	S88H2V183				Satisfactory
B6.50 B-G-1	A-33/01	2WASHER-29 Closure Head Washers	VT	VT-H-710/2	S88H2V183				Satisfactory
B6.50 B-G-1	A-33/01	2WASHER-45 Closure Head Washers	VT	VT-H-710/2	S88H2V183				Satisfactory
B6.50 B-G-1	A-33/01	2WASHER-46 Closure Head Washers	VT	VT-H-710/2	S88H2V183				Satisfactory
B6.50 B-G-1	A-33/01	2WASHER-47 Closure Head Washers	VT	VT-H-710/2	S88H2V183				Satisfactory

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 13 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>RPV EXAMINATIONS (Cont'd)</u>									
B6.50 B-G-1	A-33/01	2WASHER-48 Closure Head Washers	VT	VT-H-710/2	S88H2V183			Satisfactory	
B6.50 B-G-1	A-33/01	2WASHER-49 Closure Head Washers	VT	VT-H-710/2	S88H2V183			Satisfactory	
B6.50 B-G-1	A-33/01	2WASHER-50 Closure Head Washers	VT	VT-H-710/2	S88H2V183			Satisfactory	
B6.50 B-G-1	A-33/01	2WASHER-51 Closure Head Washers	VT	VT-H-710/2	S88H2V183			Satisfactory	
B6.50 B-G-1	A-33/01	2WASHER-52 Closure Head Washers	VT	VT-H-710/2	S88H2V183			Satisfactory	
B6.50 B-G-1	A-33/01	2WASHER-53 Closure Head Washers	VT	VT-H-710/2	S88H2V183			Satisfactory	
B6.50 B-G-1	A-33/01	2WASHER-54 Closure Head Washers	VT	VT-H-710/2	S88H2V183			Satisfactory	
B6.50 B-G-1	A-33/01	2WASHER-55 Closure Head Washers	VT	VT-H-710/2	S88H2V183			Satisfactory	
B6.50 B-G-1	A-33/01	2WASHER-56 Closure Head Washers	VT	VT-H-710/2	S88H2V183			Satisfactory	

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 14 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>RPV EXAMINATIONS (Cont'd)</u>									
B13.10 B-N-1	-----	RPV Examination of Vessel Interior	VT	VT-H-750/1	S88H2V115			x	Visual exam revealed cracklike indications See INF I88H2003. Acceptable per GE Letter G-GPC-8-053. Visual exam revealed signs of erosion in all 20 jet pumps. See INF I88H2006. No corrective action required at this outage.
B13.20 B-N-2	-----	RPV Examination of Interior Attachments Within Beltline Reg.	VT	VT-H-750/1	S88H2V115		x		
B13.21 B-N-2	-----	RPV Examination of Interior Attachments Beyond Beltline Reg.	VT	VT-H-750/1	S88H2V115		x		
B13.22 B-N-2	-----	RPV Examination of Core Support Structure	VT	VT-H-750/1	S88H2V115		x		
B15.10 B-P	-----	Class 1 Pressure Retaining Boundary Leakage Test	VT	VT-H-720/1	See Pressure Test Section of Report				

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 15 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>MAIN STEAM SYSTEM</u>									
B10.10 B-K-1	A-6/04	2B21-1MS-24A-5PL-2 Device 2B21-MS-H1	MT	MT-H-500/2	S88H2M046 S88H2M052 S88H2M061	x		x x	Linear indication detected. See INF I88H2009. After grinding, weld was re-examined and deemed acceptable.
B10.10 B-K-1	A-6/04	2B21-1MS-24A-5PL-3 Device 2B21-MS-H1	MT	MT-H-500/2	S88H2M047	y			
B10.10 B-K-1	A-6/04	2B21-1MS-24A-5PL-4 Device 2B21-MS-H1	MT	MT-H-500/2	S88H2M047	x			
B9.31 B-J	A-7/05	2B21-1MS-24B-8BC-2/ 2B21-1MS-8B-BSR Pipe to Branch Connection	MT UT	MT-H-500/2 UT-H-400/7	S88H2M036 S88H2U208 S88H2U209 S88H2C086 S88H2C087			x x x UT Cal. UT Cal.	24-CS-80-1.218-69-H
B10.10 B-K-1	A-7/05	2B21-1MS-24B-8PL-1 Device 2B21-MS-R53	MT	MT-H-500/2	S88H2M030	x			
B10.10 B-K-1	A-7/05	2B21-1MS-24B-8PL-2 Device 2B21-MS-R53	MT	MT-H-500/2	S88H2M030	x			
B10.10 B-K-1	A-7/05	2B21-1MS-24B-8PL-3 Device 2B21-MS-R53	MT	MT-H-500/2	S88H2M030	x			

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 16 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>MAIN STEAM SYSTEM (Cont'd)</u>									
B10.10 B-K-1	A-7/05	2B21-1MS-24B-8PL-4 Device 2B21-MS-R53	MT	MT-H-500/2	S88H2M030	x			
B10.10 B-K-1	A-7/05	2B21-1MS-24B-8PL-5 Device 2B21-MS-R53	MT	MT-H-500/2	S88H2M030	x			
B10.10 B-K-1	A-7/05	2B21-1MS-24B-8PL-6 Device 2B21-MS-R53	MT	MT-H-500/2	S88H2M030	x			
B10.10 B-K-1	A-7/05	2B21-1MS-24B-8PL-7 Device 2B21-MS-R53	MT	MT-H-500/2	S88H2M030	x			
B10.10 B-K-1	A-7/05	2B21-1MS-24B-8PL-8 Device 2B21-MS-R53	MT	MT-H-500/2	S88H2M030	x			
B10.10 B-K-1	A-8/06	2B21-1MS-24C-5PL-1 Device 2B21-MS-H7	MT	MT-H-500/2	S88H2M060	x			
B10.10 B-K-1	A-8/06	2B21-1MS-24C-5PL-3 Device 2B21-MS-H7	MT	MT-H-500/2	S88H2M060	x			
B10.10 B-K-1	A-8/06	2B21-1MS-24C-5PL-4 Device 2B21-MS-H7	MT	MT-H-500/2	S88H2M060	x			
B9.31 B-J	A-8/06	2B21-1MS-24C-8BC-3/ 2B21-1MS-8C-CSR Pipe to Branch Connection	MT UT	MT-H-500/2 UT-H-400/7	S88H2M029 S88H2U039 S88H2U207 S88H2C002 S88H2C085		x x x UT Cal. UT Cal.		24-CS-80-1.218-69-H

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 17 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>MAIN STEAM SYSTEM (Cont'd)</u>									
B9.11 B-J	A-9/05	2B21-1MS-24D-9 Elbow to Pipe	MT UT	MT-H-500/2 UT-H-400/7	S88H2M056 S88H2U197 S88H2C081	x			24-CS-80-1.218-69-H
B10.10 B-K-1	A-9/05	2B21-1MS-24D-9PL-2 Device 2B21-MS-R37	MT	MT-H-500/2	S88H2M031	x			
B10.10 B-K-1	A-9/05	2B21-1MS-24D-9PL-6 Device 2B21-MS-R37	MT	MT-H-500/2	S88H2M031	x			
B10.10 B-K-1	A-9/05	2B21-1MS-24D-9PL-7 Device 2B21-MS-R37	MT	MT-H-500/2	S88H2M031	x			
B10.10 B-K-1	A-9/05	2B21-1MS-24D-9PL-8 Device 2B21-MS-R37	MT	MT-H-500/2	S88H2M031	x			
<u>REACTOR COOLANT PUMPS</u>									
B6.180 B-G-1	---	2RC-A Pump Bolt Pump Bolting 1 through 5	UT	UT-H-420/4	S88H2U224 S88H2C097		x		28-H
B6.200 B-G-1	---	2RC-A Pump-Nuts and Washers 1 through 16	VT	VT-H-710/2	S88H2V203			Satisfactory	
B10.20 B-K-1	A-4/02	2RC-A Pump Lug-1A2 Restraint Lug	PT	PT-H-600/2	S88H2P060			x	Acceptable per IWB-3516-2

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 18 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NR	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>REACTOR COOLANT PUMPS (Cont'd)</u>									
B10.20 B-K-1	A-4/02	2RC-A Pump Lug-3A2 Restraint Lug	PT	PT-H-600/2	S88H2P021		x		
B10.20 B-K-1	A-4/02	2RC-A Pump Lug-3B2 Restraint Lug	PT	PT-H-600/2	S88H2P021		x		
B10.20 B-K-1	A-4/02	2RC-A Pump Lug-3C2 Restraint Lug	PT	PT-H-600/2	S88H2P021		x		
B10.20 B-K-1	A-4/02	2RC-A Pump Lug-3D2 Restraint Lug	PT	PT-H-600/2	S88H2P021		x		
<u>RESIDUAL HEAT REMOVAL SYSTEM</u>									
B7.50 B-G-2	A-20/02	2E11-1RHR-9A-HS-1FB Flange Bolting	VT	VT-H-710/2	S88H2V244			Satisfactory	
<u>CORE SPRAY SYSTEM</u>									
B9.11 B-J	A-25/03	2E21-1CS-10B-13 Elbow to Pipe	MT UT	MT-H-500/2 UT-H-400/7	S88H2M039 S88H2U161 S88H2C066		x x UT Cal.		54-H
<u>HIGH PRESSURE COOLANT INJECTION SYSTEM</u>									
B9.11 B-J	A-26/03	2E41-1HPCI-10-D-7 Pipe to Elbow	MT UT	MT-H-500/2 UT-H-400/7 UT-H-460/1	S88H2M037 S88H2U194 S88H2U195 S88H2C079		x x Weld Profile UT Cal.		10-CS-100-0.719-54-H

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 19 of 34

ASME SECTION XI CAT. NO.	EXAM. FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>HIGH PRESSURE COOLANT INJECTION SYSTEM (Cont'd)</u>									
B9.11 B-J	A-20/03	2E41-1HPCI-10-D-8 Elbow to Pipe	MT UT	MT-H-500/2 UT-H-400/7 UT-H-460/1	S88H2M035 S88H2U165 S88H2U183 S88H2U184 S88H2U206 S88H2C070 S88H2C076			x x Weld Profile x Ind. Eval. UT Cal. UT Cal.	10-CS-100-0.719-54-H Linear indication detected. See INF I88H2007. Acceptable per IWB-3514-2.
<u>VALVE BOLTING</u>									
B7.70 B-G-2	A-5/01	2B21-F013F Valve Bolting	VT	VT-H-710/2	S88H2V216			Satisfactory	
B7.70 B-G-2	A-5/01	2B21-F013G Valve Bolting	VT	VT-H-710/2	S88H2V217			Satisfactory	
B7.70 B-G-2	A-5/01	2B21-F013H Valve Bolting	VT	VT-H-710/2	S88H2V218			Satisfactory	
B7.70 B-G-2	A-5/01	2B21-F013K Valve Bolting	VT	VT-H-710/2	S88H2V219			Satisfactory	
B7.70 B-G-2	A-5/01	2B21-F013L Valve Bolting	VT	GPC-450C- INS-010-0S/0	MWO 2-87-3163			Satisfactory	Exam performed by GPC
B7.70 B-G-2	A-5/01	2B21-F013M Valve Bolting	VT	VT-H-710/2	S88H2V220			Satisfactory	

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 20 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>VALVE BOLTING (Cont'd)</u>									
B7.70 B-G-2	A-28/03	2G31-F004 Valve Bolting	VT	VT-H-710/2	S88H2V198			Satisfactory	
B7.70 B-G-2	A-28/03	2G31-F027 Valve Bolting	VT	VT-H-710/2	S88H2V157			Satisfactory	
<u>VALVE BODIES</u>									
B12.50 B-M-2	----	2B21-F022B Valve Bodies	VT	VT-H-730/3	NA			Satisfactory	Exam Performed By GPC
B12.50 B-M-2	----	2B21-F028B Valve Bodies	VT	VT-H-730/3	NA			Satisfactory	Exam Performed By GPC
<u>CORE SPRAY SPARGER SYSTEM</u>									
---	---	2N5A Sparger A-A Loop Nozzle	VT	VT-H-750/1	S88H2V115		x		IEB-80-13
---	---	2N5B Sparger A-B Loop Nozzle	VT	VT-H-750/1	S88H2V115		x		IEB-80-13

NOTE: Valve 2B21-F010A was disassembled for maintenance, however only a limited visual examination was performed. Valve 2B21-F010B was disassembled and visually examined during the Fall 1986 outage, therefore the requirement of ASME Section XI, IWB-2500-1, Examination Category B-M-2 has been satisfied (See NIS-1, Page 156).

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 21 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>MUREG-0313 EXAMINATIONS</u>									
---	---	2N2F RINTSA Weld	UT	UT-H-415/2	S88H2U190 S88H2C078			x UT Cal.	RINTSA-125-H
---	---	2N2G RINTSA Weld	UT	UT-H-415/2	S88H2U193 S88H2C078			x UT Cal.	RINTSA-125-H
---	---	2N2H RINTSA Weld	UT	UT-H-415/2	S88H2U191 S88H2C078			x UT Cal.	RINTSA-125-H
---	---	2N2J RINTSA Weld	UT	UT-H-415/2	S88H2U192 S88H2C078			x UT Cal.	RINTSA-125-H
---	---	2N2K RINTSA Weld	UT	UT-H-415/2	S88H2U189 S88H2C078			x UT Cal.	RINTSA-125-H
B5.10 B-F	A-37/00	2B31-1RC-4JP-A-1 Nozzle 2N8A to Safe-End	PT UT	PT-H-600/2 UT-H-409/3 UT-H-400/7	S88H2P047 S88H2U119 S88H2U147 S88H2C037 S88H2C055		x	x UT Cal. UT Cal.	5.437-SS-X-0.813-121-H
B9.11 B-J	A-37/00	2B31-1RC-4JP-A-2 Safe End to Penetration Seal	PT UT	PT-H-600/2 UT-H-401/6	S88H2P034 S88H2U117 S88H2C036		x	x UT Cal.	4-SS-80-0.337-80-H

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 22 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
NUREG-0313 EXAMINATIONS (Cont'd)									
B5.10 B-F	A-37/00	2B31-1RC-4JP-B-1 Nozzle 2N88 to Safe-End	PT UT	PT-H-600/2 UT-H-409/3 UT-H-400/7	S88H2P035 S88H2U120 S88H2U146 S88H2C038 S88H2C054		x	x UT Cal. UT Cal.	5.437-SS-X-0.813-121-H
B9.11 B-J	A-37/00	2B31-1RC-4JP-B-2 Safe End to Penetration Seal	PT UT	PT-H-600/2 UT-H-401/6	S88H2P036 S88H2J118 S88H2C036		x	x UT Cal.	4-SS-80-0.337-80-H
B9.11 B-J	A-14/02	2B31-1RCM-12AF-3 Pipe to Safe-End	PT UT	PT-H-600/2 UT-H-401/6	S88H2P023 S88H2U109 S88H2U111 S88H2C033 S88H2C034		x	x x UT Cal. UT Cal.	12-SS-0.792-132-H
B9.12 B-J	A-14/02	2B31-1RCM-12AF-3LU Longitudinal Seam Weld Extending Upstream	PT UT	PT-H-600/2 UT-H-401/6	S88H2P022 S88H2U106 S88H2C033		x	x UT Cal.	12-SS-0.792-132-H
B9.11 B-J	A-14/02	2B31-1RCM-12AG-2 Pipe to Safe-End	PT UT	PT-H-600/2 UT-H-401/6	S88H2P013 S88H2U067 S88H2U068 S88H2U069 S88H2C014 S88H2C015		x	x x Weld Profile UT Cal. UT Cal.	12-SS-0.792-132-H

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 23 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>NUREG-0313 EXAMINATIONS (Cont'd)</u>									
B9.11 B-J	A-14/02	2B31-1RCM-12AH-2 Pipe to Safe-End	PT UT	PT-H-600/2 UT-H-401/6	S88H2P031 S88H2U108 S88H2U110 S88H2C033 S88H2C034		x	x	12-SS-0.792-132-H
B9.11 B-J	A-14/02	2B31-1RCM-12AJ-2 Pipe to Safe-End	PT UT	PT-H-600/2 UT-H-401/6	S88H2P012 S88H2U070 S88H2U071 S88H2U072 S88H2C016 S88H2C017		x	UT Cal. UT Cal.	12-SS-0.792-132-H
B9.12 B-J	A-14/02	2B31-1RCM-12AJ-2LU Longitudinal Seam Weld Extending Upstream	PT UT	PT-H-600/2 UT-H-401/6	S88H2P033 S88H2U107 S88H2C033		x	UT Cal.	12-SS-0.792-132-H
B9.11 B-J	A-14/02	2B31-1RCM-12AK-3 Pipe to Safe-End	PT UT	PT-H-600/2 UT-H-401/6	S88H2P014 S88H2U065 S88H2U066 S88H2C012 S88H2C013		x	UT Cal. UT Cal.	12-SS-0.792-132-H
B9.11 B-J	A-15/02	2B31-1RCM-12BA-3 Pipe to Safe-End	PT UT	PT-H-600/2 UT-H-401/6	S88H2P030 S88H2U073 S88H2U074 S88H2C018 S88H2C019		x	UT Cal. UT Cal.	12-SS-0.792-132-H

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 24 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>NUREG-0313 EXAMINATIONS (Cont'd)</u>									
B9.11 B-J	A-15/02	2B31-1RCM-12BB-2 Pipe to Safe-End	PT UT	PT-H-600/2 UT-H-401/6	S88H2P032 S88H2U076 S88H2U077 S88H2C020 S88H2C021		x x x UT Cal. UT Cal.		12-SS-0.792-132-H
B9.11 B-J	A-15/02	2B31-1RCM-12BC-2 Pipe to Safe-End	PT UT	PT-H-600/2 UT-H-401/6	S88H2P024 S88H2U063 S88H2U064 S88H2C010 S88H2C011		x x x UT Cal. UT Cal.		12-SS-0.792-132-H
B9.11 B-J	A-15/02	2B31-1RCM-12BD-2 Pipe to Safe-End	PT UT	PT-H-600/2 UT-H-401/6	S88H2P025 S88H2U101 S88H2U103 S88H2C031 S88H2C032		x x UT Cal. UT Cal.	x	12-SS-0.792-132-H
B9.11 B-J	A-15/02	2B31-1RCM-12BE-3 Pipe to Safe-End	PT UT	PT-H-600/2 UT-H-401/6	S88H2P026 S88H2U100 S88H2U102 S88H2C031 S88H2C032		x x UT Cal. UT Cal.	x x	12-SS-0.792-132-H

Edwin I. Hatch Unit 2
1986 Winter Refueling Outage
Class 1 Components
Page 25 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
NUREG-0313 EXAMINATIONS (Cont'd)									
B9.11 B-J	A-17/02	2B31-1RCM-28AD-1 Pump to Pipe	PT UT	PT-H-600/2 UT-H-401/6	S88H2P002 S88H2P051 S88H2U094 S88H2U097 S88H2C029 S88H2C030		x	x	22-SS-1.184-128-H Linear and rounded indications. After flapping, weld was found to be acceptable.
B9.11 B-J	A-17/02	2B31-1RCM-28AD-2 Pipe to Valve	PT UT	PT-H-600/2 UT-H-401/6	S88H2P003 S88H2U095 S88H2U098 S88H2C029 S88H2C030	x		x	28-SS-1.184-128-H
B9.11 B-J	A-17/02	2B31-1RCM-28AD-3 Valve to Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P004 S88H2U096 S88H2U099 S88H2C029 S88H2C030	x		x	28-SS-1.184-128-H
B9.11 B-J	A-16/03	2B31-1RCM-28AS-2 Safe-End to Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P028 S88H2U083 S88H2U089 S88H2C024 S88H2C026		x	x	28-SS-1.184-128-H
B9.12 B-J	A-16/03	2B31-1RCM-28AS-2LD-1 Longitudinal Weld Downstream on Inside of Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P027 S88H2U084 S88H2C024		x	x	28-SS-1.184-128-H

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 26 of 34

ASML SECTION x1 CAL. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
NUREG-0313 EXAMINATIONS (Cont'd)									
B9.12 B-J	A-16/03	2B31-1RCM-28AS-2LD-0 Longitudinal Weld Downstream on Outside of Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P029 S88H2U085 S88H2C024		x x	UT Cal.	28-SS-1.184-128-H
B9.11 B-J	A-16/03	2B31-1RCM-28AS-8 Elbow to Valve	PT UT	PT-H-600/2 UT-H-401/6	S88H2P039 S88H2U078 S88H2U086 S88H2C024 SS8H2C025		x	x x UT Cal. UT Cal.	28-SS-1.184-128-H
B9.12 B-J	13	2B31-1RCM-28AS-8LU-1 Longitudinal Weld Upstream on Inside of Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P038 S88H2U079 S88H2C024		x x	UT Cal.	28-SS-1.184-128-H
B9.12 B-J	A-16/03	2B31-1RCM-28AS-8LU-0 Longitudinal Weld Upstream on Outside of Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P040 S88H2U080 S88H2C024		x x	UT Cal.	28-SS-1.184-128-H
B9.11 B-J	A-16/03	2B31-1RCM-28AS-9 Valve to Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P015 S88H2U081 S88H2U087 S88H2C024 S88H2C025		x x x	UT Cal. UT Cal.	28-SS-1.184-128-H

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 27 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>NUREG-0313 EXAMINATIONS (Cont'd)</u>									
B9.11 B-J	A-16/03	2B31-1RCM-28AS-10 Elbow to Pump	PT UT	PT-H-600/2 UT-H-401/6	S88H2P016 S88H2U082 S88H2UG88 S88H2C024 S88H2C025		x x x UT Cal. UT Cal.		28-SS-1.184-128-H
B9.11 B-J	A-19/02	2B31-1RCM-28BD-1 Pump to Pipe	PT UT	PT-H-600/2 UT-H-401/6	S88H2P017 S88H2U056 S88H2U058 S88H2C006 S88H2C008		x x UT Cal. UT Cal.	x	28-SS-1.184-128-H
B9.12 B-J	A-19/02	2B31-1RCM-28BD-1LD Longitudinal Seam Weld Extending Downstream	PT UT	PT-H-600/2 UT-H-401/6	S88H2P018 S88H2U057 S88H2C007	x	x UT Cal.		28-SS-1.184-128-H
B9.11 B-J	A-19/02	2B31-1RCM-28BD-2 Pipe to Valve	PT UT	PT-H-600/2 UT-H-401/6	S88H2P019 S88H2U055 S88H2U075 S88H2C005 S88H2C008		x x UT Cal. UT Cal.	x	28-SS-1.184-128-H

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 28 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
NUREG-0313 EXAMINATIONS (Cont'd)									
B9.11 B-J	A-19/02	2B31-1RCM-28BD-3 Valve to Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P020 S88H2U159 S88H2U160 S88H2C064 S88H2C065		x x x	UT Cal. UT Cal.	28-SS-1.184-128-H
B9.11 B-J	A-18/03	2B31-1RCM-28BS-2 Safe End to Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P041 S88H2U090 S88H2U091 S88H2C027 S88H2C028		x x x	UT Cal. UT Cal.	28-SS-1.184-128-H
B9.12 B-J	A-18/03	2B31-1RCM-28BS-2LD-I Longitudinal Weld Downstream on Inside of Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P042 S88H2U092 S88H2C028		x x	UT Cal.	28-SS-1.184-128-H
B9.12 B-J	A-18/03	2B31-1RCM-28BS-2LD-0 Longitudinal Weld Downstream on Outside of Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P043 S88H2U093 S88H2C028		x x	UT Cal.	28-SS-1.184-128-H
B9.11 B-J	A-18/03	2B31-1RCM-28BS-7 Elbow to Valve	PT UT	PT-H-600/2 UT-H-401/6	S88H2P007 S88H2U122 S88H2U127 S88H2C022 S88H2C023		x x x	UT Cal. UT Cal.	28-SS-1.184-128-H

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 29 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
NUREG-0313 EXAMINATIONS (Cont'd)									
B9.11 B-C	A-18/03	2B31-1RCM-28BS-8 Valve to Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P0C8 S88H2U123 S88H2U128 S88H2C022 S88H2C023		x x x UT Cal. UT Cal.		28-SS-1.184-128-H
B9.11 B-J	A-18/03	2B31-1RCM-28BS-9 Elbow to Pump	PT UT	PT-H-600/2 UT-H-401/6	S88H2P011 S88H2U124 S88H2U129 S88H2C022 S88H2C023		x x UT Cal. UT Cal.	x	28-SS-1.184-128-H
B9.12 B-J	A-18/03	2B31-1RCM-28BS-9LU-I Longitudinal Weld Upstream on Inside of Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P010 S88H2U125 S88H2C022		x x UT Cal.		28-SS-1.184-128-H
B9.12 B-J	A-18/03	2B31-1RCM-28BS-9LU-0 Longitudinal Weld Upstream on Outside of Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P009 S88H2U126 S88H2C022		x UT Cal.	x	28-SS-1.184-128-H
B5.50 B-F	A-21/03	2E11-1RHRM-20RS-3 Elbow to Pipe	PT UT	PT-H-600/2 UT-H-401/6	S88H2P057 S88H2P061 S88H2U166 S88H2C071		x UT Cal.	x x	20-SS-0.879-130-H Linear indication. Acceptable after surface preparation.

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 30 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>NUREG-0313 EXAMINATIONS (Cont'd)</u>									
B9.12 B-J	A-21/03	2E11-1RHRM-2ORS-3LU-1 Longitudinal Weld Upstream on Inside of Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P005 S88H2U168 S88H2C072		x x UT Cal.		20-SS-0.879-130-H
B9.12 B-J	A-21/03	2E11-1RHRM-2ORS-3LU-0 Longitudinal Weld Upstream on Outside of Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P006 S88H2U167 S88H2C072		x x UT Cal.		20-SS-0.879-130-H
B5.50 B-F	A-22/03	2E11-1RHRM-24A-10 Pipe to Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P044 S88H2U158 S88H2C063		x UT Cal.	x	24-SS-1.186-131-H
B5.50 B-F	A-23/03	2E11-1RHRM-24B-10 Pipe to Elbow	PT UT	PT-H-600/2 UT-H-401/6	S88H2P062 S88H2U210 S88H2C088		 UT Cal.	x	24-SS-1.186-131-H Acceptable per IWB-3514-3
B5.50 B-F	A-24/03	2E21-1CS-10A-20 Pipe to Safe-End	PT UT	PT-H-600/2 UT-H-400/7	S88H2P037 S88H2U199 S88H2C082		x UT Cal.	x	10-9-IN-X-0.600-79-H
B5.10 B-F	A-24/03	2E21-1CS-10A-21 Safe-End to Nozzle	PT UT	PT-H-600/2 UT-H-400/7 UT-H-409/3	S88H2P045 S88H2P055 S88H2U149 S88H2U150 S88H2U151 S88H2C048 S88H2C056		x x Weld Profile UT Cal. UT Cal.	x	13.2-IN-X-1.200-78-H Rounded indication. Acceptable after surface preparation.

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 1 Components
Page 31 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>NUREG-0313 EXAMINATIONS (Cont'd)</u>									
B5.50 B-F	A-25/03	2E21-1CS-10B-19 Pipe to Safe-End	PT UT	PT-H-600/2 UT-H-400/7	S88H2P056 S88H2U198 S88H2C082		x UT Cal.	x	10-9-IN-X-0.600-79-H
B5.10 B-F	A-25/03	2E21-1CS-10B-20 Safe-End Nozzle	PT UT	PT-H-600/2 UT-H-400/7 UT-H-409/3	S88H2P048 S88H2U138 S88H2U139 S88H2U148 S88H2C047 S88H2C056		x Weld Profile UT Cal. UT Cal.	x	13.2-IN-X-1.200-78-H
B9.11 B-J	A-28/03	2G31-1RWCUM-6-D-17 Valve to Penetration	PT JT	PT-H-600/2 UT-H-400/7	S88H2P050 S88H2U154 S88H2U155 S88H2C059 S88H2C060		x x x UT Cal. UT Cal.		2-H
B9.12 B-J	A-28/03	2G31-1RWCUM-6-D-6 Pipe to Valve	PT UT	PT-H-600/2 UT-H-401/6	S88H2P053 S88H2U134 S88H2U135 S88H2C043 S88H2C044		x x x UT Cal. UT Cal.		6-SS-0.432-133-H
B9.12 B-J	A-28/03	2G31-1RWCUM-6-D-6LU Longitudinal Seam Weld Extending Upstream	PT UT	PT-H-600/2 UT-H-401/6	S88H2P052 S88H2U133 S88H2C042	x	 x UT Cal.		6-SS-0.432-133-H

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 32 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>NUREG-0313 EXAMINATIONS (Cont'd)</u>									
B9.11 B-J	A-28/03	2G31-1RWCUM-6-D-7 Valve to Pipe	PT UT	PT-H-600/2 UT-H-401/6	S88H2P051 S88H2U136 S88H2U137 S88H2C045 S88H2C046		x x x UT Cal. UT Cal.		6-SS-0.432-133-H
B9.11 B-J	A-28/03	2G31-1RWCUM-6-D-14 Pipe to Valve	PT UT	PT-H-600/2 UT-H-401/6	S88H2P049 S88H2U156 S88H2U157 S88H2C061 S88H2C062		x x x UT Cal. UT Cal.		6-SS-0.432-133-H
B9.11 B-J	A-28/03	2G31-1RWCUM-6-D-15 Penetration to Pipe	PT UT	PT-H-600/2 UT-H-401/6	S88H2P065 S88H2U219 S88H2U221 S88H2C094 S88H2C095	x x		x UT Cal. UT Cal.	6-SS-0.432-133-H
B9.11 B-J	A-28/03	2G31-1RWCUM-6-D-16 Pipe to Valve	PT UT	PT-H-600/2 UT-H-401/6	S88H2P063 S88H2U220 S88H2U222 S88H2C094 S88H2C095	x		x x UT Cal. UT Cal.	6-SS-0.432-133-H
B9.12 B-J	A-28/03	2G31-1RWCUM-6-D-16LU Longitudinal Seam Weld Extending Upstream	PT UT	PT-H-600/2 UT-H-401/6	S88H2P064 S88H2U223 S88H1C096	x x		UT Cal.	6-SS-0.432-133-H

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 33 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>NUREG-0619 EXAMINATIONS</u>									
B9.11 B-J	A-10/03	2B21-1FW-12AA-12 Transition Piece To Nozzle	MT UT	MT-H-500/2 UT-H-400/7	S88H2M038 S88H2U162 S88H2U163 S88H2U164 S88H2C067 S88H2C068 S88H2C069		x x	x x	16-CS-100-1.031-53-H No significant change in length or depth when compared to past outages.
<u>JET PUMP BEAM EXAMINATIONS</u>									
---	---	RPV Jet Pump Beams No. 1-20	UT	UT-H-414/2	S88H2U130 S88H2C040		UT Cal.	x	JPB-124-H Crack-like indi- cation in jet pump beam #20. See INF I88H2004. Jet pump beam was removed and replaced.
---	---	RPV Jet Pump Beams No. 20	UT	UT-H-414/2	S88H2U196 S88H2U218 S88H2C080 S88H2C093		x x UT Cal. UT Cal.		JPB-124-H Replacement Beam Baseline Exam.

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 1 Components
 Page 34 of 34

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>SHROUD HEAD BOLTS</u>									
---	---	Shroud Head Bolts 1 thru 36	UT	UT-H-418/0	S88H2U036 S88H2C001			UT Cal. x	INC-SHB-136-H Crack-like indications found. See INF 188H2002. Six of the 8 cracked bolts were removed and replaced. No re-exam required at this time per GE MDE 39-0286. Re-exam next outage.

Exam figures referenced throughout these tables are a part of the SCS-ISI Examination Plan and can be reviewed at the Plant Site.

INFs referenced throughout these tables are part of the SCS Final Report and may be reviewed at the Plant Site.

SUMMARY
OF
CLASS 2 COMPONENTS

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 2 Components
 Page 1 of 10

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>RESIDUAL HEAT REMOVAL SYSTEM</u>									
C6.10 C-G	B-2/02	2E11-2RHR-PMI-A RHR Pump A Inlet Nozzle Weld	MT	MT-H-500/2 VT-H-710/2	S88H2M015 S88H2V048		x	Satisfactory	Limited MT Exam, Supplemented by VT.
C6.10 C-G	B-2/02	2E11-2RHR-POP-A-1 Flange to Elbow RHR Pump A	MT	MT-H-500/2	S88H2M011		x		
C6.10 C-G	B-2/02	2E11-2RHR-POP-A-1BC/ Shaft-Elbow to BC RHR Pump A	MT	MT-H-500/2	S88H2M012		x		
C6.10 C-G	B-2/02	2E11-2RHR-POP-A-2 Elbow to Flange RHR Pump A	MT	MT-H-500/2	S88H2M013		x		
C5.11 C-F	B-23/03	2E11-2RHR-8-FPS-8 45-Degree Elbow to 45-Degree Elbow	MT	MT-H-500/2	S88H2M067 S88H2M070		x	x	Linear indication. See INF I88H2016. After grinding, weld was re-examined and found to be acceptable.
C5.11 C-F	B-23/03	2E11-2RHR-8-FPS-21 Elbow to Pipe	MT	MT-H-500/2	S88H2M050	x			
C3.40 C-C	B-14/05	2E11-2RHR-16A-DS-7APS-1 Device 2E11-RHR-H321	MT	MT-H-500/2	S88H2M044		x		

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 2 Components
 Page 2 of 10

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>RESIDUAL HEAT REMOVAL SYSTEM Cont'd)</u>									
C3.40 C-C	B-14/05	2E11-2RHR-16A-DS-7APS-2 Device 2E11-RHR-H321	MT	MT-H-500/2	S88H2M045		x		
C5.11 C-F	B-14/05	2E11-2RHR-16A-DS-8 Pipe to Elbow	MT	MT-H-500/2	S88H2M043		x		
C3.40 C-C	B-29/03	2E11-2RHR-16A-PD-C-3PL-1 Device 2E11-RHR-H180	MT	MT-H-500/2	S88H2M014		x		
C3.40 C-C	B-29/03	2E11-2RHR-16A-PD-C-3PL-2 Device 2E11-RHR-H180	MT	MT-H-500/2	S88H2M014		x		
C3.40 C-C	B-29/03	2E11-2RHR-16A-PD-C-3PL-3 Device 2E11-RHR-H180	MT	MT-H-500/2	S88H2M014		x		
C3.40 C-C	B-29/03	2E11-2RHR-16A-PD-C-3PL-4 Device 2E11-RHR-H180	MT	MT-H-500/2	S88H2M016 S88H2M020		x	x	Linear indication. After flapping, weld was re-examined and found to be acceptable.
C5.11 C-F	B-36/02	2E11-2RHR-20B-D-3 Pipe to 45-Degree Elbow	MT	MT-H-500/2	S88H2M068 S88H2M059		x	x	Linear indication. See INF I88H2017. After grinding, weld was re-examined and found to be acceptable.

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 2 Components
Page 3 of 10

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>RESIDUAL HEAT REMOVAL SYSTEM Cont'd)</u>									
C5.11 C-F	B-36/02	2E11-2RHR-20B-D-8 Elbow to Pipe	MT	MT-H-500/2	S88H2M005		x		
C5.11 C-F	B-38/03	2E11-2RHR-20D-D-8 Pipe to Elbow	MT	MT-H-500/2	S88H2M019		x		
C3.40 C-C	B-38/03	2E11-2RHR-20D-D-10PL-1 Device 2E11-RHR-H174	MT	MT-H-500/2	S88H2M026		x		
C3.40 C-C	B-38/03	2E11-2RHR-20D-D-10PL-2 Device 2E11-RHR-H174	MT	MT-H-500/2	S88H2M026		x		
C3.40 C-C	B-38/03	2E11-2RHR-20D-D-10PL-3 Device 2E11-RHR-H174	MT	MT-H-500/2	S88H2M026		x		
C3.40 C-C	B-38/03	2E11-2RHR-20D-D-10PL-4 Device 2E11-RHR-H174	MT	MT-H-500/2	S88H2M026		x		
C5.11 C-F	B-38/03	2E11-2RHR-20D-D-11 Pipe to Branch Connection	MT	MT-H-500/2	S88H2M025		x		
<u>CORE SPRAY SYSTEM</u>									
C3.40 C-C	B-53/02	2E21-2CS-10A-TL-15 Pipe to Torus Penetration	MT	MT-H-500/2	S88H2M049	x			

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 2 Components
Page 4 of 10

<u>ASME SECTION XI CAT. NO.</u>	<u>EXAM FIG. NO.</u>	<u>EXAMINATION/AREA</u>	<u>EXAM METHOD</u>	<u>NDE PROCEDURE</u>	<u>EXAM/CAL. SHEET NO.</u>	<u>NI</u>	<u>NRI</u>	<u>RI GEOM/OTHER</u>	<u>REMARKS/BASIC CALIBRATION BLOCK</u>
<u>CORE SPRAY SYSTEM (Cont'd)</u>									
C3.40 C-C	B-61/03	2E21-2CS-20A-TS-1 Torus Penetration X-208A to Pipe	VT	VT-H-710/2	S88H2V2G9			Satisfactory	Inaccessible for surface exam
C3.40 C-C	B-61/03	2E21-2CS-20A-TS-12PS-1 Device 2E21-CS-H708	MT	MT-H-500/2	S88H2M021		x		
C3.40 C-C	B-61/03	2E21-2CS-20A-TS-12PS-2 Device 2E21-CS-H708	MT	MT-H-500/2	S88H2M022		x		
C3.40 C-C	B-61/03	2E21-2CS-20A-TS-12PS-2A Device 2E21-CS-R41	MT	MT-H-500/2	S88H2M027		x		
<u>HIGH PRESSURE COOLANT INJECTION SYSTEM</u>									
C5.21 C-F	B-66/03	2E41-2HPCI-14-R-37 Pipe to Elbow	MT UT	MT-H-500/2 UT-R-400/7	S88H2M028 S88H2U059 S88H2U060 S88H2C009		x	x Contour Report UT Cal.	14-CS-80-0.750-116-H
C5.21 C-F	B-66/03	2E41-2HPCI-14-R-43 Pipe to Elbow	MT UT	MT-H-500/2 UT-H-400/7	S88H2M059 S88H2U211 S88H2C089	x	x	UT Cal.	14-CS-100-0.938-43-H
C5.11 C-F	B-69/03	2E41-2HPCI-20TD-B Elbow to Pipe	MT	MT-H-500/2	S88H2M008		x		

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 2 Components
Page 5 of 10

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>HIGH PRESSURE COOLANT INJECTION SYSTEM (Cont'd)</u>									
C3.40 C-C	B-69/03	2E41-2HPCI-20-TD-15PS-1 Device 2E41-HPCI-R22	MT	MT-H-500/2	S88H2M024			x	
C3.40 C-C	B-69/03	2E41-2HPCI-20-TD-15PS-2 Device 2E41-HPCI-R22	MT	MT-H-500/2	S88H2M024			x	
C5.11 C-F	B-69/03	2E41-2HPCI-20-TD-19 Pipe to Reducer	MT	MT-H-500/2	S88H2M051	x			
<u>MAIN STEAM SYSTEM</u>									
C3.40 C-C	B-7/03	2N11-2MSA-16A-13PL-1 Device 2N11-MS-R69	MT	MT-H-500/2	S88H2M018			x	
C3.40 C-C	B-7/03	2N11-2MSA-16A-13PL-2 Device 2N11-MS-R69	MT	MT-H-500/2	S88H2M018			x	
C3.40 C-C	B-7/03	2N11-2MSA-16A-13PL-3 Device 2N11-MS-R69	MT	MT-H-500/2	S88H2M018			x	
C3.40 C-C	B-7/03	2N11-2MSA-16A-13PL-4 Device 2N11-MS-R69	MT	MT-H-500/2	S88H2M018			x	
C3.40 C-C	B-7/03	2N11-2MSA-16A-13PL-5 Device 2N11-MS-R69	MT	MT-H-500/2	S88H2M018			x	

Edwin I. Hatch Unit 2
 '938 Winter Refueling Outage
 Class 2 Components
 Page 6 of 10

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>MAIN STEAM SYSTEM (Cont'd)</u>									
C3.40 C-C	B-7/03	2N11-2MSA-16A-13PL-6 Device 2N11-MS-R69	MT	MT-H-500/2	S88H2M018		x		
C3.40 C-C	B-7/03	2N11-2MSA-16A-13PL-7 Device 2N11-MS-R69	MT	MT-H-500/2	S88H2M018		x		
C3.40 C-C	B-7/03	2N11-2MSA-16A-13PL-8 Device 2N11-MS-R69	MT	MT-H-500/2	S88H2M018		x		
C5.21 C-F	B-7/03	2N11-2MSA-16C-16 Pipe to Pipe	MT UT	MT-H-500/2 UT-H-400/7	S88H2M034 S88H2U140 S88H2C050	x	x UT Cal.		16-CS-100-1.031-53-H
C5.31 C-F	B-9/03	2N11-2MSA-24A-11BC/ 2N11-2MSA-6A-SJAE Pipe to Branch Connection	MT UT	MT-H-500/2 UT-H-400/7	S88H2M055 S88H2U152 S88H2U153 S88H2C057 S88H2C058	x	x x UT Cal. UT Cal.		12-H
C3.40 C-C	B-9/03	2N11-2MSA-24A-11PL-1 Device 2N11-MS-A60	MT	MT-H-500/2	S88H2M023		x		
C3.40 C-C	B-9/03	2N11-2MSA-24A-11PL-2 Device 2N11-MS-A60	MT	MT-H-500/2	S88H2M023		x		

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 2 Components
 Page 7 of 10

ASME SECTION XI CAT. NO.	EXAM FIS. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>MAIN STEAM SYSTEM (Cont'd)</u>									
C3.40 C-C	B-9/03	2N11-2MSA-24A-11PL-3 Device 2N11-MS-A60	MT	MT-H-500/2	S88H2M023		x		
C3.40 C-C	B-9/03	2N11-2MSA-24A-11PL-4 Device 2N11-MS-A60	MT	MT-H-500/2	S88H2M023		x		
C3.40 C-C	B-9/03	2N11-2MSA-24A-11PL-5 Device 2N11-MS-A60	MT	MT-H-500/2	S88H2M023		x		
C3.40 C-C	B-9/03	2N11-2MSA-24A-11PL-6 Device 2N11-MS-A60	MT	MT-H-500/2	S88H2M023		x		
C3.40 C-C	B-9/03	2N11-2MSA-24A-11PL-7 Device 2N11-MS-A60	MT	MT-H-500/2	S88H2M023		x		
C3.40 C-C	B-9/03	2N11-2MSA-24A-11PL-8 Device 2N11-MS-A60	MT	MT-H-500/2	S88H2M023		x		
C3.40 C-C	B-10/03	2N11-2MSA-24B-1PS-1 Pipe Support	MT	MT-H-500/2	S88H2M057 S88H2M065 S88H2M072 S88H2M073		x	x x x	Linear Indications. See INF 188H2015. After grinding, and repair welding, welds found to be acceptable.

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 2 Components
 Page 8 of 10

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>MAIN STEAM SYSTEM (Cont'd)</u>									
C3.40 C-C	B-10/03	2N11-2MSA-24B-1PS-2 Pipe Support	MT	MT-H-500/2	S88H2M058 S88H2M066 S88H2M071			x x	Linear indication. See INF I88H2015. After grinding weld found to be acceptable.
C5.21 C-F	B-10/03	2N11-2MSA-24B-18 Tee to Pipe	MT UT	MT-H-500/2 UT-H-400/7	S88H2M033 S88H2U121 S88H2C039	x		x UT Cal.	12-H
C3.40 C-C	B-11/03	2N11-2MSA-24C-6PL-1 Device 2N11-MS-R54	MT	MT-H-500/2	S88H2M017			x	
C3.40 C-C	B-11/03	2N11-2MSA-24C-6PL-2 Device 2N11-MS-R54	MT	MT-H-500/2	S88H2M017			x	
C3.40 C-C	B-11/03	2N11-2MSA-24C-6PL-3 Device 2N11-MS-R54	MT	MT-H-500/2	S88H2M017			x	
C3.40 C-C	B-11/03	2N11-2MSA-24C-6PL-4 Device 2N11-MS-R54	MT	MT-H-500/2	S88H2M017			x	
C3.40 C-C	B-11/03	2N11-2MSA-24C-6PL-5 Device 2N11-MS-R54	MT	MT-H-500/2	S88H2M017			x	

Edwin I. Hatch Unit 2
 1988 Winter Refueling Outage
 Class 2 Components
 Page 9 of 10

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>MAIN STEAM SYSTEM (Cont'd)</u>									
C3.40 C-C	B-11/03	2N11-2MSA-24C-6PL-6 Device 2N11-MS-R54	MT	MT-H-500/2	S88H2M017			x	
C3.40 C-C	B-11/03	2N11-2MSA-24C-6PL-7 Device 2N11-MS-R54	MT	MT-H-500/2	S88H2M017			x	
C3.40 C-C	B-11/03	2N11-2MSA-24C-6PL-8 Device 2N11-MS-R54	MT	MT-H-500/2	S88H2M017			x	
C3.40 C-C	B-12/03	2N11-2MSA-24D-8PL-5 Device 2N11-MS-R51	MT	MT-H-500/2	S88H2M054	x			
C3.40 C-C	B-12/03	2N11-2MSA-24D-8PL-6 Device 2N11-MS-R51	MT	MT-H-500/2	S88H2M054	x			
C3.40 C-C	B-12/03	2N11-2MSA-24D-8PL-7 Device 2N11-MS-R51	MT	MT-H-500/2	S88H2M054	x			
C3.40 C-C	B-12/03	2N11-2MSA-24D-8PL-8 Device 2N11-MS-R51	MT	MT-H-500/2	S88H2M054	x			
C5.21 C-F	B-12/03	2N11-2MSA-24D-9 Pipe to Elbow	MT UT	MT-H-500/2 UT-H-400/7	S88H2M032 S88H2U116 S88H2C035	x		x UT Cal.	12-H

Edwin I. Hatch Unit 2
1988 Winter Refueling Outage
Class 2 Components
Page 10 of 10

ASME SECTION XI CAT. NO.	EXAM FIG. NO.	EXAMINATION/AREA	EXAM METHOD	NDE PROCEDURE	EXAM/CAL. SHEET NO.	NI	NRI	RI GEOM/OTHER	REMARKS/BASIC CALIBRATION BLOCK
<u>AUGMENTED EXAMINATIONS</u>									
---	B73A/01	2E41-2HPCI-6-CS-1 BC to Flange	PT	PT-H-600/2	S88H2P001		x		
---	B-73/03	2E41-2HPCI-16-TS-9 Pipe to Elbow	MT	MT-H-500/2	S88H2M010		x		
---	B-73/03	2E41-2HPCI-16-TS-18 45 Degree Elbow to Tee	MT	MT-H-500/2	S88H2M009		x		
<u>NUREG-0619 EXAMINATIONS</u>									
---	B-83/02	2G31-2RWCU-4-2FW-3052 Tee to Pipe	UT	UT-H-400/7	S88H2U204 S88H2U205 S88H2C083 S88H2C084		x x UT Cal. UT Cal.		4-H
---	B-83/02	2C11-2CRD-3-2FW-1611 Pipe to Reducer	UT	UT-H-400/7	S88H2U202 S88H2U203 S88H2C083 S88H2C084		x x UT Cal. UT Cal.		4-H
---	B-83/02	2C11-2CRD-4-2FW-1611 Reducer to Tee	UT	UT-H-400/7	S88H2U200 S88H2U201 S88H2C083 S88H2C084		x x UT Cal. UT Cal.		4-H

Exam Figures referenced throughout these tables are a part of the SCS-ISI Examination Plan and can be reviewed at the Plant Site.

INFs referenced throughout these tables are part of the SCS Final Report and may be reviewed at the Plant Site.

SUMMARY
OF
CLASS 1, 2, AND 3 PRESSURE TESTS

PRESSURE TESTING

This section of the report provides a discussion of the pressure tests that were performed during the Plant Hatch Unit 2 Winter 1988 Refueling Outage. These pressure tests were performed for the purpose of inservice inspection on selected Class 1, 2, and 3 piping systems. The pressure tests and their boundaries are identified in the inservice examination plan prepared by Southern Company Services, Revision 1.

All pressure tests were performed in accordance with ASME Section XI, 1980 Edition with Addenda through Winter 1981. All tests were witnessed and/or reviewed by the resident ANI/ANII. The completed test reports are available for review in the Records Management Department at the plant site.

TESTING

Class 1

No class 1 Hydrostatic Tests were performed during this outage. A Class 1 System Leakage Test, 2B21-LT-1, was performed prior to unit start-up per ASME XI, Section IWA-5211(a). This test was performed using GPC Procedure 42IT-TET-006-2S under Maintenance Work Order 2-87-3043. The pressure and examination boundary was in accordance with ASME Section XI, Table IWB-2500-1 Examination Category B-P, Note 1.

Only minor leakage was detected during VT-2 examination and after some repair work the Class 1 System was deemed acceptable by plant engineering.

Any Class 1 system Components not examined during performance of 42IT-TET-006-2S were examined during plant start-up using GPC procedure 42IT-TET-001-0S. The pressure boundary was in accordance with ASME Section XI, Table IWB-2500-1 Examination Category B-P, Note 1.*

Class 2

Six Class 2 Hydrostatic Tests were performed during the outage. These hydrostatic tests were performed per ASME XI, IWA-5211(d). The tests were performed in accordance with GPC procedure 42IT-TET-001-0S. Listed below are the Class 2 Hydrostatic Tests and accompanying Maintenance Work Orders:

2E11-HT-2	MWO 2-87-3034	2E11-HT-14	MWO 2-87-3045
2E11-HT-3	MWO 2-87-3035	2E11-HT-23	MWO 2-87-3039
2E11-HT-6	MWO 2-87-3037	2E11-HT-24	MWO 2-87-3036

Only minor leakage was detected during VT-2 examination and all tests results were deemed acceptable by plant engineering.

* Valve 2B21-F001 and 2B21-F002 were disassembled prior to test, however, during test they were both in their normally closed position. As a result, valve 2B21-F002 did not experience test pressure.

Class 3

Three Class 3 Hydrostatic tests were performed during the outage. These hydrostatic tests were performed per ASME XI, IWA-5211(d) and in accordance with GPC Procedure 42IT-TET-001-0S. Only minor leakage was detected and after engineering evaluation all tests results were deemed acceptable. Listed below are the Class 3 Hydrostatic Tests and accompanying Maintenance Work Orders:

2P41-HT-13	MWO 2-87-3041
2P41-HT-28	MWO 2-87-3040
2P41-HT-29	MWO 2-87-3042

Class 3 Inservice Test

One Class 3 Inservice Test was performed per ASME XI, IWA-5211(c). A special purpose procedure, 42SP-011388-OW-1-2S, was written to perform the test. This test was on the Residual Heat Removal Service Water System and is identified as test 2E11-IT-1.

SUMMARY OF VISUAL EXAMINATIONS

CLASS 1, 2, AND 3

COMPONENT SUPPORTS

COMPONENT SUPPORT EXAMINATIONS

This section of the report provides a discussion of the visual examinations performed on selected component supports on Hatch Unit 2. The subject examinations were performed prior to and during the Refueling/Maintenance Outage. Examinations were performed using SCS Procedure VT-H-730 (VT-3). The procedure and all examination data sheets are available for review at the plant site.

Examinations

Class 1

Twenty-eight (28) component supports from the Main Steam Reactor Recirculation, and HPCI Systems were visually examined. Two reportable indications were found.

Class 2

Fifty-two (52) component supports from the following systems were visually examined: Residual Heat Removal, Core Spray, HPCI, Main Steam Auxiliary. Seventeen (17) of these Class 2 component supports were found unacceptable.

Class 3

Eighty-five (85) component supports from the following Class 3 systems were visually examined: Main Steam Relief Valve, Fuel Pool Cooling, RHR Service Water, and Plant Service Water. Four (4) of these Class 3 component supports were found to be unacceptable.

Summary of Visual Examinations

This section of the report presents an explanation of the Summary of Component Support Examinations (Summary Table). The Summary Table provides information for the visual examinations performed prior to and during the 1987 Unit 1 Refueling/Maintenance Outage to satisfy the requirements of ASME Section XI and contains the results of each visual examination performed.

1. ASME Class

The purpose of this column is self-explanatory.

2. Support

This column is for the number assigned to a particular device on a given system. For example, 2B21-MS-H4 indicates that the mark number for that particular Unit 2 main steam device is H4.

3. Figure Number

The number given is the ISI Figure Number on which the location of the pipe support or hanger is depicted. These drawings are found in the Southern Company Services-issued long-term inservice examination plans for Class 1, 2, and 3 Components at Edwin I. Hatch Nuclear Plant Unit 2.

4. Type

The type is divided only into spring, snubber (hydraulic or mechanical), and simple-type hangers.

5.-10. Examination Results

These columns give the examination results, INFs generated, MWO numbers, and re-examination results if applicable.

11. Remarks

Comments will be made in this column which describe any deficiency identified during the examination along with information concerning any additional evaluation performed.

1988 E. I. HATCH UNIT 2 PIPE SUPPORTS

ASME SUPPORT CLASS	SUPPORT	FIGURE NUMBER	TYPE	RESULTS	REPORT NO.	INF NO.	MWO NO.	RESULTS	REPORT NO.	REMARKS
1	2B21-MS-H3	A-6	SPRING	U	S88H2V093	188H2012	2-88-0970	A	S88H2V256	IMPROPER SPRING CAN SETTING
1	2B21-MS-R45	A-6	SNUBBER	A	S88H2V091	NA	NA	NA	NA	NA
1	2B21-MS-R46	A-6	SNUBBER	A	S88H2V092	NA	NA	NA	NA	NA
1	2B21-MS-H2	A-6	SPRING	A	S88H2V107	NA	NA	NA	NA	NA
1	2B21-MS-H1	A-6	SPRING	A	S88H2V154	NA	NA	NA	NA	NA
1	2B21-MS-R47	A-6	SNUBBER	A	S88H2V094	NA	NA	NA	NA	NA
1	2B21-MS-R48	A-6	SNUBBER	A	S88H2V095	NA	NA	NA	NA	NA
1	2B31-SSA21	A-16	SNUBBER	A	S88H2V222	NA	NA	NA	NA	NA
1	2B31-SSA22	A-16	SNUBBER	A	S88H2V223	NA	NA	NA	NA	NA
1	2B31-SSA8	A-16	SNUBBER	A	S88H2V057	NA	NA	NA	NA	NA
1	2B31-SSA7	A-16	SNUBBER	A	S88H2V058	NA	NA	NA	NA	NA
1	2B31-SSA6	A-16	SNUBBER	A	S88H2V059	NA	NA	NA	NA	NA
1	2B31-HB5	A-18	SPRING	A	S88H2V060	NA	NA	NA	NA	NA
1	2B31-HB6	A-18	SPRING	A	S88H2V061	NA	NA	NA	NA	NA
1	2B31-HB7	A-18	SPRING	A	S88H2V062	NA	NA	NA	NA	NA
1	2B31-SSB2	A-18	SNUBBER	A	S88H2V063	NA	NA	NA	NA	NA
1	2B31-SSB3	A-18	SNUBBER	A	S88H2V064	NA	NA	NA	NA	NA
1	2B31-SSB4	A-18	SNUBBER	A	S88H2V065	NA	NA	NA	NA	NA
1	2B31-SSB5	A-18	SNUBBER	A	S88H2V066	NA	NA	NA	NA	NA
1	2B31-SSB6	A-18	SNUBBER	A	S88H2V067	NA	NA	NA	NA	NA
1	2E41-HPC1-R110	A-26	SNUBBER	A	S88H2V096	NA	NA	NA	NA	NA
1	2E41-HPC1-H108	A-26	SPRING	U	S88H2V097	188H2013	2-88-1006	A	S88H2V237	IMPROPER SPRING CAN SETTING
1	2E41-HPC1-R111	A-26	SNUBBER	A	S88H2V098	NA	NA	NA	NA	NA
1	2E41-HPC1-R112	A-26	SNUBBER	A	S88H2V099	NA	NA	NA	NA	NA

1988 E.I. HATCH UNIT 2 PIPE SUPPORTS

ASME CLASS	SUPPORT	FIGURE NUMBER	TYPE	RESULTS	REPORT NO.	INF NO.	MWD NO.	RESULTS	REPORT NO.	REMARKS
1	2E41-HPCI-R113	A-26	SNUBBER	A	S88H2V100	NA	NA	NA	NA	NA
1	2E41-HPCI-R114	A-26	SNUBBER	A	S88H2V101	NA	NA	NA	NA	NA
1	2E41-HPCI-R115	A-26	SNUBBER	A	S88H2V102	NA	NA	NA	NA	NA
1	2E41-HPCI-H109	A-26	SPRING	A	S88H2V155	NA	NA	NA	NA	NA
2	2N11-HPS-R65	B-6	HANGER	A	S88H2V046	NA	NA	NA	NA	NA
2	2N11-HPS-R67	B-6	SNUBBER	A	S88H2V116	NA	NA	NA	NA	NA
2	2N11-HPS-R68	B-6	SNUBBER	A	S88H2V045	NA	NA	NA	NA	NA
2	2N11-MS-R48	B-9	SNUBBER	A	S88H2V044	NA	NA	NA	NA	NA
2	2E11-RHR-H195	B-15	SPRING	U	S88H2V034	188H2011	2-88-0975	A	S88H2V228	IMPROPER SPRING CAN SETTING
2	2E11-RHR-H318	B-17	SPRING	A	S88H2V121	NA	NA	NA	NA	NA
2	2E11-RHR-R382	B-18	SNUBBER	A	S88H2V152	NA	NA	NA	NA	NA
2	2E11-RHR-R124	B-18	RESTRAINT	A	S88H2V173	NA	NA	NA	NA	NA
2	2E11-RHR-H57	B-18	SPRING	U	S88H2V174	188H2011	2-88-0975	A	S88H2V233	IMPROPER SPRING CAN SETTING LOOSE JAM NUT
2	2E11-RHR-R123	B-18	SNUBBER	A	S88H2V175	NA	NA	NA	NA	NA
2	2E11-RHR-R58	B-18	ANCHOR	U	S88H2V171	188H2010	2-88-0929	A	S88H2V213	LOOSE NUT
2	2E11-RHR-R125	B-18	SNUBBER	A	S88H2V172	NA	NA	NA	NA	NA
2	2E11-RHR-R381	B-18	RESTRAINT	A	S88H2V153	NA	NA	NA	NA	NA
2	2E11-RHR-H66	B-21	SPRING	A	S88H2V119	NA	NA	NA	NA	NA
2	2E11-RHR-H205	B-22	SPRING	A	S88H2V182	NA	NA	NA	NA	NA
2	2E11-RHR-R299	B-22	RESTRAINT	U	S88H2V185	188H2010	2-88-0928	A	S88H2V212	LOOSE NUT
2	2E11-RHR-R298	B-22	RESTRAINT	U	S88H2V184	188H2010	2-88-0930	A	S88H2V214	BENT RESTRAINT
2	2E11-RHR-H46	B-23	HANGER	A	S88H2V215	NA	NA	NA	NA	NA
2	2E11-RHR-H175	B-26	SPRING	U	S88H2V032	188H2011	2-88-0975	A	S88H2V229	IMPROPER SPRING CAN SETTING

1988 E. I. HATCH UNIT 2 PIPE SUPPORTS

ASME SUPPORT CLASS	SUPPORT	FIGURE NUMBER	TYPE	RESULTS	REPORT NO.	INF NO.	MWD NO.	RESULTS	REPORT NO.	REMARKS
2	2E11-RHR-H182	B-28	SPRING	U	S88H2V033	188H2011	2-88-0975	A	S88H2V231	IMPROPER SPRING CAN SETTING
2	2E11-RHR-H181	B-28	SPRING	U	S88H2V031	188H2011	2-88-0975	A	S88H2V230	IMPROPER SPRING CAN SETTING
2	2E11-RHR-H179	B-29	SPRING	A	S88H2V030	NA	NA	NA	NA	NA
2	2E11-RHR-H183	B-30	SPRING	U	S88H2V027	188H2011	2-88-0975	A	S88H2V232	IMPROPER SPRING CAN SETTING
2	2E11-RHR-H186	B-31	SPRING	A	S88H2V025	NA	NA	NA	NA	NA
2	2E11-RHR-H187	B-33	SPRING	A	S88H2V024	NA	NA	NA	NA	NA
2	2E11-RHR-H314	B-39	SPRING	U	S88H2V104	188H2011	2-88-0975	A	S88H2V227	IMPROPER SPRING CAN SETTING
2	2E11-RHR-R317	B-39	RESTRAINT	A	S88H2V103	NA	NA	NA	NA	NA
2	2E11-RHR-HR149	B-44	HGR-REST	A	S88H2V120	NA	NA	NA	NA	NA
2	2E21-CS-H109	B-64	SPRING	A	S88H2V026	NA	NA	NA	NA	NA
2	2E41-HPCI-H31	B-65	HANGER	U	S88H2V029	188H2001	2-88-0287	A	S88H2V208	GAP BETWEEN NUTS AND BASEPLATE
2	2E41-HPCI-R53	B-65	RESTRAINT	A	S88H2V188	NA	NA	NA	NA	NA
2	2E41-HPCI-H28	B-65	HANGER	A	S88H2V186	NA	NA	NA	NA	NA
2	2E41-HPCI-H29	B-65	HANGER	A	S88H2V187	NA	NA	NA	NA	NA
2	2E41-HPCI-A709	B-66	ANCHOR	A	S88H2V082	NA	NA	NA	NA	SEE ALSO S88H2V133
2	2E41-HPCI-HR710	B-66	HGR-REST	U	S88H2V083	188H2005	2-88-0672	A	S88H2V242	BASEPLATE SEPARATION SEE ALSO S88H2V131 AND 188H2005A
2	2E41-HPCI-H38	B-66	HANGER	U	S88H2V076	188H2005	2-88-0672	A	S88H2V241	LOOSE NUT SEE ALSO S88H2V132 AND 188H2005A
2	2E41-HPCI-H99	B-66	HANGER	A	S88H2V079	NA	NA	NA	NA	SEE ALSO S88H2V136

1988 E.I. HATCH UNIT 2 PIPE SUPPORTS

ASME SUPPORT CLASS	FIGURE NUMBER	TYPE	RESULTS REPORT NO.	INF NO.	MWD NO.	RESULTS REPORT NO.	REMARKS
2	2E41-HPCI-R104	B-66	RESTRAINT U	S88H2V075	188H2005	2-88-0672	U* S88H2V243 LOOSE NUT SEE ALSO S88H2V200 AND 188H2005A *GPC ENGINEERING ACCEPT AS IS
2	2E41-HPCI-HR101	B-66	HGR-REST A	S88H2V160	NA	NA	NA NA NA
2	2E41-HPCI-R107	B-66	RESTRAINT A	S88H2V078	NA	NA	NA NA SEE ALSO S88H2V201
2	2E41-HPCI-R102	B-66	RESTRAINT U	S88H2V199	188H2005A	2-88-1120	A S88H2V238 STRUCTURAL DEGRADATION
2	2E41-HPCI-H97	B-66	HANGER A	S88H2V080	NA	NA	NA NA SEE ALSO S88H2V195
2	2E41-HPCI-R106	B-66	RESTRAINT A	S88H2V161	NA	NA	NA NA NA
2	2E41-HPCI-H96	B-66	HANGER A	S88H2V081	NA	NA	NA NA SEE ALSO S88H2V194
2	2E41-HPCI-H71	B-68	SPRING U	S88H2V190	188H2013	2-88-1006	A S88H2V235 IMPROPER SPRING CAN SETTING
2	2E41-HPCI-R55	B-94	SNUBBER A	S88H2V189	NA	NA	NA NA NA
2	2E11-RHR-R300	B-97	RESTRAINT U	S88H2V180	188H2010	2-88-0931	A S88H2V236 BENT RESTRAINT
2	2E11-RHR-H331	B-97	HGR-REST A	S88H2V178	NA	NA	NA NA NA
2	2E11-RHR-HR207	B-97	HGR-REST A	S88H2V179	NA	NA	NA NA NA
2	2E11-RHR-R301	B-97	RESTRAINT A	S88H2V181	NA	NA	NA NA NA
2	2E11-RHR-R303	B-97A	RESTRAINT A	S88H2V239	NA	NA	NA NA NA
2	2E11-RHR-H208	B-97A	HANGER A	S88H2V240	NA	NA	NA NA NA
3	2E11-RSW-R23	C-8	SNUBBER A	S88H2V028	NA	NA	NA NA NA
3	2E11-RSW-R701	C-11	RESTRAINT A	S88H2V011	NA	NA	NA NA NA
3	2P41-SW-A108	C-15	ANCHOR A	S88H2V159	NA	NA	NA NA NA
3	2P41-SW-R187	C-17	RESTRAINT A	S88H2V013	NA	NA	NA NA NA
3	2P41-SW-A102	C-17	ANCHOR A	S88H2V017	NA	NA	NA NA NA

1988 E. I. HATCH UNIT 2 PIPE SUPPORTS

ASME SUPPORT CLASS	SUPPORT	FIGURE NUMBER	TYPE	RESULTS	REPORT NO.	INF NO.	MWO NO.	RESULTS	REPORT NO.	REMARKS
3	2P41-SW-H101	C-17	SPRING	A	S88H2V009	NA	NA	NA	NA	NA
3	2P41-SW-R196	C-17	RESTRAINT	A	S88H2V015	NA	NA	NA	NA	NA
3	2P41-SW-A87	C-17	ANCHOR	A	S88H2V016	NA	NA	NA	NA	NA
3	2P41-SW-R189	C-17	RESTRAINT	A	S88H2V014	NA	NA	NA	NA	NA
3	2P41-SW-R186	C-17	RESTRAINT	A	S88H2V012	NA	NA	NA	NA	NA
3	2P41-SW-H265	C-23	SPRING	U	S88H2V047	I88H2014	2-88-1007	A	S88H2V234	IMPROPER SPRING CAN SETTING
3	2P41-SW-R339	C-25	RESTRAINT	A	S88H2V110	NA	NA	NA	NA	NA
3	2P41-SW-A148	C-25	ANCHOR	A	S88H2V004	NA	NA	NA	NA	NA
3	2P41-SW-R336	C-25	RESTRAINT	A	S88H2V109	NA	NA	NA	NA	NA
3	2P41-TSW-R732	C-26	RESTRAINT	A	S88H2V018	NA	NA	NA	NA	NA
3	2P41-SW-R326	C-27	HGR RESTR	A	S88H2V023	NA	NA	NA	NA	NA
3	2P41-SW-A185	C-27	ANCHOR	A	S88H2V008	NA	NA	NA	NA	NA
3	2P41-SW-A146	C-32	ANCHOR	A	S88H2V006	NA	NA	NA	NA	NA
3	2P41-SW-R243	C-32	RESTRAINT	A	S88H2V005	NA	NA	NA	NA	NA
3	2P41-SW-R217	C-33	RESTRAINT	A	S88H2V003	NA	NA	NA	NA	NA
3	2P41-SW-R218	C-33	RESTRAINT	A	S88H2V007	NA	NA	NA	NA	NA
3	2P41-SW-A177	C-34	ANCHOR	A	S88H2V022	NA	NA	NA	NA	NA
3	2P41-SW-R232	C-35	RESTRAINT	A	S88H2V019	NA	NA	NA	NA	NA
3	2P41-SW-R234	C-35	RESTRAINT	A	S88H2V021	NA	NA	NA	NA	NA
3	2P41-SW-R235	C-35	RESTRAINT	A	S88H2V020	NA	NA	NA	NA	NA
3	2P41-TSW-A28	C-39	ANCHOR	A	S88H2V010	NA	NA	NA	NA	NA
3	2P41-SW-R199	C-48	RESTRAINT	A	S88H2V111	NA	NA	NA	NA	NA
3	2G41-FPC-R120	C-98	RESTRAINT	A	S88H2V165	NA	NA	NA	NA	NA
3	2G41-FPC-R121	C-98	RESTRAINT	A	S88H2V166	NA	NA	NA	NA	NA
3	2G41-FPC-H81	C-98	HANGER	A	S88H2V167	NA	NA	NA	NA	NA

1988 E.I. HATCH UNIT 2 PIPE SUPPORTS

ASME CLASS	SUPPORT	FIGURE NUMBER	TYPE	RESULTS	REPORT NO.	INF NO.	MWD NO.	RESULTS	REPORT NO.	REMARKS
3	2641-FPC-A117	C-98	ANCHOR	A	S88H2V149	NA	NA	NA	NA	NA
3	2641-FPC-R119	C-98	RESTRAINT	A	S88H2V118	NA	NA	NA	NA	NA
3	2641-FPC-HR86	C-98	HGR RESTR	A	S88H2V141	NA	NA	NA	NA	NA
3	2641-FPC-HR87	C-98	HGR RESTR	A	S88H2V140	NA	NA	NA	NA	NA
3	2641-FPC-H82	C-98	HANGER	A	S88H2V148	NA	NA	NA	NA	NA
3	2641-FPC-H83	C-98	HANGER	A	S88H2V146	NA	NA	NA	NA	NA
3	2641-FPC-R122	C-98	RESTRAINT	A	S88H2V147	NA	NA	NA	NA	NA
3	2641-FPC-R124	C-98	RESTRAINT	A	S88H2V142	NA	NA	NA	NA	NA
3	2641-FPC-H85	C-98	HANGER	A	S88H2V143	NA	NA	NA	NA	NA
3	2641-FPC-H84	C-98	HANGER	A	S88H2V144	NA	NA	NA	NA	NA
3	2641-FPC-R123	C-98	RESTRAINT	A	S88H2V145	NA	NA	NA	NA	NA
3	2641-FPC-HR88	C-99	HGR RESTR	A	S88H2V139	NA	NA	NA	NA	NA
3	2641-FPC-R125	C-99	SNUBBER	A	S88H2V150	NA	NA	NA	NA	NA
3	2641-FPC-R129	C-99	RESTRAINT	A	S88H2V134	NA	NA	NA	NA	NA
3	2641-FPC-H89	C-99	HANGER	A	S88H2V137	NA	NA	NA	NA	NA
3	2641-FPC-R127	C-99	RESTRAINT	A	S88H2V136	NA	NA	NA	NA	NA
3	2641-FPC-H90	C-99	HANGER	A	S88H2V135	NA	NA	NA	NA	NA
3	2641-FPC-R126	C-99	RESTRAINT	A	S88H2V138	NA	NA	NA	NA	NA
3	2641-FPC-R141	C-100	RESTRAINT	A	S88H2V177	NA	NA	NA	NA	NA
3	2641-FPC-H100	C-100	HANGER	A	S88H2V176	NA	NA	NA	NA	NA
3	2641-FPC-R139	C-100	RESTRAINT	A	S88H2V117	NA	NA	NA	NA	NA
3	2621-MSRV-R83	C-119	SNUBBER	A	S88H2V085	NA	NA	NA	NA	NA
3	2621-MSRV-H7	C-119	SPRING	U	S88H2V087	188H2012	2-88-0970	U*	S88H2V225	IMPROPER SPRING CAN SETTING LOOSE NUT + BECTEL ACCEPTED SETTING AS IS

1988 E.I. HATCH UNIT 2 PIPE SUPPORTS

ASME CLASS	SUPPORT	FIGURE NUMBER	TYPE	RESULTS	REPORT NO.	INF NO.	MWO NO.	RESULTS	REPORT NO.	REMARKS
3	2B21-MSRV-H8	C-119	SPRING	A	S88H2V088	NA	NA	NA	NA	NA
3	2B21-MSRV-H9	C-119	SPRING	A	S88H2V129	NA	NA	NA	NA	NA
3	2B21-MSRV-R82	C-119	SNUBBER	A	S88H2V128	NA	NA	NA	NA	NA
3	2B21-MSRV-R86	C-119	RESTRAINT	A	S88H2V130	NA	NA	NA	NA	NA
3	2B21-MSRV-R84	C-119	SNUBBER	A	S88H2V086	NA	NA	NA	NA	NA
3	2B21-MSRV-R89	C-119	SNUBBER	A	S88H2V132	NA	NA	NA	NA	NA
3	2B21-MSRV-R88	C-119	SNUBBER	A	S88H2V131	NA	NA	NA	NA	NA
3	2B21-MSRV-R53	C-119/120	SNUBBER	A	S88H2V123	NA	NA	NA	NA	NA
3	2B21-MSRV-R52	C-120	SNUBBER	A	S88H2V124	NA	NA	NA	NA	NA
3	2B21-MSRV-H18	C-120	SPRING	A	S88H2V090	NA	NA	NA	NA	NA
3	2B21-MSRV-R54	C-120	SNUBBER	A	S88H2V084	NA	NA	NA	NA	NA
3	2B21-MSRV-H19	C-120	SPRING	A	S88H2V089	NA	NA	NA	NA	NA
3	2B21-MSRV-R57	C-120	SNUBBER	A	S88H2V122	NA	NA	NA	NA	NA
3	2B21-MSRV-R55	C-120	RESTRAINT	U	S88H2V125	188H2008	2-88-0703	A	S88H2V197	LOOSE NUTS
3	2B21-MSRV-R56	C-120	SNUBBER	A	S88H2V126	NA	NA	NA	NA	NA
3	2B21-MSRV-H20	C-120	SPRING	A	S88H2V127	NA	NA	NA	NA	NA
3	2B21-MSRV-R58	C-120	SNUBBER	A	S88H2V162	NA	NA	NA	NA	NA
3	2B21-MSRV-R102	C-123	RESTRAINT	A	S88H2V072	NA	NA	NA	NA	NA
3	2B21-MSRV-H28	C-123	HANGER	A	S88H2V074	NA	NA	NA	NA	NA
3	2B21-MSRV-R97	C-123	SNUBBER	A	S88H2V113	NA	NA	NA	NA	NA
3	2B21-MSRV-R98	C-123	SNUBBER	A	S88H2V105	NA	NA	NA	NA	NA
3	2B21-MSRV-H27	C-123	SPRING	A	S88H2V071	NA	NA	NA	NA	NA
3	2B21-MSRV-R99	C-123	SNUBBER	A	S88H2V106	NA	NA	NA	NA	NA
3	2B21-MSRV-R100	C-123	SNUBBER	A	S88H2V164	NA	NA	NA	NA	NA
3	2B21-MSRV-R101	C-123	SNUBBER	A	S88H2V068	NA	NA	NA	NA	NA

1988 E. I. HATCH UNIT 2 PIPE SUPPORTS

ASME CLASS	SUPPORT	FIGURE NUMBER	TYPE	RESULTS	REPORT NO.	INF NO.	MWO NO.	RESULTS	REPORT NO.	REMARKS
3	2B21-MSRV-H29	C-123	SPRING	A	S88H2V114	NA	NA	NA	NA	NA
3	2B21-MSRV-R103	C-123	SNUBBER	A	S88H2V069	NA	NA	NA	NA	NA
3	2B21-MSRV-R104	C-123	SNUBBER	A	S88H2V070	NA	NA	NA	NA	NA
3	2B21-MSRV-R122	C-123	RESTRAINT	A	S88H2V073	NA	NA	NA	NA	NA
3	2B21-MSRV-R96	C-123	SNUBBER	A	S88H2V151	NA	NA	NA	NA	NA
3	2B21-MSRV-H26	C-123	SPRING	U	S88H2V108	188H2012	2-88-0970	A	S88H2V226	IMPROPER SPRING CAN SETTINGS LOOSE JAM NUTS
3	2B21-MSRV-R112	C-124	RESTRAINT	A	S88H2V163	NA	NA	NA	NA	NA

SUMMARY OF
REACTOR PRESSURE VESSEL
INTERNAL INSPECTIONS

REACTOR PRESSURE VESSEL INTERNALS

This section of the report provides a summary of the remote visual and ultrasonic examinations performed by SCS and CTS Power Services on selected RPV internals. The visual examinations were performed utilizing SCS Procedure VT-H-750. This procedure incorporates requirements for ASME Section XI, GE Service Information Letters and NRC IEB 80-13. SCS procedures were also used to perform the required UT examinations.

All visual examination tapes were reviewed by SCS or EBASCO certified Level II and/or III visual examiners to determine the acceptability of the various RPV internal components. All procedure data sheets and video tapes are available in the Document Control Department at the plant site.

Core Spray Sparger Inspection

Per the requirements of NRC IEB 80-13, the core spray spargers and associated piping were examined. Underwater video equipment recorded the examinations to the resolution of a .001 inch diameter visual acuity standard. No reportable indications were found on the upper or lower Core Spray Spargers or the Core Spray Headers.

Jet Pump Sensing Lines Inspection

A remote visual examination of the accessible Jet Pump Sensing Lines was performed per the recommendations of GE SIL - 420. No reportable indications were recorded on the accessible sensing lines, support brackets and welds.

RPV Internals Inspections

A representative vessel cladding sample (10%) was visually examined and no recordable indications were found.

Steam Dryer Inspections

A remote visual examination was performed on various components of the Steam Dryer which consisted of; lifting lugs, stirreners, stiffener welds, vertical welds numbered 1 through 42, steam dryer support brackets and support ring. A total of ninety-two (92) linear indications were recorded. Listed below are the affected areas and number of associated indications:

1. Vertical Weld #12	2 Cracks
2. Support	45 Cracks
3. Support Bracket at 34 degrees Az.	4 Cracks
Support Bracket at 146 degrees Az.	13 Cracks
Support Bracket at 214 degrees Az.	15 Cracks
Support Bracket at 326 degrees Az.	13 Cracks

GE reviewed the indications and after engineering analysis determined them to be acceptable for continued operation with additional monitoring requested during the next scheduled refueling outage. No other reportable indications were observed.

Jet Pump Beam - UT

Per GE SIL - 330, all twenty Jet Pump Beams were UT examined using SCS Procedure UT-H-414. Jet pump beam #20 had a crack like indication and was removed and replaced. No other indications were detected.

Shroud Head Bolt - UT

Per GE SIL - 433, all thirty-six moisture separator head hold down bolts were UT examined using SCS Procedure UT-H-418. Eight (8) bolts were observed to have reportable indications. GPC elected to replace six (6) of the bolts and GE concurred with the acceptability of the other two (2) bolts. Listed below are the replacement bolts.

#6	#24
#10	#32
#17	#36

No other reportable indications were observed.

Jet Pump Inlet Mixer Nozzles

The jet pump inlet mixing nozzle area was visually examined using SCS Procedure VT-H-750. The remote camera was positioned to allow examination looking down into the throat at approximately a 45 degree angle. Evidence of erosion was detected in the throat area of all 20 jet pump mixing nozzles. GE evaluated the examination results and confirmed the acceptability of the mixing nozzles. GE did recommend additional examinations in future outages and also recommended an examination of the jet pump mixing nozzles on Unit 1 using the same examination technique.

The following pages contain a copy of the RPV Internal Inspection Tape Log which is an itemized list of all components and areas visually examined during the outage. This log was supplied to Document Control with the video tapes for use as a reader sheet.

INVESSEL EXAMINATION TAPE LOG

<u>TAPE # 1</u>	<u>INDEX</u>
0000-0016	RESOLUTION
0016-0330	VERTICAL WELD #1 5 AZ BANK 3
0330-0525	VERTICAL WELD #2 10 AZ BANK 2
0525-0696	VERTICAL WELD #3 20 AZ BANK 2
0686-0696	VERTICAL WELD #4 30 AZ BANK 2
0939-1172	LIFTING LUG 35 AZ
	NO ACCESS #5
1172-1247	VERTICAL WELD #6 40 AZ BANK 1
1247-1450	VERTICAL WELD #7 45 AZ BANK 1
1450-1636	VERTICAL WELD #8 65 AZ BANK 1
1636-1656	RESOLUTION CHECK
1656-1832	VERTICAL WELD #11 115 AZ BANK 1 NO ACCESS 9-10
1832-2209	VERTICAL WELD #12 125 AZ BANK 1
2209-2455	VERTICAL WELD #13 130 AZ BANK 1

<u>TAPE #1</u>	<u>INDEX</u>
2455-2656	LIFTING LUG 145 AZ
	NO ACCESS #14
2656-2820	VERTICAL WELD #15 145 AZ BANK 2
2820-2938	VERTICAL WELD #16 155 AZ BANK 2
2938-3030	VERTICAL WELD #18 170 AZ BANK 2
3030-3200	VERTICAL WELD #19 180 AZ BANK 3
3200-3310	VERTICAL WELD #21 185 AZ BANK 3
3310-3313	RESOLUTION CHECK
3313-3556	VERTICAL WELD #22 135 AZ BANK 3
3556-3748	VERTICAL WELD #23 200 AZ BANK 3

3748-4010	VERTICAL WELD #24	225 AZ	BANK 4
4010-4206	VERTICAL WELD #25	230 AZ	BANK 4
4206-4447	VERTICAL WELD #26	230 AZ	BANK 4
4447-4632	LIFTING LUG	215 AZ	
4632-4789	VERTICAL WELD #28	220 AZ	BANK 5
4789-4915	VERTICAL WELD #29	225 AZ	BANK 5
4915-5009	VERTICAL WELD #31	230 AZ	BANK 5
5009-5089	VERTICAL WELD #33	300 AZ	BANK 5
5105-5113	RESOLUTION CHECK		
5113-5206	VERTICAL WELD #34	305 AZ	BANK 5
5206-5306	VERTICAL WELD #36	321 AZ	BANK 5
5306-5438	LIFTING LUG	326 AZ	
5438-5538	VERTICAL WELD #37	345-330 AZ	BANK 4
5538-5605	VERTICAL WELD #38	346 AZ	BANK 4
5605-5695	VERTICAL WELD #39	348 AZ	BANK 4

TAPE #2

INDEX

0000-0247	VERTICAL WELD #40	346 AZ	BANK 3
0247-0530	VERTICAL WELD #41	357 AZ	BANK 3
0530-0834	VERTICAL WELD #42	360 AZ	BANK 3

SUPPORT RING INSPECTION

TAPE #3

INDEX

0000-0052	RESOLUTION CHECK		
0052-0370	0-5 AZ	1ST PASS SCAN	
	0-5 AZ	2ND PASS SCAN	
	0-5 AZ	3RD PASS SCAN	
	5-10 AZ	1ST PASS SCAN	
	5-10 AZ	2ND PASS SCAN	
	5-10 AZ	3RD PASS SCAN	

0378-0547	10-18 AZ	1ST PASS SCAN
0563-0699	18-42 AZ	1ST PASS SCAN
	42-45 AZ	INACCESSIBLE DUE TO LADDER
0699-0798	45-60 AZ	1ST PASS SCAN
0798-0839	60-80 AZ	1ST PASS SCAN
0839-0885	80-95 AZ	1ST PASS SCAN
0885-0918	95-105 AZ	1ST PASS SCAN
0918-0947	105-115 AZ	1ST PASS SCAN
0947-0971	115-125 AZ	1ST PASS SCAN
0971-1013	125-135 AZ	1ST PASS SCAN
1013-1055	135-145 AZ	1ST PASS SCAN

1ST SUPPORT RING PASS STEAM DRYER

TAPE #3

INDEX

1055-1075	145-155 AZ	1ST PASS SCAN
1075-1112	155-165 AZ	1ST PASS SCAN
1112-1146	165-175 AZ	1ST PASS SCAN
1146-1175	175-177 AZ	1ST PASS SCAN
1175-1201	177-180 AZ	1ST PASS SCAN
1201-1230	180-185 AZ	1ST PASS SCAN
1230-1257	185-190 AZ	1ST PASS SCAN
1257-1342	190-195 AZ	1ST PASS SCAN
1345-1427		INDICATION AT 195 AZ
1427-1569		EVALUATIONS OF INDICATIONS AT 192&195 AZ
1569-1596	195-200 AZ	1ST PASS SCAN
1596-1626	200-205 AZ	1ST PASS SCAN
1689-1699	205-210 AZ	1ST PASS SCAN
1699-1705	210-215 AZ	1ST PASS SCAN

1705-1728	215-220 AZ	1ST PASS SCAN
1728-1750	220-225 AZ	1ST PASS SCAN
1750-1770	225-230 AZ	1ST PASS SCAN
1770-1793	230-235 AZ	1ST PASS SCAN
1793-1813	235-240 AZ	1ST PASS SCAN
1814-1828	240-245 AZ	1ST PASS SCAN
1828-1845	245-250 AZ	1ST PASS SCAN
1845-1865	250-260 AZ	1ST PASS SCAN
1865-1881	260-270 AZ	1ST PASS SCAN
1881-1898	270-275 AZ	1ST PASS SCAN
1898-1920	275-280 AZ	1ST PASS SCAN

TAPE #3

INDEX

1920-1939	280-290 AZ	1ST PASS SCAN
1939-1953	290-295 AZ	1ST PASS SCAN
1953-1965	295-300 AZ	1ST PASS SCAN
1965-1982	300-305 AZ	1ST PASS SCAN
1982-1997	305-310 AZ	1ST PASS SCAN
1997-2010	310-315 AZ	1ST PASS SCAN
2010-2025	315-320 AZ	1ST PASS SCAN
2025-2037	320-325 AZ	1ST PASS SCAN
2037-2054	325-330 AZ	1ST PASS SCAN
2054-2070	330-335 AZ	1ST PASS SCAN
2070-2089	335-340 AZ	1ST PASS SCAN
2089-2113	340-345 AZ	1ST PASS SCAN
2113-2127	345-350 AZ	1ST PASS SCAN
2127-2147	350-355 AZ	1ST PASS SCAN
2147-2159	355-360 AZ	1ST PASS SCAN

END OF 1ST PASS

BEGINNING OF 2ND PASS

2159-2177	20-25 AZ 2ND PASS SCAN
2177-2196	25-30 AZ 2ND PASS SCAN
2196-2315	30-35 AZ 2ND PASS SCAN
2334-2356	35-42 AZ 2ND PASS SCAN
2356-2380	SIZING OF INDICATION AT 34 AZ
2380-2454	SIZING OF INDICATION #1 ON 34 AZ SUPPORT LUG
2454-2462	SIZING OF INDICATION #2 ON 34 AZ SUPPORT
2462-2470	SIZING OF INDICATION #3 ON 34 AZ SUPPORT LUG
2470-2494	SIZING OF INDICATION #4 ON 34 AZ SUPPORT LUG 42-45 AZ INACCESSIBLE

TAPE #3

INDEX

2494-2515	42-45 AZ INACCESSIBLE
2515-2526	45-50 AZ 2ND PASS SCAN
2526-2541	50-55 AZ 2ND PASS SCAN
2541-2562	55-60 AZ 2ND PASS SCAN
2562-2578	60-65 AZ 2ND PASS SCAN
2578-2593	65-70 AZ 2ND PASS SCAN
2593-2607	70-75 AZ 2ND PASS SCAN
2607-2619	75-80 AZ 2ND PASS SCAN
2619-2636	80-85 AZ 2ND PASS SCAN
2636-2707	85-90 AZ 2ND PASS SCAN
2707-2720	RESOLUTION CHECK
2720-2734	90-95 AZ 2ND PASS SCAN
2734-2747	95-100 AZ 2ND PASS SCAN
2747-2758	100-105 AZ 2ND PASS SCAN
2758-2769	105-110 AZ 2ND PASS SCAN
2769-2779	110-115 AZ 2ND PASS SCAN
2779-2786	115-120 AZ 2ND PASS SCAN
2786-2794	120-125 AZ 2ND PASS SCAN
2794-2805	125-130 AZ 2ND PASS SCAN

2805-2818	130-135 AZ	2ND PASS SCAN
2818-2833	135-140 AZ	2ND PASS SCAN
2833-2853	140-150 AZ	2ND PASS SCAN
2853-2972	SIZING OF INDICATIONS ON 146 AZ SUPPORT LUG	
2972-2982	150-155 AZ	2ND PASS SCAN
2982-2991	155-160 AZ	2ND PASS SCAN
2991-3007	160-165 AZ	2ND PASS SCAN
3007-3021	165-170 AZ	2ND PASS SCAN
3021-3026	SIZING INDICATION AT 165 AZ	
3026-3035	170-175 AZ	2ND PASS SCAN
3035-3052	175-180 AZ	2ND PASS SCAN
3081-3092	SIZING INDICATIONS AT 178-180 AZ	
3092-3117	180-182 AZ	2ND PASS SCAN
3117-3129	183-190 AZ	2ND PASS SCAN
3129-3135	190-193 AZ	2ND PASS SCAN
3135-3156	193-200 AZ	2ND PASS SCAN
3156-3162	200-205 AZ	2ND PASS SCAN
3162-3171	205-210 AZ	2ND PASS SCAN
3171-3233	210-215 AZ	2ND PASS SCAN
3233-3242	215-220 AZ	2ND PASS SCAN
3242-3253	220-230 AZ	2ND PASS SCAN
3253-3260	230-240 AZ	2ND PASS SCAN
3260-3272	240-250 AZ	2ND PASS SCAN
3272-3282	250-260 AZ	2ND PASS SCAN
3282-3300	260-270 AZ	2ND PASS SCAN
3300-3306	270-280 AZ	2ND PASS SCAN
3306-3318	280-290 AZ	2ND PASS SCAN
3318-3329	290-300 AZ	2ND PASS SCAN

3329-3340	300-310 AZ 2ND PASS SCAN
3340-3349	310-320 AZ 2ND PASS SCAN
3349-3360	320-330 AZ 2ND PASS SCAN
3360-3393	326 AZ SUPPORT BRACKET SCAN
3393-3455	SIZING INDICATIONS ON 326 AZ SUPPORT BRACKET
3455-3467	325-335 AZ 2ND PASS SCAN
3467-3488	335-345 AZ 2ND PASS SCAN
3488-3507	345-355 AZ 2ND PASS SCAN
3507-3540	244-360 AZ 2ND PASS SCAN END 2ND SUPPORT RING SCAN

STEAM DRYER STIFFENERS
& STIFFENER WELDS

TAPE #3

INDEX

3540-3546	RESOLUTION CHECK
3546-3561	STIFFENER #1
3561-3576	STIFFENER #2
3576-3601	STIFFENER #3
3601-3626	STIFFENER #4
3626-3653	STIFFENER #5
3653-3683	STIFFENER #6
3683-3713	STIFFENER #7
3713-3721	STIFFENER #12
3721-3728	STIFFENER #11
3728-3734	STIFFENER #10
3734-3741	STIFFENER #9
3741-3766	STIFFENER #8
3766-3775	STIFFENER #13
3775-3785	STIFFENER #14
3785-3808	STIFFENER #9

3808-3812

STIFFENER #15

MOISTURE SEPARATOR STIFFENERS

TAPE #3

INDEX

3812-3821	STIFFENER #16
3821-3844	STIFFENER #10
3844-3857	STIFFENER #17
3857-3866	STIFFENER #18
3866-3896	STIFFENER #11
3896-3903	STIFFENER #19
3903-3911	STIFFENER #20
3911-3936	STIFFENER #12
3936-3968	STIFFENER #21
3968-3976	STIFFENER #28
3976-3993	STIFFENER #20
3993-4001	STIFFENER #27
4001-4017	STIFFENER #19
4017-4024	STIFFENER #26
4024-4045	STIFFENER #18
4045-4060	STIFFENER #17
4060-4065	STIFFENER #25
4065-4084	STIFFENER #16
4084-4091	STIFFENER #24
4091-4110	STIFFENER #15
4110-4117	STIFFENER #23
4117-4131	STIFFENER #14
4131-4137	STIFFENER #22
4137-4154	STIFFENER #13
4154-4176	STIFFENER #22

MOISTURE SEPARATOR STIFFENERS

TAPE #3

INDEX

4176-4196	STIFFENER #23
4196-4212	STIFFENER #24
4212-4235	STIFFENER #25
4235-4252	STIFFENER #26
4252-4273	STIFFENER #27
4273-4310	STIFFENER #28

-----END TAPE

THIRD PASS AND SIZING OF INDICATIONS ON SUPPORT RING

TAPE #4

INDEX

0000-0024	RESOLUTION CHECK
0024-0071	SIZING INDICATIONS AT 20 AZ
0071-0103	20-25 AZ SCANNING
0103-0140	25-30 AZ SCANNING
0140-0166	30-35 AZ SCANNING
0166-0210	35-42 AZ SCANNING
	42-45 AZ NO ACCESS
0210-0234	45-50 AZ SCANNING
0234-0260	50-55 AZ SCANNING
0260-0283	55-60 AZ SCANNING
0283-0300	60-65 AZ SCANNING
0300-0319	65-70 AZ SCANNING
0319-0374	70-75 AZ SCANNING
0374-0395	75-80 AZ SCANNING
0395-0417	80-90 AZ SCANNING
0417-0485	90-95 AZ SCANNING
0485-0500	95-100 AZ SCANNING

0500-0516	100-105 AZ SCANNING
0516-0532	105-110 AZ SCANNING
0532-0548	110-115 AZ SCANNING
0549-0564	115-120 AZ SCANNING
0564-0582	120-125 AZ SCANNING
0582-0599	125-135 AZ SCANNING
0599-0660	SIZING INDICATIONS #3 135-140 AZ
0660-0675	140-145 AZ
0675-0708	145-150 AZ NOTE: IND'S ALREADY RECORDED ON SECOND PAST
0708-0827	SIZING INDICATIONS #4 & #5
0827-0841	150-160 AZ SCANNING
0841-0941	160-165 AZ SCANNING-SIZING OF IND'S #6-8
0941-1024	165-170 AZ NOTE: IND'S SEEN ON 10-86 INSPECTION AT 170 COULD NOT BE LOCATED
1024-1168	170-175 AZ SCANNING
1168-1212	175-180 AZ SCANNING
1212-1238	180-185 AZ SCANNING
1238-1271	185-190 AZ SCANNING
1271-1882	SIZING OF INDICATIONS AT 190-200 AZ IND'S #8-#22
1882-1906	200-205 AZ SCANNING
1908-1940	205-215 AZ SCANNING
1940-1948	LOOKING INSIDE LUG FOR WEAR
1948-2114	SIZING OF IND'S #23-#31
2114-2198	215-225 AZ SCANNING
2198-2222	225-235 AZ SCANNING
2222-2244	235-240 AZ SCANNING
2244-2259	240-245 AZ SCANNING
2259-2276	245-250 AZ SCANNING
2276-2297	250-255 AZ SCANNING

2297-2312	255-260 AZ SCANNING
2312-2325	260-265 AZ SCANNING
2325-2337	265-270 AZ SCANNING
2337-2354	270-275 AZ SCANNING
2354-2374	275-280 AZ SCANNING
2374-2393	280-285 AZ SCANNING
2393-2408	285-290 AZ SCANNING
2408-2426	290-295 AZ SCANNING
2426-2440	295-300 AZ SCANNING
2440-2450	300-305 AZ SCANNING
2450-2462	305-310 AZ SCANNING
2462-2472	310-315 AZ SCANNING
2472-2483	315-320 AZ SCANNING
2483-2500	320-326 AZ NOTE: INDICATIONS RECORDED ON SECOND PASS
2500-2521	326-330 AZ SCANNING
2521-2532	330-335 AZ SCANNING
2532-2700	335-350 AZ SIZING OF IND'S 36-42
2700-2715	350-355 AZ SCANNING
2715-2732	355-360 AZ SCANNING END OF TAPE #4

TAPE # 5 COMPLETE INSPECTION MOISTURE SEPARATOR

<u>INDEX</u>	<u>EXAMINATION AREA</u>
0010-0020	RESOLUTION CHECK
0020-0308	GUIDE PIN & BRACKET @ 0 AZ
0308-0369	DIAGONAL SUPPORT @ 1 AZ
0369-0431	DIAGONAL SUPPORT @ 18 AZ 90 AZ SIDE OF WELD INACCESSIBLE
0431-0619	LIFTING LUG @ 20 AZ
0619-0696	DIAGONAL SUPPORT @ 45 AZ
0696-0766	DIAGONAL SUPPORT @ 60 AZ
0766-0823	DIAGONAL SUPPORT @ 0 AZ

OBSTRUCTION = SHROUD HEAD BOLT

0823-0970 LIFTING LUG @ 90 AZ

0970-0980 RESOLUTION CHECK

0980-1044 DIAGONAL SUPPORT @ 100 AZ
OBSTURCTION = SHROUD HEAD BOLT

1044-1092 DIAGONAL SUPPORT @ 125 AZ

1092-1145 DIAGONAL SUPPORT @ 140 AZ
OBSTRUCTION = SHROUD HEAD BOLT

1145-1192 DIAGONAL SUPPORT @ 165 AZ

1192-1284 GUIDE PIN & BRACKET @ 180 AZ

1284-1342 DIAGONAL SUPPORT @ 181 AZ
OBSTRUCTION = GUIDE PIN @ 180 AZ

1342-1425 DIAGONAL SUPPORT @ 197 AZ
OBSTRUCTION = LIFTING LUG @ 200 AZ

1425-1497 LIFTING LUG @ 200 AZ

1497-1565 DIAGONAL SUPPORT @ 220 AZ

1565-1645 DIAGONAL SUPPORT @ 240 AZ

1645-1722 DIAGONAL SUPPORT @ 260 AZ
180 AZ SIDE OF WELD OBSTRUCTED

1722-1811 LIFTING LUG @ 270 AZ

TAPE #5 COMPLETE INSPECTION MOISTURE SEPARATOR

INDEX

EXAMINATION AREA

1811-1862 DIAGONAL SUPPORT @ 285 AZ

1862-1936 DIAGONAL SUPPORT @ 300 AZ
0 AZ SIDE OF WELD OBSTRUCTED

1936-2010 DIAGONAL SUPPORT @ 320 AZ

2010-2027 DIAGONAL SUPPORT @ 350 AZ

2027-2031 RESOLUTION CHECK

2031-2219 STAND PIPE #1 @ 8 AZ EXTERIOR SCAN
STAND PIPE #2 WAS OBSTRUCTED BY
LIFTING LOG

2219-2352 STAND PIPE #3 @ 25 AZ EXTERIOR SCAN

2352-2463 STAND PIPE #4 @ 30 AZ EXTERIOR SCAN

2463-2566 STAND PIPE #5 @ 35 AZ EXTERIOR SCAN

2566-2722	STAND PIPE #6 @ 40 AZ EXTERIOR SCAN
2722-2980	STAND PIPE #7 @ 55 AZ EXTERIOR SCAN
3129-3150	RESOLUTION CHECK
3150-3293	STAND PIPE #8 @ 65 AZ EXTERIOR SCAN
3293-3393	STAND PIPE #9 @ 75 AZ EXTERIOR SCAN
3393-3493	STAND PIPE #10 @ 85 AZ EXTERIOR SCAN
3493-3593	STAND PIPE #11 @ 95 AZ EXTERIOR SCAN
3593-3697	STAND PIPE #12 @ 105 AZ EXTERIOR SCAN
3697-3797	STAND PIPE #13 @ 115 AZ EXTERIOR SCAN
3797-3878	STAND PIPE #14 @ 125 AZ EXTERIOR SCAN
3878-3965	STAND PIPE #15 @ 135 AZ EXTERIOR SCAN
3965-4043	STAND PIPE #16 @ 150 AZ EXTERIOR SCAN
4043-4145	STAND PIPE #17 @ 165 AZ EXTERIOR SCAN
4145-4223	STAND PIPE #18 @ 175 AZ EXTERIOR SCAN

TAPE #5 COMPLETE INSPECTION MOISTURE SEPARATOR

<u>INDEX</u>	<u>EXAMINATION AREA</u>
4223-4303	STAND PIPE #19 @ 185 AZ EXTERIOR SCAN STAND PIPE #20 WAS OBSTRUCTED BY LIFTING LOG
4303-4395	STAND PIPE #21 @ 210 AZ EXTERIOR SCAN
4395-4483	STAND PIPE #22 @ 220 AZ EXTERIOR SCAN
4483-4569	STAND PIPE #23 @ 230 AZ EXTERIOR SCAN
4569-4715	STAND PIPE #24 @ 240 AZ EXTERIOR SCAN
4715-4838	STAND PIPE #25 @ 250 AZ EXTERIOR SCAN
4838-4927	STAND PIPE #26 @ 260 AZ EXTERIOR SCAN STAND PIPE #27 WAS OBSTRUCTED BY LIFTING LOG
4927-4988	STAND PIPE #28 @ 280 AZ EXTERIOR SCAN
4988-5054	STAND PIPE #29 @ 290 AZ EXTERIOR SCAN
5054-5126	STAND PIPE #30 @ 300 AZ EXTERIOR SCAN

5126-5182	STAND PIPE #31 @ 310 AZ EXTERIOR SCAN
5182-5242	STAND PIPE #32 @ 320 AZ EXTERIOR SCAN
5242-5308	STAND PIPE #33 @ 330 AZ EXTERIOR SCAN
5308-5311	STAND PIPE #34 @ 340 AZ EXTERIOR SCAN
5373-5440	STAND PIPE #35 @ 350 AZ EXTERIOR SCAN
5440-5497	STAND PIPE #36 @ 360 AZ EXTERIOR SCAN

NOTE

Tape #6 was used for special reexaminations per a request of GPC. These exams are covered by tapes included in this report, therefore tape #6 is not included.

1-29-88

TAPE #7 CORE SPRAY SPARGERS
1ST SCAN

0000-0011 RESOLUTION CHECK
0011-0148 NOZZLE 1A - JUNCTION BOX A
0148-0276 JUNCTION BOX A - NOZZLE 53A
0276-0424 NOZZLE 1C - JUNCTION BOX C
0424-0541 JUNCTION BOX C - NOZZLE 53C

2ND SCAN (SCAN OF UPPER AND LOWER SPARGER RINGS)

0541-0656 NOZZLE 1B-53A
0656-0777 NOZZLE 1D-53C
NOTE: BENT DISPERSAL KNOB IN NOZZLE BY JUNCTION
 BOX D

3RD SCAN (3RD SCAN LOWER SPARGER RINGS B & D)

0777-0888 NOZZLE 1B-JUNCTION BOX B
0888-1016 JUNCTION BOX B-NOZZLE 53B
1016-1126 NOZZLE 1D-JUNCTION BOX D
1126-1256 JUNCTION BOX D-NOZZLE 53D

TAPE #8 CORE SPRAY SUPPLY PIPING

0000-0028 RESOLUTION

FIRST PASS

0028-0078 90 AZ CORE SPRAY COUPLING 100 AZ AND VERTICAL
 RUN FROM COUPLING TO UPPER ELBOW TO BRACKET 30
 AZ
0078-0328 HORIZONTAL SECTION FROM ELBOW TO BRACKET AT 30
 AZ
0328-0463 BRACKET AND ATTACHMENT WELDS
0463-0700 HORIZONTAL SECTION FROM 30 AZ BRACKET TO
 JUNCTION BOX AT 90 AZ
0700-0806 JUNCTION BOX AT 90 AZ

TAPE #8

0806-1015 HORIZONTAL SECTION FROM JUNCTION BOX 90 AZ TO
 BRACKET AT 150 AZ
1015-1075 BRACKETS AND ATTACHMENT WELDS

1075-1094 HORIZONTAL SECTION FROM BRACKET-UPPER ELBOW
150 AZ - 170 AZ

1094-1145 VERTICAL RUN FROM UPPER ELBOW TO COUPLING AT 170
AZ INCLUDING COUPLING SCAN

SECOND RUN

1145-1228 COUPLING AT 170 AZ-UPPER ELBOW 170 AZ

1228-1260 UPPER ELBOW 170 AZ

1260-1290 HORIZ. SECTION 170 AZ - 150 AZ UPPER ELBOW
BRACKET

1290-1310 BRACKET 150 AZ

1310-1414 HORIZONTAL SECTION FROM BRACKET TO JUNCTION BOX
150 AZ - 90 AZ

1414-1561 HORIZONTAL SECTION FROM JUNCTION BOX TO BRACKET
INCLUDING BRACKET 90 AZ - 30 AZ

1561-1603 HORIZONTAL SECTION FROM 30 AZ BRACKET TO 10 AZ
ELBOW

1603-1689 VERTICAL DOWN FROM 10 AZ ELBOW TO COUPLING AT 10

FIRST PASS 270 AZ CORE SPRAY NOZZLE

1689-1749 COUPLING 190 AZ

1749-1791 VERTICAL RUN FROM COUPLING 190 AZ TO UPPER ELBOW
190 AZ

1791-1810 HORIZONTAL SECTION FROM UPPER ELBOW-BRACKET 190
AZ - 210 AZ

1810-1879 BRACKET AT 210 AZ AND ATTACHMENT WELDS

1879-1943 HORIZONTAL SECTION FROM 210 AZ BRACKET TO 270 AZ
JUNCTION BOX

1943-2019 JUNCTION BOX AT 270 AZ

TAPE #8

2019-2148 HORIZONTAL SECTION FROM JUNCTION BOX AT 270 AZ
TO BRACKET AT 330 AZ

2148-2189 BRACKET AT 330 AZ

2189-2201 HORIZONTAL SECTION FROM BRACKET 330 AZ TO UPPER
ELBOW 330 AZ - 350 AZ

2201-2220 UPPER ELBOW AT 350 AZ
2220-2265 VERTICAL RUN FROM UPPER ELBOW TO COUPLING 350 AZ

SECOND PASS

2265-2374 COUPLING TO UPPER ELBOW 350 AZ
2374-2443 HORIZONTAL SECTION FROM UPPER ELBOW TO BRACKET
350 AZ TO 330 AZ

2443-2505 BRACKET AT 330 AZ - JUNCTION BOX 270
2505-2639 JUNCTION BOX AT 270 AZ - 210 AZ BRACKET
2639-2652 BRACKET 210 AZ TO ELBOW 190 AZ
2652-2682 ELBOW 190 AZ TO COUPLING 190 AZ
2689-2694 RESOLUTION
2694-2767 HEADER FROM SHROUD TO LOWER ELBOW 10 AZ, LOWER
ELBOW 10 AZ AND VERTICAL RUN FROM LOWER ELBOW TO
COUPLING 10 AZ
2767-2834 VERTICAL RUN FROM COUPLING TO LOWER ELBOW AND
FROM HEADER TO LOWER ELBOW TO SHROUD ALL AT
170 AZ
2834-2934 HEADER FROM SHROUD TO LOWER ELBOW, LOWER ELBOW
190 AZ AND VERTICAL RUN FROM LOWER ELBOW TO
COUPLING
2934-3034 VERTICAL RUN FROM COUPLING TO LOWER ELBOW AT 350
AZ AND HEADER TO LOWER ELBOW TO SHROUD 350 AZ

TAPE #9 TOP GUIDE ROD BRACKETS

0000-0675 0 AZ TOP GUIDE ROD BRACKET AND ATTACHMENT WELDS
0675-0690 0 AZ BOTTOM ROD BRACKETS AND ATTACHMENT WELDS
0690-1290 180 AZ TOP GUIDE ROD BRACKETS AND ATTACHMENT
WELDS

TAPE #9

1290-1295 - 180 AZ BOTTOM GUIDE BRACKET AND ATTACHMENT WELDS

STEAM DRYER SUPPORT LUGS

1293-1466 146 AZ SUPPORT LUG AND ATTACHMENT WELDS SEE
INDICATION SHEET
1466-1611 214 AZ SUPPORT LUG AND ATTACHMENT WELDS SEE
INDICATION SHEET
1611-1800 326 AZ SUPPORT LUG AND ATTACHMENT WELDS SEE
INDICATION SHEET

1800-2046- 34 AZ SUPPORT LUG AND ATTACHMENT WELDS SEE INDICATION SHEET

VESSEL CLADDING

2046-2326 STARTS AT 0 AZ ROD GUIDE FROM 6' ABOVE FEEDWATER SPARGER TO FEEDWATER SPARGER GOING 6' TO THE RIGHT 6 SCANS

TAPE #10 SURVEILLANCE SPECIMEN BRACKETS

0006-0043 UPPER SURVEILLANCE SPECIMEN BRACKET AND ATTACHMENT AT 30 AZ

0043-0071 LOWER BRACKET AT 30 AZ ON SURVEILLANCE SPECIMEN AND ATTACHMENT WELD

0071-0121 UPPER AND LOWER SURVEILLANCE SPECIMEN BRACKETS AND ATTACHMENT WELDS

0121-0154 UPPER AND LOWER SURVEILLANCE SPECIMEN BRACKETS AND ATTACHMENT WELDS

TAPE #11 SHROUD SUPPORT RING
A. SUPPORT RING ATTACHMENT WELD TO VESSEL

0000-0025 RESOLUTION CHECK

0025-0131 INDICATION FOUND BY ACCIDENT ON RECIRC NOZZLE 28-1A. EVALUATION DONE ON TAPE #14 FOUND TO BE NOTHING.

0131-0157 AREAS BETWEEN 0 AZ-----JET PUMP #1

0157-0179 AREAS BETWEEN JET PUMP #2-----JET PUMP #3

0179-0239 AREAS BETWEEN JET PUMP #4-----JET PUMP #5

0239-0264 AREAS BETWEEN JET PUMP #6-----JET PUMP #7

TAPE #11

0264-0419 AREAS BETWEEN JET PUMP #8-----JET PUMP #9
NOTE: LINEAR INDICATION SEEN THIS AREA.
0310-0354 COUNTS

0419-0475 AREAS BETWEEN JET PUMP #10----180 AZ MANWAY

0475-0538 AREAS BETWEEN 180 AZ MANWAY---- JET PUMP #11

0542-0595 AREAS BETWEEN JET PUMP #12----JET PUMP #13

0595-0619 AREAS BETWEEN JET PUMP #14----JET PUMP #15

0619-0647 AREAS BETWEEN JET PUMP #16----JET PUMP #17
NOTE:LIMITED SCAN DUE TO INSTRUMENT LINES.

0647-0671 AREAS BETWEEN JET PUMP #18----JET PUMP #19

0671-0689- AREAS BETWEEN JET PUMP #20---0 AZ MANWAY
SUPPORT RING ATTACHMENT W L TO SHROUD

0689-0725 AREAS BETWEEN 0 AZ MANWAY---JET PUMP #1

0725-0735 AREAS BETWEEN JET PUMP #2---JET PUMP #3

0735-0754 AREAS BETWEEN JET PUMP #4---JET PUMP #5
NOTE: AREAS BETWEEN JET PUMP #6 & #7 ARE LIMITED

0754-0771 AREAS BETWEEN JET PUMP #8---JET PUMP #9

0771-0791 AREAS BETWEEN JET PUMP #10---180 AZ MANWAY

0791-0806 AREAS BETWEEN JET PUMP #12---JET PUMP #13

0806-0821 AREAS BETWEEN JET PUMP #14---JET PUMP #15

0821-0836 AREAS BETWEEN JET PUMP #16---JET PUMP #17
ARE LIMITED DUE TO INSTRUMENT LINES

0836-0848 AREAS BETWEEN JET PUMP #18---JET PUMP #19

0848-0878 AREAS BETWEEN JET PUMP #20--- 0 AZ MANWAY

0879-1023 0 AZ SUPPORT RING MANWAY

1023-1180 180 SUPPORT RING MANWAY COVER

TAPE #12 SHROUD HEAD HOLD DOWN BRACKET & WELD

0000-0039 BRACKET & WELD @ 5 AZ

0039-0064 BRACKET & WELD @ 15 AZ
TAPE #12

0064-0087 BRACKET & WELD @ 25 AZ

0087-0112 BRACKET & WELD @ 35 AZ

0112-0134 BRACKET & WELD @ 45 AZ

0134-0160 BRACKET & WELD @ 55 AZ

0160-0182 BRACKET & WELD @ 65 AZ

0182-0209 BRACKET & WELD @ 75 AZ

0209-0227 BRACKET & WELD @ 85 AZ

0227-0249 BRACKET & WELD @ 95 AZ

0249-0283 BRACKET & WELD @ 105 AZ

0283-0331 BRACKET & WELD @ 115 AZ

0331-0383 BRACKET & WELD @ 125 AZ
0383-0406 BRACKET & WELD @ 135 AZ
0406-0435 BRACKET & WELD @ 145 AZ
0435-0465 BRACKET & WELD @ 155 AZ
0465-0501 BRACKET & WELD @ 165 AZ
0501-0522 BRACKET & WELD @ 175 AZ
0522-0557 BRACKET & WELD @ 185 AZ
0557-0574 BRACKET & WELD @ 195 AZ
0574-0596 BRACKET & WELD @ 205 AZ
0596-0626 BRACKET & WELD @ 215 AZ
0626-0646 BRACKET & WELD @ 225 AZ
0646-0669 BRACKET & WELD @ 235 AZ
0669-0695 BRACKET & WELD @ 245 AZ
0695-0733 BRACKET & WELD @ 255 AZ

0733-0781 BRACKET & WELD @ 265 AZ
0781-0805 BRACKET & WELD @ 275 AZ

TAPE #12

0805-0819 BRACKET & WELD @ 285 AZ
0819-0831 BRACKET & WELD @ 295 AZ
0831-0851 BRACKET & WELD @ 305 AZ
0851-0872 BRACKET & WELD @ 315 AZ
0872-0894 BRACKET & WELD @ 325 AZ
0894-0905 BRACKET & WELD @ 335 AZ
0905-0920 BRACKET & WELD @ 345 AZ
0920-0945 BRACKET & WELD @ 355 AZ
0945-0952 RESOLUTION CHECK

SHROUD FLANGE SURFACE

0952-1067 0 AZ --- 90 AZ
1067-1152 90 AZ --- 180 AZ

1152-1232	180 AZ --- 270 AZ
1232-1350	270 AZ --- 360 AZ
	<u>TOP GUIDE HOLD DOWN</u>
1350-1357	HOLD DOWN @ 356 AZ
1357-1364	HOLD DOWN @ 86 AZ
1364-1376	HOLD DOWN @ 176 AZ
1376-1397	HOLD DOWN @ 266 AZ
<u>TAPE #13</u>	<u>JET PUMP HOLD DOWN BEAMS</u>
0000-0038	JET PUMP #1 BEAM
0038-0076	JET PUMP #2 BEAM
0076-0109	JET PUMP #3 BEAM
0109-0141	JET PUMP #4 BEAM
0141-0162	JET PUMP #5 BEAM
0162-0180	JET PUMP #6 BEAM
<u>TAPE #13</u>	
0180-0206	JET PUMP #7 BEAM
0206-0228	JET PUMP #8 BEAM
0228-0265	JET PUMP #9 BEAM
0265-0291	JET PUMP #10 BEAM
0291-0322	JET PUMP #11 BEAM
0322-0354	JET PUMP #12 BEAM
0354-0396	JET PUMP #13 BEAM
0396-0441	JET PUMP #14 BEAM
0441-0482	JET PUMP #15 BEAM
0482-0531	JET PUMP #16 BEAM
0531-0581	JET PUMP #17 BEAM
0581-0629	JET PUMP #18 BEAM
0629-0674	JET PUMP #19 BEAM
0674-0708	JET PUMP #20 BEAM

TAPE #13

JET PUMP INSPECTIONS
ACCESSIBLE AREA OF JET PUMPS

JET PUMP #1

0707-0741 180 AZ BEND NOZZLE & PARTS OF TRANSITION PIECE
0741-0842 INLET MIXER & JET PUMP RISER BRACE
0842-0913 RESTRAINER
0913-0954 DIFFUSER SLIP JOINT & RISER NOZZLE
0954-1070 DIFFUSER

JET PUMP #2

1070-1152 180 AZ BEND NOZZLE & PARTS OF TRANSITION PIECE
1152-1423 INLET MIXER & JET PUMP RISER BRACE
1423-1517 RESTRAINER
1517-1610 DIFFUSER SLIP JOINT
1610-1660 SENSING LINE - DIFFUSER

TAPE #13

1660-1665 SENSING LINE UPPER BRACKET
1665-1676 SENSING LINE
1676-1695 LOWER SENSING LINE BRACKET
1695-1731 SENSING LINE & COUPLING
1731-1882 DIFFUSER

JET PUMP #3

1882-1929 180 AZ BEND NOZZLE & TRANSITION PIECE
1929-2051 INLET MIXER & RISER BRACE

2051-2153 RESTRAINER
2153-2203 DIFFUSER SLIP JOINT
2203-2389 DIFFUSER

JET PUMP #4

2389-2437 100 AZ BEND NOZZLE & TRANSITION PIECE
2437-2537 INLET MIXER & RISER BRACE
2537-2599 RESTRAINER
2599-2654 DIFFUSER SLIP JOINT
2654-2691 SENSING LINE

2691-2697	SENSING LINE-UPPER BRACKET
2697-2715	SENSING LINE
2715-2742	SENSING LINE LOWER BRACKET
2742-2774	SENSING LINE & COUPLING
2774-2945	DIFFUSER
	<u>JET PUMP #5</u>
2945-2996	180 AZ BEND NOZZLE & TRANSITION
2996-3001	INLET MIXER & RISER BRACE
3001-3080	RESTRAINER
3080-3125	DIFFUSER SLIP JOINT
	<u>TAPE #13</u>
3125-3275	DIFFUSER
	<u>JET PUMP #6</u>
3275-3300	180 AZ BEND NOZZLE & TRANSITION
3300-3458	INLET MIXER & RISER BRACE
3458-3501	RESTRAINER
3501-3544	DIFFUSER SLIP JOINT
3544-3568	SENSING LINE
3568-3588	SENSING LINE-UPPER BRACKET
3588-3606	SENSING LINE
3606-3616	SENSING LINE LOWER BRACKET
3616-3708	SENSING LINE & COUPLING
3708-3768	DIFFUSER
	<u>JET PUMP #7</u>
3768-3785	180 AZ BEND NOZZLE & TRANSITION
3785-3853	INLET MIXER - RISER BRACE
3853-3894	RESTRAINER
3894-3910	DIFFUSER SLIP JOINT
3910-3950	CAMERA MISPLACED-RAN OVER SAME AREA TWICE
3950-4044	SENSING LINE DIFFUSER

4044-4053	SENSING LINE UPPER BRACKET
4053-4062	SENSING LINE & DIFFUSER
4062-4078	LOWER SENSING LINE BRACKET
4078-4103	SENSING LINE & DIFFUSER & COUPLING
4103-4154	180 AZ BEND NOZZLE & TRANSITION
4154-4280	INLET MIXER & RISER BRACE
4280-4300	RESTRAINER
4300-4321	DIFFUSER SLIP JOINT
TAPE #14 13	2-3-86
4321-4425	DIFFUSER
	<u>JET PUMP #9</u>
4425-4446	180 AZ BEND NOZZLE & TRANSITION
4446-4489	INLET MIXER & RISER BRACE
4489-4509	RESTRAINER
4509-4545	DIFFUSER SLIP JOINT
4545-4557	SENSING LINE
4557-4560	UPPER SENSING LINE BRACKET
4560-4562	SENSING LINE
4562-4569	LOWER SENSING LINE BRACKET
4569-4576	SENSING LINE & COUPLING
4576-4632	DIFFUSER
	<u>JET PUMP #10</u>
4632-4642	180 AZ BEND NOZZLE & TRANSITION
4642-4675	INLET MIXER & RISER BRACE
4675-4692	RESTRAINER
4692-4701	DIFFUSER SLIP JOINT
4701-4765	DIFFUSER
4765-4769	RESOLUTION CHECK
4769-4770	<u>JET PUMP #1</u> TOP OF SENSING LINE

JET PUMP #4
 4770-4773 TOP OF SENSING LINE
JET PUMP #6
 4773-4775 TOP OF SENSING
JET PUMP #7
 4775-4778 TOP OF SENSING LINE
 TAPE #14 13 ~~14~~ 2-3-80
JET PUMP #9
 4778-4781 TOP OF SENSING LINE
JET PUMP #9
 4781-4791 UPPER & LOWER SENSING LINE BRACKET
 TAPE #15 RELOOK OF MANWAY COVERS
 0000-0015 RESOLUTION CHECK
 0015-0120 0 AZ MANWAY COVER & WELD
 0120-0390 180 AZ MANWAY COVER & WELD
 TAPE #16 JET PUMP INSPECTION
 0000-0018 RESOLUTION CHECK
JET PUMP #11
 0018-0050 180 AZ BEND NOZZLE & TRANSITION
 0050-0173 INLET MIXER
 0173-0227 RESTRAINER
 0227-0246 DIFFUSER SLIP JOINT
 0246-0351 DIFFUSER
 0351-0365 RISER BRACE
JET PUMP #12
 0365-0390 180 AZ BEND NOZZLE & TRANSITION
 0390-0473 INLET MIXER & BRACE
 0473-0539 RESTRAINER
 0539-0564 DIFFUSER SLIP JOINT
 0564-0702 DIFFUSER & SENSING LINE
 0702-0726 UPPER SENSING LINE BRACKET
 0726-0735 LOWER SENSING LINE BRACKET

NOTE

Tape #14 was used for special reexaminations per a request to GPC. These exams are covered by tapes included in this report, therefore tape #14 is not included.

0735-0739 " SENSING LINE COUPLING
 0739-0767 SENSING LINE
 0767-0792 JET PUMP #13
 180 AZ BEND NOZZLE & TRANSITION
TAPE #16
 0792-0851 INLET MIXER
 0851-0908 RESTRAINT
 0908-0937 SLIP JOINT DIFFUSER
 0937-1044 DIFFUSER
JET PUMP 14
 1044-1066 180 AZ BEND NOZZLE & TRANSITION
 1066-1165 INLET MIXER & RISER BRACE
 1165-1197 RESTRAINER
 1197-1218 DIFFUSER SLIP JOINT
 1218-1245 SENSING LINE
 1245-1254 UPPER SENSING LINE BRACKET
 1254-1263 SENSING LINE
 1263-1267 SENSING LINE LOWER BRACKET
 1267-1284 SENSING LINE & COUPLING
JET PUMP #15
 1285-1317 180 BEND NOZZLE
 1317-1400 INLET MIXER & RISER BRACKET
 1400-1434 RESTRAINER
 1434-1467 DIFFUSER SLIP JOINT
 1467-1540 DIFFUSER
JET PUMP #16
 1540-1597 180 AZ BEND & TRANSITION
 1597-1701 INLET MIXER & RISER BRACE
 1701-1730 RESTRAINER
 1730-1740 DIFFUSER SLIP JOINT
 1740-1775 SENSING LINE & DIFFUSER
 1775-1780 SENSING LINE UPPER BRACKET

1780-1782 COUPLING

TAPE #16

1794-1829 180 AZ BEND & TRANSITION PIECE

1829-1950 INLET MIXER & RISER BRACE

1950-1979 RESTRAINER

1979-1986 DIFFUSER SLIP JOINT

1986-2016 DIFFUSER & SENSING LINE

2016-2020 SENSING-LINE BRACKET UPPER

2020-2031 LOWER SENSING LINE BRACKET

2031-2064 SENSING LINE

JET PUMP #18

2064-2084 180 AZ BEND & TRANSITION PIECE

2084-2117 INLET MIXER & RISER BRACE

2117-2131 RESTRAINER

2131-2137 SLIP JOINT DIFFUSER

2137-2202 DIFFUSER

JET PUMP #19

2202-2221 180 AZ BEND & TRANSITION PIECE

2221-2280 INLET MIXER & RISER BRACE

2280-2302 RESTRAINER

2302-2318 SLIP JOINT DIFFUSER

2318-2363 DIFFUSER & SENSING LINE & BRACKETS

JET PUMP #20

2363-2383 180 AZ BEND & TRANSITION

2383-2455 INLET MIXER & RISER BRACE

2455-2475 RESTRAINER

2475-2500 DIFFUSER SLIP JOINT

2500-2608 DIFFUSER

SUMMARY
OF CLASS 1 AND 2
REPAIRS AND REPLACEMENTS

REPAIRS AND REPLACEMENTS

Repairs and Replacements

No significant repairs or replacements were performed during the outage. As mentioned previously in the report, one (1) Jet Pump Hold Down Beam and six (6) Shroud Head Hold Down Bolts were replaced due to rejectable indications reported from ISI examinations.

Numerous repairs were initiated on component supports due to indications detected during ISI examination. These repairs are not described in detail in this report, but Deficiency Card Numbers and MWO Numbers are referenced in the ABSTRACT SECTION and in the EXAMINATION TABLES for additional information.

Valves 2B21-F001 and 2B21-F002 were disassembled and repaired due to leakage detected during performance of the Class 1 System Leakage Test prior to plant start-up. These valves were examined after repairs during performance of an isolated leakage inspection that was performed during plant start-up.

The ANI/ANII was utilized for review and/or inspection of all repair and/or replacement NDE activities.