

Georgia Power Company
333 Piedmont Avenue
Atlanta, Georgia 30303
Telephone 404 526-6526

Mailing Address:
Post Office Box 4545
Atlanta, Georgia 30302

Nuclear Operations Department



Georgia Power

the southern electric system

SL-4805
0980m
X7GJ17-V540

June 17, 1988

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

PLANT VOGTLE - UNIT 1
NRC DOCKET 50-424
OPERATING LICENSE NPF-68
SPECIAL REPORT
INVALID DIESEL GENERATOR FAILURES

Gentlemen:

In accordance with the requirements of the Plant Vogtle - Unit 1 Technical Specification section 4.8.1.1.3 and 6.8.2, Georgia Power Company is submitting the enclosed revised Special Report concerning invalid diesel generator failures. The enclosed report supercedes the special report previously submitted by our letter SL-4483 dated April 22, 1988.

Sincerely,

W. G. Hairston, III
Senior Vice President

PAH/lm

Enclosure: Special Report 88-002, Revision 1

c: Georgia Power Company
Mr. P. D. Rice
Mr. G. Bockhold, Jr.
GO-NORMS

U. S. Nuclear Regulatory Commission
Mr. J. N. Grace, Regional Administrator
Mr. J. B. Hopkins, Licensing Project Manager, NRR (2 copies)
Mr. J. F. Rogge, Senior Resident Inspector-Operations, Vogtle

8806260277 880617
PDR ADOCK 05000424
S PDR

IE22
||

ENCLOSURE

PLANT VOGTLE - UNIT 1
NRC DOCKET 50-424
OPERATING LICENSE NPF-68
SPECIAL REPORT 88-002

A. Requirement for Report

This report is required in accordance with the Plant Vogtle - Unit 1 Technical Specifications section 4.8.1.1.3. This section of the Technical Specifications requires that all diesel generator failures, valid or nonvalid, shall be reported to the Commission in a Special Report pursuant to Specification 6.8.2 within 30 days. This report is being submitted due to the recent clarification by the NRC - Region II of the definition of an invalid failure.

B. Description of Invalid Failures for the Train A Diesel Generator

On February 18, 1987, Start No. 1-87-0043 was attempted after performing maintenance activities on the Unit 1 - Train A diesel generator. Shortly after startup, the engine tripped. A subsequent investigation revealed the valve from the fuel oil day tank to the diesel was locked closed, thus starving the engine. Start No. 1-87-0044 was attempted but a pre-lube valve was left open. This led to a trip due to low turbocharger oil pressure, a normal trip function which is bypassed in the emergency mode. Start No. 1-87-0045 was attempted and the pre-lube valve was closed in a timely manner. However, a low turbocharger oil pressure trip occurred again, even though a turbocharger oil pressure gauge registered a pressure above the trip setpoint. A search discovered a loose fitting on the right bank turbocharger pressure switch. The fitting was tightened and a successful start was achieved on Start No. 1-87-0046.

On June 23, 1987, start attempt 1-87-0055 was performed on the Unit 1 - Train A diesel generator. The generator was paralleled to the grid and loading was in progress when the operator noticed air escaping from some of the cylinder locks. The output breaker was tripped and the diesel was shut down. The cylinder locks had been left open following the performance of the routine checks. The operator failed to follow the procedure. This was an invalid failure.

ENCLOSURE (Continued)

SPECIAL REPORT 88-002

C. Description of an Invalid Failure for the Train B Diesel Generator

On February 6, 1987, start no. 1-87-0036 was performed on the Unit 1 - Train B diesel generator. While the generator was being paralleled to the grid, the operator allowed the KVAR to go negative for a percent of time sufficient that the loss of excitation relay tripped the output breaker and the diesel. For this event, the operator failed to follow a procedure. This was an invalid failure.

D. Summary

All the above failures to start were invalid failures. There was no change to the surveillance frequency since these were invalid failures.