



Log # TXX-88030  
File # 10130  
IR 85-18  
IR 85-15  
Ref. # 10CFR2.201

William G. Council  
Executive Vice President

January 11, 1988

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)  
DOCKET NOS. 50-445 AND 50-446  
INSPECTION REPORT NOS. 50-445/85-18 AND 50-446/85-15  
REVISED RESPONSE FOR NOTICE OF VIOLATION (NOV)  
445/8518-V-15 (ITEM C)

REF: TU Electric Letter TXX-6692 from W. G. Council to the  
NRC dated August 31, 1987

Gentlemen:

Our referenced letter stated that we would provide an updated response to NOV 445/8518-V-15 by January 15, 1988. Our investigation of methods for evaluating fire effects on instrument tubing is not yet complete. We are currently attempting to ascertain the expected maximum temperature in affected areas during fire conditions. We are also pursuing a design modification which will eliminate the zinc embrittlement hazard for a substantial number of instruments. Accordingly, our date for submission of an updated response to NOV 445/8518-V-15, is hereby revised to be no later than May 30, 1988.

Very truly yours,

*W. G. Council*  
W. G. Council

RSB/grr

c - Mr. R. D. Martin, Region IV  
Resident Inspectors, CPSES (3)

8801200294 890111  
PDR ADDOCK 05000445  
Q PDR

*IED/1/0*