

**FLORIDA POWER CORPORATION
CRYSTAL RIVER UNIT 3
DOCKET NO. 50-302/LICENSE NO. DPR-72**

ATTACHMENT

**LICENSE AMENDMENT REQUEST #221, REVISION 2
ONCE THROUGH STEAM GENERATOR
TUBE SURVEILLANCE PROGRAM**

Proposed Technical Specification Change Page

9811240067 981117
PDR ADOCK 05000302
P PDR

5.7 Reporting Requirements

5.7.2 Special Reports (continued)

5. For first span "B" OTSG pit-like IGA, a summary of analyses performed to determine if estimated leakage based on the projected end-of-cycle percent throughwall distribution exceeds the leak limit (determined from the licensing basis dose calculation for the main steamline break) for the next operating cycle.
6. A deterministic assessment for the first span "B" OTSG pit-like IGA.

Results of OTSG tube inspections that fall into Category C-3 shall be reported to the NRC prior to resumption of plant operation. This report shall provide a description of investigations conducted to determine cause of the tube degradation and corrective measures taken to prevent recurrence.
