



**Northeast  
Nuclear Energy**

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385-0128  
(860) 447-1791  
Fax (860) 444-4277

The Northeast Utilities System

**JUN 9 1999**  
**Docket No. 50-336**  
**B17800**

Re: 10 CFR 50.73(a)(2)(i)

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555


Millstone Nuclear Power Station, Unit No. 2  
Licensee Event Report 99-008-00  
Auxiliary Feedwater Regulating Valve Failed  
Surveillance Test, Entry into Technical Specification 3.0.3

This letter forwards Licensee Event Report (LER) 99-008-00, documenting an event that occurred at Millstone Nuclear Power Station, Unit No. 2, on May 11, 1999. This LER is being submitted pursuant to 10 CFR 50.73(a)(2)(i).

Northeast Nuclear Energy Company's (NNECO) commitments made within this letter are included in Attachment 1.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

  
\_\_\_\_\_  
C. J. Schwarz  
Director - Millstone Unit No. 2

Attachments: 1. List of Regulatory Commitments  
2. LER 99-008-00

cc: H. J. Miller, Region I Administrator  
R. B. Eaton, NRC Senior Project Manager, Millstone Unit No. 2  
D. P. Beaulieu, Senior Resident Inspector, Millstone Unit No. 2

11  
IE22

9906180022 990609  
PDR ADOCK 05000336  
S PDR

Docket No. 50-336  
B17800

Attachment 1  
Millstone Nuclear Power Station, Unit No. 2  
Commitments

June 1999

Attachment 1

Regulatory Commitment Enclosure  
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document.

REGULATORY COMMITMENT	COMMITTED DATE OR OUTAGE
B17800.01: Applicable procedures will be revised to provide additional guidance on determining action required upon failure of the monthly inservice operability test.	August 1, 1999

Docket No. 50-336  
B17800

Attachment 2

Millstone Nuclear Power Station, Unit No. 2

LER 99-008-00

June 1999