



An Illinova Company

Illinois Power Company  
P.O. Box 678  
Clinton, IL 61727  
Tel 217 935-8881 x3900  
Fax 217 935-4632

John P. McElwain  
Chief Nuclear Officer

U-603220  
2C.220

June 12, 1999

Docket No. 50-461

10CFR50.73

Document Control Desk  
Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: Clinton Power Station - Unit 1  
Licensee Event Report No. 1999-007-00

Dear Madam or Sir:

Enclosed is Licensee Event Report (LER) No. 1999-007-00: Design Error Causes Main Steam Isolation Valve Leakage Control System to be Outside of its Design Basis. This report is being submitted in accordance with the requirements of 10CFR50.73.

The enclosed report contains the following commitment:

- A design change will be prepared to change the setpoint of the main steam isolation valve leakage control system so that the main steam isolation valve leakage rate of 28 scfh is accommodated, including instrument uncertainties, without overloading the capabilities of the main steam isolation valve leakage control system.

Sincerely yours,

John P. McElwain  
Chief Nuclear Officer

11  
IE22

MRS/krk

Enclosure

9906180042 990612  
PDR ADOCK 05000461  
S PDR

cc: NRC Clinton Licensing Project Manager  
NRC Resident Office, V-690  
Regional Administrator, Region III, USNRC  
Illinois Department of Nuclear Safety  
INPO Records Center