

June 9, 1988

Docket No. 50-440

Mr. Alvin Kaplan, Vice President
Nuclear Group
The Cleveland Electric Illuminating
Company
10 Center Road
Perry, Ohio 44081

DISTRIBUTION:

<u>Docket Files</u>	NRC & Local PDRs
PDIII-3 r/f	KPerkins
PKreutzer	TColburn
GHolahan	OGC-WF1
EJordan	JPartlow
ACRS(10)	PDIII-3 Gray Files
WHodges	TCollins
MMcCoy	

Dear Mr. Kaplan:

SUBJECT: PERRY NUCLEAR POWER PLANT UNIT 1 - COMPLIANCE WITH 10 CFR 50.62

In reviewing your submittals with regard to the subject item, we have determined that we will need the additional information identified in the enclosure to this letter in order to complete our review. In order for us to maintain our review schedule, we request that you provide the information within 30 days receipt of this letter.

This request for information affects fewer than ten respondents; therefore, OMB clearance is not required under Pub. L. 96-511.

Sincerely,

/s/

Timothy G. Colburn, Project Manager
Project Directorate III-3
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
Request for Additional
Information

cc: See next page

Office: LA/PDIII-3
Surname: PKreutzer
Date: 6/7/88

See
PM/PDIII-3
TColburn/tg
6/8/88

PD/PDIII-3
KPerkins
6/9/88

Mr. Alvin Kaplan
The Cleveland Electric
Illuminating Company

Perry Nuclear Power Plant
Unit 1

cc:

Shaw, Pittman, Potts & Trowbridge
2300 N Street, N.W.
Washington, D.C. 20037

Mr. James W. Harris, Director
Division of Power Generation
Ohio Department of Industrial
Relations
P.O. Box 825
Columbus, Ohio 43216

David E. Burke
The Cleveland Electric
Illuminating Company
P.O. Box 5000
Cleveland, Ohio 44101

The Honorable Lawrence Logan
Mayor, Village of Perry
4203 Harper Street
Perry, Ohio 44081

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
Parmly at Center Road
Perry, Ohio 44081

The Honorable Robert V. Orosz
Mayor, Village of North Perry
North Perry Village Hall
4778 Lockwood Road
North Perry Village, Ohio 44081

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43216

Frank P. Weiss, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Radiological Health Program
Ohio Department of Health
1224 Kinnear Road
Columbus, Ohio 43212

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Ohio Environmental Protection
Agency
361 East Broad Street
Columbus, Ohio 43266-0558

Terry J. Lodge, Esq.
618 N. Michigan Street
Suite 105
Toledo, Ohio 43624

Mr. Phillip S. Haskell, Chairman
Perry Township Board of Trustees
Box 65
4171 Main Street
Perry, Ohio 44081

John G. Cardinal, Esq.
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047

State of Ohio
Public Utilities Commission
180 East Broad Street
Columbus, Ohio 43266-0573

Eileen M. Buzzelli
The Cleveland Electric
Illuminating Company
P. O. Box 97 E-210
Perry, Ohio 44081

Mr. Murray R. Edelman
Centerior Energy
6200 Oaktree Blvd.
Independence, Ohio 44131

REQUEST FOR ADDITIONAL INFORMATION

PERRY NUCLEAR POWER PLANT UNIT 1

Section 4.1.5 of the Perry Technical Specifications for the Reactivity Control Systems contains a Surveillance Requirement that states that both standby liquid control system (SLCS) pumps will be operated during periodic tests of the system. Describe the pre-operational or periodic testing of both pumps simultaneously to assure that a total flowrate of 82.4 gpm can be achieved against full reactor operating pressure without lifting of the SLCS pump relief valve.