

3.6 CONTAINMENT SYSTEMS

3.6.17 Containment Valve Injection Water System (CVIWS)

LCO 3.6.17 Two CVIWS trains shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One CVIWS train inoperable.	A.1 Restore CVIWS train to OPERABLE status.	7 days
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	6 hours
	<u>AND</u> B.2 Be in MODE 5.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.17.1 Verify system surge tanks pressure is $\geq 36.4$ psig.	31 days
SR 3.6.17.2 Verify valve injection flow rate is $< 1.29$ gpm (Unit 1) $< 1.21$ gpm (Unit 2) for Train A and $< 1.16$ gpm for Train B with a surge tank pressure $\geq 36.4$ psig.	18 months
SR 3.6.17.3 Verify each automatic valve actuates to its correct position on an actual or simulated actuation signal.	18 months

9811270079 981120  
PDR ADOCK 05000413  
P PDR