



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-362

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 136
License No. NPF-15

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Southern California Edison Company, et al. (SCE or the licensee) dated September 22, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9811300076 981123
PDR ADOCK 05000362
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2 C(2) of Facility Operating License No. NPF-15 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 136, are hereby incorporated in the license. Southern California Edison Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



James W. Clifford, Senior Project Manager
Project Directorate IV-2
Division of Reactor Projects III, IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: November 23, 1998

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 136 TO FACILITY OPERATING LICENSE NO. NPF-15

DOCKET NO. 50-362

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by Amendment number and contain marginal lines indicating the areas of change.

REMOVE

3.3-8

3.3-9

INSERT

3.3-8

3.3-9

Table 3.3.1-1 (page 1 of 2)
Reactor Protective System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
1. Linear Power Level - High	1,2	SR 3.3.1.1 SR 3.3.1.4 SR 3.3.1.6 SR 3.3.1.7 SR 3.3.1.8 SR 3.3.1.9 SR 3.3.1.13	$\leq 111.0\%$ RTP
2. Logarithmic Power Level - High ^(a)	2 ^(b)	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.9 SR 3.3.1.12 SR 3.3.1.13	$\leq .934$ RTI
3. Pressurizer Pressure - High	1,2	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.9 SR 3.3.1.13	≤ 2385 psia
4. Pressurizer Pressure - Low ^(c)	1,2	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.9 SR 3.3.1.12 SR 3.3.1.13	≥ 1700 psia
5. Containment Pressure - High	1,2	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.9 SR 3.3.1.13	≤ 3.4 psig
6. Steam Generator 1 Pressure-Low	1,2	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.9 SR 3.3.1.13	≥ 729 psia
7. Steam Generator 2 Pressure-Low	1,2	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.9 SR 3.3.1.13	≥ 729 psia

(continued)

- (a) Trip may be bypassed when logarithmic power is $> 1E-4\%$ RTP. Bypass shall be automatically removed when logarithmic power is $\leq 1E-4\%$ RTP. Trip may be manually bypassed during physics testing pursuant to LCO 3.1.12.
- (b) When any RTCB is closed.
- (c) The setpoint may be decreased to a minimum value of 300 psia, as pressurizer pressure is reduced, provided the margin between pressurizer pressure and the setpoint is maintained ≥ 400 psia. Trips may be bypassed when pressurizer pressure is ≤ 400 psia. Bypass shall be automatically removed before pressurizer pressure exceeds 500 psia (the corresponding bistable allowable value is ≤ 472 psia).

Table 3.3.1-1 (page 2 of 2)
Reactor Protective System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
8. Steam Generator 1 Level - Low	1,2	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.9 SR 3.3.1.13	$\geq 20\%$
9. Steam Generator 2 Level - Low	1,2	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.9 SR 3.3.1.13	$\geq 20\%$
10. Reactor Coolant Flow - Low ^(d)	1,2	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.9 SR 3.3.1.12 SR 3.3.1.13	Ramp: ≤ 0.231 psid/sec. Floor: ≥ 12.1 psid Step: ≤ 7.25 psid
11. Local Power Density - High ^(d)	1,2	SR 3.3.1.1 SR 3.3.1.3 SR 3.3.1.4 SR 3.3.1.7 SR 3.3.1.9 SR 3.3.1.10 SR 3.3.1.11 SR 3.3.1.12 SR 3.3.1.13	≤ 21.0 kW/ft
12. Departure From Nucleate Boiling Ratio (DNBR) - Low ^(d)	1,2	SR 3.3.1.1 SR 3.3.1.2 SR 3.3.1.3 SR 3.3.1.4 SR 3.3.1.5 SR 3.3.1.7 SR 3.3.1.9 SR 3.3.1.10 SR 3.3.1.11 SR 3.3.1.12 SR 3.3.1.13	≥ 1.31

(d) Trip may be bypassed when logarithmic power is $< 1E-4\%$ RTP. Bypass shall be automatically removed when logarithmic power is $\geq 1E-4\%$ RTP. During testing pursuant to LCO 3.1.12, trip may be bypassed below 5% RTP. Bypass shall be automatically removed when logarithmic power is $\geq 5\%$ RTP.