Docket No. 50-382

Mr. J. G. Dewease Senior Vice President -Nuclear Operations Louisiana Power and Light Company 317 Baronne St., Mail Unit 17 New Orleans, Lousiana 70160

Dear Mr. Dewease:

SUBJECT: GENERIC LETTER 88-03, "STEAM BINDING OF AUXILIARY FEEDWATER PUMPS (TAC NOS. 67289)

On February 17, 1988, Generic Letter 88-03 was issued and requested all licensees of operating PWRs and holders of construction permits for PWRs to confirm that appropriate procedures are in place, and will be maintained, to minimize the occurrence of steam binding of the auxiliary feedwater (AFW) pumps. The procedures require monitoring fluid conditions within the AFW system each shift during times when the system is required to be operable, and recognizing steam binding and restoring the ArW system to operable status should steam binding occur.

Your response, dated April 5, 1988, confirmed that you have in place, and will maintain, the necessary procedures. Thus, your response to Generic Letter 88-03 is satisfactory and no further action is necessary.

Sincerely

181

David L. Wigginton, Project Manager Project Directorate - IV Division of Reactor Projects - III. IV, V and Special Projects Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION Docket File Local PDR

NRC PDR PD4 Reading

L. Rubenstein P. Noonan PD4 Plant File D. Crutchfield J. Calvo

D. Wigginton

PDIV: LA PNoonar? 06/17/88

PDIV:D MC PDIV: PM DWigginton: kb/ JCalvo 06/16/88 06/20/88

8806300106 890620 PDR ADDCK 05000382



## UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

June 20, 1988

Docket No. 50-382

Mr. J. G. Dewease
Senior Vice President Nuclear Operations
Louisiana Power and Light Company,
317 Baronne St., Mail Unit 17
New Orleans, Lousiana 70160

Dear Mr. Dewease:

SUBJECT: GENERIC LETTER 88-03, "STEAM BINDING OF AUXILIARY FEEDWATER PUMPS (TAC NOS. 67289)

On February 17, 1988, Generic Letter 88-03 was issued and requested all licensees of operating PWRs and holders of construction permits for PWRs to confirm that appropriate procedures are in place, and will be maintained, to minimize the occurrence of steam binding of the auxiliary feedwater (AFW) pumps. The procedures require monitoring fluid conditions within the AFW system each shift during times when the system is required to be operable, and recognizing steam binding and restoring the AFW system to operable status should steam binding occur.

Your response, dated April 5, 1988, confirmed that you have in place, and will maintain, the necessary procedures. Thus, your response to Generic Letter 88-03 is satisfactory and no further action is necessary.

Sincerely

David L. Wigginton, Project Manager

Project Directorate - IV

Division of Reactor Projects - III.

IV, V and Special Projects

Office of Nuclear Reactor Regulation

cc: See next page

Mr. Jerrold G. Dewease Louisiana Power & Light Company Waterford 3

cc: W. Malcolm Stevenson, Esq. Monroe & Leman 1432 Whitney Building New Orleans, Louisiana 70103

Mr. E. Blake Shaw, Pittman, Potts & Trowbridge 2300 N Street, NW Washington, D.C. 20037

Resident Inspector/Waterford NPS Post Office Box 822 Killona, Louisiana 70066

Mr. Ralph T. Lally Manager of Quality Assurance Middle South Services, Inc. Post Office Box 61000 New Orleans, Louisiana 70161

Chairman Louisiana Public Service Commission One American Place, Suite 1630 Baton Rouge, Louisiana 70825-1697

Mr. R. F. Burski, Acting Nuclear Safety and Regulatory Affairs Manager Louisiana Power & Light Company 317 Baronne Street New Orleans, Louisiana 70112

Regional Administrator, Region IV U.S. Nuclear Regulatory Commission Office of Executive Director for Operations 611 Ryan Plaza Drive, Suite 1000 Arlington, Texas 76011

Mr. William H. Spell, Administrator Nuclear Energy Division Office of Environmental Affairs Post Office Box 14690 Baton Rouge, Louisiana 70898

President, Police Jury St. Charles Parish Hahnville, Louisiana 70057

William A. Cross Bethesda Licensing Office 3 Metro Center Suite 610 Bethesda, Maryland 20814