

JAMES R. LEMONS
Manager
Nuclear Support Services

Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 586-2200 Ext. 3693 Local
410 760-3693 Baltimore

June 21, 1999



U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit No. 2; Docket No. 50-318
Emergency Response Data System

The attached revision to the Emergency Response Data System (ERDS) Data Point Library for the Calvert Cliffs Nuclear Power Plant is provided pursuant to 10 CFR Part 50, Appendix E, Section VI.3.a.

The table below provides a brief summary of the changes:

Point Identifier	Unit	Description	Old Range	New Range
F131A	2	RCS Total Flow Channel A	-51.70:146.2 % Flow	-53.49:151.25% Flow

Revised ERDS Data Point Library sheets are attached.

Should you have questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

JRL/TWG/dlm

40001

Attachment: As Stated

cc: R. S. Fleishman, Esquire
J. E. Silberg, Esquire
Director, Project Directorate I-1, NRC
A. W. Dromerick, NRC
J. R. Jolicoeur, NRC

H. J. Miller, NRC
Resident Inspector, NRC
R. I. McLean, DNR
J. H. Walter, PSC

9906240032 990621
PDR ADOCK 05000318
F PDR

PWR DATA POINT LIBRARY REFERENCE FILE

REV DATE: 07/23/97

PAGE : 5

DATE: 07/23/97

REACTOR UNIT: CC2

DATA FEEDER: CC21

NRC ERDS PARAMETER: CORE FLOW

POINT ID: F131A

PLANT SPEC POINT DESC.: RCS TOTAL FLOW CH A

GENERIC/COND DESC.: TOTAL REACTOR COOLANT FLOW

ANALOG/DIGITAL: A

ENGR UNITS/DIG STATES: % FLOW

ENGR UNITS CONVERSION: 100% RX COOLANT FLOW = 370,000 GPM

MINIMUM INSTR RANGE: -51.70

MAXIMUM INSTR RANGE: 146.20

ZERO POINT REFERENCE: N/A

REFERENCE POINT NOTES: N/A

PROC OR SENS: S

NUMBER OF SENSORS: 1

HOW PROCESSED: N/A

SENSOR LOCATIONS: N/A

ALARM/TRIP SET POINTS: N/A

NI DETECTOR POWER
SUPPLY CUT-OFF POWER LEV: N/A

NI DETECTOR POWER
SUPPLY TURN-ON POWER LEV: N/A

INSTRUMENT FAILURE MODE: N/A

TEMPERATURE COMPENSATION
FOR DP TRANSMITTERS: N

LEVEL REFERENCE LEG: N/A

UNIQUE SYSTEM DESC.: REACTOR COOLANT FLOW IS DETERMINED BY THE D/P
ACROSS THE STEAM GENERATORS. WHERE TOTAL FLOW IS
THE SUM OF BOTH LOOP FLOWS.

PWR DATA POINT LIBRARY REFERENCE FILE

REV DATE: 06/01/99

PAGE : 5

DATE: 06/01/99

REACTOR UNIT: CC2

DATA FEEDER: CC21

NRC ERDS PARAMETER: CORE FLOW

POINT ID: F131A

PLANT SPEC POINT DESC.: RCS TOTAL FLOW CH A

GENERIC/COND DESC.: TOTAL REACTOR COOLANT FLOW

ANALOG/DIGITAL: A

ENGR UNITS/DIG STATES: % FLOW

ENGR UNITS CONVERSION: 100% RX COOLANT FLOW = 370,000 GPM

MINIMUM INSTR RANGE: -53.49

MAXIMUM INSTR RANGE: 151.25

ZERO POINT REFERENCE: N/A

REFERENCE POINT NOTES: N/A

PROC OR SENS: S

NUMBER OF SENSORS: 1

HOW PROCESSED: N/A

SENSOR LOCATIONS: N/A

ALARM/TRIP SET POINTS: N/A

NI DETECTOR POWER
SUPPLY CUT-OFF POWER LEV: N/A

NI DETECTOR POWER
SUPPLY TURN-ON POWER LEV: N/A

INSTRUMENT FAILURE MODE: N/A

TEMPERATURE COMPENSATION
FOR DP TRANSMITTERS: N

LEVEL REFERENCE LEG: N/A

UNIQUE SYSTEM DESC.: REACTOR COOLANT FLOW IS DETERMINED BY THE D/P
ACROSS THE STEAM GENERATORS. WHERE TOTAL FLOW
THE SUM OF BOTH LOOP FLOWS.