

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of ) UNIT NO. 1 UNIT NO. 2  
) Docket No. 50-334 Docket No. 50-412  
Duquesne Light Company ) License No. DPR-66 License No. NPF-73  
Beaver Valley Power Station)

APPLICATION FOR AMENDMENT  
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U. S. Nuclear Regulatory Commission, Duquesne Light Company hereby requests that the Technical Specifications set forth in Appendix A to that license be amended to 1) clarify Axial Flux Difference requirements between 15% and 50% Rated Thermal Power, 2) delete a BV-1 blank page, 3) change the steam generator tube inspection results reporting requirements, and 4) add the steam generator tube ISI report to 6.9.2.

The proposed technical specification change is set forth in Attachment A to this Application. A Safety Evaluation is set forth in Attachment B. A no significant hazard evaluation is set forth in Attachment C. Based on the guidance provided by the Commission, the proposed changes have been determined to involve no significant hazards consideration in accordance with 10 CFR 50.92.

WHEREFORE, Applicant respectfully requests that Appendix A to these Operating Licenses be amended in the form attached hereto as Attachment A.

Duquesne Light Company

By J. D. Sieber  
J. D. Sieber  
Vice President, Nuclear

8802160122 880205  
PDR ADOCK 05000334  
P PDR

Subscribed and sworn to before me

on this 4th day of February, 1988

Shirley M. Lantz