

**Omaha Public Power District**  
1623 Harney Omaha, Nebraska 68102-2247  
402/536-4000

December 5, 1988  
LIC-88-1021

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555


References: Docket No. 50-285

Gentlemen:

SUBJECT: Steam Generator Tube Plugging Report

In accordance with Section 3.17(5)(i) of the Fort Calhoun Station Technical Specifications, Omaha Public Power District (OPPD) reports that no steam generator tubes were plugged as a result of the eddy current testing conducted during the 1988 refueling outage. If you have any questions, please contact us.

Sincerely,

  
K.J. Morris  
Division Manager  
Nuclear Operations

KJM/sa

c: LeBoeuf, Lamb, Leiby & MacRae  
R. D. Martin, NRC Regional Administrator  
P. D. Milano, NRC Project Manager  
P. H. Harrell, NRC Senior Resident Inspector

8812090150 881205  
PDR ADOCK 05000285  
P FDC

A001  
1/0