



Public Service Electric and Gas Company P.O. Box L Hancocks Bridge, New Jersey 08038

Hope Creek Operations

February 16, 1988

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

ANNUAL REPORT  
TECHNICAL SPECIFICATION 6.9.1.5  
HOPE CREEK GENERATING STATION  
DOCKET NO. 50-354

This Annual Report of Challenges to Main Steam Line Safety/Relief Valves (SRVs) is being submitted pursuant to the requirements of Technical Specification 6.9.1.5 for the year 1987.

During 1987, Hope Creek Generating Station (HCGS) experienced one (1) unplanned challenge to SRVs "H" and "P" as a result of a reactor scram on 2/24/87 (Ref: Licensee Event Report 87-017-00). A planned lifting of all SRVs occurred on 10/10/87 following completion of a scheduled maintenance outage to verify the operation of the acoustic monitoring system. During the course of this evolution, SRV "J" stuck open, and was subsequently replaced (Ref: Licensee Event Report 87-047).

Should you have any questions or comments on this submittal, do not hesitate to contact us.

Sincerely,

S. LaBruna  
General Manager-  
Hope Creek Operations

*RBC*  
RBC/tlb

C: Distribution

8803010284 880216  
PDR ADDCK 05000354  
R PDR

The Energy People

*Aoc1  
1/10*