



Northeast
Nuclear Energy

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791
Fax (860) 444-4277

The Northeast Utilities System

NOV 25 1998

Docket No. 50-336
B17555

Re: 10 CFR 50.73(a)(2)(ii)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Millstone Nuclear Power Station Unit No. 2
Licensee Event Report 98-024-00
Potential Leakage Path through Containment Pressure Instrument Identified


This letter forwards Licensee Event Report (LER) 98-024-00, documenting a condition that was discovered at Millstone Nuclear Power Station, Unit No. 2, on October 30, 1998. This LER is being submitted pursuant to 10 CFR 50.73(a)(2)(ii).

The Northeast Nuclear Energy Company's (NNECO) commitments made within this letter are included in Attachment 1.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

FOR: J.A. Price
Director - Millstone Unit No. 2

BY: 
John T. Swintoniewski
Assistant Unit Director
Millstone Unit No. 2

cc: see page 2

9812080067 981125
PDR ADOCK 05000336
S PDR

JE22

Attachments: 1. List of Regulatory Commitments
2. LER 98-024-00

cc: H. J. Miller, Region I Administrator
D. G. McDonald, Jr., NRC Senior Project Manager, Millstone Unit No. 2
D. P. Beaulieu, Senior Resident Inspector, Millstone Unit No. 2
E. V. Imbro, Director, Millstone ICAVP Inspections
S. Dembek, Unit 1 Project Manager, Millstone Unit 1

Docket No. 50-336
B17555

Attachment 1
Millstone Nuclear Power Station, Unit No. 2
Commitments

November 1998

Attachment 1

Regulatory Commitment Enclosure
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document.

REGULATORY COMMITMENT	COMMITTED DATE OR OUTAGE
B17555.01: The nonconforming containment pressure instruments will be replaced with suitable components that comply with FSAR Section 5.2.8.2.1.	Mode 4 from current outage

Docket No. 50-336
B17555

Attachment 2

Millstone Nuclear Power Station, Unit No. 2

LER 98-024-00

November 1998