

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004

JOHN D. SIEBER
Vice President - Nuclear Group

June 27, 1988

(412) 643-5255

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1 and No. 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
Proposed Operating License Change Request No. 151/7

Gentlemen:

Enclosed are:

1. One (1) original Application for Amendment to the above Operating Licenses to incorporate revisions to: (1) change the surveillance frequency from monthly to refueling for Table 4.3-1 item 19, Safety Injection Input from ESF, (2) delete the BV-1 and BV-2 Turbine Driven Pump Discharge Pressure Low initiating signal for auxiliary feedwater from the ESF instrumentation tables, and (3) remove the requirement to test the RHR pumps on recirculation flow.

This change was reviewed by the OSC and ORC and determined to be safe and does not involve an unreviewed safety question.

2. One (1) copy of documents designated Attachments A, B and C which set forth the change in Technical Specifications, the safety analysis and the no significant hazards evaluation.

A check in the amount of \$150.00 is attached as payment of the license amendment application fee in accordance with 10 CFR 170.

Very truly yours,

8807060474 880.27
PDR ADOCK 05000334
P PNU

J. D. Sieber
J. D. Sieber
Vice President
Nuclear Group

Attachment

cc: Mr. J. Beall, Sr. Resident Inspector
Mr. W. T. Russell, NRC Region I Administrator
Mr. P. Tam, Project Manager
Director, Safety Evaluation & Control (VEPCO)
Mr. T. M. Gerusky, Director BRP/DER

*Adol w/ check
11/11 \$150
05000334
649174*