

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004

JOHN D. SIEBER
Vice President - Nuclear Group

(412) 643-6255

June 22, 1988

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1 and No. 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
Proposed Operating License Change Request No. 153/14

Gentlemen:

Enclosed are:

1. One (1) original Application for Amendment to the above Operating Licenses to 1) revise the source range instrumentation channels surveillance requirements of Table 4.3-1 for both Units to be consistent with the applicable modes of Table 3.3-1 and 2) correct typographical errors in action 5 of Table 3.3-1 and the action statement for LCO 3.1.3.3 for Unit 2.

This change has been reviewed by the OSC and ORC and determined to be safe and does not involve an unreviewed safety question.

2. One (1) copy of documents designated Attachments A, B and C which set forth the change in Technical Specifications, the safety analysis and the no significant hazards evaluation.

A check in the amount of \$150.00 is attached as payment of the license amendment application fee in accordance with 10 CFR 170.

Very truly yours,

J. D. Sieber
J. D. Sieber
Vice President
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector
Mr. W. T. Russell, NRC Region I Administrator
Mr. P. Tam, Project Manager
Director, Safety Evaluation & Control (VEPCO)

8807060493 880622
PDR ADOCK 05000334
P PNU

File w/ check \$150 #65009A