

ATTACHMENT 2

Marked-up TS Page 3.4-3 attached

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>E. Total core flow as a function of THERMAL POWER within Region A.</p> <p>OR</p> <p>No recirculation loops in operation in MODE 1.</p>	<p>E.1 Place the reactor mode switch in the shutdown position.</p>	<p>Immediately</p>
<p><i>B.F.</i> No recirculation loops in operation, in MODE 2.</p>	<p><i>B.F.1</i> Be in MODE 3.</p>	<p>12 hours</p>
<p><i>C.S.</i> Required limit modifications not performed.</p>	<p><i>C.S.1</i> Declare associated limit(s) not met.</p>	<p>Immediately</p>