

June 29, 1988

Docket No.: 50-267

Mr. R. O. Williams, Jr.  
Vice President Nuclear Operations  
Public Service Company of Colorado  
Post Office Box 840  
Denver, Colorado 80201-0840

Dear Mr. Williams:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION GENERIC LETTER 88-03 -  
FORT ST. VRAIN

We are reviewing your letter dated May 27, 1988 (P-88115), submitted in response to Generic Letter 88-03. Our review discloses the need for additional information as described in the enclosed request.

The information requested in this letter affects fewer than 10 respondents; therefore, OMB clearance is not required under P. L. 96-511.

Sincerely,

/s/

Paul W. Michaud  
Acting Project Manager-FSV  
Project Directorate - IV  
Division of Reactor Projects - III  
IV, V and Special Projects

Enclosure:  
As stated above

cc: See next page

DISTRIBUTION

Docket File  
NRC & Local PDRs  
PDIV R/F  
DCrutchfield  
LRubenstein  
PNoonan  
PMichand  
OGC-Rockville  
EJordan  
JPartlow  
ACRS (10)  
PD Plant-specific file

OFC	:PM:PDIV	<i>Pm</i>	:D:PDIV	:	:	:	:	:
NAME	:PMichaud:jc		:JCalvo	<i>JK</i>	:	:	:	:
DATE	:06/29/88		:06/29/88		:	:	:	:

OFFICIAL RECORD COPY

*JEED 14004*  
*1/9*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

June 29, 1988

Docket No.: 50-267

Mr. R. O. Williams, Jr.  
Vice President Nuclear Operations  
Public Service Company of Colorado  
Post Office Box 840  
Denver, Colorado 80201-0840

Dear Mr. Williams:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION GENERIC LETTER 88-03 -  
FORT ST. VRAIN

We are reviewing your letter dated May 27, 1988 (P-88115), submitted in response to Generic Letter 88-03. Our review discloses the need for additional information as described in the enclosed request.

The information requested in this letter affects fewer than 10 respondents, therefore, OMB clearance is not required under P. L. 96-511.

Sincerely,

*Paul W. Michaud*

Paul W. Michaud  
Acting Project Manager-FSV  
Project Directorate - IV  
Division of Reactor Projects - III  
IV, V and Special Projects

Enclosure:  
As stated above

cc: See next page

Mr. R. O. Williams, Jr.  
Public Service Company of Colorado

Fort St. Vrain

cc:

Mr. D. W. Warembourg, Manager  
Nuclear Engineering Division  
Public Service Company  
of Colorado  
P. O. Box 840  
Denver, Colorado 80201-0840

Albert J. Hazle, Director  
Radiation Control Division  
Department of Health  
4210 East 11th Avenue  
Denver, Colorado 80220

Mr. David Alberstein, 14/159A  
GA Technologies, Inc.  
Post Office Box 85608  
San Diego, California 92138

Mr. R. O. Williams, Jr., Acting Manager  
Nuclear Production Division  
Public Service Company of Colorado  
16805 Weld County Road 19-1/2  
Platteville, Colorado 80651

Mr. H. L. Brey, Manager  
Nuclear Licensing and Fuel Division  
Public Service Company of Colorado  
P. O. Box 840  
Denver, Colorado 80201-0840

Mr. D. F. Tomlinson, Manager  
Quality Assurance Division  
Public Service Company of Colorado  
16805 Weld County Road 19-1/2  
Platteville, Colorado 80651

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 640  
Platteville, Colorado 80651

Mr. R. F. Walker  
Public Service Company of Colorado  
Post Office Box 840  
Denver, Colorado 80201-0840

Kelley, Stansfield & O'Donnell  
Public Service Company Building  
Room 900  
550 15th Street  
Denver, Colorado 80202

Commitment Control Program  
Coordinator  
Public Service Company of Colorado  
2420 W. 26th Ave. Suite 100-D  
Denver, Colorado 80211

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Chairman, Board of County Commissioners  
of Weld County, Colorado  
Greeley, Colorado 80631

Public Representative  
Federal Programs  
Environmental Protection Agency  
1300  
99  
1300  
2413

ENCLOSURE

REQUEST FOR ADDITIONAL INFORMATION  
GENERIC LETTER 88-03  
FORT ST. VRAIN NUCLEAR GENERATING STATION

The emergency water booster pumps P-2109 and P-2110, were not included in the licensee's evaluation of Generic Letter 88-03. Although not used to supply water to the steam generators, these pumps would be used to provide the motive force to drive the helium circulators when using firewater. These pumps are also normally lined up such that two check valves provide the only isolation from the emergency feedwater system. The staff considers the unique aspect of these pumps and the system's configuration to warrant their inclusion in the evaluation of Generic Letter 88-03 for the Fort St. Vrain Nuclear Generating Station.