

**Comanche Peak Unit 1  
RELIEF REQUEST NUMBER SNB-1**

**Table 1 - Snubber Tests Requested for Deferral to 1RF22**

#	Snubber Component	Snubber Model	Defined Test Plan Group (DTPG)	Test Required	Test History	Service Life Expiration
1	CC-1-030-008-S33K	3	PSA	Sample	Tested SAT 1RF06	2030
2	CC-1-043-011-A43K	10	PSA	Sample	Not Tested	2030
3	CC-1-043-022-A33K	3	PSA	Sample	Not Tested	2030
4	CC-1-066-013-S33K	10	PSA	Sample	Tested SAT 1RF15	2030
5	CC-1-RB-005-006-3A	1/2	PSA	Sample	Tested SAT 1RF08	2030
6	CC-1-RB-009-001-3	1/4	PSA	Sample	Tested SAT 1RF16	2030
7	CS-1-106-706-C42K	1/4	PSA	Sample	Not Tested	2030
8	SI-1-066-709-C42K	1/4	PSA	Sample	Tested SAT 1RF04	2030
9	CS-1-252-710-A55K	1/2	PSA	Sample	Tested SAT 1RF12	2030
10	CS-1-906-038-S42K	1/2	PSA	Sample	Tested SAT IRF04	2030
11	CS-1-001-006-C42K	1/4	PSA	Sample	Tested SAT 1RF02	2030
12	FW-1-018-709-C72K	100	PSA	Sample	Tested SAT 1RF02	2030
13	FW-1-020-704-C42K	100	PSA	Sample	Not Tested	2030
14	MS-1-004-007-C72KA	100	PSA	Sample	Tested SAT 1RF06	2030
15	FW-1-097-036-C62K	3	PSA	Sample	Not Tested	2030
16	FW-1-103-700-S62K	3	PSA	Sample	Tested SAT 1RF06	2030
17	MS-1-001-007-C72K	35	PSA	Sample	Not Tested	2030
18	MS-1-002-007-C72K	100	PSA	Sample	Tested SAT 1RF15	2030
19	CT-1-051-418-C72KA	1	PSA	Sample	Not Tested	2030
20	DO-1-038-003-S63KA	35	PSA	Sample	Tested SAT 1RF11	2030
21	MS-1-150-062-C52K	1/4	PSA	Sample	Not Tested	2030
22	MS-1-344-005-C52K	1	PSA	Sample	Tested SAT 1RF09	2030
23	MS-1-RB-033-010-2	1/4	PSA	Sample	Tested SAT 1RF01	2030
24	MS-1-SB-053-015-2	1/4	PSA	Sample	Tested SAT 1RF05	2030
25	RC-1-052-026-C41K	1	PSA	Sample	Not Tested	2030
26	RC-1-103-705-C75K	1/4	PSA	Sample	Not Tested	2030
27	RC-1-112-003-C86K	3	PSA	Sample	Tested SAT 1RF15	2030
28	RH-1-002-012-C41K	10	PSA	Sample	Tested SAT 1RF01	2030
29	SI-1-051-024-C42K	1	PSA	Sample	Tested SAT 1RF18	2030
30	SI-1-091-009-C41K	10	PSA	Sample	Tested SAT 1RF02	2030
31	SW-1-001-018-F33K	10	PSA	Sample	Tested SAT 1RF16	2030
32	FW-1-096-701-C62KA	10	PSA	Sample	Tested SAT 1RF06	2030
33	FW-1-098-013-C62KA	3	PSA	Sample	Tested SAT 1RF19	2030
34	RC-1-901-701-C82KA	1/4	PSA	Sample	Tested SAT 1RF15	2030
35	CS-1-RB-024-011-5B	1/2	PSA	Sample	Tested SAT 1RF08	2030
36	CT-1-097-414-C42KA	1/2	PSA	Sample	Tested SAT 1RF04	2030
37	MS-1-026-008-S72K	3	PSA	Sample	Not Tested	2030

NOTE: The service life of all CPNPP Unit 1 snubbers is based on 40 years of expected service, (based on manufacturer's recommendation) and is evaluated each refueling outage to make adjustments, if needed. Due to the performance of the CPNPP Unit 1 snubber population, there has not been a need to adjust the service life of any snubber location to date.