

TABLE 1

SUSQUEHANNA SES SEWAGE TREATMENT PLANT
TOTAL SUSPENDED SOLIDS DATA

Sample Collection Dates	Influent (mg/l)	Effluent ⁽¹⁾ (mg/l)	Percent ⁽²⁾ Reduction %
9/23-24/86	920	20	98
9/25-26/86	1,260	35	97
9/30 & 10/1/86	270	19	93
10/2-3/86	740	14	98
10/7-8/86	330	23.5	93
10/9-10/86	500	19	96
10/14-15/86	232	24	90
10/16-17/86	350	22	94

(1) Effluent limits 30 mg/l - monthly average, 60 mg/l - max

(2) Percent reduction limit at least 85%

8610270298 861021
PDR ADDOCK 05000387
R PDR