



May 7, 1986

Public Service of New Hampshire

SBN-1031  
T.F. 199.99.10, B7.1.2

United States Nuclear Regulatory Commission  
Washington, DC 20555

Attention: Mr. Vincent S. Noonan, Project Director  
PWR Project Directorate No. 5

References: (a) Construction Permits CPPR-135 and CPPR-136, Docket  
Nos. 50-443 and 50-444  
(b) Environmental Qualification Site Audit dated February  
24-27, 1986  
(c) PSNH Letter (SBN-998) dated April 10, 1986, "Response  
to Environmental Qualification Audit Observation",  
J. DeVincentis to V. S. Noonan

Subject: Environmental Qualification: Evaluation Work Sheets

Dear Sir:

In accordance with our conversations with your Staff on April 18 and  
April 29, 1986; enclosed, as Attachment 1, are the 20 revised Qualification  
Evaluation Work Sheets.

Also, since our last transmittal [Reference (c)], the total package count  
has increased to 112 packages which leaves 15 Qualification Evaluation Work  
Sheet packages to be submitted to the NRC. Enclosed, as Attachment 2, please  
find the remaining 15 work sheet packages.

We have also included hererin, as Attachment 3, a revised copy of  
the work sheet for File 600-01-04 which should replace the copy transmitted  
under Reference (c).

We trust the information provided herewith is acceptable and request  
that the satisfactory resolution of this issue be reflected in the Staff's  
status report to the Atomic Safety and Licensing Board.

Very truly yours,

John DeVincentis  
Director of Engineering

Attachments

cc: Atomic Safety and Licensing Board Service List

8605120410 860507  
PDR ADOCK 05000443  
A PDR

A048  
1/1

ATTACHMENT 1

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 113-03-01

Prepared By: Doug A. Moore Date: 4/30/86  
Checked By: Jim Buckley Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-113-03	Operating Time	1 Year	2 p. 1	1 Year Note 2	3 Appendix 4	Test and Analysis	None
Equipment ID No(s): EDE-CBL-1	Peak Temperature (°F)	375	2 p. 1	390	3 p. 3 5	Test	None
Equipment Type: 600 Volts Power Cable	Peak Pressure (Psig)	60	2 p. 1 Appendix 5	112	3 p. 3, 9	Test	None
Manufacturer: Okonite	Relative Humidity (%)	100	2 p. 1	100	p. 3, 7	Test	None
Model Number: 600 Volt w/Okonite (EPR) Insulation	Chemical Spray (pH)	Boric Acid 1.2% WT pH = 7.5 - 10.5	2 p. 1	Boric Acid 1.7% WT pH = 10.5	4, 3 p. 4 Appendix 4 p. 7	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2 x 10 <sup>8</sup>	2 p. 1	2 x 10 <sup>8</sup>	3 p. 3, 9	Test	None
Limiting Environment:	Year Accident Radiation Dose (Rads)	---	2 p. 1				
Location: Containment Building (All Zones) Rad Zone: Primary Aux. Building (PB-15A, PB-18) Note 1	Aging (°F/Years)	194/40 (90°C)	1 pp. 3, 4	194/40 (90°C)	3 Appendix 2	Test and Analysis	None
Lowest Elevation: (-)23'8" Flood Level: (-)20'8" Above Flood Level: No	Submergence	3' Below Flood Level	7, 8, 10	30 days	9 Note 2	Test and Analysis	None

Documentation References:

1. UE&C Specification No. 9763-006-113-3, Rev. 2, dated 11/30/82.
2. UE&C Drawing No. 9763-F-300219, Rev. 17, Service Environment Chart, dated 7/22/85.
3. FP-31412-06, Nuclear Qualification Document for Okonite Insulated Cable.
4. Seabrook E.Q. File No. 113-03-01, Assessment Checklist, Note 9.
5. Seabrook E.Q. File No. 113-03-01, Assessment Checklist, Note 2.
6. SBU-92605, UE&C's letter to Impell, dated 2/13/85.
7. SBU-92623, Seabrook Station Flooding Study Matrix.
8. Impell Letter No. 0570-032-156, dated 2/2/86.
9. Seabrook E.Q. File No. 113-03-01, Assessment Checklist, Note 3.
10. Memorandum from G. Moore (Impell) to A. Biswas (Impell), 2/22/86.

Notes:

1. The limiting radiation zones are PB-15A and PB-18. Zones PB-4 and PB-19 have been excluded since no electrical equipment is installed in these zones (Reference 6).
2. Inside containment, this cable is connected to motor operated valves SI-V-17 and 32 and CS-V-149. These valves perform safety functions within 24 hours during a LOCA or MSLB. Only the cable connected to these valves may be submerged during these events; however, it is qualified for 30 days when submerged (Ref. 9) during which time all the valves' safety functions will be completed. After 30 days, this equipment will not fail in a manner detrimental to plant safety or mislead the operator. Areas outside containment will be pumped down prior to exceeding the 30 day submergence qualification time.

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
 Seabrook Station  
 Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO.113-06-02

Prepared By: Jim Buckley Date: 4/30/86  
 Checked By: Buy A More Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-113-06	Operating Time	1 Year	2 p. 1	1 Year	3 p. 19 4	Test and Analysis	None
Equipment ID No(s): EDE-CBL-4	Peak Temperature (°F)	375	2 p. 1	385	3 Attachment I p. 19	Test	None
Equipment Type: Cable	Peak Pressure (Psig)	60	2 p. 1	113	3 Attachment I p. 19	Test	None
Manufacturer: Brand-Rex	Relative Humidity (%)	100	2 p. 1	100	3 Attachment I p. 19	Test	None
Model Number: 300V Instrument & Thermocouple Extension Cable	Chemical Spray (pH)	Boric Acid 1.2% by wt. pH 7.5 to 10.5	2 p. 1	Boric Acid 3.6% by wt. pH 7.5 to 10.5	3 p. 15 6	Test	None
Accuracy: Spec: N/A Demon: N/A Note 3	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>8</sup>	2 p. 1, Note 1	2.0 x 10 <sup>8</sup>	3 p. C-2	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	-----	2 p. 1				
Location: Containment Building Rad Zone: Primary Aux. Building (PB-15A, PB-18) Note 1	Aging (°F/Years)	194/40 (90°C)	1 p. 7	194/40 (90°C)	3 Attachment II	Test and Analysis	None
Lowest Elevation: 4'-5" Flood Level: 5'-5" Above Flood Level: No	Submergence	1' Below Flood Level	8, 9 and 10	30 Days	11 Note 2	Test and Analysis	None

Documentation References:

1. UE&C Specification No. 9763-006-113-6, Rev. 2, 300V Instrument Cable, 11/30/82.
2. UE&C Drawing No. 9763-F-300219, Rev. 17, Service Environment Chart, 7/22/85.
3. FP-31732-03, FRC Report No. F-C5120-4, Qualification of Instrumentation Cables in a Simulated Steam Line Break and Loss-of-Coolant-Accident Environment, 4/12/82.
4. Impell Calculation, 0570-032-004.
5. SBU-92605, UE&C's letter to Impell, dated 2/13/85
6. Seabrook E.Q. File No. 113-06-02, Assessment Checklist, Note 11.
7. Seabrook E.Q. File No. 113-06-02, Assessment Checklist, Note 10.
8. SBU-96263, UE&C letter, "Flooding Study Matrix".
9. Impell Letter No. 0570-032-NY-156, 2/2/86
10. Impell Memorandum from G. Moore to A. Biswas, dated 2/22/86.
11. Seabrook E.Q. File No. 113-06-02, Assessment Checklist, Note 7.

Notes:

1. The limiting zones for radiation are Zones PB-15A and PB-18. Environmental Zones PB-4 and PB-19 have been excluded since no electrical equipment is installed in these areas. (Reference 5)
2. Areas outside containment will be pumped down prior to exceeding the 30 day submergence qualification time.
3. Thermocouple Cable is not required to perform an active safety function subsequent to accident events (Reference 7), and accuracy does not have to be addressed.

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 113-17-01

Prepared By: Ray A. Moore Date: 4/30/86

Checked By: Jim Buckley Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-113-17	Operating Time	1 Year	1 Sheet 1	1 Year Note 2	4, p. 4-1, 5, p. 4-2, 6, p. 10 7, Point 3, 6 9	Test and Analysis	None
Equipment ID No(s).: EDE-CBL-2	Peak Temperature (°F)	375	1 Sheet 1	385	5 p. 3-10, 4-2	Test	None
Equipment Type: 600 V Control Cable	Peak Pressure (Psig)	60	1 Sheet 1	66	5 p. 3-10, 4-2	Test	None
Manufacturer: Anaconda Model Number: FR-EP, 600V	Relative Humidity (%)	100	1 Sheet 1	100	5 p. 4-2	Test	None
Accuracy:Spec: N/A Demon: N/A	Chemical Spray (pH)	Boric Acid 1.2% by wt. pH=7.5 to 10.5	1 Sheet 1	Boric Acid 3.54% by wt. pH=7.5 to 10.5	5 p. 3-10, 4-2, 4-3 7, point 5 8	Test	None
Limiting Environment: Location: Containment (All Zones)	40 Year Normal Radiation Dose (Rads)	2 x 10 <sup>8</sup>	1, Sheet 3 Note 1	2 x 10 <sup>8</sup>	5 p. 3-2 Appendix C	Test	None
Rad Zone: Primary Aux. Bldg. (PB-15A, PB-18) Note 1	1 Year Accident Radiation Dose (Rads)	---	1, Sheet 3				
Lowest Elevation: (-)23'0" Flood Level: (-)20'8" Above Flood Level: No	Aging (°F/Years)	160.7/40 (71.5°C)	3	160.7/40 (71.5°C)	2	Test and Analysis	None
	Submergence	3' Below Flood Level	11, 13 and 14	30 days	12 Note 2	Test and Analysis	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Revision 17, Service Environment Chart, 7/22/85.
2. FP-32541-02, Attachment AT-1 to FIRL Technical Report No. F-C4969-1, 7/13/81.
3. MM-#8110A, UE&C Memorandum, dated 12/1/81.
4. FP-32540-02, Attachment AT-2 to F-C4969-1, July 1980.
5. FP-32538-02, FIRL Report No. F-C4969-1, Qualification Test of Class IE Electric Cable in a simulated SLB and LOCA Environment, July 1979.
6. FP-33266-01, ACTON Environmental Testing Corporation, Test Report No. 16587-81N, Revision 1, 7/23/81.
7. VU032814, Anaconda-Ericsson Letter to UE&C, dated 1/6/82.
8. Seabrook E.Q. File No. 113-17-01, Assessment Checklist, Note 3.
9. Seabrook E.Q. File No. 113-17-01, Assessment Checklist, Note 2.
10. SBU-92605, Letter from UE&C to Impell, dated 2/13/85.
11. SBU-96263, Seabrook Station Flooding Study Matrix.
12. Seabrook EQ File No. 113-17-01, Assessment Checklist, Note 13.
13. Impell Letter No. 0570-032-NY-156, 2/2/86.
14. Memorandum from G. Moore (Impell) to A. Biswas (Impell), 2/22/86.

Notes:

1. The limiting radiation zones are PB-15A and PB-18. Environmental Zones PB-4 and PB-19 are excluded since no electrical equipment is installed in these areas (Ref. 10)
2. Inside containment, this cable is connected to motor operated valves SI-V-17 and 32 and CS-V-149. These valves perform their safety functions within 24 hours during a LOCA or MSLB. Only the cable connected to these valves may be submerged during these events; however, it is qualified for 30 days when submerged (Ref. 12) during which time all the valves' safety functions will be completed. After 30 days, this equipment will not fail in a manner detrimental to plant safety or mislead the operator. Areas outside containment will be pumped down prior to exceeding the 30 day submergence qualification time.

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 113-18-01

Prepared By: Jim Buckley Date: 9/30/86  
Checked By: Doug A. Moore Date: 4/10/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-113-18	Operating Time	1 Year	2 p. 1	1 Year Note 2	4, p. 10 5, p. 4-2 10, p. 4-1 6, Points 3, 6 7	Test and Analysis	None
Equipment ID No(s).: EDE-CBL-3	Peak Temperature (°F)	375	2 p. 1	385	5 p. 3-10, 4-2	Test	None
Equipment Type: Instrumentation Cable	Peak Pressure (Psig)	60	2 p. 1	66	5 p. 3-10, 4-2	Test	None
Manufacturer: Anaconda	Relative Humidity (%)	100	2 p. 1	100	5 p. 4-2	Test	None
Model Number: 300 Volt, FR-EP	Chemical Spray (pH)	Boric Acid 1.2% by Wt. pH 7.5 to 10.5	2 p. 1	Boric Acid 3.54% by Wt. pH 7.5 to 10.5	5, p. 3-10, 4-2, 4-3 6, Point 5 9	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>8</sup>	2 p. 3, Note 1	2. x 10 <sup>8</sup>	5 p. 3-2 Appendix C	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	---	2 p. 3				
Location: Containment (All Zones) Rad Zone: Primary Aux. Bldg. (Note 1)	Aging (°F/Years)	194/40 (90°C)	1 p. 5	194/40 (90°C)	4 p. 6	Test and Analysis	None
Lowest Elevation: (-) 22'8" Flood Level: (-) 20'8" Above Flood Level: No	Submergence	2' Below Flood Level	8, 11 and 12	30 Days	13 Note 2	Test and Analysis	None

Documentation References:

1. UE&C Specification No. 9763-006-113-18, Rev. 1, Specification for 300 Volt Instrument Cable, 11/30/81.
2. UE&C Drawing No. 9763-F-300219, Rev. 17, Service Environment Chart, 7/22/85.
3. SBU-92605, UE&C Letter, dated 2/13/85.
4. FP-33266-01, ACTON Test Report No. 16587-81N, 7/23/81.
5. FP-32652-02, FIRL Report F-C4969-1, Qualification Test of Class IE Electric Cable in a Simulated SLB and LOCA Environment, 7/80.
6. VU32814, Anaconda's letter to UE&C, dated 1/6/82.
7. Seabrook EQ File No. 113-18-01, Assessment Checklist, Note 3.
8. SBU-96263, UE&C Letter addressed to YAEC on Flooding Study Matrix.
9. Seabrook EQ File No. 113-18-01, Assessment Checklist, Note 12.
10. FP-32654-02, Attachment AT-2 to FIRL Report No. F-C4969-1, 7/13/81.
11. Impell Letter No. 0570-032-NY-156, 2/2/86.
12. Impell Memorandum from G. Moore to A. Biswas, 2/22/86.
13. Seabrook EQ File No. 113-18-01, Assessment Checklist, Note 14.

Notes:

1. The limiting zones for radiation are PB-15A and PB-18. Zones PB-4 and PB-19 have been excluded since no electrical equipment is installed in these areas (Reference 3).
2. Inside containment, this cable is connected to motor operated valves SI-V-17 and 32 and CS-V-149. These valves perform their safety functions within 24 hours during a LOCA or MSLB. Only the cable connected to these valves may be submerged during these events; however, it is qualified for 30 days when submerged (Ref. 13) during which time all the valves' safety functions will be completed. After 30 days, this equipment will not fail in a manner detrimental to plant safety or mislead the operator. Areas outside containment will be pumped down prior to exceeding the 30 day submergence qualification time.

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 113-20-01

Prepared By: Dug A. Moore Date: 4/30/86

Checked By: Jim Buckley Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-113-20	Operating Time	1 Year	1 p. 1	1 Year	4	Test and Analysis	None
Equipment ID No(s): EDE-CBL-7	Peak Temperature (°F)	375	1 p. 1	390	2, p. 11	Test	None
Equipment Type: Instrument Cable	Peak Pressure (Psig)	60	1 p. 1	113	2, p. 11	Test	None
Manufacturer: ITT Surprenant	Relative Humidity (%)	100	1 p. 1	100	2, p. 11	Test	None
Model Number: 300V Instrument Cable	Chemical Spray (pH)	Boric Acid 1.2% by Wt. pH 7.5 to 10.5	1 p. 11	Boric Acid 1.7% by Wt. pH 10.5	2, p. 11 6	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>8</sup>	1 p. 1 Note 1	2.20 x 10 <sup>8</sup>	2, p. 1	Test	None
Limiting Environment: Location: Containment Building (All Zones) Rad Zone: Primary Aux. Building (PB-15A, PB-18) Note 1	1 Year Accident Radiation Dose (Rads)	---	1 p. 1				
	Aging (°F/Years)	194/40 (90°C)	3 p. 3	208/40 (98°C)	4, 5	Test and Analysis	None
Lowest Elevation: (-) 23'8" Flood Level: (-) 20'8" Above Flood Level: No	Submergence	3' Below Flood Level	8, 9 and 10	30 Days	11 Note 2	Test and Analysis	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Rev. 17, Service Environment Chart, 7/22/85.
2. FP-33835-01, FIRL Report F-A5550-8, dated 1/14/83.
3. UE&C Specification 9763-006-113-20, Rev. 1, 12/7/85.
4. Letter of March 16, 1983 from J. Sibley (ITT Surprenant) to R. Mizzau (UE&C).
5. FP-33829-01, Letter of 1/13/83 from J. Sibley (ITT Surprenant) to E.H. Case (UE&C).
6. Seabrook E.Q. File No. 113-20-01, Assessment Checklist, Note 8.
7. SBU-92605, UE&C's letter to Impell, 2/13/85.
8. SBU-96263, UE&C Flooding Study Matrix.
9. Impell Letter No. 0570-032-NY-156, 2/2/86.
10. Impell Memorandum from G. Moore to A. Biswas, 2/22/86.
11. Seabrook E.Q. File No. 113-20-01, Assessment Checklist, Note 9.

Notes:

1. The limiting environment for radiation are Zones PB-15A and PB-18. Environmental Zones PB-4 and PB-19 have been excluded since no electrical equipment is installed in these areas (Ref. 7).
2. Inside containment, this cable is connected to motor operated valves SI-V-17 and 32 and CS-V-149. These valves perform their safety functions within 24 hours during a LOCA or MSLB. Only the cable connected to these valves may be submerged during these events; however, it is qualified for 30 days when submerged (Ref. 11) during which time all the valves' safety functions will be completed. After 30 days, this equipment will not fail in a manner detrimental to plant safety or mislead the operator. Areas outside containment will be pumped down prior to exceeding the 30 day submergence qualification time.

Public Service Company of New Hampshire  
 Seabrook Station  
 Docket: 50-443

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 129-01-01

Prepared By: Ray A. Moore Date: 9/30/86  
 Checked By: Jim Buckley Date: 9/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-129-01	Operating Time	1 Year	1 P. 1	1 Year	2 P. 6 - 4 Note 1	Test	None
Equipment ID No(s).: EDE-MM-584	Peak Temperature (°F)	N/A	N/A Note 1	N/A	N/A	N/A	None
Equipment Type: Fuse Blocks and Fuses	Peak Pressure (Psig)	N/A	N/A Note 1	N/A	N/A	N/A	None
Manufacturer: Underwriters Safety Device Company/ Gould	Relative Humidity (%)	N/A	N/A Note 1	N/A	N/A	N/A	None
Model Number: J60030-2SR A4J30	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1.0 x 10 <sup>3</sup>	1 p. 4	1.43 x 10 <sup>7</sup>	2 p. 6-4	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	3.4 x 10 <sup>4</sup>	1 p. 4				
Location: Electrical Penetration Area (ET3B) Rad Zone: Electrical Penetration Area (ET3B)	Aging (°F/Years)	85/40	1 p. 4	104/36.66	2 p. 6-3 5	Test and Analysis	None
Lowest Elevation: N/A Flood Level: N/A Above Flood Level: N/A	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-34333-01, Acton Qualification Test Report No. 18950-84N, for USD Fuse Blocks to be used at Seabrook Station, dated 12/7/84.
3. Seabrook EQ File No. 129-1-01, Assessment Checklist, Note 2.
4. SBU-96263, UE&C Letter, "Flooding Study Matrix".
5. Seabrook E.Q. File NO. 129-01-01, Assessment Checklist, Note 7

Notes:

1. The equipment is located in the Electrical Penetration Area where radiation is the only harsh environmental parameter.



QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 129-01-01

Prepared By: Ray A. Moore Date: 4/30/86  
 Checked By: Jim Buckley Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-129-01	Operating Time	1 Year	1 P. 1	1 Year	2 p. 5-3 Note 1	Test	None
Equipment ID No(s).: EDE-MM-584	Peak Temperature (°F)	N/A	N/A Note 1	N/A	N/A	N/A	None
Equipment Type: Terminal Blocks	Peak Pressure (Psig)	N/A	N/A Note 1	N/A	N/A	N/A	None
Manufacturer: Westinghouse	Relative Humidity (%)	N/A	N/A Note 1	N/A	N/A	N/A	None
Model Number: TBAL-90	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy:Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1.0 x 10 <sup>3</sup>	1 p. 4	1.87 x 10 <sup>8</sup>	2 p. 5-3	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	3.4 x 10 <sup>4</sup>	1 p. 4				
Location: Electrical Penetration Area (ET3B) Rad Zone: Electrical Penetration Area (ET3B)	Aging (°F/Years)	85/40	1 p. 4	114/41	3	Test and Analysis	None
Lowest Elevation: N/A Flood Level: N/A Above Flood Level: N/A	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-32766-06, Acton Test Report No. 16751-82N, Environmental and Seismic Qualification of Class 1E Terminal Blocks, Rev. 2, 2/6/83.
3. Seabrook EQ File No. 129-01-01, Note 7 of Assessment Checklist.
4. SBU-96263, UE&C Letter, "Flooding Study Matrix"

Notes:

1. The equipment is located in the Electrical Penetration Area where radiation is the only harsh environmental parameter.

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-172-01	Operating Time	62 Minutes	5	7 Hours	3	Test and Analysis	None
Equipment ID No(s).: RM-RE-6535A, B RM-RI-6535A, B RM-RM-6535A RM-RM-6535B	Peak Temperature (°F)	116	3	131	2 App. E-4 p. 18	Test	None
Equipment Type: Radiation Element, Indicator and Monitor Manufacturer: GA Technologies, Inc.	Peak Pressure (Psig)	N/A	N/A Note 1	N/A	N/A	N/A	None
Model Number: RD-10B RL-10 RM-80	Relative Humidity (%)	N/A	N/A Note 1	98	2 App. E-4 p. 17	Test	None
Accuracy: Spec: N/A Demon: N/A	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Limiting Environment: Location: Containment Building (All Zones) Rad Zone: Containment Bldg (Gen. Area/Not Submerged)	40 Year Normal Radiation Dose (Rads)	1.35 x 10 <sup>2</sup>	3 6 Note 2	1.1 x 10 <sup>3</sup>	2 p. 4-1	Test and Analysis	None
	1 Year Accident Radiation Dose (Rads)	8.40 x 10 <sup>2</sup>	3 6 Note 2				
Lowest Elevation: (-) 25'-2" Flood Level: (-) 20'-8" Above Flood Level: Yes Note 3	Aging (°F/Years)	95/40	3	95/40	2 p. 4-2	Test and Analysis	None
	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. DE&C Drawing No. 9763-F-300219, Service Environment Chart, Revision 17, dated 7/22/85.
2. FP-72747-01, Qualification Test Report No. E-255-996, dated 12/7/82.
3. Seabrook E.Q. File No. 172-01-01, Assessment Checklist No. 1, Note 2.
4. SBU-96263, Seabrook Station Flooding Study Matrix.
5. SBN-1024, Environmental Qualification; Post Accident Operability Time, dated 4/30/86.
6. YAEC Memorandum, SB-N02-04.08, E.Q. Dose Spec., dated 5/5/86.

Notes:

1. This equipment is required to function during a Fuel Handling Accident (FHA) only. It will be installed in containment only during outages, and will not be inside containment during normal plant operation. During a FHA, the only above normal environmental parameters to which this equipment will be exposed to are increased temperature and radiation.
2. Normal and accident radiation doses correspond to 25 refueling cycles (90 days each = 2250 days) and 1 day of Fuel Handling Accident operating time (Reference 6), respectively.
3. RM-RM-6535B is located below postulated LOCA/MSLB flood levels. However, equipment will not be installed inside containment whenever a LOCA/MSLB could occur (see Note 1).

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-172-01  Equipment ID No(s): RM-RE-6576A RM-RE-6576B	Operating Time	1 year	1 p. 1	1 year	3	Test and Analysis	None
	Peak Temperature (°F)	375	1 p. 1	400	2 App. 9 p. 12	Test	None
Equipment Type: Radiation Element	Peak Pressure (Psig)	60	1 p. 1	77	2 App. 9 p. 17	Test	None
Manufacturer: General Atomic	Relative Humidity (%)	100	1 p. 1	100	2 App. 9 p. 4	Test	None
Model Number: RD-23 (0360-2062)	Chemical Spray (pH)	Boric Acid 1.2% by wt. pH = 7.5-10.5	1 p. 1	Boric Acid 1.72% by wt. pH = 10.5	2 App. 9 p. 18 4	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	$2 \times 10^7$	1 p. 1	$2.9 \times 10^8$	3	Test and Analysis	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	$1.04 \times 10^8$	1 p. 1				
Location: Containment Building (Zone CS-13) Rad Zone: Containment Building (General Area/ Not Submerged)	Aging (°F/Years)	120/40	1 p. 1	120/40	3	Test and Analysis	None
Lowest Elevation: 30'-0" Flood Level: (-)20'-8" Above Flood Level: Yes	Submergence	N/A	5	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Revision 17, dated 7/22/85.
2. FP-72746-01, Design Qualification Testing of Analog HRRM (RD-23) Rev. 1, dated 5/1/81.
3. Seabrook E.Q. File No. 172-01-01, Assessment Checklist No. 3, Note 2.
4. Seabrook E.O. File No. 172-01-01, Assessment Checklist No. 3, Note 3.
5. SBU-96263, Seabrook Station Flooding Study Matrix.

Notes:

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 172-01-01

Prepared By: Jay A. Moore Date: 5/7/86  
 Checked By: Jim Buckley Date: 5/7/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 5763-006-172-01	Operating Time	1 year	1 p. 1	1 year	2	Test and Analysis	None
Equipment ID No(s).: RM-SKD-53-1 RM-SKD-53-2 (Note 1) RM-RM-6528	Peak Temperature (°F)	130	5	131	2 3 App. B p. 5	Test	None
Equipment Type: Wide Range Gas Monitoring Detection and Sample Conditioning Skids Radiation Monitor Manufacturer: GA Technologies, Inc.	Peak Pressure (Psig)	N/A	N/A Note 2	N/A	N/A	N/A	None
Model Number: P/N 0366-1001 P/N 0366-2001 RM-80	Relative Humidity (%)	N/A	N/A Note 2	95	3 App. B p. 5	Test	None
Accuracy: Spec: N/A Demon: N/A	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Limiting Environment: Location: Primary Auxiliary Building (Zone PB-8) Rad Zone: Primary Auxiliary Building (Zone PB-8)	40 Year Normal Radiation Dose (Rads)	N/A	N/A Note 2	N/A	N/A	N/A	None
	1 Year Accident Radiation Dose (Rads)	N/A	N/A Note 2				
	Aging (°F/Years)	104/40	1 p. 3	104/9	2	Test and Analysis	None
Lowest Elevation: 28'-6" Flood Level: (-)21'-6" Above Flood Level: Yes	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Revision 17, dated 7/22/85.
2. Seabrook E.O. File No. 172-01-01, Assessment Checklist No. 2, Note 2.
3. FP-72745-02, Qualification Report for WRGM No. E-255-968, Rev. 1, dated 6/81.
4. SBU-96263, Seabrook Station Flooding Study Matrix.
5. UE&C Memorandum No. 29267A, dated 4/2/86.

Notes:

1. Includes I.D. Nos. RM-FCV-6528-1, -2; RM-FI-6528-1, -2; RM-FT-6528-1, -2; RM-FY-6528-1, -2, -3, -4, -5, -6, -7, -8, -9, -10; RM-P-240-1, -2; RM-RC-6528-2; and RM-RE-6528-1, -2 & -3.
2. Qualification required for LOCA and FHA events only. Therefore, the only harsh environmental condition this equipment will be exposed to is temperature.

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 172-01-01

Prepared By: Greg A. Moore Date: 5/7/86  
 Checked By: Jim Buckley Date: 5/7/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-172-01	Operating Time	1 year	1 p. 1	1 year	5	Test and Analysis	None
Equipment ID No(s): RM-RE-6527A RM-RE-6527B	Peak Temperature (°F)	135	1 p. 3	165	2 App. B, p. 10 5	Test	None
Equipment Type: Radiation Element	Peak Pressure (Psig)	N/A	N/A Note 1	N/A	N/A	N/A	None
Manufacturer: GA Technologies, Inc.	Relative Humidity (%)	N/A	N/A Note 1	95	2 App. B, p. 10	Test	None
Model Number: RD-7	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	$2.5 \times 10^2$	5 6 Note 2	$1.1 \times 10^3$	3 p. 4-1	Test	None
	1 Year Accident Radiation Dose (Rads)	$8.2 \times 10^2$	6				
Limiting Environment: Location: Primary Aux. Building (Zone PB-11) Rad Zone: Primary Aux. Building (Zone PB-11)	Aging (°F/Years)	104/40	1 p. 3	Note 2 104/40	3 p. 4-2 5	Test and Analysis	None
Lowest Elevation: 25'-0" Flood Level: (-)21'-6" Above Flood Level: Yes	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Revision 17, dated 7/22/85.
2. FP-73171-01, Qualification Test Report No. E-255-999, dated 7/7/81.
3. FP-73747-01, Qualification Test Report No. E-255-966, dated 12/7/82.
4. SBU-96263, Seabrook Station Flooding Study Matrix.
5. Seabrook E.Q. File No. 172-01-01, Assessment Checklist No. 1, Note 2.
6. UE&C Calculation 44.14-70F Total Integrated Dose Tables, Rev. 2, 5/15/84.

Notes:

1. Qualification required for LOCA and FHA events only. Therefore, increased temperature and radiation are the only above normal environmental conditions to which this equipment may be exposed (Reference 1).
2. The normal radiation dose is reduced to ensure that the qualified dose of  $1.1 \times 10^3$  rads envelopes the postulated normal and 1 year accident dose with margin. The  $2.5 \times 10^2$  normal dose is equivalent to 10 years (Reference 5). Therefore, the qualified life of this equipment is 10 years based on radiation aging and 40 years based on thermal aging.

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 172-01-01

Prepared By: Jay A. Moore Date: 5/2/86  
 Checked By: John Buckley Date: 5/7/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-172-01	Operating Time	1 year	1 p. 1	1 year	4	Test and Analysis	None
Equipment ID No(s): RM-RM-6527A RM-RM-6527B	Peak Temperature (°F)	125	1 p. 3	131	2 App. E-1, p. 18 4	Test	None
Equipment Type: Radiation Monitor	Peak Pressure (Psig)	N/A	N/A Note 1	N/A	N/A	N/A	None
Manufacturer: GA Technologies, Inc.	Relative Humidity (%)	N/A	N/A Note 1	98	2 App. E-1, p. 17	Test	None
Model Number: RM-80	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1.0 x 10 <sup>3</sup>	1 p. 3	1.1 x 10 <sup>3</sup>	2 p. 4-1	Test	None
<u>Limiting Environment:</u>	1 Year Accident Radiation Dose (Rads)	----	1 p. 3				
Location: Primary Aux. Building (Zone PB-28) Rad Zone: Primary Aux. Building (Zone PB-28)	Aging (°F/Years)	104/40	1 p. 3	104/40	2 p. 4-2 4	Test and Analysis	None
Lowest Elevation: 26'-9" Flood Level: (-)21'-6" Above Flood Level: Yes	Submergence	N/A	3	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Revision 17, dated 7/22/85.
2. FP-72747-01, Qualification Test Report No. E-255-996, dated 12/7/82.
3. SBU-96263, Seabrook Station Flooding Study Matrix.
4. Seabrook E.Q. File No. 172-01-01, Assessment Checklist No. 1, Note 2.

Notes:

1. Qualification required for LOCA and FHA events only. Therefore, increased temperature is the only harsh environmental condition to which this equipment may be exposed (Reference 1).

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-172-01	Operating Time	62 Minutes	5	2 Hours	4	Test and Analysis	None
Equipment ID No(s): RM-RE-6566 RM-RM-6566	Peak Temperature (°F)	125	1 p. 3	131	2 App. E-1, p. 18 4	Test	None
Equipment Type: Radiation Monitor	Peak Pressure (Psig)	N/A	N/A Note 1	N/A	N/A	N/A	None
Manufacturer: GA Technologies, Inc.	Relative Humidity (%)	N/A	N/A Note 1	98	2 App. E-1, p. 17	Test	None
Model Number: RD-7 RM-80	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy:Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	$6.0 \times 10^2$	7 Note 2	$1.1 \times 10^3$	2 p. 4-1	Test	None
	1 Year Accident Radiation Dose (Rads)	$4.0 \times 10^2$	6				
Limiting Environment: Location: Containment Enclosure (Zone CE-1) Rad Zone: Containment Enclosure (Zone CE-1)	Aging (°F/Years)	104/40	1 p. 3	Note 2 104/40	2 p. 4-2 4	Test and Analysis	None
Lowest Elevation: N/A Flood Level: N/A Above Flood Level: N/A	Submergence	N/A	3	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Revision 17, dated 7/22/85.
2. FP-72747-01, Qualification Test Report No. E-255-996, dated 12/7/82.
3. SBU-96263, Seabrook Station Flooding Study Matrix.
4. Seabrook E.Q. File No. 172-01-01, Assessment Checklist No. 1, Notes 2.
5. SBN-1024 Environmental Qualification; Post Accident Operability Time, dated 4/30/86.
6. SBU-99373, Seabrook Station Integrated Radiation Doses for RM-RM-6566 and RM-RE-6566 dated 5/6/86.
7. Yankee Atomic Memorandum, T. F. 15.1.00, Radiation Monitor RM 6566, dated 4/25/86.

Notes:

1. Qualification required for LOCA events only. Therefore, increased temperature is the only harsh environmental condition to which this equipment may be exposed (Reference 1).
2. The normal radiation dose is reduced to ensure that the qualified dose of  $1.1 \times 10^3$  rads envelopes the postulated normal and 1 year accident dose with margin. The  $6 \times 10^2$  normal dose is equivalent to 24 years. Therefore, the qualified life of this equipment is 24 years based on radiation aging and 40 years based on thermal aging.

Public Service Company of New Hampshire  
 Seabrook Station  
 Docket: 50-443

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 173-05-03

Prepared By: Jim Buckley Date: 4/30/86  
 Checked By: D. A. Moore Date: 7/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-173-05	Operating Time	100 Days	7	204 Days	6	Test and Analysis	None
Equipment ID No(s): CC-TY-2171-4 CC-TY-2171-5 CC-TY-2271-4 CC-TY-2271-5	Peak Temperature (°F)	135	1 p. 3	335	3 p.	Test	None
Equipment Type: E/P Transducer	Peak Pressure (Psig)	0.4	1 p. 3	8.5	3 p.	Test	None
Manufacturer: Masoneilan	Relative Humidity (%)	100	1 p. 3	100	3 p.	Test	None
Model Number: 8005A	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	$4.7 \times 10^6$	1 p. 3	$1 \times 10^7$	3 p.	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	$1.9 \times 10^5$	1 p. 3				
Location: Primary Aux. Bldg. (PB-11) Rad Zone: Primary Aux. Bldg. (PB-11)	Aging (°F/Years)	104/40	1 p. 3	104/13.95	5 pp. 4-6 4	Test and Analysis	None
Lowest Elevation: 27'-0" Flood Level: (-)21'-6" Above Flood Level: Yes	Submergence	N/A	2	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. SBU-96263, Seabrook Station Flooding Study Matrix.
3. Cygna Report No. 81041-RN002, Rev. C, 2/83.
4. Seabrook Station E.Q. File No. 173-05-03, Assessment Checklist, Note 3.
5. Masoneilan Report No. 1129, dated 1/27/86.
6. Seabrook Station E.Q. File No. 173-05-03, Checklist, Note 8.
7. SBN-988, E.Q.; Post Accident Operating Time, Dated 4/3/86.

Notes:



QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 248-65-01

Prepared By: Jim Buckley Date: 4/30/86  
Checked By: Ray A. Mon Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-248-65	Operating Time	1 year	1	1 year	3	Test and Analysis	None
Equipment ID No(s).: MS-V-204 MS-V-205 MS-V-206 MS-V-207 Note 2	Peak Temperature (°F)	325	p. 2	310	p. 14 8 Note 1	Test	None
Equipment Type: Actuators (and Position Switches)	Peak Pressure (Psig)	4.8	p. 2	81	p. 16	Test	None
Manufacturer: Limatorque	Relative Humidity (%)	100	p. 2	100	p. 18	Test	None
Model Number: SMB-00-10	Chemical Spray (pH)	N/A	N/A	Boric Acid 1.72% by wt. pH 10.5	p. 17 6	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1.0 x 10 <sup>3</sup>	p. 2	2.04 x 10 <sup>8</sup>	p. 12 and Appendix C	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	8.2 x 10 <sup>4</sup>	p. 2				
Location: Main Steam FW Pipe Chases (PCE-2, PCW-2) Rad Zone: Main Steam FW Pipe Chases (PCE-2, PCW-2)	Aging (°F/Years)	130/40	p. 2	Note 3 130/40	p. 11	Test and Analysis	None
Lowest Elevation: 28'-0" Flood Level: 5'-5" Above Flood Level: Yes	Submergence	N/A	5	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-91743-02, Qualification Test Report, Limatorque Valve Actuators for PWR Service, Project #600456, Rev. 1, dated 12/9/75.
3. Impell Calculation No. 0570-032-060.
4. FP-93952-01, Limatorque Valve Actuator Qualification for Nuclear Power Station Service, Report # B0058, Rev. 0, dated 1/11/80.
5. SBU-96263, UE&C Letter addressed to YAEC on Flooding Study Matrix.
6. Seabrook E.Q. File No. 248-65-01, Assessment Checklist No. 1, Note 8.
7. Seabrook E.Q. File No. 248-65-01, Assessment Checklist No. 1, Note 13.
8. Seabrook E.Q. File No. 248-65-01, Assessment Checklist No. 1, Note 1.

Notes:

1. Reference 7 demonstrates using a thermal lag test that the actuator internals will not be exposed to temperatures in excess of 228°F when the external environmental MSLB temperature is 325°F. Therefore the peak test temperature of 310°F envelopes the actual 228°F seen by the actuator internals.
2. Equipment I.D. Nos. MS-ZS-204, -205, -206, -207 are for the integral position indication within these actuators.
3. Although the qualified life as per thermal and aging is 40 years, the number of mechanical cycles during testing limits the qualified life to 16.78 years (Reference 7).

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 248-65-01

Prepared By: Jim Buckley Date: 4/30/86  
Checked By: Greg A. Moore Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-248-65	Operating Time	1 Year	1 p. 1	1 Year	3	Test and Analysis	None
Equipment ID No(s).: Note 1	Peak Temperature (°F)	325	1 p. 2	312	2 App. E Figure 4 4 Note 2	Test and Analysis	None
Equipment Type: Terminal Blocks	Peak Pressure (Psig)	4.8	1 p. 2	70	2 App. E Figure 4	Test	None
Manufacturer: GE	Relative Humidity (%)	100	1 p. 2	100	2 Para. 3.4.2	Test	None
Model Number: GE EB5	Chemical Spray (pH)	N/A	N/A	Boron 2950 mg/L pH 11.2	2 App. I	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	$1.0 \times 10^3$	1 p. 2	$2.04 \times 10^8$	2 Para. 3.2 and Imp. A	Test	None
Limiting Environment: Location: Main Steam FW Pipe Chases (PCE-2, PCW-2)	1 Year Accident Radiation Dose (Rads)	$8.2 \times 10^4$	1 p. 2				
Rad Zone: Main Steam FW Pipe Chases (PCE-2, PCW-2)	Aging (°F/Years)	130/40	1 p. 2	130/40	2 App. A 5	Test and Analysis	None
Lowest Elevation: 28'-0" Flood Level: 5'-5" Above Flood Level: Yes	Submergence	N/A	6	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, 7/22/85.
2. Limitorque Test Report No. B0119, Qualification Type Test Report of Multipoint Terminal Strips for use in Limitorque Valve Actuators for PWR Service.
3. Impell Calculation No. 0570-032-103.
4. Seabrook EQ File No. 248-65-01, Assessment Report No. 2, Note 2.
5. Seabrook EQ File No. 248-65-01, Assessment Report No. 2, Note 6.
6. SBU-96263, Seabrook Flooding Study Matrix.

Notes:

1. The terminal blocks are used as a component of Limitorque Actuators and do not have a separate I.D. No. I.D. Nos. for the actuators are listed in QEW Sheet 1.
2. Reference 4 demonstrates using a thermal lag test that these terminal blocks, which are located inside the valve actuator, will not be exposed to temperatures in excess of 228°F when the external environmental MSLB temperature is 325°F. Therefore, the peak test temperature of 312°F envelopes the actual 228°F seen by the terminal blocks.

Public Service Company of New Hampshire  
 Seabrook Station  
 Docket: 50-443

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 248-65-01

Prepared By: Jim Buckley Date: 4/30/86  
 Checked By: Dug A. Mon Date: 4/30/86

> Equipment Description	>> Postulated Environment			> Qualified Environment		> Qualification Method	> Outstanding Items
	>> Parameter	>> Value	>> Reference	> Value	> Reference		
> Purchase Order No.: > 9763-006-248-65	>> Operating Time	>> 1 Year	>> 1 >> p. 1	> 1 Year	> 3	> Test and Analysis	> None
> Equipment ID No(s).: > Note 1	>> Peak Temperature (°F)	>> 325	>> 1 >> p. 2	> 341	> 2, p. 74 > 4	> Test and Analysis	> None
> Equipment Type: > Cable	>> Peak Pressure (Psig)	>> 4.8	>> 1 >> p. 2	> 107.5	> 2 > p. 74	> Test	> None
> Manufacturer: Rockbestos	>> Relative Humidity (%)	>> 100	>> 1 >> p. 2	> 100	> 2 > p. 28	> Test	> None
> Model Number: Rockbestos > Firewall SIS Wire > (Chemically XLPE)	>> Chemical Spray (pH)	>> N/A	>> N/A	> Boric Acid > 1.7% by wt. > pH 11.7	> 2 > p. 79 > 5	> Test	> None
> Accuracy:Spec: N/A > Demon: N/A	>> 40 Year Normal Radiation Dose (Rads)	>> 1.0 x 10 <sup>3</sup>	>> 1 >> p. 2	> 2.0 x 10 <sup>8</sup>	> 2 > p. 10	> Test	> None
> Limiting Environment: > Location: Main Steam FW > Pipe Chases (PCE-2, PCW-2)	>> 1 Year Accident Radiation Dose (Rads)	>> 8.2 x 10 <sup>4</sup>	>> 1 >> p. 2				
> Rad Zone: Main Steam FW > Pipe Chases (PCE-2, PCW-2)	>> Aging (°F/Years)	>> 130/40	>> 1 >> p. 2	> 194/40	> 2 > p. 49	> Test and Analysis	> None
> Lowest Elevation: 28'-0"							
> Flood Level: 5'-5" > Above Flood Level: Yes	>> Submergence	>> N/A	>> 6	> N/A	> N/A	> N/A	> None

Documentation References:

1. U&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, 7/22/85.
2. Rockbestos Test Report No. QR#5804, 9/13/85.
3. Impell Calculation No. 0570-032-104.
4. Seabrook EQ File No. 248-65-01, Assessment Report No. 3, Note 2.
5. Seabrook EQ File No. 248-65-01, Assessment Report No. 3, Note 5.
6. SBU-96263, Seabrook Flooding Study Matrix.

Notes:

1. The Firewall SIS wires are used as a component of Limitorque Actuators covered under EQ File 248-65-01. There is no separate I.D. for the cables.

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 248-65-01

Prepared By: Jim Buckley Date: 4/30/86  
Checked By: Aug A. Moore Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-248-65	Operating Time	1 Year	1 p. 1	1 Year	3	Test and Analysis	None
Equipment ID No(s).: Note 1							
	Peak Temperature (°F)	325	1 p. 2	341	2 p. 67 4	Test and Analysis	None
	Peak Pressure (Psig)	4.8	1 p. 2	117.2	2 p. 67	Test	None
Equipment Type: Cable							
Manufacturer: Rockbestos	Relative Humidity (%)	100	1 p. 2	100	2 p. 65	Test	None
Model Number: Rockbestos Firewall SIS Wire (Irradiation XLPE)	Chemical Spray (pH)	N/A	N/A	Boric Acid 1.7% by wt. pH 9.6	2 p. 64 5	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1.0 x 10 <sup>3</sup>	1 p. 2	2.0 x 10 <sup>8</sup>	2 p. 10 & 47	Test	None
Limiting Environment: Location: Main Steam FW Pipe Chases (PCE-2, PCW-2)	1 Year Accident Radiation Dose (Rads)	8.2 x 10 <sup>4</sup>	1 p. 2				
	Aging (°F/Years)	130/40	1 p. 2	194/40	2 p. 42	Test and Analysis	None
Lowest Elevation: 28'-0" Flood Level: 5'-5" Above Flood Level: Yes	Submergence	N/A	6	N/A	N/A	N/A	None

Documentation References:

1. DE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, 7/22/85.
2. Rockbestos Test Report No. QR#5805, 9/13/85.
3. Impell Calculation No. 0570-032-105.
4. Seabrook EQ File No. 248-65-01, Assessment Report No. 4, Note 2.
5. Seabrook EQ File No. 248-65-01, Assessment Report No. 4, Note 5.
6. SBU-96263, Seabrook Flooding Study Matrix.

Notes:

1. The Firewall SIS wires are used as a component of Limatorque Actuators covered under EQ File 248-65-01. There is no separate I.D. for the cables.

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 252-16-03

Prepared By: Jim Buckley Date: 4/30/86

Checked By: Aug A Moon Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-252-16	Operating Time	1 Year	1 p. 1	1 Year	3	Test and Analysis	None
Equipment ID No(s): EAH-FIT-5791 EAH-PDT-5782 EAH-PDT-5783 EAH-PDT-5789 EAH-PDT-5790	Peak Temperature (°F)	148.8	6 p. 105	420	2 p. V-278 p. VI-265	Test	None
Equipment Type: Differential Pressure Transmitter Manufacturer: ITT Barton	Peak Pressure (Psig)	N/A	N/A Note 1	N/A	N/A	N/A	None
Model Number: 765	Relative Humidity (%)	N/A	N/A Note 1	N/A	N/A	N/A	None
	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: 10.07% Demon: 10.07%	40 Year Normal Radiation Dose (Rads)	4.7 x 10 <sup>6</sup>	1 p. 3	50.0 x 10 <sup>6</sup>	2 p. III-6	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	3.6 10 <sup>6</sup>	1 p. 3				
Location: Containment Enclosure (CE-1) Rad Zone: Containment Enclosure (CE-1)	Aging (°F/Years)	104/40	1 p. 1	104/40	2 p. III-4 5	Test and Analysis	None
Lowest Elevation: N/A Flood Level: N/A Above Flood Level: N/A	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Revision 17, dated 7/22/85.
2. FP-73786-02, ITT Barton Test Report #R3-765-2, Low D/P Transmitters, dated 3/5/85.
3. Impell Calculation 0570-032-120.
4. SBU-96263, Seabrook Flooding Study Matrix, 10/25/85.
5. PSNH, Seabrook EQ File No. 252-16-03, Assessment Checklist, Note 5.
6. UE&C Calculation Set No. MSVCS-FAG-08, LOCA Outside Containment, dated 4/26/85.

Notes:

1. Qualification is required for a LOCA event only. Therefore, the only harsh environmental conditions this equipment will be exposed to are temperature and radiation.

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 600-01-01

Prepared By: Jim Buckley Date: 4/20/86  
 Checked By: Aug A. Moore Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-600-01	Operating Time	1 year	1 p.1	1 year	4	Test and Analysis	None
Equipment ID No(s).: EDE-SPL-1	Peak Temperature (°F)	375	1 p.1	390	2 p.6 (Fig. 4)	Test	None
Equipment Type: Heat-Shrink Sleeve	Peak Pressure (Psig)	60	1 p.1	66	2 p.6 (Fig. 4)	Test	None
Manufacturer: Raychem Corporation	Relative Humidity (%)	100	1 p.1	100	2 p.6 (Fig. 4)	Test	None
Model Number: WCSF-N	Chemical array (pH)	Boric Acid 1.2% by wt pH=7.5 to 10.5	1 p.1	Boric Acid 3.5% by wt pH = 10.5	2 p.7 5	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>8</sup>	1 p.3 Note 2	2.9 x 10 <sup>8</sup>	2 p.6 App. 1	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	-----	1 p.3				
Location: Inside Containment (All Zones) Rad Zone: Prim. Aux. Bldg. (PB-15A, PB-18)	Aging (°F/Years)	194/40 (90°C)	Note 1	194/40 (90°C)	3 p.9 (Fig. 2) 2 p.4	Test and Analysis	None
Lowest Elevation: Note 3 Flood Level: Note 3 Above Flood Level: Yes	Submergence	N/A	7	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-34175-01, Wyle Laboratories Test Report No. 58442-1, Environmental Qualification Test Report of Raychem WCSF-N Nuclear In-Line Cable Splice Assemblies, dated 5/15/80.
3. FP-34183-01, Raychem Energy Division Report No. EDR-5046, Analysis of Heat Aging Data on WCSF Material to determine pre-aging conditions for Nuclear Qualification Testing, dated 3/4/82.
4. Impell Calculation No. 0570-032-032.
5. PSNH, Seabrook EQ File No. 600-1-01, Assessment Checklist, Note 3.
6. SBU-92605 Letter from UE&C to Impell, dated 2/13/85.
7. SBU-96263, UE&C letter addressed to YAEC on Flooding Study Matrix, dated 4/9/85.
8. Seabrook Station, EQ File No. 600-01-01, Assessment Report, Note 8.

Notes:

1. The temperature 194°F (90°C) is consistent with the manufacturer's and Seabrook Class 1E cable specification.
2. The total integrated radiation dose in Environmental Zones PB-4 and PB-19 is greater than 2.0 x 10<sup>8</sup> rads. No electrical equipments installed in these areas (Ref. 6).
3. This is generic equipment which is not qualified for submergence, and is not submerged in the plant in any application where operability is required (Ref. 8).

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 600-01-02

Prepared By: Jim Buckley Date: 4/30/86  
 Checked By: Doug A. Moore Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-600-01	Operating Time	1 year	1 p.1	1 year	5	Test and Analysis	None
Equipment ID No(s).: EDE-SPL-2	Peak Temperature (°F)	375	1 p.1	390	2 p.8 (Fig. 5)	Test	None
Equipment Type: Cable Breakout	Peak Pressure (Psig)	60	1 p.1	66	2 p.8 (Fig. 5)	Test	None
Manufacturer: Raychem Corporation	Relative Humidity (%)	100	1 p.1	100	2 p.8 (Fig. 5)	Test	None
Model Number: NCBK-3	Chemical Spray (pH)	Boric Acid 1.2% by wt pH=7.5 to 10.5	1 p.1	Boric Acid 3.5% by wt. pH = 10.5	2 p. 9 6	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>8</sup>	1 p.3 Note 2	2.9 x 10 <sup>8</sup>	2 p.8 App. A	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	-----	1 p.3				
Location: Inside Containment (all zones) Rad Zone: Prim. Aux. Bldg. (PB-15A, PB-18)	Aging (°F/Years)	194/40 (90°C)	Note 1	194/40 (90_C)	3 p.9 (Fig. 2) 4 p.8 (Fig. 2)	Test and Analysis	None
Lowest Elevation: Note 3 Flood Level: Note 3 Above Flood Level: Yes	Submergence	N/A	8	N/A	N/A	N/A	None

Documentation References:

Notes:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-34176-01, Wyle Laboratories Test Report No. 58442-2, dated 4/3/81.
3. FP-34183-01, Raychem Energy Division Report No. EDR-5046, dated 3/4/82.
4. FP-34182-01, Raychem Energy Division Report No. EDR-5040, dated 10/15/81.
5. Impell Calculation No. 0570-032-035.
6. PSNH, Seabrook EQ File No. 600-1-02, Assessment Checklist, Note 3.
7. SBU-92605, Letter from UE&C to Impell, dated 2/13/85.
8. SBU-96263, UE&C Letter addressed to YAEC on Flooding Study Matrix, dated 4/9/85.
9. Seabrook Station, EQ File No. 600-01-02, Assessment Report, Note 8.

1. The temperature 194°F (90°C) is consistent with the manufacturer's and Seabrook Class 1E cable specification.
2. The total integrated radiation dose in Environmental Zones PB-4 and PB-19 is greater than 2.0 x 10<sup>8</sup> rads. No electrical equipment is installed in these areas (Ref. 7).
3. This is generic equipment which is not qualified for submergence, and is not submerged in the plant in any application where operability is required (Reference 9).

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 600-01-03

Prepared By: Jim Buckley Date: 4/30/80  
Checked By: Dry A. Mon Date: 4/30/80

Equipment Description	Parameter	Postulated Environment		Qualified Environment		Qualification Method	Outstanding Items
		Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-600-01	Operating Time	1 year	1 p. 1	1 year	5	Test and Analysis	None
Equipment ID No(s): EDE-SPL-3	Peak Temperature (°F)	375	1 p. 1	390	2 p. 7 (Fig. 5)	Test	None
Equipment Type: Motor Connection Kits	Peak Pressure (Psig)	60	1 p. 1	66	2 p. 7 (Fig. 5)	Test	None
Manufacturer: Raychem Corporation	Relative Humidity (%)	100	1 p. 1	100	2 p. 7 (Fig. 5)	Test	None
Model Number: NMCK-35-00	Chemical Spray (pH)	Boric Acid 1.2% by wt pH=7.5 to 10.5	1 p. 1	Boric Acid 3.5% by wt pH = 10.5	2 p. 8 6	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>8</sup>	1 p. 3 Note 2	2.0 x 10 <sup>8</sup>	2 p. 7 App. A	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	-----	1 p. 3				
Location: Inside Containment (all zones) Rad Zone: Prim. Aux. Bldg. (PB-15A, PB-18)	Aging (°F/Years)	194/40 (90°C)	Note 1	194/40 (90°C)	3 p. 9 (Fig. 2) 2 p. 4 4, p. 8 (Fig. 2)	Test and Analysis	None
Lowest Elevation: Note 3 Flood Level: Note 3 Above Flood Level: Yes	Submergence	N/A	8	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-34177-01, Wyle Laboratories Test Report No. 58442-3, Environmental Qualification Test Report of Raychem NMCK Nuclear Motor Connection Kits, dated 7/28/80.
3. FP-34183-01, Raychem Energy Division Report No. EDR-5046, Analysis of Heat Aging Data on WCSF Material to determine pre-aging conditions for Nuclear Qualification Testing, dated 3/4/82.
4. FP-34182-01, Raychem Energy Division Report No. EDR-5040, Analysis of Heat Aging Data on -52 Molding Material to determine pre-aging conditions for Nuclear Qualification Testing.
5. Impell Calculation No. 0570-032-034.
6. PSNH, Seabrook EQ File No. 600-1-03, Assessment Checklist, Note 3.
7. SBU-92605 Letter from UE&C to Impell, dated 2/13/85.
8. SBU-96263, UE&C Letter addressed to YAEC on Flooding Study Matrix, dated 4/9/85.
9. Seabrook Station EQ File No. 600-01-03, Assessment Report, Note 8.

Notes:

1. The temperature 194°F (90°C) is consistent with the manufacturer's and Seabrook Class 1E cable specification.
2. The total integrated radiation dose in Environmental Zones PB-4 and PB-19 is greater than 2.0 x 10<sup>8</sup> rads. No electrical equipment is installed in these areas (Ref 7).
3. This is generic equipment which is not qualified for submergence, and is not submerged in the plant in any application where operability is required (Reference 9).



QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 600-01-05

Prepared By: Jim Buckley Date: 4/30/86

Checked By: Doug A. More Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-600-01	Operating Time	1 year	1 p. 1	1 year	5	Test and Analysis	None
Equipment ID No(s).: EDE-SPL-5	Peak Temperature (°F)	375	1 p. 1	442	2 p. 10 (Fig. 5)	Test	None
Equipment Type: 120V Wire Connection Kits	Peak Pressure (Psig)	60	1 p. 1	132	2 p. 10 (Fig. 5)	Test	None
Manufacturer: Raychem Corporation	Relative Humidity (%)	100	1 p. 1	100	2 p. 10 (Fig. 5)	Test	None
Model Number: NPKV-2	Chemical Spray (pH)	Boric Acid 1.2% by wt pH=7.5 to 10.5	1 p. 1	Boric Acid 1.7% by wt pH = 10.5	2 p. 9 6	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>8</sup>	1 p. 3 Note 2	2.2 x 10 <sup>8</sup>	2 p. 16 (Table 1) App. A	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	-----	1 p. 3				
Location: Containment (all zones) Rad Zone: Prim. Aux. Bldg. (PB-15A, PB-18)	Aging (°F/Years)	194(90°C)/40	Note 1	194(90°C)/40	3 p. 9 (Fig. 2) 2 p. 5, 16 (Table 1) 4, p. 8 (Fig. 2)	Test and Analysis	None
Lowest Elevation: Note 3 Flood Level: Note 3 Above Flood Level: Yes	Submergence	N/A	8	N/A	N/A	N/A	None

Documentation References:

Notes:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-34174-01, Wyle Laboratories Test Report No. 58722-1, Environmental Qualification Test Report of Raychem NPKV Nuclear Plant Stub Connection Kits, dated 8/24/82.
3. FP-34183-01, Raychem Energy Division Report No. EDR-5046, Analysis of Heat Aging Data on WCSF Material to determine pre-aging conditions for Nuclear Qualification Testing, dated 3/4/82.
4. FP-34182-01, Raychem Energy Division Report No. EDR-5040, Analysis of Heat Aging Data on -52 Molding Material to determine pre-aging conditions for Nuclear Qualification Testing.
5. Impell Calculation No. 0570-032-042.
6. PSNH, Seabrook EQ File No. 600-1-05, Assessment Checklist, Note 3.
7. SBU-92605 Letter from UE&C to Impell, dated 2/13/85.
8. SBU-96263, UE&C Letter addressed to YAEC on Flooding Study Matrix, dated 4/9/85.
9. Seabrook Station, EQ File 600-01-05, Assessment Checklist Note 8.

1. The temperature 194°F (90°C) is consistent with the manufacturer's and Seabrook Class 1E cable specification.
2. The total integrated radiation dose in Environmental Zones PB-4 and PB-19 is greater than 2.0 x 10<sup>8</sup> rads. No electrical equipment is installed in these areas (Ref 7).
3. This is generic equipment which is not qualified for submergence, and is not submerged in the plant in any application where operability is required (Ref. 9).

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 600-01-06

Prepared By: Jim Buckley Date: 4/30/86  
 Checked By: Dug A. Moore Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-600-01	Operating Time	1 year	1 p. 1	1 year	3 4	Test and Analysis	None
Equipment ID No(s).: EDE-SPL-6	Peak Temperature (°F)	144	1 p. 2	194	2 p. 5 4	Test	None
Equipment Type: Cable Jacket Repair Sleeve	Peak Pressure (Psig)	Slightly Positive	1 p. 2	Slightly Positive	2 p. 8 4	Test	None
Manufacturer: Raychem Corporation	Relative Humidity (%)	100	1 p. 2	100	2 p. 8 4	Test	None
Model Number: NJRS	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1.0 x 10 <sup>3</sup>	1 p. 3	5.0 x 10 <sup>7</sup>	2 p. 7 4	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	1.1 x 10 <sup>5</sup>	1 p. 3				
Location: MS&FW Pipe Chase (PCW-4) EFW PMP BLD (EFW-2) Rad Zone: Primary Aux. Bldg. (PB-1) Note 3	Aging (°F/Years)	194(90°C)/40	Note 1	194(90°C)/40	3 p. 9 (Fig. 2)	Test and Analysis	None
Lowest Elevation: Note 2 Flood Level: Note 2 Above Flood Level: Yes	Submergence	N/A	5	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-34348-01, Raychem Energy Division Report No. EDR-5059, dated 3/30/83.
3. Raychem Energy Division Report No. EDR-5046, dated 3/4/82.
4. PSNH, Seabrook EQ File No. 600-1-06, Assessment Checklist, Note 4.
5. SBU-96263, UE&C Letter addressed to YAEC on Flooding Study Matrix.
6. Seabrook Station EQF No. 600-01-06, Rev. 0.
7. Seabrook Station, EQ File No. 600-01-06, Assessment Report, Note 5.

Notes:

1. The temperature 194°F (90°C) is consistent with the manufacturer's and Seabrook Class 1E cable specification.
2. This is generic equipment which is not qualified for submergence, and is not submerged in the plant in any application where operability is required (Reference 7).
3. Tested parameters restrict the use of this equipment to the environmental zones listed in Section 4.0 (ESE) of Reference 6. Zones PCW-4, EFW-2, and PB-1 are the limiting zones of those listed.

*Jim Buckleby*  
*Doug A. Mars*

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-600-01	Operating Time	1 year	1 p. 1	1 Year	4	Test and Analysis	None
Equipment ID No(s).: EDE-SPL-7	Peak Temperature (°F)	375	1 p. 1	442	2 p. 10 (Fig. 6)	Test	None
Equipment Type: Shrinkable Cable Sleeve	Peak Pressure (Psig)	60	1 p. 1	132	2 p. 10 (Fig. 6)	Test	None
Manufacturer: Raychem Corporation	Relative Humidity (%)	100	1 p. 1	100	2 pp. 8-10	Test	None
Model Number: WCSF-N	Chemical Spray (pH)	Boric Acid 1.2% by Wt. pH = 7.5 to 10.5	1 p. 1	Boric Acid pH = 10.5	2 p. 8 5	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>8</sup>	1 p. 3 Note 2	2.2 x 10 <sup>8</sup>	2 pp. 6, 16 Table 1	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	----	1 p. 3				
Location: Containment (All zones) Rad Zone: Primary Aux. Bldg. (PB-15A, PB-18)	Aging (°F/Years)	194/40 (90°C)	Note 1	194 (90°C)/40	3 p. 9 (Fig. 2) 2 p. 5, 6, 16 (Table 1)	Test and Analysis	None
Lowest Elevation: Note 3 Flood Level: Note 3 Above Flood Level: Yes	Submergence	N/A	7	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-34473-01, Wyle Laboratories Test Report No. 58772-2, dated 11/18/82, Environmental Qualification Test Report of Raychem WCSF-N In-Line Bolted Splice Assemblies for Raychem Corp.
3. FP-34183-01, Raychem Energy Division Report No. EDR-5046, Analysis of Heat Aging Data on WCSF Material to determine pre-aging conditions for Nuclear Qualification Testing, dated 3/4/82.
4. Impell Calculation No. 0570-032-135.
5. PSNH, Seabrook E.Q. File No. 600-01-07, Assessment Checklist, Note 3.
6. SBU-92605, Letter from UE&C to Impell, dated 2/13/85.
7. SBU-96263, UE&C Letter addressed to YAEC on Flooding Study Matrix, dated 4/9/85.
8. Seabrook Station, E.Q. File No. 600-01-07, Assessment Checklist, Note 7.

Notes:

1. The temperature 194°F (90°C) is consistent with the manufacturer's and Seabrook Class 1E cable specification.
2. The total integrated radiation dose in Environmental Zones PB-4 and PB-11 are greater than 2.0 x 10<sup>8</sup> Rads. No electrical equipment is installed in these areas (Reference 6).
3. This is generic equipment which is not qualified for submergence, and is not submerged in the plant in any application where operability is required (Reference 8).

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 600-01-08

Prepared By: Jim Buckley Date: 4/30/80  
Checked By: Doug A. Moore Date: 4/30/80

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-600-01	Operating Time	1 year	1 p. 1	1 year	5	Test and Analysis	None
Equipment ID No(s).: EDE-SPL-8	Peak Temperature (°F)	375	1 p. 1	442	2 p. 10 (Fig. 6)	Test	None
Equipment Type: Control Cable Splicing Kit	Peak Pressure (Psig)	60	1 p. 1	132	2 p. 10 (Fig. 6)	Test	None
Manufacturer: Raychem Corporation	Relative Humidity (%)	100	1 p. 1	100	2 p. 10 (Fig. 6)	Test	None
Model Number: NPKC	Chemical Spray (pH)	Boric Acid 1.2% by wt pH=7.5 to 10.5	1 p. 1	Boric Acid 1.7% by wt pH = 10.5	2 p. 9 6	Test	None
Accuracy:Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>8</sup>	1 p. 3 Note 2	2.2 x 10 <sup>8</sup>	2 p. 17 (Table 1) App. A	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	-----	1 p. 3				
Location: Containment (all zones) Rad Zone: Prim. Aux. Bldg. (PB-15A, PB-18)	Aging (°F/Years)	194(90°C)/40	Note 1	194(90°C)/40	3 p. 9 (Fig. 2) 2 p.7,17 (Table 1) 4, p. 8 (Fig. 2)	Test and Analysis	None
Lowest Elevation: Note 3 Flood Level: Note 3 Above Flood Level: Yes	Submergence	N/A	8	N/A	N/A	N/A	None

Documentation References:

Notes:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-34474-01, Wyle Laboratories Test Report No. 58722-6, Environmental Qualification Test Report of Raychem Nuclear Plant Kit (NPK), dated 12/21/82.
3. FP-34183-01, Raychem Energy Division Report No. EDR-5046, Analysis of Heat Aging Data on WCSF Material to determine pre-aging conditions for Nuclear Qualification Testing, dated 3/4/82.
4. FP-34182-01, Raychem Energy Division Report No. EDR-5040, Analysis of Heat Aging Data on -52 Molding Material to determine pre-aging conditions for Nuclear Qualification Testing.
5. Impell Calculation No. 0570-032-136.
6. Seabrook Station EQ File No. 600-01-08, Assessment Report, Note 3.
7. SBU-92605 Letter from UE&C to Impell, dated 2/13/85.
8. SBU-96263, UE&C Letter addressed to YAEC on Flooding Study Matrix, dated 10/25/85.
9. Seabrook Station, EQ File 600-01-08, Assessment Report, Note 8.

1. The temperature 194°F (90°C) is consistent with the manufacturer's and Seabrook Class 1E cable specification.
2. The total integrated radiation dose in Environmental Zones PB-4 and PB-19 is greater than 2.0 x 10<sup>8</sup> rads. No electrical equipment is installed in these areas (Ref 7).
3. This is generic equipment which is not qualified for submergence, and is not submerged in the plant in any application where operability is required (Reference 9).

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 600-03-01

Prepared By: Joe A. Moore Date: 4/30/80  
Checked By: Jim Buckley Date: 4/30/80

Equipment Description	Parameter	Postulated Environment		Qualified Environment		Qualification Method	Outstanding Items
		Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-600-03	Operating Time	1 year	1 p. 1	1 year	4	Test and Analysis	None
Equipment ID No(s).: EDE-TRM-1	Peak Temperature (°F)	375	1 p. 1	470	2 p. 9	Test	None
Equipment Type: Electrical Terminal	Peak Pressure (Psig)	60	1 p. 1	74.5	2 p. 10	Test	None
Manufacturer: AMP, Inc.	Relative Humidity (%)	100	1 p. 1	100	2 p. 9	Test	None
Model Number: PIDG	Chemical Spray (pH)	Boric Acid 1.2% by wt. pH 7.5-10.5	1 p. 1	Boric Acid 1.72% by wt. pH 10.5 - 12.5	2 p. 9 3	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0x 10 <sup>8</sup>	1 p. 3 Note 1	2.59 x 10 <sup>8</sup>	2 p. 8	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	-----	N/A				
Location: Containment (All Zones) Rad Zone: Prim. Aux. Bldg. (Zones PB-15A, PB-18)	Aging (°F/Years)	194/40 (90°C)	Note 2	194/40 (90°C)	2 p. 6	Test	None
Lowest Elevation: Note 3 Flood Level: Note 3 Above Flood Level: Yes	Submergence	N/A	5	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Rev. 17, 7/22/85, Service Environment Chart.
2. AMP Qual. Test Report No. 110-11004, Rev. 0, 2/2/82.
3. Seabrook EQ File No. 600-3-01, Assessment Checklist, Note 4.
4. Impell Calculation No. 0570-032-058, Test Profile Extrapolation.
5. SBU-96263, UE&C Flooding Study Matrix.
6. Seabrook Station, Equipment Qualification File No. 600-03-01, Checklist Note 7.

Notes:

1. The total integrated radiation dose in Environmental Zones PB-4 and PB-19 is greater than 2.0x10<sup>8</sup>. No electrical equipment is installed in these zones (UE&C Letter No. SBU-92605, dated 2/13/85), therefore these locations will not be considered.
2. This temperature, 194°F (90°C), is consistent with the manufacturers specification and Seabrook Class IE cable specification.
3. This is generic equipment which is not qualified for submergence, and is not submerged in the plant in any application where operability is required (Reference 6).

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 600-06-01

Prepared By: Jim Buckley Date: 4/30/86  
 Checked By: Big A. Moore Date: 7/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-600-6  Equipment ID No(s).: Reference 1	Operating Time	1 year	2, p. 1	1 Year	3	Test and Analysis	None
				318 Days Note 1			
Equipment Type: Receptacle and Connector/ Cable Assembly EC-210 Series Manufacturer: Namco Controls  Model Number: EC 210-19000 EC 210-29000 EC 210-34000 EC 210-44000 Accuracy:Spec: N/A Demon: N/A	Peak Temperature (°F)	325	2, p. 2	340	4 p. 7-8 8-2 8-61	Test	None
	Peak Pressure (Psig)	4.8	2, p. 2	68	4 p. 7-8 8-2 8-61	Test	None
	Relative Humidity (%)	100	2, p. 2	100	4 p. 4-3 8-58	Test	None
	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>8</sup>	6 Note 3	2.04 x 10 <sup>8</sup>	4 p. 5-11 7-8 8-30	Test	None
	1 Year Accident Radiation Dose (Rads)	----	6 Note 3				
Limiting Environment:  Location: MS/FW Pipe Chase (All Zones) Rad Zone: Primary Aux. Bldg. (Zone 18)	Aging (°F/Years)	104/40  130/40	2 p. 2, 3 & 4	104/13.91  130/5.12 Note 1	5	Test and Analysis	None
Lowest Elevation: Note 2 Flood Level: Note 2 Above Flood Level: Yes	Submergence	N/A	7	N/A	Note 2	N/A	None

Documentation References:

1. UE&C Engineering Change Authorization No. 03/14443, Rev. C, dated 3/13/86.
2. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
3. Seabrook Station E.Q. File No. 600-06-01, Assessment Checklist, Note 1.
4. Namco Controls Report No. QTR 142, Rev. 0, dated 3/19/84.
5. Seabrook Station E.Q. File No. 600-06-01, Assessment Checklist, Note 4.
6. SBU-92605 Letter from UE&C to Impell, dated 2/13/85.
7. SBU-96263, Seabrook Station Flooding Study Matrix..
8. Seabrook Station E.Q. File No. 600-06-01, Assessment Checklist, Note 7.

Notes:

1. The 318 day operating time and 5.12 year thermal life applies to equipment located in the MS/FW pipe chases only. Equipment located outside containment has a 1 year operating time and a 13.91 year thermal life.
2. This is generic equipment which is not qualified for submergence, and is not submerged in the plant in any application where operability is required (Reference 8).
3. The total integrated radiation dose in Environmental Zones PB-4 and PB-19 is greater than 2.0 x 10<sup>8</sup> rads. No electrical equipment is installed in these areas (Reference 6).

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. NSS-220-01

Prepared By: Jim Buckley Date: 4/30/86  
 Checked By: Bry A. Moore Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: NSS-220	Operating Time	1 Year	1	1 Year	4	Test and Analysis	None
Equipment ID No(s): CS-V-149, 168 RC-V-22, 23, 87, 88, 122, 124 SI-V-3, 17, 32, 47 (Note 1)	Peak Temperature (°F)	375	1 p. 1	420	3 p. 51	Test	None
	Peak Pressure (Psig)	60	1 p. 1	72	3 p. 51	Test	None
Equipment Type: Valve Actuator	Relative Humidity (%)	100	1 p. 1	100	3 p. 51	Test	None
Manufacturer: Limitorque	Chemical Spray (pH)	Boric Acid 1.2% by wt. pH = 7.5 - 10.5	1 p. 1	Boric Acid 1.43% by Wt. pH = 10.5	3 p. 17 5	Test	None
Model Number: SMB-000, SMB-00, SMB-1, SB-00 and SBD-3	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>7</sup>	1 p. 1	1.85 x 10 <sup>8</sup>	3 p. 72	Test	None
Accuracy:Spec: N/A Demon: N/A	1 Year Accident Radiation Dose (Rads)	1.04 x 10 <sup>8</sup>	1 p. 1				
Limiting Environment: Location: Containment Bldg. (All Zones) Rad Zone: Containment Bldg. (General Area/ Not Submerged)	Aging (°F/Years)	120/40	1 p. 1	Note 3 120/5.6	7	Test and Analysis	None
Lowest Elevation: (-)25'0" Flood Level: (-)20'8" Above Flood Level: No Note 2	Submergence	N/A	2 Note 2	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Revision 17, 7/22/85.
2. SBU-96263, UE&C Letter, Flooding Study Matrix.
3. WCAP-8687, Supp. 2 - H01A, Revision 1, October, 1984.
4. Impell Calculation No. 0570-032-078.
5. Seabrook E.Q. File No. NSS-220-01, Assessment Checklist No. 1, Note 9.
6. Seabrook E.Q. File No. NSS-220-01, Assessment Checklist No. 1, Note 3.
7. Seabrook E.Q. File No. NSS-220-01, Assessment Checklist No. 1, Note 4.
8. RAI 430.62, Amendment 48, January 1983, pp. RAI 430-47, -48.

Notes:

1. Equipment I.D. #CS-ZS-149 & 168, RC-ZS-23, 87, 122, 124, 7302B and 7311A, & SI-ZS-2403-2, 2413-2, 2423-2 & 2433-2 are for the integral position indication within these actuators.
2. Valve CS-V-168 is submerged [(-)25'-0"] following design basis events. However, it will have performed its containment isolation safety function prior to being submerged. Once submerged the containment isolation safety function will be maintained and postulated failure modes are not detrimental to plant safety (Ref. 8) and will not mislead the operator. All other equipment is located above anticipated flood levels.
3. Although the qualified life per thermal and radiation aging is 5.6 years, the number of mechanical cycles during testing limits the qualified life to 5 years (Reference 6).

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. NSS-220-01

Prepared By: Jim Buckley Date: 4/30/86  
 Checked By: Ray A. Moore Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: NSS-220	Operating Time	1 Year	1 p. 1	1 Year	3	Test and Analysis	None
Equipment ID No(s): Note 1	Peak Temperature (°F)	375	1 p. 1	375	2 App. E Figure 4	Test and Analysis	None
Equipment Type: Terminal Blocks	Peak Pressure (Psig)	60	1 p. 1	70	2 App. E Figure 4	Test	None
Manufacturer: Marathon, GE, Curtis	Relative Humidity (%)	100	1 p. 1	100	2 Para. 3.4.2	Test	None
Model Number: Marathon 300 & 1600, GE EB5, Curtis Type "L"	Chemical Spray (pH)	Boric Acid 1.2% by wt. pH 7.5-10.5	1 p. 1	Boric Acid 1.65% by wt. pH 11.2	2 App. I 5	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>7</sup>	1 p. 1	2.04 x 10 <sup>8</sup>	2 Para. 3.2	Test	None
Limiting Environment: Location: Containment (All Zones),	1 Year Accident Radiation Dose (Rads)	1.04 x 10 <sup>8</sup>	1 p. 1				
Rad Zone: Containment (General Area/Not submerged)	Aging (°F/Years)	120/40	1 p. 1	120/40	2 App. A 6	Test and Analysis	None
Lowest Elevation: (-)25'-0"							
Flood Level: (-)20'-8"	Submergence	N/A	7 Note 2	N/A	N/A	N/A	None
Above Flood Level: No Note 2							

Documentation References:

1. DE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. Limitorque Test Report No. B0119, Qualification Type Test Report of Miltipoint Terminal strips for use in Limitorque Valve Actuators for PWR Service.
3. Impell Calculation No. 0570-032-128.
4. Seabrook E.Q. File No. NSS-220-01, Assessment Report No. 2, Note 2.
5. Seabrook E.Q. File No. NSS-220-01, Assessment Report No. 2, Note 8.
6. Seabrook E.Q. File No. NSS-220-01, Assessment Report No. 2, Note 6.
7. SBU-96263, Seabrook Flooding Study Matrix.
8. RAI 430.62, Amendment 48, January 1983, pp. RAI 430-47, 48.
9. Seabrook E.Q. File No. NSS-220-01, Assessment Report No. 5, Note 7.

Notes:

1. The terminal blocks are used as a component of Limitorque Actuators and do not have a separate I.D. No. I.D. Nos. are listed in QEWs, P. 1 of 5.
2. Valve CS-V-168 is submerged [(-)25'-0"] following design basis events. However, it will have performed its containment isolation safety function prior to being submerged. Once submerged the containment isolation safety function will be maintained and postulated failure modes are not detrimental to plant safety (Reference 8) and will not mislead the operator. All other equipment is located above anticipated flood levels.



QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. NSS-220-01

Prepared By: Jim Buckley Date: 4/30/86  
 Checked By: Ray A. Moore Date: 4/30/86

> Equipment Description	>> Postulated Environment			> Qualified Environment		> Qualification Method	> Outstanding Items
	>> Parameter	>> Value	>> Reference	> Value	> Reference		
> Purchase Order No.: NSS-220	>> Operating Time	>> 1 Year	>> 1 p. 1	> 1 Year	> 4	> Test and Analysis	> None
> Equipment ID No(s): Note 1	>> Peak Temperature (°F)	>> 375	>> 1 p. 1	> 375	> 2, p. 74 > 3, p. 4 > 5	> Test and Analysis	> None
> Equipment Type: Cable	>> Peak Pressure (Psig)	>> 60	>> 1 p. 1	> 107.5	> 2 p. 74	> Test	> None
> Manufacturer: Rockbestos	>> Relative Humidity (%)	>> 100	>> 1 p. 1	> 100	> 2 p. 73	> Test	> None
> Model Number: Rockbestos Firewall SIS Wire (Chemically XLPE)	>> Chemical Spray (pH)	>> Boric Acid 1.2% by wt. pH 7.5-10.5	>> 1 p. 1	> Boric Acid 1.71% by wt. pH 11.7	> 2 p. 79 > 6	> Test	> None
> Accuracy: Spec: N/A Demon: N/A	>> 40 Year Normal Radiation Dose (Rads)	>> 2.0 x 10 <sup>7</sup>	>> 1 p. 1	> 2.04 x 10 <sup>8</sup>	> 2 p. 10	> Test	> None
> Limiting Environment: Location: Containment (All Zones),	>> 1 Year Accident Radiation Dose (Rads)	>> 1.04 x 10 <sup>8</sup>	>> 1 p. 1				
> Rad Zone: Containment (General Area/Not submerged)	>> Aging (°F/Years)	>> 120/40	>> 1 p. 1	> 194/40 (90_C)	> 2 p. 49	> Test and Analysis	> None
> Lowest Elevation: (-)25'-0"							
> Flood Level: (-)20'-8"	>> Submergence	>> N/A	>> 7 Note 2	> N/A	> N/A	> N/A	> None
> Above Flood Level: No Note 2							

Documentation References:

1. U&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. Rockbestos Test Report No. QR#5804, 9/13/85.
3. Limitorque Project #600508, Valve Actuator Temperature related to high superheat ambient temperatures, Rev. A 8/31/78.
4. Impell Calculation No. 0570-032-129.
5. Seabrook E.Q. File No. NSS-220-01, Assessment Report No. 3, Note 2.
6. Seabrook E.Q. File No. NSS-220-01, Assessment Report No. 3, Note 5.
7. SBU-96263, Seabrook Flooding Study Matrix.
8. RAI 430.62, Amendment 48, January 1983, pp. RAI 430-47, 48.

Notes:

1. The Firewall SIS Wires are used as a component of Limitorque Actuators covered under this E.Q. File. There is no separate I.D. No. for the cables.
2. Valve CS-V-168 is submerged [(-)25'-0"] following design basis events. However, it will have performed its containment isolation safety function prior to being submerged. Once submerged the containment isolation safety function will be maintained and postulated failure modes are not detrimental to plant safety (Reference 8) and will not mislead the operator. All other equipment is located above anticipated flood levels.

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. NSS-220-01

Prepared By: Jim Buckley Date: 4/30/86  
Checked By: Buy A More Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: NSS-220	Operating Time	1 Year	1 p. 1	1 Year	4	Test and Analysis	None
Equipment ID No(s): Note 1	Peak Temperature (°F)	375	1 p. 1	375	2, p. 67 3, p. 4 5	Test and Analysis	None
Equipment Type: Cable	Peak Pressure (Psig)	60	1 p. 1	117.2	2 p. 67	Test	None
Manufacturer: Rockbestos	Relative Humidity (%)	100	1 p. 1	100	2 p. 65	Test	None
Model Number: Rockbestos Firewall SIS Wire (Irradiation XLPE)	Chemical Spray (pH)	Boric Acid 1.2% by wt. pH 7.5-10.5	1 p. 1	Boric Acid 1.71% by wt. pH 9.6	2 p. 64 6	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>7</sup>	1 p. 1	2.04 x 10 <sup>8</sup>	2 p. 10	Test	None
Limiting Environment: Location: Containment (All Zones),	1 Year Accident Radiation Dose (Rads)	1.04 x 10 <sup>8</sup>	1 p. 1				
Rad Zone: Containment (General Area/Not submerged)	Aging (°F/Years)	120/40	1 p. 1	194/40 (90°C)	2 p. 49	Test and Analysis	None
Lowest Elevation: (-)25'-0"							
Flood Level: (-)20'-8"	Submergence	N/A	7 Note 2	N/A	N/A	N/A	None
Above Flood Level: No Note 2							

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, 7/22/85.
2. Rockbestos Test Report No. QR#5805, 9/13/85.
3. Limitorque Project #600508, Valve Actuator Temperature related to high superheat ambient temperatures, Rev. A, 8/31/78.
4. Impell Calculation No. 0570-032-130.
5. Seabrook EQ File No. NSS-220-01, Assessment Report No. 4, Note 2.
6. Seabrook EQ File No. NSS-220-01, Assessment Report No. 4, Note 5.
7. SBU-96263, Seabrook Flooding Study Matrix.
8. RAI 430.62, Amendment 48, January 1983, pp. RAI 430-47, -48.

Notes:

1. The Firewall SIS wires are used as a component of Limitorque Actuators covered under this EQ File. There is no separate I.D. No. for the cables.
2. Valve CS-V-168 is submerged [(-)25'-0"] following design basis events. However, it will have performed its containment isolation safety function prior to being submerged. Once submerged the containment isolation safety function will be maintained and postulated failure modes are not detrimental to plant safety (Ref. 8) and will not mislead the operator. All other equipment is located above anticipated flood levels.

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. NSS-220-01

Prepared By: Jim Buckley Date: 4/30/86  
 Checked By: Greg A. Stone Date: 4/10/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: NSS-220	Operating Time	1 Year	1 p. 1	1 Year	4	Test and Analysis	None
Equipment ID No(s).: Note 1	Peak Temperature (°F)	375	1 p. 1	375	2, p. 6, 7 3, p. 4 5	Test and Analysis	None
Equipment Type: Cable	Peak Pressure (Psig)	60	1 p. 1	70	2 p. 6	Test	None
Manufacturer: Raychem	Relative Humidity (%)	100	1 p. 1	100	2 p. 6	Test	None
Model Number: Raychem "Flamtrol" Insulated and Jacketed Cables	Chemical Spray (pH)	Boric Acid 1.2% by wt. pH 7.5-10.5	1 p. 1	Boric Acid 1.71% by wt. pH 9.5 - 11.0	2 p. 6 6	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>7</sup>	1 p. 1	2.0 x 10 <sup>8</sup>	2 p. 1, 6, 11	Test	None
Limiting Environment: Location: Containment (All Zones),	1 Year Accident Radiation Dose (Rads)	1.04 x 10 <sup>8</sup>	1 p. 1				
Rad Zone: Containment (General Area/Not submerged)	Aging (°F/Years)	120/40	1 p. 1	194/40 (90°C)	9	Test and Analysis	None
Lowest Elevation: (-)25'-0"	Flood Level: (-)20'-8"	Submergence	N/A	N/A	N/A	N/A	None
Above Flood Level: No Note 2			Note 2				

Documentation References:

1. U&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. Franklin Institute (FIRL) Test Report No. F-C4033-1 for Raychem "Flamtrol" Cables, 1/75.
3. Limatorque Project #600508, Valve Actuator Temperature related to high superheat ambient temperatures, Rev. Z 8/31/78.
4. Impell Calculation No. 0570-032-131.
5. Seabrook E.Q. File No. NSS-220-01, Assessment Report No. 5, Note 2.
6. Seabrook E.Q. File No. NSS-220-01, Assessment Report No. 5, Note 5.
7. SBU-96263, Seabrook Flooding Study Matrix.
8. RAI 430.62, Amendment 48, January 1983, pp. RAI 430-47, 48.
9. Seabrook E.Q. File No. NSS-220-01, Assessment Report No. 5, Note 7.

Notes:

1. The Raychem "Flamtrol" wires are used as a component of Limatorque Actuators covered under this E.Q. File. There is no separate I.D. No. for the cables.
2. Valve CS-V-168 is submerged [(-)25'-0"] following design basis events. However, it will have performed its containment isolation safety function prior to being submerged. Once submerged the containment isolation safety function will be maintained and postulated failure modes are not detrimental to plant safety (Reference 8) and will not mislead the operator. All other equipment is located above anticipated flood levels.

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. NSS-220-05

Prepared By: Ray A. Pons Date: 4/30/80

Checked By: Jim Buckley Date: 4/30/80

> Equipment Description	>> Postulated Environment			> Qualified Environment		> Qualification Method	> Outstanding Items
	>> Parameter	>> Value	>> Reference	> Value	> Reference		
> Purchase Order No.: > 9763-006-NSS-220	>> Operating Time	>> 1 year	>> 1 >> p. 1	> 1 year	> 6	> Test and Analysis	> None
> Equipment ID No(s): > EDE-ECSA-2	>> Peak Temperature (°F)	>> 375	>> 1 >> p. 1	> 420	> 2 > p. 73	> Test	> None
> Equipment Type: > Electrical Conductor > Seal Assembly > Manufacturer: > Conax	>> Peak Pressure (Psig)	>> 60	>> 1 >> p. 1	> 80	> 2 > p. 73	> Test	> None
> Model Number: > N-11007	>> Relative Humidity (%)	>> 100	>> 1 >> p. 1	> 100	> 3 > p. 14 > 2 > p. 16	> Test	> None
> Accuracy: Spec: N/A > Demon: N/A	>> Chemical Spray (pH)	>> Boric Acid >> 1.2% Wt. >> pH 7.5 to 10.5	>> 1 >> p. 1	> Boric Acid > 1.43% by wt. > pH 10.5	> 2 > p. 16 > 5	> Test	> None
> Limiting Environment:	>> 40 Year Normal Radiation Dose (Rads)	>> 2.0 x 10 <sup>7</sup>	>> 1 >> p. 3	> 2.04 x 10 <sup>8</sup>	> 2 > p. 17	> Test	> None
> Location: Containment, > (CS-10)	>> 1 Year Accident Radiation Dose (Rads)	>> 1.04 x 10 <sup>8</sup>	>> 1 >> p. 1				
> Rad Zone: Containment > (Gen. Area/Not Submerged)	>> Aging (°F/Years)	>> 120/40	>> 1 >> p. 1	> 120/21	> 2 > p. 12 > 4	> Test and Analysis	> None
> Lowest Elevation: Note 1	>> Submergence	>> N/A	>> 7	> N/A	> N/A	> N/A	> None
> Flood Level: Note 1							
> Above Flood Level: Yes							

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. WCAP-8687, Supp. 2 - H08A, Revision 0, Equipment Qualification Test Report - Conax and Litton Electrical Seal Assemblies, August 1983.
3. EQDP-HE-8, Revision 0, 8/83, Equipment Qualification Data Package - Conax and Litton Electrical Seal Assemblies.
4. Seabrook Station, Equipment Qualification File No. NSS-220-05, Checklist Note 3.
5. Seabrook Station, Equipment Qualification File No. NSS-220-05, Checklist Note 4.
6. Impell Calculation No. 0570-032-090.
7. SBU-96263, Seabrook Flooding Study Matrix.
8. Seabrook Station, Equipment Qualification File No. NSS-220-05, Checklist Note 8.

Notes:

1. This is generic equipment which is not qualified for submergence, and is not submerged in the plant in any application where operability is required (Reference 8).

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. NSS-220-05

Prepared By: Dug A More Date: 4/30/86

Checked By: Jim Buckley Date: 4/30/86

> Equipment Description	>> Postulated Environment			> Qualified Environment		> Qualification Method	> Outstanding Items
	>> Parameter	>> Value	>> Reference	> Value	> Reference		
> Purchase Order No.: > 9763-006-NSS-220	>> Operating Time	>> 1 year	>> 1 >> p. 1	> 1 year	> 6	> Test and Analysis	> None
> Equipment ID No(s).: > EDE-ECSA-2	>> Peak Temperature (°F)	>> 300	>> 1 >> p. 3	> 420	> 2 > p. 73	> Test	> None
> Equipment Type: > Electrical Conductor > Seal Assembly > Manufacturer: > Conax	>> Peak Pressure (Psig)	>> 0.5	>> 1 >> p. 3	> 80	> 2 > p. 73	> Test	> None
> Model Number: > N-11007	>> Relative Humidity (%)	>> 100	>> 1 >> p. 3	> 100	> 3 > p. 14 > 2 > p. 16	> Test	> None
> Accuracy: Spec: N/A > Demon: N/A	>> Chemical Spray (pH)	>> N/A	>> N/A	> Boric Acid > 1.43% by wt. > pH 10.5	> 2 > p. 16 > 5	> Test	> None
> Limiting Environment:	>> 40 Year Normal Radiation Dose (Rads)	>> 2.0 x 10 <sup>8</sup>	>> 1 >> p. 3 >> Note 1	> 2.04 x 10 <sup>8</sup>	> 2 > p. 17	> Test	> None
> Location: Primary Aux. > Building (PB-15A) > Rad Zone: Primary Aux. > Building (PB-15A)	>> 1 Year Accident Radiation Dose (Rads)	>> -	>> -				
> Lowest Elevation: Note 2 > Flood Level: Note 2 > Above Flood Level: Yes	>> Aging (°F/Years)	>> 104/40	>> 1 >> p. 3	> 104/40	> 4	> Test and Analysis	> None
	>> Submergence	>> N/A	>> 7	> N/A	> N/A	> N/A	> None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. WCAP-8687, Supp. 2 - HOBA, Revision 0, Equipment Qualification Test Report - Conax and Litton Electrical Seal Assemblies, August 1983.
3. EQDP-HE-8, Revision 0, 8/83, Equipment Qualification Data Package - Conax and Litton Electrical Seal Assemblies.
4. Seabrook Station, Equipment Qualification File No. NSS-220-05, Checklist Note 3.
5. Seabrook Station, Equipment Qualification File No. NSS-220-05, Checklist Note 4.
6. Impell Calculation No. 0570-032-090.
7. SBU-96263, UE&C Letter, "Flooding Study Matrix".
8. Seabrook Station, Equipment Qualification File No. NSS-220-05, Checklist Note 8.

Notes:

1. The total integrated radiation dose in Environmental Zone PB4 and PB19 is greater than 2 x 10<sup>8</sup> rads. No electrical equipment is installed in these areas, as confirmed by UE&C letter SBU 92605, dated 2/13/85. Therefore, these locations are ignored.
2. This is generic equipment which is not qualified for submergence, and is not submerged in the plant in any application where operability is required (Reference 8).

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
 Seabrook Station  
 Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. NSS-220-05

Prepared By: Dog A. Mann Date: 4/30/86  
 Checked By: Jim Buckley Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-NSS-220	Operating Time	1 year	1 p. 1	1 year	6	Test and Analysis	None
Equipment ID No(s).: EDE-ECSA-2	Peak Temperature (°F)	325	1 p. 2	420	2 p. 73	Test	None
Equipment Type: Electrical Conductor Seal Assembly	Peak Pressure (Psig)	4.8	1 p. 2	80	2 p. 73	Test	None
Manufacturer: Conax	Relative Humidity (%)	100	1 p. 2	100	3 p. 14 2 p. 16	Test	None
Model Number: N-11007	Chemical Spray (pH)	N/A	N/A	Boric Acid 1.43% by Wt. pH 10.5	2 p. 16 5	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1.0 x 10 <sup>3</sup>	1 p. 2	2.04 x 10 <sup>8</sup>	2 p. 17	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	8.2 x 10 <sup>4</sup>	1 p. 2				
Location: MSFW Pipe Chases, (PCW1) Rad Zone: MSFW Pipe Chases, (PCW1)	Aging (°F/Years)	130/40	1 p. 2	130/12.93	4	Test and Analysis	None
Lowest Elevation: Note 1 Flood Level: Note 1 Above Flood Level: Yes	Submergence	N/A	7	N/A	N/A	N/A	None

Documentation References:

1. DE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. WCAP-8687, Supp. 2 - H08A, Revision 0, Equipment Qualification Test Report - Conax and Litton Electrical Seal Assemblies, August 1983.
3. EQDP-HE-8, Revision 0, 8/83, Equipment Qualification Data Package - Conax and Litton Electrical Seal Assemblies.
4. Seabrook Station, Equipment Qualification File No. NSS-220-05, Checklist Note 3.
5. Seabrook Station, Equipment Qualification File No. NSS-220-05, Checklist Note 4.
6. Impell Calculation No. 0570-032-090.
7. SBU-96263, Seabrook Flooding Study Matrix.
8. Seabrook Station, Equipment Qualification File No. NSS-220-05, Checklist Note 8.

Notes:

1. This is generic equipment which is not qualified for submergence, and is not submerged in the plant in any application where operability is required (Reference 8).

ATTACHMENT 2

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-118-01	Operating Time	1 year	1 p. 1	1 year	4	Test and Analysis	None
Equipment ID No(s): EDE-MM-83, -84, -85, -86, -89, -90, -91, -94, -95, -96, -100, -101, -104, -105, -106, -107, -109, -110, -111, -112, -113, -115, -117, -118, -119, -120, -121, -122, -123, *continued	Peak Temperature (°F)	375	1 p. 1	375	2 p. 21 3	Test and Analysis	None
Equipment Type: Electrical Penetrations (Low Voltage Power, Control and Instrumentation)	Peak Pressure (Psig)	60	1 p. 1	108	2 p. 21	Test	None
Manufacturer: Westinghouse	Relative Humidity (%)	100	1 p. 1	100	2 p. 21	Test	None
Model Number: WX-33511 to WX-33518 and WX-33521, WX-33522	Chemical Spray (pH)	Boric Acid 1.2% by wt. pH 7.5 - 10.5	1 p. 1	Boric Acid 2.28% by wt. pH 8.5 - 11	2 p. 21	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>7</sup>	1 p. 1	2.2 x 10 <sup>8</sup>	2 p. 13A and 118	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	1.04 x 10 <sup>8</sup>	1 p. 1				
Location: Containment (Zones CS-10, -12) Rad Zone: Containment (Zones CS-10, -12)	Aging (°F/Years)	120/40	1 p. 1	158/40 (70°C)	2 p. 12 7	Test and Analysis	None
Lowest Elevation: (-)16'-8" Flood Level: (-)26'-0" Above Flood Level: Yes	Submergence	N/A	5	N/A	N/A	N/A	N/A

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-31510-03, Technical Reports and Qualification Data for Low Voltage, Control and Instrumentation Electrical Penetrations for the Seabrook Station.
3. Seabrook E.Q. File No. 118-01-01, Assessment Checklist No. 1, Note 2.
4. Impell Calculation No. 0570-032-121.
5. SBU-96263, Seabrook Flooding Study Matrix.
6. Seabrook E.Q. File No. 118-01-01, Assessment Checklist No. 1, Note 7.
7. Seabrook E.Q. File No. 118-01-01, Assessment Checklist No. 1, Note 6.

Notes:

- \* -124, -125, -126, -128, -130, -131, -133, -135, -137, -139



QUALIFICATION EVAL JN WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 118-01-01

Prepared By: Doug A. Moore Date: 4/21/86  
Checked By: Jim Buckley Date: 4/21/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-118-01-01	Operating Time	1 year	1 p. 1	1 year	3	Test and Analysis	None
Equipment ID No(s): Note 1	Peak Temperature (°F)	375	1 p. 1	440	2 p. 57 4	Test and Analysis	None
Equipment Type: Thermocouple Cable	Peak Pressure (Psig)	60	1 p. 1	117.2	2 p. 67	Test	None
Manufacturer: Rockbestos	Relative Humidity (%)	100	1 p. 1	100	2 p. 65	Test	None
Model Number: Rockbestos Firewall III, 2/C #16 AWG TC + SH Type kx	Chemical Spray (pH)	Boric Acid 1.2% by wt. pH 7.5 - 10.5	1 p. 1	Boric Acid 1.7% by wt. pH 8.9-10.7	2 p. 67 5	Test	None
Accuracy: Spec: N/A Demon: N/A Note 2	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>7</sup>	1 p. 1	2.04 x 10 <sup>8</sup>	2 p. 10	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	1.04 x 10 <sup>8</sup>	1 p. 1				
Location: Containment (Zones CS-10, -12) Rad Zone: Containment (Zones CS-10, -12)	Aging (°F/Years)	120/40	1 p. 1	194/40 (90°C)	2 p. 42	Test and Analysis	None
Lowest Elevation: (-)16'-8" Flood Level: (-)20'-8" Above Flood Level: Yes	Submergence	N/A	6	N/A	N/A	N/A	N/A

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. Rockbestos Test Report No. QR#5805, 9/13/85.
3. Impell Calculation No. 0570-032-124.
4. Seabrook E.Q. File No. 118-01-01, Assessment Checklist No. 2, Note 3.
5. Seabrook E.Q. File No. 118-01-01, Assessment Checklist No. 2, Note 7.
6. SBU-96263, Seabrook Flooding Study Matrix.

Notes:

1. The Thermocouple cable is used with the penetration modules Type WX-33521, WX-33815 and WX-33522 (I.D. #EDE-MM-120, EDE-MM-130 and EDE-MM-131). The cable does not have its own I.D. No.
2. These cables are connected to Incore thermocouple which have an Operating Code B (Reference: Equipment List Sort: P.O. NSS-090, 10/07/85). Hence, these cables are not required to function to mitigate the accident, but must not fail. Therefore, demonstration of accuracy by the cables is not a requirement.

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-118-01	Operating Time	1 year	1 p. 1	1 year	3	Test and Analysis	None
Equipment ID No(s).: Note 1	Peak Temperature (°F)	N/A	Note 2	N/A	Note 2	N/A	None
Equipment Type: Insulating Board	Peak Pressure (Psig)	N/A	Note 2	N/A	Note 2	N/A	None
Manufacturer: Westinghouse	Relative Humidity (%)	N/A	Note 2	N/A	Note 2	N/A	None
Model Number: Insulating Board with Limitrak Coating	Chemical Spray (pH)	N/A	N/A p.	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	$1 \times 10^3$	1 p. 4	$1 \times 10^8$	2 p. 6a	Test and Analysis	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	$3.4 \times 10^4$	1 p. 4				
Location: Elect. Pen. Area (Zone ET-3A) Rad Zone: Elect. Pen. Area (Zone ET-3B)	Aging (°F/Years)	98/40	1 p. 4	129,2/40 (54°C)	2 p. 6	Test and Analysis	None
Lowest Elevation: (-)16'8" Flood Level: N/A Above Flood Level: N/A	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-32288-04, Qualification Test Report for "Limitrak" Coated Polyplate, M PDS44763BB, Insulation Board following the requirements of IEEE 323-1974.
3. PSNH, Seabrook E.Q. File No. 118-01-01, Assessment Checklist No. 3, Note 3.
4. SBU-96263, Seabrook Station "Flooding Study Matrix."

Notes:

1. The insulating boards are used as a component to support the cable connections and do not have any I.D. No.
2. All postulated accident parameters are considered mild except radiation.

QUALIFICATION EVAL. .ON WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 118-01-01

Prepared By: Gregory Moore Date: 4/24/86  
Checked By: Jim Buckley Date: 4/24/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-118-01-01	Operating Time	1 year	1 p. 1	1 year	3	Test and Analysis	None
Equipment ID No(s): Note 1	Peak Temperature (°F)	N/A	Note 2	N/A	Note 2	N/A	None
Equipment Type: Terminal Block	Peak Pressure (Psig)	N/A	Note 2	N/A	Note 2	N/A	None
Manufacturer: Curtis	Relative Humidity (%)	N/A	Note 2	N/A	Note 2	N/A	None
Model Number: Curtis, Type "L"	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1 x 10 <sup>3</sup>	1 p. 4	2.6 x 10 <sup>7</sup>	2, p. 2 (Add. 1, p. 4) 4	Test and Analysis	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	3.4 x 10 <sup>4</sup>	1 p. 4				
Location: Elect. Pen. Area (Zone ET-3A) Rad Zone: Elect. Pen. Area (Zone ET-3A)	Aging (°F/Years)	98/40	1 p. 4	158/5.31 (70°C)	6	Test	None
Lowest Elevation: (-)16'8" Flood Level: N/A Above Flood Level: N/A	Submergence	N/A	5	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-32289-03, Qualification Test Report for Curtis Type "L" Terminal Block used on the Seabrook Station Electrical Penetrations (PEN-TR-80-86).
3. PSNH, Seabrook E.Q. File No. 118-01-01, Assessment Checklist No. 4, Note 4.
4. PSNH, Seabrook E.Q. File No. 118-01-01, Assessment Checklist No. 4, Note 5.
5. SBU-96263, Seabrook Station "Flooding Study Matrix."
6. PSNH, Seabrook E.Q. File No. 118-01-01, Assessment Checklist No. 4, Note 7.

Notes:

1. There is no separate I.D. No. for the terminal blocks. These blocks are used on the outboard side of the penetration assembly for interconnection in Module I.D. Nos. EDE-MM-104 to 107 and EDE-MM-91, 94, 95 and 100.
2. All postulated accident parameters are considered mild except radiation.

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-118-01-01	Operating Time	1 year	1 p. 1	1 year	3	Test and Analysis	None
Equipment ID No(s).: Note 1	Peak Temperature (°F)	N/A	Note 2	N/A	Note 2	N/A	None
Equipment Type: Terminal Block	Peak Pressure (Psig)	N/A	Note 2	N/A	Note 2	N/A	None
Manufacturer: Marathon	Relative Humidity (%)	N/A	Note 2	N/A	Note 2	N/A	None
Model Number: 315	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	$1 \times 10^3$	1 p. 4	$2.2 \times 10^8$	2 p. 20	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	$3.4 \times 10^4$	1 p. 4				
Location: Elect. Pen. Area (Zone ET-3A) Rad Zone: Elect. Pen. Area (Zone ET-3B)	Aging (°F/Years)	98/40	1 p. 4	121.87/40 (49.92°C)	2 p. 10 4	Test and Analysis	None
Lowest Elevation: (-)16'8" Flood Level: N/A Above Flood Level: N/A	Submergence	N/A	5	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-31838-03, Qualification Test Report for Terminations, Terminal Block and Connectors to be used in the Electrical Penetrations of the Seabrook Plants, Test Report #PEN-TR-80-18, Rev. 4.
3. PSNH, Seabrook E.Q. File No. 118-01-01, Assessment Checklist No. 5, Note 4.
4. PSNH, Seabrook E.Q. File No. 118-01-01, Assessment Checklist No. 5, Note 5.
5. SBU-96263, Seabrook Station "Flooding Study Matrix."

Notes:

1. There is no separate I.D. No. for the terminal blocks. These blocks are used on the outboard side of the penetration assembly for interconnection in Module I.D. Nos. EDE-MM-125, 128, 109, 121, 122, 123, 126, 133, 135, 137, 139, 120, 131, 124 and 130.
2. All postulated accident parameters are considered mild except radiation.

QUALIFICATION EVAL. JN WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 118-01-01

Prepared By: Ray A. Moore Date: 4/21/86  
Checked By: Jim Buckley Date: 4/21/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.:	Operating Time	1 year	1 p. 1	1 year	3	Test and Analysis	None
Equipment ID No(s).: Note 1	Peak Temperature (°F)	N/A	Note 2	N/A	Note 2	N/A	None
Equipment Type: Terminal Block	Peak Pressure (Psig)	N/A	Note 2	N/A	Note 2	N/A	None
Manufacturer: Buchanon	Relative Humidity (%)	N/A	Note 2	N/A	Note 2	N/A	None
Model Number: #0530 End Section OTCB CU/AL/CH Blocks	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: (Ref. 5)	40 Year Normal Radiation Dose (Rads)	1 x 10 <sup>3</sup>	1 p. 4	2.5 x 10 <sup>8</sup>	2 p. 3	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	8.4 x 10 <sup>3</sup>	1 p. 4				
Location: Elect. Pen. Area Zone ET-3A Rad Zone: Elect. Pen. Area Zone ET-3A	Aging (°F/Years)	98/40	1 p. 4	122/40	2 p. 3	Test	None
Lowest Elevation: 15'-8" Flood Level: (-)26'-0" Above Flood Level: Yes	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-33826-02, Qualification Test Report for the Buchanon Thermocouple Terminal Block used on the Seabrook Plant Electrical Penetrations.
3. Seabrook Station; EQ File No. 118-01-01, Assessment Checklist No. 6, Note 4.
4. SBU-96263, Seabrook Station Flooding Study Matrix.
5. Seabrook Station, Assessment Checklist No. 6, Note 7.

Notes:

1. The terminal blocks are used as a component for thermocouple cable interconnection and do not have any separate I.D. Nos.
2. All postulated accident parameters are considered mild except radiation.

Public Service Company of New Hampshire  
 Seabrook Station  
 Docket: 50-443

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 118-01-01

Prepared By: John A. Moore Date: 4/21/86

Checked By: Jim Buckley Date: 4/21/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-118-1	Operating Time	1 year	1 p. 1	1 year	2 p. 9 3	Test and Analysis	None
Equipment ID No(s).: Note 1							
Equipment Type: Terminal Blocks	Peak Temperature (°F)	N/A	Note 2	N/A	Note 2	N/A	None
	Peak Pressure (Psig)	N/A	Note 2	N/A	Note 2	N/A	None
	Relative Humidity (%)	N/A	Note 2	N/A	Note 2	N/A	None
	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Manufacturer: Westinghouse	40 Year Normal Radiation Dose (Rads)	1 x 10 <sup>3</sup>	1 p. 4	2.20 x 10 <sup>8</sup>	2 p. 3	Test	None
Model Number: W#542247							
Accuracy: Spec: N/A Demon:	1 Year Accident Radiation Dose (Rads)	3.4 x 10 <sup>4</sup>	1 p. 4				
Limiting Environment:	Aging (°F/Years)	98/40	1 p. 4	138°F/40 (59°C)	2 p. 2	Test and Analysis	None
Location: Elect. Pen. Area (Zone ET-3A) Rad Zone: Elect. Pen. Area (Zone ET-3B)	Submergence	N/A	4	N/A	N/A	N/A	None
Lowest Elevation: (-)16'8" Flood Level: N/A Above Flood Level: N/A							

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-32354-02, Qualification of W Electrical Terminal Blocks for Use in Seabrook Nuclear Plant per Spec. 9763-118-1, Rev. 1.
3. Seabrook Station, E.Q. File No. 118-01-01, Assessment Checklist No. 7, Note 3.
4. SBU-96263, Seabrook Station Flooding Study Matrix.

Notes:

1. There is no separate I.D. No. for the terminal blocks. These blocks are used on the outboard side of the penetration assembly for interconnection of cables in Module I.D. Nos. EDE-MH-110 to 113, 115, 117 to 119.
2. All postulated accident parameters are considered mild except radiation.

Public Service Company of New Hampshire  
 Seabrook Station  
 Docket: 50-443

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 118-01-01

Prepared By: Greg A. Moore Date: 4/24/86

Checked By: Jim Buckley Date: 4/24/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-118-1	Operating Time	1 year	1 p. 1	1 year	3	Test and Analysis	None
Equipment ID No(s).: Note 1	Peak Temperature (°F)	N/A	Note 2	N/A	Note 2	N/A	None
Equipment Type: Terminals	Peak Pressure (Psig)	N/A	Note 2	N/A	Note 2	N/A	None
Manufacturer: AMP	Relative Humidity (%)	N/A	Note 2	N/A	Note 2	N/A	None
Model Number: 53416-2	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1 x 10 <sup>3</sup>	1 p. 4	2.59 x 10 <sup>8</sup>	2 p. 8	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	3.4 x 10 <sup>4</sup>	1 p. 4				
Location: Elect. Pen. Area (Zone ET-3A) Rad Zone: Elect. Pen. Area (Zone ET-3B)	Aging (°F/Years)	98/40	1 p. 4	194/40 (90°C)	2 p. 6	Test	None
Lowest Elevation: (-)16'8" Flood Level: N/A Above Flood Level: N/A	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-34385-01, AMP Qualification Test Report #110-11004.
3. Seabrook Station, E.Q. File No. 118-01-01, Assessment Checklist No. 8, Note 3.
4. SBU-96263, Seabrook Station "Flooding Study Matrix."

Notes:

1. There is no separate I.D. No. for these AMP terminals. The terminals are used in the interconnection of cables in power, control and instrumentation circuits.
2. All postulated accident parameters are considered mild except radiation.

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 118-01-01

Prepared By: Bruce A. Morse Date: 4/1/86  
Checked By: Jim Buckley Date: 4/21/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.:	Operating Time	1 year	1 p. 1	1 year	3	Test and Analysis	None
Equipment ID No(s).: Note 1	Peak Temperature (°F)	375	1 p. 1	392	2 Add. #1 p. 4	Test and Analysis	None
Equipment Type: Triax and Coax Connectors	Peak Pressure (Psig)	60	1 p. 1	120	2 Add. #1 p. 4	Test	None
Manufacturer: Amphenol	Relative Humidity (%)	100	1 p. 1	100	2 Add. #1 p. 4	Test	None
Model Number: Amphenol Jack 52975-1001, 35500-1000 Amphenol Plug 53175-1004, 34500-1000	Chemical Spray (pH)	Boric Acid 1.2% by wt. pH 7.5 - 10.5	1 p. 1	Boric Acid 2.28% by wt. pH 10.5	2 Add. #1 p. 4	Test	None
Accuracy: Spec: Note 2 Demon:	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>7</sup>	1 p. 1	2.55 x 10 <sup>8</sup>	2 Add. #1 p. 3	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	1.04 x 10 <sup>8</sup>	1 p. 1				
Location: Containment (Zones CS-10, -12) Rad Zone: Containment (Zones CS-10, -12)	Aging (°F/Years)	120/40	1 p. 1	150.11/40 (65.62°C)	2 Add. #1 p. 3	Test and Analysis	None
Lowest Elevation: (-)15'-8" Flood Level: (-)20'-8" Above Flood Level: Yes	Submergence	N/A	6	N/A	N/A	N/A	N/A

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-32287-04, Qualification Report for a Triax (Coax) connector for use in Seabrook Station Units 1 and 2 following the guidelines of IEEE Standard 323-1974 and 317-1976.
3. Impell Calculation No. 0570-032-125.
4. Seabrook E.Q. File No. 118-01-01, Assessment Checklist No. 9, Note 6.
5. Seabrook E.Q. File No. 118-01-01, Assessment Checklist No. 9, Note 3.
6. SBU-96263, Seabrook Flooding Study Matrix.

Notes:

1. There is no specific I.D. Nos. for this component. These plugs and jacks are used for interconnection of triax and coax cables inside and out of containment.
2. For specified and demonstrated accuracy, refer to Seabrook Station E.Q. File No. 118-01-01, Assessment Checklist No. 9, Note 5.



Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 170-13-01

Prepared By: Ray A. Moore Date: 4/10/86  
Checked By: Jim Buckley Date: 4/10/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-170-0013	Operating Time	1 Year	1 p. 1	1 Year	4	Test and Analysis	None
Equipment ID No(s): NI-NE-6690 NI-NE-6691 EDE-TBX-XP8 EDE-TBX-XP9	Peak Temperature (°F)	375	1 p. 1	420	2 p. 12 3 p. 4-4	Test	None
Equipment Type: Neutron Flux Monitoring System	Peak Pressure (Psig)	60	1 p. 1	70	2 p. 12 3 p. 4-4	Test	None
Manufacturer: Gamma-Metrics	Relative Humidity (%)	100	1 p. 1	100	3 p. 4-1	Test	None
Model Number: RCS Series, Model Nos. 200113-107, 108 200289-101, 103	Chemical Spray (pH)	Boric Acid 1.2% by wt. pH 7.5-10.5	1 p. 1	Boric Acid 1.7% by wt. pH 10.5	2 p. 12 5	Test	None
Accuracy:Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2 x 10 <sup>7</sup>	1 p. 1	2.0 x 10 <sup>8</sup>	2 p. 45 Note 2	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	1.04 x 10 <sup>8</sup>	1 p. 1				
Location: Containment (All Zones) Rad Zone: Containment (General Area/Not Submerged)	Aging (°F/Years)	120/40	1 p. 1	120/5	2 p. 27 Note 1	Test	None
Lowest Elevation: (-) 32'6" Flood Level: (-) 20'--8" Above Flood Level: No Note 2	Submergence	1 Year	5	1 Year	7	N/A	N/A

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Revision 17, 7/22/85.
2. FP-73326-01, Qualification Test Report for the RCS Series Neutron Flux Monitoring System, Test Report No. 010, Revision 0, dated April, 1983.
3. FP-73327-01, Seismic and MSLB/LOCA Test Report for the RCS Series Neutron Flux Monitoring System, Wyle Test Report No. 58826.
4. Impell Calculation No. 0570-032-016, Revision 0.
5. Seabrook E.Q. File No. 170-13-01, Assessment Checklist, Note 5.
6. SBU-96263, UE&C Flooding Matrix.
7. Seabrook E.Q. File No. 170-13-01, Assessment Checklist, Note 10.

Notes:

1. The limiting component is the Junction Box, the connectors and coaxial cables. All other components of the assembly are qualified for 40 years except O-ring, which has a qualified life of 5 years.
2. The lower part of the detector and a portion of the cable assembly are the only items submerged.

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 174-00-01

Prepared By: Jim Buckley Date: 4/30/86  
 Checked By: Buy A. More Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-174-00	Operating Time	100 Days	7	100 Days	3	Test and Analysis	None
Equipment ID No(s): RH-FT-618, RH-FT-619, SI-FT-918, SI-FT-922, CBS-PT-2312, CBS-PT-2313, CBS-PT-2314, CBS-PT-2315, CC-FT-2103, CC-FT-2203, SI-FT-917, SW-FT-6181, SW-FT-6191	Peak Temperature (°F)	196	1 p. 4	350	2 Sect. X p. X-70	Test	None
Equipment Type: Flow/Pressure Transmitter	Peak Pressure (Psig)	1.01	1 p. 4	85	2 Sect. X p. X-70	Test	None
Manufacturer: Foxboro Co.	Relative Humidity (%)	100	1 p. 4	100	2 Sect. X p. X-70	Test	None
Model Number: N-E10 Series	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: (N-E11GM) (N-E13DM) Spec: 9.44% 9.11% Demon: 9.44% 9.11%	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>7</sup>	1 p. 2	2.0 x 10 <sup>8</sup>	2, p. iii Sect. IX p. IX-2, -6	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	7.5 x 10 <sup>7</sup>	1 p. 2				
Location: Equipment Vault (EV-1A/EV-6A) Rad Zone: Mech. Penet. Area (MPA-1)	Aging (°F/Years)	104/40	1 p. 1	104/22.2	2 p. ix 5	Test and Analysis	None
Lowest Elevation: (-)56'-0" Flood Level: (-)55'11" Above Flood Level: No Note 1	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-73912-01, Wyle Report #45592-4, Foxboro N-E10 Series Pressure Transmitters, 5/18/83.
3. Impell Calculation No. 0570-032-092.
4. SBU-96263, UE&C Flooding Study Matrix, 10/25/85.
5. PSNH, Seabrook E.Q. File No. 174-00-01, Assessment Checklist, Note 5.
6. PSNH, Seabrook E.Q. File No. 174-00-01, Assessment Checklist, Note 7.
7. SBN-988, E.Q.; Post Accident Operating Time, dated 4/3/86.

Notes:

1. All equipment is above postulated flood levels except RH-FT-618 and 619 and CBS-PT-2314. Justification for not addressing submergence for these I.D.'s is given in Reference 6.

Public Service Company of New Hampshire  
 Seabrook Station  
 Docket: 50-443

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 174-14-01

Prepared By: Greg Adams Date: 4/18/86  
 Checked By: Jim Buckley Date: 4/19/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-174-14	Operating Time	1 year	1 p. 1	1 year	3	Test and Analysis	None
Equipment ID No(s): MM-TE-1000A, 1000B, 1001A, 1001B, 1002A, 1002B, 1003A, 1003B, 1004A, 1004B, 1005A, 1005B CC-TE-2171, CC-TE-2271	Peak Temperature (°F)	229	1 p. 3	485	2 Vol. 1 p. 70	Test	None
Equipment Type: Temperature Elements	Peak Pressure (Psig)	1.0	1 p. 2	84.7	2 Vol. 1 p. 70	Test	None
Manufacturer: Weed	Relative Humidity (%)	100	1 p. 3	100	2 Vol. 1 p. 70	Test	None
Model Number: N-9015S-E, NE4B250G- 18.75AS	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: +10°F Demon: ±10°F	40 Year Normal Radiation Dose (Rads)	2 x 10 <sup>7</sup>	1 p. 3	3.03 x 10 <sup>8</sup>	2 Vol. 1 p. 73	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	3.4 x 10 <sup>7</sup>	1 p. 3				
Location: Prim. Aux. Bldg. (Zone PB-21) Rad Zone: Prim. Aux. Bldg. (Zone PB-21)	Aging (°F/Years)	104/40	1 p. 3	104/40	2 Vol. 1, p. 8 4	Test and Analysis	None
Lowest Elevation: (-)19'-9" Flood Level: (-)25'-11" Above Flood Level: Yes Note 1	Submergence	N/A	5	N/A	N/A	N/A	None

Documentation References:

- 1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
- 1. FP-93869-01, NTS Report Number 548-8854-2, Rev. B, dated 10/21/82 (Three Volumes).
- 1. Impell Calculation No. 0570-032-093.
- 1. Seabrook EQ File No. 174-14-01, Note 4 of Assessment Checklist.
- 1. SBU-96263, UE&C Flooding Study Matrix.

Notes:

- 1. Lowest elevation and flood level given represents the worst case based in the actual location of the I.D. Nos. listed.

Public Service Company of New Hampshire  
 Seabrook Station  
 Docket: 50-443

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 174-14-01

Prepared By: Jim A. Moore Date: 7/18/86  
 Checked By: Jim Buckley Date: 8/18/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-174-14	Operating Time	1 year	1 p. 1	1 year	3	Test and Analysis	None
Equipment ID No(s).: RH-TE-604, 605	Peak Temperature (°F)	167	1 p. 2	485	2 Vol. 1 p. 70	Test	None
Equipment Type: Temperature Elements	Peak Pressure (Psig)	1.0	1 p. 2	84.7	2 Vol. 1 p. 70	Test	None
Manufacturer: Weed	Relative Humidity (%)	100	1 p. 2	100	2 Vol. 1 p. 70	Test	None
Model Number: 612	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: +10°F Demon: ±10°F	40 Year Normal Radiation Dose (Rads)	2 x 10 <sup>7</sup>	1 p. 2	3.03 x 10 <sup>8</sup>	2 Vol. 1 p. 73	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	3.9 x 10 <sup>7</sup>	1 p. 2				
Location: Mech. Penet. Area (MPA-3) Rad Zone: Mech. Penet. Area (MPA-1)	Aging (°F/Years)	104/40	1 p. 2	104/40	2 Vol. 1, p. 8 4	Test and Analysis	None
Lowest Elevation: (-)18'0" Flood Level: (-)25'11" Above Flood Level: Yes	Submergence	N/A	5	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-93869-01, NTS Report Number 548-8854-2, Rev. B, dated 10/21/82 (Three Volumes).
3. Impell Calculation No. 0570-03-093.
4. Seabrook EQ File No. 174-14-01, Note 4 of Assessment Checklist.
5. SBU-96263, UE&C Flooding Stud Matrix.

Notes:

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 174-15-01

Prepared By: Suzanne M... Date: 7/23/86  
Checked By: Jim Buckley Date: 8/23/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-174-15	Operating Time	1 year	1 p. 1	1 year	2 p. XII-7 3	Test and Analysis	None
Equipment ID No(s).: CBS-LE-2384-1 CBS-LE-2384-2 CBS-LE-2385-1 CBS-LE-2385-2	Peak Temperature (°F)	375	1 p. 1	400	2 p. XII-7	Test	None
Equipment Type: Level Transmitter	Peak Pressure (Psig)	60	1 p. 1	66	2 p. XII-7	Test	None
Manufacturer: Transamerican Delavel Gems Sensor Division	Relative Humidity (%)	100	1 p. 1	100	2 p. XII-3	Test	None
Model Number: XM-54852 XM-54853	Chemical Spray (pH)	Boric Acid 1.2% pH 7.5	1 p. 1	Boric Acid 1.72% pH 8.5 - 11.0	2 p. XII-1, XII-4 4	Test	None
Accuracy Spec: + 3% Demon: ± 3%	40 Year Normal Radiation Dose (Rads)	2 x 10 <sup>7</sup>	1 p. 1	2.0 x 10 <sup>8</sup>	2 p. II-3	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	1.04 x 10 <sup>8</sup>	1 p. 1				
Location: Containment Bldg. CS-10 Rad Zone: Containment Bldg. (General Area/ Not Submerged)	Aging (°F/Years)	120/40	1 p. 1	120/40	2 3	Test and Analysis	None
Lowest Elevation: (-)21'-2 5/8" Flood Level: (-)20'8" Above Flood Level: No Note 1	Submergence	1 Year	5	1 Year	6	Test and Analysis	None

Notes:

- Documentation References:
1. UE&C Drawing No. 9763-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
  2. Wyle Laboratories Test Report No. 45700-2, dated 12/14/82.
  3. Impell Calculation 0570-032-067.
  4. Seabrook Station Equipment Qualification File No. 174-15-01, Checklist Note 6.
  5. SBU-96263, Seabrook Station Flooding Study Matrix.
  6. Seabrook Station E.Q. File No. 174-15-01, Checklist Note 11.
1. Equipment I.D. Nos. CBS-LE-2384-1 and CBS-LE-2385-1 only are submerged.

2

QUALIFICATION EVAL    JN WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 248-36-01

Prepared By: Jim Buckley    Date: 4/22/86  
Checked By: Doug Moore    Date: 4/22/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-248-36	Operating Time	61 minutes	3	4 hours	2 p. 97 (Fig. 3)	Test	None
Equipment ID No(s): FW-V-30 FW-V-39 FW-V-48 FW-V-57 Note 2	Peak Temperature (°F)	325	1 p. 2	390	2 p. 97 (Fig. 3)	Test	None
Equipment Type: Hydraulic Operator	Peak Pressure (Psig)	4.8	1 p. 2	110	2 p. 97 (Fig. 3)	Test	None
Manufacturer: Borg-Warner Corporation	Relative Humidity (%)	100	1 p. 2	100	2 p. 38	Test	None
Model Number: 37951	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1.0 x 10 <sup>3</sup>	1 p. 2	1.2 x 10 <sup>6</sup>	2 p. 46	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	8.2 x 10 <sup>4</sup>	1 p. 2				
Location: MS & FW Pipe Chases (PCW-1/PCE-1) Rad Zone: MS & FW Pipe Chases (PCW-1/PCE-1)	Agfng (°F/Years)	130/40	1 p. 2	130/1.12	5	Test and Analysis	None
Lowest Elevation: 11'0" Flood Level: 5'5" Above Flood Level: Yes Note 1	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-23756-02, Borg-Warner Report #2064, Rev. A, 8/2/85.
3. SB-20692 PSNH Letter to N. Woodward (Impell) from T.C. Tillman and J.W. Stacey (YAEC), dated 4/10/86.
4. SBU-96263, UE&C Flooding Study Matrix, 10/25/85.
5. PSNH, Seabrook EQ File No. 248-36-01, Assessment Checklist No. 1, Note 6a.

Notes:

1. The lowest elevation and flood level represent the worst-case for the location of the equipment I.D. Nos. listed and those in Note 2.
2. Equipment I.D. #FW-FY-V1A1, -V2B1, -V3A1, -V4B1; -V1A2, -V2B2, -V3A2, -V4B2; -V1A3, -V2B3, -V3A3, -V4B3; -V1A4, -V2B4, -V3A4, -V4B4 are for actuation and #FW-PS-PS1A1, -PS1B1; -PS1A2, -PS1B2; -PS1A3, -PS1B3; -PS1A4, -PS1B4 are for closing within the operator.

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-248-36	Operating Time	61 minutes	3	4 hours	2 p. 97 (Fig. 3)	Test	None
Equipment ID No(s): FW-2S-PS3B1 FW-2S-PS3B2 FW-2S-PS3B3 FW-2S-PS3B4 Note 2	Peak Temperature (°F)	325	1 p. 2	390	2 p. 97 (Fig. 3)	Test	None
Equipment Type: Limit Switch	Peak Pressure (Psig)	4.8	1 p. 2	110	2 p. 97 (Fig. 3)	Test	None
Manufacturer: Namco Controls	Relative Humidity (%)	100	1 p. 2	100	2 p. 38	Test	None
Model Number: EA 170	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1.0 x 10 <sup>3</sup>	1 p. 2	1.2 x 10 <sup>6</sup>	2 p. 46	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	8.2 x 10 <sup>4</sup>	1 p. 2				
Location: MS & FW Pipe Chases (PCW-1/PCE-1) Rad Zone: MS & FW Pipe Chases (PCW-1/PCE-1)	Aging (°F/Years)	130/40	1 p. 2	130/1.12	5	Test and Analysis	None
Lowest Elevation: 11'0" Flood Level: 5'5" Above Flood Level: Yes Note 1	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-23756-02, Borg-Warner Report #2064, Rev. A, 8/2/85.
3. SB-20692 PSNH Letter to N. Woodward (Impell) from T.C. Tillman and J.W. Stacey (YAEC), dated 4/10/86.
4. SBU-96263, UE&C Flooding Study Matrix, 10/25/85.
5. PSNH, Seabrook EQ File No. 248-36-01, Assessment Checklist No. 1, Note 6b.

Notes:

1. The lowest elevation and flood level represent the worst-case for the location of the equipment I.D. Nos. listed.
2. This equipment is tested as part of Borg-Warner Mod. #37951 Hydraulic Operator.

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 248-36-01

Prepared By: Jim Buckley Date: 4/22/86  
 Checked By: By A. Howe Date: 4/22/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-248-36	Operating Time	1 year	1 p. 1	1 year	3	Test and Analysis	None
Equipment ID No(s): FW-ZS-PS3A1 FW-ZS-PS3A2 FW-ZS-PS3A3	Peak Temperature (°F)	325	1 p. 2	374	2 p. 10-14	Test	None
Equipment Type: Limit Switch	Peak Pressure (Psig)	4.8	1 p. 2	100	2 p. 10-14	Test	None
Manufacturer: Namco Controls	Relative Humidity (%)	100	1 p. 2	100	2 p. 10-14	Test	None
Model Number: EA 180	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1.0 x 10 <sup>3</sup>	1 p. 2	2.04 x 10 <sup>8</sup>	2 p. 10-5	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	8.2 x 10 <sup>4</sup>	1 p. 2				
Location: MS & FW Pipe Chases (PCW-1/PCE-1) Rad Zone: MS & FW Pipe Chases (PCW-1/PCE-1)	Aging (°F/Years)	130/40	1 p. 2	130/5.5	2 p. 4-12 (Fig. 8)	Test and Analysis	None
Lowest Elevation: 11'0" Flood Level: 5'5" Above Flood Level: Yes	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. Namco Test Report #QTR105 for Namco Limit Switches EA 180 (Mfgd. after 2/80) Rev. 4, 1/9/84.
3. Impell Calculation No. 0570-032-105, Rev. 0.
4. SBU-96263, UE&C Flooding Study Matrix, 10/25/85.

Notes:



Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 248-36-01

Prepared By: Jim Buckley Date: 4/22/86  
Checked By: Ray A. Mon Date: 4/22/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-248-36	Operating Time	1 year	1 p. 1	1 Year	3	Test and Analysis	None
Equipment ID No(s).: FW-ZS-PS3A4	Peak Temperature (°F)	325	1 p. 2	348	2 App. D p. 8	Test	None
Equipment Type: Limit Switch	Peak Pressure (Psig)	4.8	1 p. 2	125	2 App. D p. 8	Test	None
Manufacturer: Namco Controls	Relative Humidity (%)	100	1 p. 2	100	2 p. 8 of 11	Test	None
Model Number: EA-180	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Denom: N/A	40 Year Normal Radiation Dose (Rads)	1.0 x 10 <sup>3</sup>	1 p. 2	2.04 x 10 <sup>8</sup>	2 p. 4 of 11 App. A	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	8.2 x 10 <sup>4</sup>	1 p. 2				
Location: MS & FW Pipe Chase (PCW-1) Rad Zone: MS & FW Pipe Chase (PCW-1)	Aging (°F/Years)	130/40	1 p. 2	130/.839	5	Test and Analysis	None
Lowest Elevation: 11'-0" Flood Level: 5'-5" Above Flood Level: Yes	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. ACCC Report Qualification of Namco Controls Limit Switch Model EA-180, Rev. 1, Sept. 5, 1978.
3. Seabrook E.Q. File No. 248-36-01, Assessment Checklist No. 3, Note 12.
4. SBU-96263, Flooding Study Matrix.
5. Seabrook E.Q. File No. 248-36-01, Assessment Checklist No. 3, Note 6.

Notes:

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 248-38-01

Prepared By: Jim Buckley Date: 4/30/86  
Checked By: Buy A. Moore Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-248-38	Operating Time	1 year	1 p. 1	1 year	4	Test and Analysis	None
Equipment ID No(s): MSD-V-44 MSD-V-45 MSD-V-46 MSD-V-47 Note 2	Peak Temperature (°F)	325	1 p. 2	385	5 Figure 2 9	Test	None
Equipment Type: Valve Actuator	Peak Pressure (Psig)	4.8	1 p. 2	66	5 Figure 2	Test	None
Manufacturer: Limatorque	Relative Humidity (%)	100	1 p. 2	100	3 p. 18	Test	None
Model Number: SMB-000-2	Chemical Spray (pH)	N/A	N/A	Boric Acid 1.72 % by wt. pH 10.5 - 11.1	3 p. 17 7	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1 x 10 <sup>3</sup>	1 p. 2	2.04 x 10 <sup>8</sup>	3 p. 12 and Appendix C	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	8.2 x 10 <sup>4</sup>	1 p. 2				
Location: Main Steam FW Pipe Chase (PCE-1, PCW-1) Rad Zone: Main Steam FW Pipe Chase (PCE-1, PCW-1)	Aging (°F/Years)	130/40	1 p. 2	(Note 1) 130/40	2 p. 10	Test and Analysis	None
Lowest Elevation: 6'0" Flood Level: 5'5" Above Flood Level: Yes	Submergence	N/A	6	N/A	N/A	N/A	None

Documentation References:

Notes:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-93952-01, Limatorque Report B0058, Rev. 0, 1/11/80.
3. FP-91743-02, Limatorque Report 600456, Rev. 0, 12/9/75.
4. Impell Calculation 0570-032-075.
5. FP-51935-01, Limatorque Report B0027, Rev. A, 10/18/78.
6. SBU-96263, Seabrook Station Flooding Study Matrix.
7. Seabrook E.Q. File No. 248-38-01, Assessment Checklist No. 1, Note 9.
8. Seabrook E.Q. File No. 248-38-01, Assessment Checklist No. 1, Note 8.
9. Seabrook E.Q. File No. 248-38-01, Assessment Checklist No. 1, Note 1.

1. Although the qualified life as per thermal and radiation aging is 40 years, the number of mechanical cycles done during the test limits the qualified life to 16.78 years (Reference 8).
2. Equipment I.D. Nos. MSD-ZS-44, 45, 46 and 47 are for the integral position indication within these actuators.

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 248-38-01

Prepared By: James Buckley Date: 9/2/86

Checked By: Dug A. Mann Date: 4/2/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-248-38	Operating Time	1 Year	1 p. 1	1 Year	3	Test and Analysis	None
Equipment ID No(s): Note 1	Peak Temperature (°F)	325	1 p. 2	325	2 App. E Figure 4 4	Test and Analysis	None
Equipment Type: Terminal Blocks	Peak Pressure (Psig)	4.8	1 p. 2	70	2 App. E Figure 4	Test	None
Manufacturer: Marathon, GE, Buchanan, Curtis	Relative Humidity (%)	100	1 p. 2	100	2 Para. 3.4.2	Test	None
Model Number: Marathon 300 & 1600, Buchanan 0222 & 0524, GE EBS, Curtis Type "L"	Chemical Spray (pH)	N/A	N/A	Boron Acid 1.65% by Wt. pH 11.2	2 App. I 7	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1 x 10 <sup>3</sup>	1 p. 2	2.04 x 10 <sup>8</sup>	2 Para. 3.2	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	8.2 x 10 <sup>4</sup>	1 p. 2				
Location: Main Steam FW Pipe Chase PCE-1, PCW-1 Rad Zone: Main Steam FW Pipe Chase PCE-1, PCW-1	Aging (°F/Years)	130/40	1 p. 2	130/40	2 App. A 5	Test and Analysis	None
Lowest Elevation: 6'-0" Flood Level: 5'-5" Above Flood Level: Yes	Submergence	N/A	6	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, 7/22/85.
2. Limitorque Test Report No. 80119, Qualification Type Test Report of Multipoint Terminal Strips for use in Limitorque Valve Actuators for PWR Service.
3. Impell Calculation No. 0570-032-
4. Seabrook E.Q. File No. 248-38-01, Assessment Report No. 2, Note 2.
5. Seabrook E.Q. File No. 248-38-01, Assessment Report No. 2, Note 6.
6. SBU-96263, Seabrook Flooding Study Matrix.
7. Seabrook E.Q. File No. 248-38-01, Assessment Report No. 2, Note 8.

Notes:

1. The terminal blocks are used as a component of Limitorque Actuators and do not have a separate I.D. No. I.D. Nos. are listed in QEW Sheet 1.

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-248-38	Operating Time	1 Year	1 p. 1	1 Year	3	Test and Analysis	None
Equipment ID No(s).: Note 1	Peak Temperature (°F)	325	1 p. 2	341	2, p. 72 7, p. 4 4	Test and Analysis	None
Equipment Type: Cable	Peak Pressure (Psig)	4.8	1 p. 2	107	2 p. 72	Test	None
Manufacturer: Rockbestos	Relative Humidity (%)	100	1 p. 2	100	2 p. 72	Test	None
Model Number: Rockbestos Firewall SIS Wire (Chemically XLPE)	Chemical Spray (pH)	N/A	N/A	Boric Acid 1.7% by wt. pH 11.7	2 p. 79 5	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1 x 10 <sup>3</sup>	1 p. 2	2.04 x 10 <sup>8</sup>	2 p. 10	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	8.2 x 10 <sup>4</sup>	1 p. 2				
Location: Main Steam FW Pipe Chase PCE-1, PCW-1 Rad Zone: Main Steam FW Pipe Chase PCE-1, PCW-1	Aging (°F/Years)	130/40	1 p. 2	194/40	2 p. 49	Test and Analysis	None
Lowest Elevation: 6'-0" Flood Level: 5'-5" Above Flood Level: Yes	Submergence	N/A	6	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, 7/22/85.
2. Rockbestos Test Report No. QR#5804, 9/13/85.
3. Impell Calculation No. 0570-032-
4. Seabrook E.Q. File No. 248-38-01, Assessment Report No. 3, Note 2.
5. Seabrook E.Q. File No. 248-38-01, Assessment Report No. 3, Note 5.
6. SBU-96263, Seabrook Flooding Study Matrix.
7. FP-91935-01, Limitorque Valve Actuators Temperature Related to High Superheat Ambient Temperatures.

Notes:

1. The Firewall SIS wires are used as a component of Limitorque Actuators covered under EQ File 248-38-01. There is no separate I.D. for the cables.

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-248-38	Operating Time	1 Year	1 p. 1	1 Year	3	Test and Analysis	None
Equipment ID No(s): Note 1	Peak Temperature (°F)	325	1 p. 2	341	2, p. 65 7, p. 4 4	Test and Analysis	None
Equipment Type: Cable	Peak Pressure (Psig)	4.8	1 p. 2	117	2 p. 65	Test	None
Manufacturer: Rockbestos	Relative Humidity (%)	100	1 p. 2	100	2 p. 65	Test	None
Model Number: Rockbestos Firewall SIS Wire (Irradiation XLPE)	Chemical Spray (pH)	N/A	N/A	Boric Acid 1.7% by wt. pH 9.6	2 p. 64 5	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	$1 \times 10^3$	1 p. 2	$2.00 \times 10^8$	2 p. 10	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	$8.2 \times 10^4$	1 p. 2				
Location: Main Steam FW Pipe Chase PCE-1, PCW-1 Rad Zone: Main Steam FW Pipe Chase PCE-1, PCW-1	Aging (°F/Years)	130/40	1 p. 2	194/40	2 p. 42	Test and Analysis	None
Lowest Elevation: 6'-0" Flood Level: 5'-5" Above Flood Level: Yes	Submergence	N/A	6	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, 7/22/85.
2. Rockbestos Test Report No. QR#5805, 9/13/85.
3. Impell Calculation No. 0570-032-
4. Seabrook E.Q. File No. 248-38-01, Assessment Report No. 4, Note 2.
5. Seabrook E.Q. File No. 248-38-01, Assessment Report No. 4, Note 5.
6. SBU-96263, Seabrook Flooding Study Matrix.
7. FP-91935-01, Limitorque Valve Actuators Temperature Related to High Superheat Ambient Temperatures.

Notes:

1. The Firewall SIS wires are used as a component of Limitorque Actuators covered under EQ File 248-38-01. There is no separate I.D. for the cables.

QUALIFICATION EVA ON WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 252-16-01

Prepared By: Ray A. Morse Date: 4/1/86  
Checked By: Jim Buckley Date: 4/14/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: NSS-325	Operating Time	1 year	1 p. 1	1 year	3	Test and Analysis	None
Equipment ID No(s).: RH-FIS-610 RH-FIS-611	Peak Temperature (°F)	189	1 p. 4	370	2 Vol. 3 V-49	Test	None
Equipment Type: Differential Pressure Switch	Peak Pressure (Psig)	1.01	1 p. 4	82	2 Vol. 3 V-50	Test	None
Manufacturer: ITT Barton	Relative Humidity (%)	100	1 p. 4	100	2 Vol. 3 p. V-48, 49, 50	Test	None
Model Number: 581A-0	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: 9.2% Demon: 9.2%	40 Year Normal Radiation Dose (Rads)	$4.7 \times 10^6$	1 p. 4	$2.0 \times 10^8$	2 Vol. 2 Appendix II Section C pp. 5, 6	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	$9.6 \times 10^6$	1 p. 4				
Location: Equipment Vault EV-1A, 1B Rad Zone: Equipment Vault EV-1A, 1B	Aging (°F/Years)	104/40	1 p. 3	104/20	2 Vol. 1 Sec. 3.1.B1 (p. 10)	Test	None
Lowest Elevation: (-)57'0" Flood Level: (-)55'11" Above Flood Level: No Note 1	Submergence	N/A	4	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Revision 17, dated 7/22/85.
2. FP-73500-01, ITT Barton Qualification Test Report #R3-580A-9, ITT Barton 580A Series Differential Pressure Switches, dated 12/22/83, Volumes 1 through 4.
3. Seabrook E.Q. File No. 252-16-01, Assessment Checklist, Note 9.
4. SBU-96263, UE&C Letter, "Flooding Study Matrix".
5. Seabrook E.Q. File No. 252-16-01, Assessment Checklist, Note 8
6. FP-73645-01, Engineering Report #R3-580A-15, dated 1/30/84.

Notes:

1. Equipment I.D. No. RH-FIS-610 is submerged. However, justification for not addressing submergence is provided in Reference 5.

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-252-16	Operating Time	1 year	1 p. 1	1 year	3	Test and Analysis	None
Equipment ID No(s).: COP-PDS-1788 COP-PDS-1789	Peak Temperature (°F)	158	1 p. 3	180	4 p. 1-2	Test	None
Equipment Type: Differential Pressure Switch	Peak Pressure (Psig)	.5	1 p. 3	5	4 p. 1-2	Test	None
Manufacturer: ITT Barton	Relative Humidity (%)	100	1 p. 3	100	4 p. 1-2	Test	None
Model Number: 581A-1	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1 x 10 <sup>3</sup>	1 p. 3	5.0 x 10 <sup>7</sup>	4 p. 1-2	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	1.8 x 10 <sup>2</sup>	1 p. 3				
Location: Primary Aux. Bldg. PB-3 Rad Zone: Primary Aux. Bldg. PB-3	Aging (°F/Years)	104/40	1 p. 3	104/20	2 Vol. 1 Sec. 3.1.B1 (p. 10)	Test	None
Lowest Elevation: 57'6" Flood Level: (-)21'6" Above Flood Level: Yes	Submergence	N/A	5	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Revision 17, dated 7/22/85.
2. FP-73500-01, ITT Barton Qualification Test Report #R3-580A-9, ITT Barton 580A Series Differential Pressure Switches, dated 12/22/83, Volumes 1 through 4.
3. Impell Calculation No. 0570-032-065, Revision 1.
4. FP-73645-01, Engineering Report #R3-580A-15, dated 1/30/84.
5. SBU-96263, UE&C Letter, "Flooding Study Matrix".

Notes:

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-252-16	Operating Time	1 year	1 p. 1	1 Year	6	Test and Analysis	None
Equipment ID No(s).: CAP-PDSH-5497 CAP-PDSH-5498	Peak Temperature (°F)	129.4	4 Table 1	220	2 Appendix II Section C	Test	None
Equipment Type: Differential Pressure Switch	Peak Pressure (Psig)	N/A	N/A Note 1	3.4	2 Appendix II Section C	Test	None
Manufacturer: ITT Barton	Relative Humidity (%)	N/A	N/A Note 1	100	2 Appendix II Section C	Test	None
Model Number: 581-1	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	1 x 10 <sup>3</sup>	5 pp. 27, 28 Note 1	1.94 x 10 <sup>8</sup>	2, p. 9 Appendix II Section C 3, pp. 3, 9	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	1.8 x 10 <sup>2</sup>	5 pp. 27, 28 Note 1				
Location: Primary Aux. Bldg. (PB-5) Rad Zone: Primary Aux. Bldg. (PB-5)	Aging (°F/Years)	104/40	1 p. 3	104/40	8	Test and Analysis	None
Lowest Elevation: 59'-0" Flood Level: (-)21'-6" Above Flood Level: Yes	Submergence	N/A	7	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. ITT Barton Qualification Test Report No. R3-580-10, ITT Barton Differential Pressure Indicating Switches, Models 580-1 and 581-1, dated 6/2/83.
3. ITT Barton Qualification Test Report No. R3-580-10, Models 580 and 581, Amendment No. 1, September 6, 1983.
4. UE&C Calculation Set No. MSVCS-FAG-08, dated 4/26/85.
5. UE&C Calculation Set No. 4.4.14-70F, Total Integrated Dose Tables, Revision 3, 11/84.
6. Seabrook E.Q. File No. 252-16-04, Assessment Checklist, Note 3.
7. SBU-96263, Seabrook Station Flooding Study Matrix, 10/25/85.
8. Seabrook E.Q. File No. 252-16-04, Assessment Checklist, Note 6.

Notes:

1. Qualification required for LOCA events only. Therefore, the only harsh parameter is temperature for Zones PB-3 and PB-5. To obtain a more accurate value for the TID, doses for areas 19 and 22 from Reference 5 were used, based on specific equipment locations.



Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-252-38	Operating Time	30 Days	5	160 Days	3	Test and Analysis	None
Equipment ID No(s).: EPA-TSH-5430 EPA-TSH-5431 PAH-TSH-5391 PAH-TSH-5393	Peak Temperature (°F)	135	1 p. 3	210	2 p. 22	Test	None
Equipment Type: Temperature Switch	Peak Pressure (Psig)	0.4	1 p. 3	2.0	2 p. 33	Test	None
Manufacturer: ASCO	Relative Humidity (%)	100	1 p. 3	100	2 p. 22	Test	None
Model Number: SALIAQR/QF10A4R	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: 1% of Full Range Value Demon: 1% of Full Range Value	40 Year Normal Radiation Dose (Rads)	4.7 x 10 <sup>6</sup>	1 p. 3	6.47 x 10 <sup>6</sup>	2 App. D, p. 4	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	1.9 x 10 <sup>5</sup>	1 p. 3				
Location: Primary Aux. Building (PB-11) Rad Zone: Primary Aux. Building (PB-11)	Aging (°F/Years)	104/40	1 p. 3	104/12.90	1	Test and Analysis	None
Lowest Elevation: 30'-0" Flood Level: -21'-6" Above Flood Level: YES	Submergence	N/A	4	N/A	N/A	N/A	N/A

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Revision 16, 4/12/85.
2. FP-73561-02, AQR 020184, Revision 1, Report on Qualification of ASCO Tri-point Temperature Switches.
3. Impell Calculation No. 0570-032-072.
4. SBU-96263, Flooding Study Matrix.
5. SBU-19963, PSNH Letter "Qualified Temperature Switches".
6. Seabrook E.Q. File No. 252-38-01, Assessment Checklist Note 2.
7. Seabrook E.Q. File No. 252-38-01, Assessment Checklist Note 14.

Notes:

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 600-01-09

Prepared By: Jim Buckley Date: 4/11/86  
Checked By: Ray A. More Date: 4/11/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-600-01	Operating Time	1 year	1 p. 1	1 Year	4	Test and Analysis	None
Equipment ID No(s).: EDE-SPL-9	Peak Temperature (°F)	375	1 p. 1	442	2 p. 10 (Fig. 6)	Test	None
Equipment Type: Electrical Splices	Peak Pressure (Psig)	60	1 p. 1	132	2 p. 10 (Fig. 6)	Test	None
Manufacturer: Raychem Corporation	Relative Humidity (%)	100	1 p. 1	100	2 pp. 8-10	Test	None
Model Number: WCSF-N S1119	Chemical Spray (pH)	Boric Acid 1.2% by Wt. pH = 7.5 to 10.5	1 p. 1	Boric Acid pH = 10.5	2 p. 8 5	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>8</sup>	1 p. 3 Note 2	2.2 x 10 <sup>8</sup>	2 pp. 6, 16 Table 1	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	----	1 p. 3				
Location: Containment (All zones) Rad Zone: Primary Aux. Bldg. (PB-15A, PB-18)	Aging (°F/Years)	194/40 (90°C)	Note 1	194 (90°C)/40	3 p. 9 (Fig. 2) 2 p. 5, 6, 16 (Table 1)	Test and Analysis	None
Lowest Elevation: Note 3 Flood Level: Above Flood Level: Note 3	Submergence	N/A	7	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. FP-34473-01, Wyle Laboratories Test Report No. 58772-2, dated 11/18/82, Environmental Qualification Test Report of Raychem WCSF-N In-Line Bolted Splice Assemblies for Raychem Corp.
3. FP-34183-01, Raychem Energy Division Report No. EDR-5046, Analysis of Heat Aging Data on WCSF Material to determine pre-aging conditions for Nuclear Qualification Testing, dated 3/4/82.
4. Impell Calculation No. 0570-032-143, Rev. 0.
5. PSNH, Seabrook E.Q. File No. 600-01-09, Assessment Checklist, Note 3.
6. SBU-92605, Letter from UE&C to Impell, dated 2/13/85.
7. SBU-96263, UE&C Letter addressed to YAEC on Flooding Study Matrix, dated 4/9/85.
8. Seabrook Station, E.Q. File No. 600-01-09, Assessment Checklist, Note 7.

Notes:

1. The temperature 194°F (90°C) is consistent with the manufacturer's and Seabrook Class 1E cable specification.
2. The total integrated radiation dose in Environmental Zone PB-4 is greater than 2.0 x 10<sup>8</sup> Rads. No electrical equipment is installed in this area (Reference 6).
3. Verification with respect to whether this splice is submerged subsequent to a design basis event is complete and addressed in Reference 8.

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 600-01-10

Prepared By: Jim Buckley Date: 4/30/86  
Checked By: Ray A. Moore Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-600-01	Operating Time	1 year	1 p. 1	1 Year	7	Test and Analysis	None
Equipment ID No(s): EDE-SPL-10	Peak Temperature	375	1 p. 1	442	2, p. 10(Fig.5) 3, p. 10(Fig.6) 4, p. 10(Fig.6)	Test	None
Equipment Type: Electrical Splices (Hydrogen Recombiner)	Peak Pressure (Psig)	60	1 p. 1	132	2, p. 10(Fig.5) 3, p. 10(Fig.6) 4, p. 10(Fig.6)	Test	None
Manufacturer: Raychem Corporation	Relative Humidity (%)	100	1 p. 1	100	2, p. 10(Fig.5) 3, p. 10(Fig.6) 4, p. 10(Fig.6)	Test	None
Model Number: WCFS-N 502A834-52/144	Chemical Spray (pH)	Boric Acid 1.2% by Wt. pH=7.5 to 10.5	1 p. 1	Boric Acid 1.7% by Wt. pH=10.5	2, p. 9 3, p. 9 4, p. 8 9	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>7</sup>	1 p. 1	2.2 x 10 <sup>8</sup>	2, p.16(Table 1) 3, p.17(Table 1) 4, p.16(Table 1)	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	1.04 x 10 <sup>8</sup>	1 p. 1				
Location: Containment (CS-13)	Aging (°F/Years)	194/40	Note 1	194/40	2, p. 5, 16 3, p. 7, 17 4, p. 5, 16 5, p. 9(Fig. 2) 6, p. 8(Fig. 2)	Test and Analysis	None
Rad Zone: Containment (CS-13)	Submergence	N/A	8	N/A	N/A	N/A	None
Lowest Elevation: 25'-0" Flood Level: (-)20'-8" Above Flood Level: Yes							

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17 dated 7/22/85.
2. FP-34176-01, Wyle Laboratories Test Report No. 58722-1, dated 8/24/82.
3. FP-34474-01, Wyle Laboratories Test Report No. 58722-6, dated 12/21/82.
4. FP-34473-01, Wyle Laboratories Test Report No. 58722-2, dated 11/18/82.
5. FP-34183-01, Raychem Energy Division Report No. EDR-5046, dated 3/4/82.
6. FP-34182-01, Raychem Energy Division Report No. EDR-5040, dated 10/15/81.
7. Seabrook Station, EQ File 600-01-10, Assessment Report, Note 1.
8. SBU-96263, UE&C letter addressed to YAEC on Flooding Study Matrix, dated 10/25/85.
9. Seabrook Station, EQ File 600-01-10, Assessment Report, Note 3.

Notes:

1. The temperature 194°F (90°C) is consistent with the manufacturer's and Seabrook Class 1E cable specification.

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 600-08-01

Prepared By: Ray A. Moore Date: 4/30/86  
Checked By: Jim Buckley Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-600-08	Operating Time	1 year	1 p. 1	1 Year	3	Test and Analysis	None
Equipment ID No(s).: EDE-TERM-2	Peak Temperature	325	1 p. 2	340	7 pp. 5, 6 4	Test	None
Equipment Type: Terminal Blocks	Peak Pressure (Psig)	4.8	1 p. 2	70	2 App. E Figure 4	Test	None
Manufacturer: Marathon	Relative Humidity (%)	100	1 p. 2	100	2 para. 3.4.2	Test	None
Model Number: Marathon 300 Series	Chemical Spray (pH)	N/A	N/A	Boron 2950 mg/L Ph 11.2	2 App. 1	Test	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	2.0 x 10 <sup>8</sup>	1 p. 3	2.04 x 10 <sup>8</sup>	2 para 3.2	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	-----	1 p. 3				
Location: MS & FW Pipe Chase (PCW-1, 2, 3, 5 - PCE-1, 2, 3,) Rad Zone: Primary Aux. Bldg. (Note 1)	Agfng (°F/Years)	130/40	1 p. 3	130/40	2 App. A 9	Test and Analysis	None
Lowest Elevation: Note 2 Flood Level: Note 2 Above Flood Level: Yes	Submergence	N/A	6	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. Limatorque Test Report No. B0119, Qualification Type Test Report of Multipoint Terminal Strips for use in Limatorque Valve Actuators for PWR Service.
3. Seabrook E.Q. File No. 600-08-01, Assessment Report, Note 2.
4. Seabrook E.Q. File No. 600-08-01, Assessment Report, Note 1.
5. Seabrook E.Q. File No. 600-08-01, Assessment Report, Note 7.
6. SBU-96263, Seabrook Flooding Study Matrix.
7. FP-31838-03, Qualification Test Report for Terminations, Terminal Block and Connectors to be used in the Electrical Penetrations of the Seabrook Plants, Test Report #PEN-TR-80-18, Rev. 4.
8. SBU-92605, Letter from UE&C to Impell, dated 2/13/86.
9. Seabrook E.Q. File No. 600-08-01, Assessment Report, Note 4.

Notes:

1. The limiting zones for radiation are PB-15A and PB-18. Environmental zones PB-4 and PB-19 have been excluded since no electrical equipment is installed in these zones (Ref. 8).
2. This is generic equipment which is not qualified for submergence, and is not submerged in the plant in any application where operability is required (Reference 5).

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: NSS-205	Operating Time	1 year	1 p. 1	1 year	4	Test and Analysis	None
Equipment ID No(s).: CS-P-2A CS-P-2B	Peak Temperature (°F)	144	1 p. 3	324	3 p. 15 & 37	Test	None
Equipment Type: Charging Pump Motors 600 HP 4000 V, 1800 RPM	Peak Pressure (Psig)	1.00	1 p. 3	81.9	3 p. 26	Test	None
Manufacturer: Westinghouse	Relative Humidity (%)	100	1 p. 3	100	2 p. 9	Test	None
Model Number: HSW 5B10S Frame	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	$4.7 \times 10^6$	1 p. 3	$2.0 \times 10^8$	3 p. 14 & 16	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	$2.9 \times 10^7$	1 p. 3				
Location: Primary Aux. Bldg. (PB-20A) Rad Zone: Primary Aux. Bldg. (PB-20A)	Aging (°F/Years)	104/40	1 p. 3	248/13.88 (120°C)	5 Note 1	Test and Analysis	None
Lowest Elevation: 9'0" Flood Level: (-)21'-6" Above Flood Level: Yes	Submergence	N/A	6	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. WCAP 8687, Supp. 2-A02A, Environmental, Rev. 2, March 1983.
3. WCAP 7829, Fan Cooler Motor Unit Test, Rev. 0, April 1972.
4. Impell Calculation No. 0570-032-046, Rev. 0
5. PSNH, Seabrook EQ File No. NSS-205-01, Assessment Checklist, Note 1.
6. SBU-96263, Seabrook Station Flooding Study Matrix.

Notes:

1. Qualified life accounts for normal ambient plus heat rise for a continuously running motor.

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: NSS-205	Operating Time	1 year	1 p. 1	1 year	4	Test and Analysis	None
Equipment ID No(s).: RH-P-8A RH-P-8B	Peak Temperature (*F)	189	1 p. 4	324	3 p. 15 & 37	Test	None
Equipment Type: RHR Pump Motors 400 HP, 4000 V, 1800 RPM.	Peak Pressure (Psig)	1.00	1 p. 4	81.9	3 p. 26	Test	None
Manufacturer: Westinghouse	Relative Humidity (%)	100	1 p. 4	100	2 p. 9	Test	None
Model Number: VSWI 5009P39 Frame	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	$4.7 \times 10^6$	1 p. 4	$2.0 \times 10^8$	3 p. 14 & 16	Test	None
	1 Year Accident Radiation Dose (Rads)	$4.7 \times 10^7$	1 p. 4				
Limiting Environment:	Aging (*F/Years)	104/40	1 p. 4	266/6.20 (130°C)	5	Test and Analysis	None
Location: Equipment Vaults (EV-3A) Rad Zone: Equipment Vaults (EV-3A)	Submergence	N/A	6	N/A	N/A	N/A	None
Lowest Elevation: (-)54'6" Flood Level: (-)55'-11" Above Flood Level: Yes							

Documentation References:

1. UE&C Drawing No. 9763-F300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. WCAP 8687, Supp. 2-A02A, Environmental, Rev. 2, March 1983.
3. WCAP 7829, Fan Cooler Motor Unit Test, Rev. 0, April 1972.
4. Impell Calculation No. 0570-032-046, Rev. 0
5. PSNH, Seabrook EQ File No. NSS-205-01, Assessment Checklist, Note 1.
6. SBU-96263, Seabrook Station Flooding Study Matrix.

Notes:

1. Qualified life accounts for normal ambient plus heat rise for a continuously running motor.

QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. NSS-205-01

Prepared By: ASB Date: 10/30/85  
Checked By: [Signature] Date: 10/30/85

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: NSS-205	Operating Time	1 year	1 p. 1	1 year	4	Test and Analysis	None
Equipment ID No(s): SI-P-6A SI-P-6B	Peak Temperature (°F)	189	1 p. 4	324	3 p. 15 & 37	Test	None
Equipment Type: SI Pump Motors 450 HP, 4000 V, 3600 RPM.	Peak Pressure (Psig)	1.00	1 p. 4	81.9	3 p. 26	Test	None
Manufacturer: Westinghouse	Relative Humidity (%)	100	1 p. 4	100	2 p. 9	Test	None
Model Number: HSWI 5808-H Frame	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy: Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	$4.7 \times 10^6$	1 p. 4	$2.0 \times 10^8$	3 p. 14 & 16	Test	None
	1 Year Accident Radiation Dose (Rads)	$3.0 \times 10^7$	1 p. 4				
Limiting Environment:	Aging (°F/Years)	104/40	1 p. 4	104/40	5	Test and Analysis	None
Location: Equipment Vaults (EV-4A) Rad Zone: Equipment Vaults (EV-4A)	Submergence	N/A	6	N/A	N/A	N/A	None
Lowest Elevation: (-)48'6" Flood Level: (-)55'-11" Above Flood Level: Yes							

Documentation References:

1. UE&C Drawing No. 9763-F300219, Service Environment Chart, Rev. 17, dated 7/22/85.
2. WCAP 8687, Supp. 2-A02A, Environmental, Rev. 2, March 1983.
3. WCAP 7829, Fan Cooler Motor Unit Test, Rev. 0, April 1972.
4. Impell Calculation No. 0570-032-046, Rev. 0
5. PSNH, Seabrook EQ File No. NSS-205-01, Assessment Checklist, Note 1.
6. SBU-96263, Seabrook Station Flooding Study Matrix.

Notes:

1. Qualified life is based on normal standby de-energized condition of motor.

ATTACHMENT 3



QUALIFICATION EVALUATION WORK SHEET

Public Service Company of New Hampshire  
Seabrook Station  
Docket: 50-443

EQUIPMENT QUALIFICATION FILE NO. 600-01-04

Prepared By: Jim Buckley Date: 9/30/86  
Checked By: Ray A. Moore Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-600-01	Operating Time	100 Days	9	100 Days	3	Test and Analysis	None
Equipment ID No(s).: EDE-SPL-4	Peak Temperature (°F)	189	1 p. 4	348	2 Att. 4, p. 6	Test	None
Equipment Type: 8 Kv Motor Connection Kit	Peak Pressure (Psig)	1.00	1 p. 4	28	2 Att. 4, p.6	Test	None
Manufacturer: Raychem Corporation	Relative Humidity (%)	100	1 p. 4	100	2 Att. 4, p.3	Test	None
Model Number: NMCK8	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy:Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	4.7 x 10 <sup>6</sup>	1 p.4	5.0 x 10 <sup>7</sup>	2 p.2 & 16	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	2.9 x 10 <sup>7</sup>	6 p. 13				
Location: Equipment Vault (EV-3A)	Aging (°F/Years)	104/40	1 p. 4	104/40	5	Test and Analysis	None
Rad Zone: Equipment Vault (EV-3A)	Submergence	N/A	7	N/A	N/A	N/A	None
Lowest Elevation: Note 1							
Flood Level: (-)55'11"							
Above Flood Level: Note 1							

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 16, dated 4/12/85.
2. FP-34181-01, Raychem Energy Division Report No. EDR-5037, dated 1/15/82.
3. Impell Calculation No. 0570-032-039.
4. Report on Analysis of High Energy Line Break (HELB) Outside Containment, UE&C Report No. 9763-006-S-N-2, dated 3/1/85.
5. PSNH, EQ File No. 600-01-04, Assessment Checklist, Note 1a.
6. UE&C PIN #7737-NA-01200-4-02110113, dated 11/6/84, Total Integrated Radiation Doses.
7. SBU-96263, UE&C Letter addressed to YAEC on Flooding Study Matrix.
8. PSNH, EQ File No. 600-01-04, Assessment Checklist, Note 7.
9. SBN-988, E.Q.; Post Accident Operating Time, dated 4/3/86.

Notes:

1. Equipment where these splice kits have been used are located either above flood level or if located below flood level their failure will not be detrimental to plant safety for the postulated event which causes flooding in that area (Ref. 8).

QUALIFICATION EVALUATION WORK SHEET

EQUIPMENT QUALIFICATION FILE NO. 600-01-04

Prepared By: Jim Buckley Date: 4/30/86  
 Checked By: Aug A. Moore Date: 4/30/86

Equipment Description	Postulated Environment			Qualified Environment		Qualification Method	Outstanding Items
	Parameter	Value	Reference	Value	Reference		
Purchase Order No.: 9763-006-600-01	Operating Time	100 Days	9	100 Days	3	Test and Analysis	None
Equipment ID No(s).: EDE-SPL-4	Peak Temperature (°F)	189	1 p. 4	348	2 Att. 4, p. 6	Test	None
Equipment Type: 8 Kv Motor Connection Kit	Peak Pressure (Psig)	1.00	1 p. 4	28	2 Att. 4, p.6	Test	None
Manufacturer: Raychem Corporation	Relative Humidity (%)	100	1 p. 4	100	2 Att. 4, p.3	Test	None
Model Number: NMCK8	Chemical Spray (pH)	N/A	N/A	N/A	N/A	N/A	None
Accuracy:Spec: N/A Demon: N/A	40 Year Normal Radiation Dose (Rads)	4.7 x 10 <sup>6</sup>	1 p.4	5.0 x 10 <sup>7</sup>	2 p.2 & 16	Test	None
Limiting Environment:	1 Year Accident Radiation Dose (Rads)	2.9 x 10 <sup>7</sup>	6 p. 13				
Location: Equipment Vault (EV-3A) Rad Zone: Equipment Vault (EV-3A)	Aging (°F/Years)	194(90°C)/40	Note 1	194(90°C)/15.92 Note 1	5	Test and Analysis	None
Lowest Elevation: Note 2 Flood Level: (-)55'11" Above Flood Level: Note 2	Submergence	N/A	7	N/A	N/A	N/A	None

Documentation References:

1. UE&C Drawing No. 9763-F-300219, Service Environment Chart, Rev. 16, dated 4/12/85.
2. FP-34181-01, Raychem Energy Division Report No. EDR-5037, dated 1/15/82.
3. Impell Calculation No. 0570-032-039.
4. Report on Analysis of High Energy Line Break (HELB) Outside Containment, UE&C Report No. 9763-006-S-N-2, dated 3/1/85.
5. PSNH, EQ File No. 600-01-04, Assessment Checklist, Note 1b.
6. UE&C PIN #7737-NA-01200-4-02110113, dated 11/6/84, Total Integrated Radiation Doses.
7. SBU-96263, UE&C Letter addressed to YAEC on Flooding Study Matrix.
8. PSNH, EQ File No. 600-01-04, Assessment Checklist, Note 7.
9. SBN-988, E.Q.; Post Accident Operating Time, dated 4/3/86.

Notes:

1. The temperature 194°F (90°C) is consistent with the manufacturer's and Seabrook Class 1E cable specification.
2. Equipment where these splice kits have been used are located either above flood level or if located below flood level their failure will not be detrimental to plant safety for the postulated event which causes flooding in that area (Ref. 8).