

October 17, 1986

Mr. Harold R. Denton, Director Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, DC 20555

Subject: Zion Nuclear Power Station Units 1 and 2

Proposed Amendment to Facility Operating

License Nos. DPR-39 and DPR-48

ASME Section XI

NRC Docket Nos. 50-295 and 50-304

Dear Mr. Denton:

Attachment 1 to this letter is a proposed amendment to Facility Operating License Nos. DPR-39 and DPR-48, Appendix A, Section 3.3.2 (Pressurization and System Integrity) and Section 3.3.4 (Structural Integrity). This change will modify the Zion Technical Specifications to remove references to the initial base line inservice inspection and to a specific version of the ASME Section XI code.

The discussion of the inservice inspection baseline inspection is being deleted because this one-time inspection has been performed. The references to a specific addendum to the ASME Section XI Code are being deleted because they are altered every 10 years in accordance with 10 CFR 50.55a.

Attachment 2 to this letter is a demonstration that the issue involves no significant hazards consideration. The proposed amendment has received On-site and Off-site review and approval.

In accordance with 10 CFR 170, a fee remittance in the amount of \$150.00 is enclosed. As provided by 10 CFR 50.91, the State of Illinois is being notified of this amendment request by transmittal of this letter and the attachments.

Please direct any questions you may have concerning this matter to this office.

8610270454 861017 PDR ADOCK 05000295 PDR

Aou!

Rec'd WICHECK \$15000

Three (3) signed originals and thirty-seven (37) copies of this transmittal and its attachments are provided for your use.

Very truly yours,

P. C. LeBlond

Nuclear Licensing Administrator

lm

Attachments

cc: Region III Inspector - Zion

J. A. Norris - NRR

M. C. Parker - State of Ill.

SUBSCRIBED AND SHORN to before me this / day

- 10 1 1-1

Notary Public