

MAY 05 1986

Docket Nos. 50-245  
50-336

Northeast Nuclear Energy Company  
ATTN: Mr. John F. Opeka  
Senior Vice President - Nuclear  
Engineering and Operations Group  
Post Office Box 270  
Hartford, Connecticut 06141-0270

Gentlemen:

Subject: Inspection 50-245/86-03; 50-336/86-03 (2/25/86 - 4/7/86)

This letter transmits the findings of the routine NRC inspection of Millstone Nuclear Station Units 1 and 2 from February 25 through April 7, 1986. These findings have been discussed with Mr. Romberg of your staff.

No violations were identified. However, Section 8 of the enclosed report identifies an unresolved issue. This involves the disabling of automatic initiation of the Isolation Condenser by closing condensate return valve 1-1C-3 by hand. The closure by hand was not found to have been identified to and appropriately evaluated by site management, possibly because the recommended but not required plant information report was not submitted. Please review the adequacy of your management controls over such activities, and inform me of your planned corrective measures within 30 days of receipt of this letter.

Your cooperation with us is appreciated.

Sincerely,

*Original Signed By:*

Edward C. Wenzinger, Chief  
Projects Branch No. 3  
Division of Reactor Projects

Enclosure: NRC Region I Report 50-245/86-03; 50-336/86-03

cc w/encl:

E. J. Mroczka, Vice President, Nuclear Operations  
W. D. Romberg, Station Superintendent  
D. O. Nordquist, Manager of Quality Assurance  
R. T. Laudenat, Manager, Generation Facilities Licensing  
Gerald Garfield, Esquire  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
State of Connecticut

8605130232 860505  
PDR ADDCK 05000245  
Q PDR

11  
TEO1

MAY 05 1986

Northeast Nuclear Energy Company

2

bcc w/2ncl:

Region I Docket Room (with concurrences)

Director DRS

Director DRS&S

DRP Section Chief

M. McBride, SRI, Pilgrim Nuclear Station

D. Osborne, LPM, NRR

J. Shedlosky, SRI, Millstone 3

A. Rubin, Div. Safety Tech., NRR

J. Shea, LPM, NRR

P. Swetland, SRI, Haddam Neck

J. Durr, Region I

J. Wiggins, Region I

RI:DRP

*[Signature]*  
Rebelowski  
5/1/86

RI:DRP

*[Signature]*  
McCabe  
5/2

RI:DRP

*[Signature]*  
Wenzinger  
5/5/86

*called [Signature] 2:35 PM*

OFFICIAL RECORD COPY