



South Carolina Electric & Gas Company
P.O. Box 88
Jenkinsville, SC 29065
(803) 345-4344

Gary J. Taylor
Vice President
Nuclear Operations

December 19, 1997
RC-97-0257

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Gentlemen:


Subject: VIRGIL C. SUMMER NUCLEAR STATION
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
FOLLOW-UP REPLY TO NOTICE OF VIOLATION
NRC INSPECTION REPORT 50-395/97-02

In the South Carolina Electric & Gas Company (SCE&G) response to the Notice of Violation delineated on NRC Inspection Report 50-395/97-02 dated July 17, 1997, corrective actions were outlined for the Leak Detection system level switches. Section III of Attachment I to the letter stated that level switches identified under design modification MRF 34428 (base package) were scheduled to be replaced by December 31, 1997 to enhance system reliability. That action has been completed.

Since that time, an additional five switches were identified during interface review of Modification Change Notice (MCN) A to MRF 34428 which increased the scope of the level switch upgrade. These additional switches will be replaced with the new design by June 30, 1998.

Should you have any questions, please call at your convenience.


Very truly yours,


Gary J. Taylor

GJT/ljm

9712310032 971219
PDR ADOCK 05000395
G PDR

100034



IEC1/0



NUCLEAR EXCELLENCE - A SUMMER TRADITION!

Document Control Desk
Follow-up to Notice of Violation
Number 50-395/97-02
RC-97-0257
Page 2

c: J. L. Skolds
W. F. Conway
R. R. Mahan
R. J. White
L. A. Reyes
A. R. Johnson
NRC Resident Inspector
Paulette Ledbetter

J. B. Krotts
General Managers
R. B. Clary
S. F. Fipps
NSRC
RTS (IE 970203)
DMS (RC-97-0257)
File (815.01)