

In Reply Refer To:
Docket: 50-298/88-04

JUN - 9 1988

Nebraska Public Power District
ATTN: George A. Trevors
Division Manager - Nuclear Support
P.O. Box 499
Columbus, NE 68601

Gentlemen:

Thank you for your letter of May 9, 1988, in response to our letter and Notice of Violation dated April 7, 1988. We have reviewed your reply and find it responsive to the concerns raised in our Notice of Violation. However, with respect to your request that we reconsider Item A.1 in the statement of violation, it will be necessary that you retain the four replacement diesel generator cooling fan blades which had not been used and were stored in the warehouse. These blades will be reinspected in natural lighting during a subsequent NRC inspection and a determination will be made at that time regarding your request. While no further correspondence regarding Item B is required, we do not consider the violation to be merely the result of a failure to expedite development of a formal procedure, in that the requirements delineated in 10 CFR Part 21 have been in effect since January 6, 1978. We will review the implementation of your corrective actions during a future inspection to determine that full compliance has been achieved and will be maintained.

Sincerely,

Original Signed By
L. J. Callan

L. J. Callan, Director
Division of Reactor Projects

cc:
Cooper Nuclear Station
ATTN: Guy Horn, Division Manager
of Nuclear Operations
P.O. Box 98
Brownville, Nebraska 68321

Kansas Radiation Control Program Director

Nebraska Radiation Control Program Director

RI
LEE E. Pershaw/cz
6/3/88

C:M&QPS
IBarnes
6/3/88

D:DRS
JLMilhoan
6/3/88

C:PSC
EJHoller
6/3/88

D:DRS
LJCallan
6/6/88

8806150223 880609
PDR ADOCK 05000298
Q PDR

1E01
40

bcc to DMB (IE-01)

bcc distrib. by RIV:

RRI
Section Chief (DRP/C)
RPSB-DRSS
RIV File
RSTS Operator
DRS
G. F. Sanborn, EO
I. Barnes

R. D. Martin, RA
Lisa Shea, RM/ALF
MIS System
Project Engineer, DRP/C
W. Long, NRR Project Manager
DRP
L. E. Ellershaw