

**North  
Atlantic**

North Atlantic Energy Service Corporation  
P.O. Box 300  
Seabrook, NH 03874  
(603) 474-9521

The Northeast Utilities System

December 19, 1997

Docket No. 55-443  
NYN-97122

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555


Seabrook Station  
Cycle 6 Core Operating Limits Report, Revision 2

North Atlantic Energy Service Corporation (North Atlantic) has enclosed Revision 2 to the Cycle 6 Core Operating Limits Report (COLR) for Seabrook Station pursuant to Technical Specification 6.8.1.6.c. Changes were made to Figure 2, "Rod Insertion Limits Versus Thermal Power" to allow for deeper insertion of control banks D, C and B at power levels below 50% of rated thermal power.

Should you have any questions regarding this letter, please contact Mr. James M. Peschel, Regulatory Compliance Manager, at (603) 773-7194.

Very truly yours,

NORTH ATLANTIC ENERGY SERVICE CORP.

  
\_\_\_\_\_  
William A. DiProfio  
Station Director

cc: H. J. Miller, Region I Administrator  
C. W. Smith, Project Manager  
R. K. Lorson, Sr. Resident NRC Inspector

5712310263 971219  
PDR ADOCK 05000443  
P PDR

AUDIT



ENCLOSURE 1 TO NYN-97122