



Document Control Desk U. S. Nuclear Regulatory Commission Washington, DC 20555

Attention: Mr. L. M. Padovan

Gentlemen:

Gary 1. Taylor Vice President Nuclear Operations

South Carolina Electric & Gas Co

Virgil C. Summer Nuclear Station

Jenkinsville, South Carolina

P. O. Box 88

803.345.4344

803.345.5209 www.scana.com

29065

Subject:

VIRGIL C. SUMMER NUCLEAR STATION

DOCKET NO. 50/395

OPERATING LICENSE NO. NPF-12

TECHNICAL SPECIFICATION CHANGE REQUEST -

TSP 960005, REVISION 1

CHARCOAL ADSORBER TESTING

Reference:

1. S. A. Byrne (SCE&G) to Ms. Tilda Y. Liu (NRC) letter,

RC-96-0039, dated February 10, 1996

2. G. J. Taylor to Document Control Desk letter,

RC-98-0108, dated May 21, 1997.

NOTE:

This letter supercedes the above previously submitted letter

(Reference 2) to correct information pertaining to the Methyl Iodide Penetration Acceptance Criteria for the charcoal adsorbers of the Spent Fuel Pool Ventilation System.

South Carolina Electric & Gas Company (SCE&G), acting for itself and as agent for South Carolina Public Service Authority, hereby requests an amendment to the Virgil C. Summer Nuclear Station (VCSNS) Technical Specifications (TS). This request is being submitted pursuant to 10 CFR 50.90.

The proposed changes will revise the testing methodology utilized by VCSNS to determine the operability of the charcoal adsorbers in the Engineering Safeguards Features (ESF) air handling units. Technical Specifications 3/4.7.6, "Control Room Normal and Emergency Air Handling System," and 3/4.9.11, "Spent Fuel Pool Ventilation System," charcoal adsorber testing methodology are being changed to reference ASTM D 3803-1989 instead of ANSI N509-1980.

9812140133 981204 PDR ADOCK 05000395 PDR

146006

NUCLEAR EXCELLENCE - A SUMMER TRADITION!

100/

Document Control Desk 709 9600 35, Revision 1 RC-98-0214 Page 2 of 3

Currently, VCSNS tests the charcoal adsorbers in the ESF air handling units per ANSI N509-1980. Although this method of testing provides assurance that the charcoal adsorbers will perform their design function, it is being revised to reflect our statement in the referenced letter (Reference 1) that SCE&G would submit a TS change to implement standard ASTM D 3803-1989.

The TS change request is contained in the following attachments:

Attachment I Explanation of Changes Summary

Marked-up Technical Specification Pages Revised Technical Specification Pages

Attachment II Safety Evaluation

Attachment III No Significant Hazards Evaluation

This proposed amendment has been reviewed and approved by the Plant Safety Review Committee and the Nuclear Safety Review Committee.

These statements and matters set forth herein are true and correct to the best of my knr aledge, information, and belief.

Should you have questions, please call Mr. Jim Turkett at (803) 345-4047.

Very truly yours,

. . . .

Tour he

JT/GJT/dr Attachments (3)

c: J. L. Skolds

W. F. Conway

R. R. Mahan (w/o Attachment)

P J. White

L. A. Reyes

NRC Resident Inspector

Paulett Ledbetter

J. B. Knotts, Jr.

M. K. Batavia

RTS (TSP 960005)

File (813.20)

DMS (RC-98-0214)

Document Control Desk TSP 960005, Revision 1 RC-98-0214 Page 3 of 3

STATE OF SOUTH CAHOLINA

TO WIT :

Document Control Desk Attachment I TSP 960005, Revision 1 RC-97-0214 Page 1 of 2

SCE&G -- EXPLANATION OF CHANGES

Page	Affected Section	Bar #	Description of Change	Reason for Change
3/4 7-15	4.7.6.c.2	1	Replaced "ANSI N 509-1980, at a relative humidity of 70% and 25°C with a methyl iodide penetration of < 1%" with "ASTM D 3803-1989, at a relative humidity of 70% and 30°C with a methyl iodide penetration of < 2.5%."	The proposed change incorporates the statement made in the letter from Mr. S. A. Byrne (SCE&G) to Ms. Tilda Y. Liu (NRC) dated February 10, 1996. The letter stated SCE&G's intent to incorporate ASTM D 3803-1989 into requirements for testing the charcoal adsorber in the ESF air handling units.
3/4 7-15	4.7.6.d	2	Replaced "ANSI N 509-1980, at a relative humidity of 70% and 25°C with a methyl iodide penetration of < 1%" with "ASTM D 3803-1989, at a relative humidity of 70% and 30°C with a methyl iodide penetration of < 2.5%."	The proposed change incorporates the statement made in the letter from Mr. S. A. Byrne (SCE&G) to Ms. Tilda Y. Liu (NRC) dated February 10, 1996. The letter stated SCE&G's intent to incorporate ASTM D 3803-1989 into requirements for testing the charcoal adsorber in the ESF air handling units.
3/4 9-13	4.9.11.b.2	1	Replaced "ANSI N 509- 1980, at a test media temperature of 30°C" with "ASTM D 3803-1989, at a relative humidity of 95% and 30°C with a methyl iodide penetration of < 2.5%."	The proposed change incorporates the statement made in the letter from Mr. S. A. Byrne (SCE&G) to Ms. Tilda Y. Liu (NRC) dated February 10, 1996. The letter stated SCE&G's intent to incorporate ASTM D 3803-1989 into requirements for testing the charcoal adsorber in the ESF air handling units.

Document Control Desk Attachment I TSP 960005, Revision 1 RC-97-0214 Page 2 of 2

Page	Affected Section	Bar #	Description of Change	Reason for Change
3/4 9-13	4.9.11.c	2	Replaced "ANSI N 509- 1980, at a test media temperature of 30°C" with "ASTM D 3803-1989, at a relative humidity of 95% and 30°C with a methyl iodide penetration of < 2.5%."	The proposed change incorporates the statement made in the letter from Mr. S. A. Byrne (SCE&G) to Ms. Tilda Y. Liu (NRC) dated February 10, 1996. The letter stated SCE&G's intent to incorporate ASTM D 3803-1989 into requirements for testing the charcoal adsorber in the ESF air handling units.