

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Clay C. Warren
Chief Operating Officer

December 23, 1997
WO 97-0141

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555


Subject: Docket No. 50-482: Licensee Event Report 97-024-00

Gentlemen:

The attached Licensee Event Report (LER) 97-024-00 is being submitted pursuant to 10 CFR 50.73(a)(2)(iv) concerning Engineered Safety Features and Reactor Protection System actuations. The actuations were caused by a spike on the Ex-Core Neutron Monitoring System Nuclear Instrument NI-35 Intermediate Range Channel.

If you should have any questions regarding this submittal, please contact me at (316) 364-8831 Extension 4485, or Mr. Michael J. Angus at extension 4077.

Very truly yours,



Clay C. Warren

CCW/jad

Attachment

cc: W. D. Johnson (NRC), w/a
E. W. Merschoff (NRC), w/a
J. F. Ringwald (NRC), w/a
K. M. Thomas (NRC), w/a

9801020148 971223
PDR ADOCK 05000482
S PDR

IE2211

310031

