



GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057-0191
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:
(717) 948-8005

May 13, 1992
C311-92-2036

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Dear Sir:

SUBJECT: Three Mile Island Nuclear Generating Station, Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Technical Specification Change Request (TSCR) No. 214
Once Through Steam Generator (OTSG) Primary-to-Secondary Leak
Rate Limit

In accordance with 10 CFR 50.4(b)(1), TSCR No. 214 is forwarded for your approval.

The purpose of this TSCR is to request a change to license condition 2(c)(8)(2). The change increases the allowable primary-to-secondary leakage rate from 0.1 to 0.2 gpm above the baseline leak rate when the increased leakage is judged to be caused by leaking plugs or joints. Under all other conditions, the current 0.1 gpm limit would remain in effect.

Also enclosed is one (1) signed copy of the Certificate of Service for this request to the Chief Executives of the Township and County in which the facility is located, as well as the Commonwealth of Pennsylvania, Bureau of Radiation Protection.


Pursuant to 10 CFR 50.91(a)(1), we have also enclosed an analysis in support of our determination of no significant hazards consideration. Pursuant to 10 CFR 50.91(b) a copy of this letter, the proposed change to the facility operating license and the no significant hazards consideration analysis have been provided to Mr. William P. Dornsife, the designated representative of the Commonwealth of Pennsylvania.

9205190226 920513
PER ADCK 05000289
PDR

A001
111

It is requested that the amendment authorizing this TSCR be issued by July 30, 1992 and be effective upon issuance in order that we may be able to implement the change during the current operating cycle.

Sincerely,



T. G. Broughton
Vice President and Director, TMI-1

EJP/plp

Enclosures

cc: Administrator, Region 1
TMI Senior Resident Inspector
TMI-1 Senior Project Manager