

**Attachment 2**

**GGNS PCOL 97-04, Revision 1**

Revised Mark-up of Affected Technical Specification Page

**Insert A**

5.5.12      10 CFR 50 Appendix J, Testing Program

This program establishes the leakage rate testing program of the containment as required by 10 CFR 50.54 (c) and 10 CFR 50, Appendix J, Option B, as modified by approved exemptions. This program shall be implemented in accordance with the Safety Evaluation issued by the Office of Nuclear Reactor Regulation dated April 26, 1995 (GNRI-95/00087) as modified by the Safety Evaluation issued for Amendment \_\_\_\_\_ to the Operating License. Consistent with standard scheduling practices for Technical Specifications required surveillances, intervals for the recommended surveillance frequency for Type A, B and C testing may be extended by up to 25 percent of the test interval, not to exceed 15 months.