

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station Northeast Nuclear Energy Company P.O. Box 128 Waterford, CT 06385-0128 (860) 447-1791 Fax (860) 444-4277

The Northeast Utilities System

DEC 23 1998

Docket No. 50-336 B17540

Re: 10 CFR 50.73(a)(2)(ii)

U.S. Nuclear Regulatory Commission Document Control Desk Washington, DC 20555

Millstone Nuclear Power Station Unit No. 2
Licensee Event Report 98-012-01
Nonconservative Assumptions in the Facility
Loss of Normal Feedwater Analysis

This letter forwards Licensee Event Report (LER) 98-012-01, documenting a condition that was discovered at Millstone Nuclear Power Station, Unit No. 2, on May 21, 1998. This LER is being submitted pursuant to 10 CFR 50.73(a)(2)(ii). This LER supplement provides an update on the analyses and investigation which was completed for this condition. There are no regulatory commitments contained within this letter.

The Northeast Nuclear Energy Company's (NNECO) commitments made within this letter are included in Attachment 1.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

FOR: J. A. Price

Director - Millstone Unit No. 2

BY:

J. T. Swientoniewski

Assistant Unit Director - Millstone Unit No. 2

cc: see page 2

9812300359 981223 PDR ADOCK 05000336 S PDR IE221.

U.S. Nuclear Regulatory Commission B17540\Page 2

Attachments: 1. List of Regulatory Commitments

2. LER 98-012-01

cc: H. J. Miller, Region I Administrator

S. Dembek, NRC Project Manager, Millstone Unit No. 2

D. P. Beaulieu, Senior Resident Inspector, Millstone Unit No. 2

E. V. Imbro, Director, Millstone ICAVP Inspections

## Attachment 1 Millstone Nuclear Power Station, Unit No. 2 Commitments

U.S. Nuclear Regulatory Commission B17540\Attachment 1\Page 1

## Attachment 1

## Regulatory Commitment Enclosure List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document.

REGULATORY COMMITMENT	COMMITTED DATE OR OUTAGE
NONE	

## Attachment 2 Millstone Nuclear Power Station, Unit No. 2 LER 98-012-01