

UNITED STATES NUCLEAR REGULATORY COMMISSION WAEHINGTON, D.C. 20555-0001

January 7, 1998

MEMORANDUM TO: Thomas H. Essig, Acting Chief Generic Issues and Environmental Projects Branch Division of Reactor Program Management Office of Nuclear Reactor Regulation

Stewart L. Magruder, Project Manager Stewart Z. Mogulu Generic Issues and Environmental Projects Branch FROM: Division of Reactor Program Management Office of Nuclear Reactor Regulation

SUBJECT: SUMMARY OF THE DECEMBER 3, 1997, MEETING WITH NUCLEAR ENERGY INSTITUTE (NEI) REGARDING STEAM GENERATOR TUBE DATABASE FOR VOLTAGE-BASED ALTERNATE TUBE REPAIR CRITERIA

On December 3, 1997, representatives of the nuclear power industry met with members of the Nuclear Regulatory Commission (NRC) staff in Rockville, Maryland. The purpose of the meeting was to discuss issues related to the steam generator tube database for voltage-based alternate tube repair criteria for outside diameter stress corrosion cracking in Westinghouse plants with drilled hole tube support plates. The main topics of discussion were statistical techniques for simulation and treatment of steam generator tube data obtained from French nuclear plants. Meeting attendees are identified in Attachment 1. T. e agenda and staff's viewgraphs are included as Attachment 2.

The staff provided the following comments during the meeting:

With respect to statistical techniques for simulation, the staff commented that the currently adopted framework for performing conditional burst and leak calculations is Bayesian, which the staff and the industry both consider to be an appropriate model to address sampling uncertainty.

Any industry proposed modifications to the current statistical analysis framework need to be justified in terms of the goals of the analysis and the adopted analysis framework. In addition, the proposed modifications should be explicit with respect to the theoretical basis for the analysis framework; i.e., the formulation of the probabilistic problem and the model should be provided. This comment would also apply to the proposed alternative to the current probability of leak (POL) model or to the use of a Bootstrap approach. Calculations should be based on a consistent model and on applicable assumptions concerning data distributions and sampling

certainty, i.e., the same analysis framework should be used for all the calculations. The DFD31. PRO 5-689 umptions made about the tail of the distributions should be conservative because the tail cal...tot be justified by the data.

9801140424 980107 PDR REVOP ERONUMRC NRC FILE CENTER GOR PDR

P. 0062, P203

98-7

T. Essig

.

The staff commented that the proposed single sided p-test for the leak rate vs. voltage data correlation is acceptable. The industry representatives indicated that this approach results in a correlation and will be reflected in upcoming 90-day reports for plants with 7/8" tubing.

The staff commented that the industry proposed unbiased estimation for leak rate calculations as documented in section 6.3.2 of the EPRI report NP-7480-L is not acceptable for use in the current analysis framework because the approach has not demonstrated that the simulation will result in a conservative leak rate value at the 95% guantile.

With respect to the industry's proposal to modify the current statistical POL model, the staff believes that the industry needs to apply Goodness-of-Fit tests to the data to determine the applicability of the proposed model; and it needs to perform sensitivity studies to other statistical models to critically examine the proposed model.

With respect to the industry proposed exclusion of French data from the steam generator database, the staff noted that it is advantageous to include the French data in the database because the French data contain high voltage data points and have intergranular stress corrosion cracking (IGSCC) that has been in service for an extended time which is valuable for the future application to domestic plants. The staff commented that: (1) statistical tests cannot be used by themselves as a decision tool for excluding the data, (2) the primary bases for including or excluding the French data should rest on the experimental protocol, (3) the industry has not provided sufficient physical evidence to conclusively exclude the French data from the database, (4) the industry needs to perform a quality assurance review of the French data, (5) the quality assurance review will need to be performed expeditiously in order to satisfy the schedule requirement in the protocol for updating the database, and (6) any rules or criteria for including or excluding the French data should be applied consistently across the database.

With respect to the protocol for updating the steam generator database, NEI submitted the final version of the industry proposal in a letter dated October 28, 1997. The staff finds the proposal acceptable and will forward a letter to NEI to bring this issue to a closure.

With respect to the proposed treatment of fractional tube indications in the tube integrity calculations, the staff commented that it will review the proposed method when it is submitted formally.

Project No. 689

Attachments: 1. List of Attendees 2. Agenda and Viewgraphs

cc w/att: See next page

T. Essig

The staff commented that the proposed single sided p-test for the leak rate vs. voltage data correlation is acceptable. The industry representatives indicated that this approach results in a correlation and will be reflected in upcoming 90-day reports for plants with 7/8" tubing.

The staff commented that the industry proposed unbiased estimation for leak rate calculations as documented in section 6.3.2 of the EPRI report NP-7480-L is not acceptable for use in the current analysis framework because the approach has not demonstrated that the simulation will result in a conservative leak rate value at the 95% quantile.

With respect to the industry's proposal to modify the current statistical POL model, the staff believes that the industry needs to apply Goodness-of-Fit tests to the data to determine the applicability of the proposed model; and it needs to perform sensitivity studies to other statistical models to critically examine the proposed model.

With respect to the industry proposed exclusion of French data from the steam generator database, the staff noted that it is advantageous to include the French data in the database because the French data contain high voltage data points and have intergranular stress corrosion cracking (IGSCC) that has been in service for an extended time which is valuable for the future application to domestic plants. The staff commented that: (1) statistical tests cannot be used by themselves as a decision tool for excluding the data, (2) the primary bases for including or excluding the French data should rest on the experimental protocol, (3) the industry has not provided sufficient physical evidence to conclusively exclude the French data from the database, (4) the industry needs to perform a quality assurance review of the French data, (5) the quality assurance review will need to be performed expeditiously in order to satisfy the schedule requirement in the protocol for updating the database, and (6) any rules or criteria for including or excluding the French data should be applied consistently across the database.

With respect to the protocol for updating the steam generator database, NEI submitted the final version of the industry proposal in a letter dated October 28, 1997. The staff finds the proposal acceptable and will forward a letter to NEI to bring this issue to a closure.

With respect to the proposed treatment of fractional tube indications in the tube integrity calculations, the staff commented that it will review the proposed method when it is submitted formally.

Project No. 689 Attachments: 1. List of Attendeec 2. Agenda and Viewgraphs cc w/att: See next page DISTRIBUTION: See attach page

OFFICE	PM:PGEB	EMCB	SC:PGEB
NAME	SMagruder:sw ^{5um}	JTsao , of	FAkstulewicz
DATE	1/5/98	1/6/98	1/ 7/98

-2-

Distribution: Mtg. Summary w/ NEI Re SG Tube Database Dated January 7, 1998 Hard Copy Docket File PUBLIC PGEB R/F OGC ACRS SMagruder JTsao

EMail SCollins/FMiraglia BSheron RZimmerman GLainas/JStrosnider JRoe DMatthews FAkstulewicz SDembek ESullivan JDavis SCoffin LAbramson, RES JMuscara, RES

.

.

NRC-INDUSTRY MEETING REGARDING STEAM GENERATOR DATABASE FOR VOLTAGE-BASED ALTERNATE TUBE REPAIR CRITERIA DECEMBER 3, 1997

LIST OF ATTENDEES

ORGANIZATION

NAME

1. John Tsao

.

- 2. Rick Mullins
- 3. Steve Dembek
- 4. Stu Magruder
- 5. Brian Woodman
- 6. Ron Gamble
- 7. Ted Sullivan
- 8. Jim Davis
- 9. Lee Abramson 10. Joe Muscara
- 10. Joe Muscara
- Christopher Begley
 Robert Keating
- 13. Patrick Heasler
- 15. Patrick neasier
- 14. Stephanie Coffin

NRC/NRR Southern Company NRC/NRR NRC/NRR APTECH Engineering Sartrex NRC/NRR NRC/NRR NRC/RES NRC/RES APTECH Engineering Westinghouse Pacific Northwest National Lab. NRC/NRR

Attachment 1

AGENDA FOR NRC-INDUSTRY MEETING REGARDING STEAM GENERATOR DATABASE FOR VOLTAGE-BASED ALTERNATE TUBE REPAIR CRITERIA

DECEMBER 3, 1997 8:00 AM - 2:30 PM ONE WHITE FLINT NORTH ROOM O-10B13

1	. STATISTICAL TECHNIQUES FOR SIMULATION	8:00 am
	A. TREATMENT OF UNCERTAINTIES IN PARAMETERSSTAFF B. DISTRIBUTION FOR LEAK RATESSTAFF C. UNBIASED ESTIMATIONSTAFF D. PROBABILITY OF LEAK DATAWESTINGHOUSE E. BOOTSTRAP APPROACHWESTINGHOUSE	
	2. TREATMENT OF FRENCH DATA IN 7/8 TUBE DATABASE	10:00 am
	A. STATISTICAL ANALYSIS OF BURST DATASTAFF B. IMPLICATION ON LEAK RATE DATASTAFF C. PHYSICAL EVIDENCEWESTINGHOUSE	
	3. CAUCUS	11:30 am
	TREATMENT OF FACTIONAL INDICATIONSWESTINGHOUSE	1:30 pm
	CAUCUS/SUMMARY	2:30 pm

ATTACHMENT 2

SLB Leak Rate and Tube Burst Probability Models for ODSCC

Patrick G. Heasler PNNL

Dec. 1997

12/01/97 MON 10:27 FAI 1 509 375 3614

2400 STEVENS PNNL

Steam Gen

Problem Formulation

- Objective is to estimate the 95% quantile on Total Leak Rate for an inspected Steam Generator.
- Total leak rate is leak rate the steam generator would experience during a pressure transient.
- The Total Leak Rate Distribution depends upon the inspection results.

12/01/07 MON 10:28 FAI 1 509 375 3614 2400 STEVENS PNNL

Steam Gen

Problem Formulation

Simplified Leak Rate Model:

$$T = \sum_{k=1}^{N} R_k Q_k \tag{1}$$

- R_kQ_k is leak rate of tube k.
- Q_k is the conditional leak rate, with lognormal distribution $F_Q(q|\beta_3, \beta_4)$.
- R_k is binary variable with $Pr(R_k = 1) = logit(\beta_1 + \beta_2 V_k).$
- Want to Calculate U_{95} , where $Pr(T < U_{95}) = .95$.

12/01/97 MON 10:28 FAX 1 509 375 3614

2400 STEVENS PNNL

2000

Steam Gen

Problem Formulation

If unknown parameters β (alternatively $F_Q()$ and $Pr(R_k = 1)$) are known, then problem has been solved:

- The distribution F_T() of T can be calculated numerically or by a Monte Carlo using the previous formulas.
- Result is $F_T(t|V,\beta) = Pr(T < t|V,\beta)$
- $F_T()$ can be used to find U_{95} .

Problem: We don't know β , but have data than can be used to estimate β . These estimates will contain substantia! uncertainties. How can we modify the problem to account for this uncertainty?

Two solutions are available:

- Bayesian solution: Treat β as a random variable and describe uncertainty as a probability distribution.
- Frequentist solution: Put confidence bounds on U_{95} , which creates a tolerance bound or create a 95% prediction interval for T.

Bayesian Solution:

- Use leak rate data X to calculate $f(\beta|X)$, the posterior distribution of β given the data.
- Note: for this problem $f(\beta|X)$ can be expressed as $f(\beta|\hat{\beta})$.
- Solution is 95% quantile of F_T(t|V, X), which is:

$$F_T(t|V,X) = \int F_T(t|V,\beta) f(\beta|X) d\beta$$
(2)

• \hat{U}_{95} satisifies:

$$F_T(\hat{U}_{95}|V,X) = .95$$
 (3)

Bayesian Posterior:

$$f(\beta|X) = \frac{f(X|\beta)f(\beta)}{f(X)}$$
(4)

Important Point: posterior $f(\beta|X)$ is completely determined by data distribution $f(X|\beta)$ and prior $f(\beta)$. If standard non-informative priors are chosen, then $f(\beta|X)$ is completely determined by $f(X|\beta)$.

Advantages of Bayesian Solution:

- Requires the least modification to present
 M.C. code to implement.
- Provides a coherent framework for dealing with all parametric uncertainty.
- Gives results that are asymptotically similar to frequentist results.
- Is a well-documented methodology.

Unbiased Estimation

Given the problem formulation, we are interested in the properties of an estimator of U_{95} , call it $\hat{U}_{95} = h(X)$. The properties of other estimators (that are not even used to construct \hat{U}_{95}) are not relevant.

- Bayesian Property: $F_T(\hat{U}_{95}|V,X) = .95$.
- Tolerance Bound Property: $Pr(U_{95} < \hat{U}_{95}) = .95$
- Prediction Bound Property: $Pr(T < \hat{U}_{95}) = .95$
- An estimate of the mean of Q_k is not even used to construct the present \hat{U}_{95} .
- Even if the mean of Q_k were used to construct \hat{U}_{95} , its acceptability should be determined by one of the three properties above.

2400 STEVENS PNNL

Steam Gen

Unbiased Estimation

If we were interested in estimating μ_Q , the mean of Q_k , EPRI's observations are correct with the following qualifications.

 There seems to be an error in "unbiased" estimation formula. If natural logs are used the formula is,

$$\hat{\mu}_Q = \exp(M_{lnQ})g(\frac{1}{2}S_{lnQ}^2)$$
 (7)

so the formula for base-10 logs is,

$$\hat{\mu}_Q = \exp(\ln(10)M_{\log Q})g(\frac{1}{2}\ln(10)^2 S_{\log Q}^2)$$
(8)

Using the formula

$$\hat{\mu}_Q = \exp(M_{lnQ} + \frac{1}{2}S_{lnQ}^2)$$
 (9)

is asymptotically correct.

2014

Comments about log-normal distribution

- Fits existing data well (Fig. 6-8).
- Has a very heavy right-hand tail.
- Clearly is not bounded, as leak rate should be.
- Important information about right hand tail May exist.

Steam Gen

375 3614

500

2400 STEVENS PNNL



017



12/01/97 MON 10:32 FAX 1 509 375 3614

2400 STEVENS PNNL

018

Statistical Analysis of French Data

- The GOF tests are performed correctly.
- The tests have NOT been interpreted correctly.
- From the results presented, I would favor retaining the French data, and it would be to industry's advantage to do this.

comparison	1	2	3	4	5	6	7
null Hyp	model 4	model 🎝	model 6	model 4	model 11	model 14	model 16
Alt Hyp	model 1	model 5	model 7	model 8	model 12	model 15	model 17
N-H SSE	66.94	66.94	52.12	66.94	52.118	20.83	54.36
N-H DOF	91	91	72	91	72	47	61
A-H SSE	62.47	65.96	52.11	60.203	49.849	19.971	50.586
A-H DOF	89	89	76	87	70	45	59
F Stats	3.183	0.662	0.00806	2.434	1.594	0.967	2.2
F stats DOF	2.89	2. 89	2. 70	4.87	2. 70	2. 45	2. 59
P value, %	4.6	51.83	99.2	5.32	21.1	38.8	12
comments	reject NH accept AH	accept NH	accept NH	need more tests	accept NH	accept NH	accept NH

model 1 US and MB data are from a different population than that of Edf data

model 4 All (US, MB & Edf) data are from the same population.

model 5 All (US. MB. & Edf) data that are less than 3 volts and data that are greater than 3 volts are from different populations.

model 6 US+MB data less than 3 volts and greater than 3 volts are from the same population.

model 7 US+MB data less than 3 volts and greater than 3 volts are from different populations.

model 8 US data. MB data, and Edf data are from three separate populations.

model 11 US data and MB data are from the same population.

model 12 US data and MB data are from different populations.

model 14 MB data and EDF data are from the same population.

model 15 MB data and Edf data are from different populations.

model 16 Edf data and US data are from the same population.

model 17 Edf data and US data are from different populations.

. 4

12/01/87 MON 10:34 FAI 1 508 375 3614 2400 STEVENS PNNL

Steam Gen

0024

Interpretation of Tests

- A significant F-test implies (1) the model does not fit, or (2) something is "wrong" with the data.
- Original reason for conducting such tests was to evaluate (1), because validity of model is very important.
- These tests can be used to prove (1), but not (2).
- (2) can only be concluded if compelling external proof can be found that the data is "in error."



Project No. 689

Nuclear Energy Institute

.

cc: Mr. Ralph Beedle Senior Vice President and Chief Nuclear Officer Nuclear Energy Institute Suite 400 1776 I Street, NW Washington, DC 20006-3708

> Mr. Alex Marion, Director Programs Nuclear Energy Institute Suite 400 1776 I Street W Washington, DC 20006-3708

> Mr. David Modeen, Director Engineering Nuclear Energy Institute Suite 400 1776 I Street, NW Washington, DC 20006-3708

Mr. Anthony Pieirangelo, Director Licensing Nuclear Energy Institute Suite 400 1776 I Street, NW Washington, DC 20006-3708

Mr. Nicholas J. Liparulo, Manager Nuclear Safety and Regulatory Activities Nuclear and Advanced Technology Division Westinghouse Electric Corporatior. P.O. Box 355 Pittsburgh, Pennsylvania 15230

Mr. Jim Davis, Director Operations Nuclear Energy Institute Suite 400 1776 I Street, NW Washington, DC 20005-3708 Ms. Lynnette Hendricks, Director Plant Support Nuclear Energy Institute Suite 400 1776 I Street, NW Washington, DC 20006-3708



UNITED STATES NUCLEAR REGULATORY COMMISSION

January 7, 1998

MEMORANDUM TO: Thomas H. Essig, Acting Chief Generic Issues and Environmental Projects Branch Division of Reactor Program Management Office of Nuclear Reactor Regulation

FROM:

Stewart L. Magruder, Project Manager Stewart Z. Monule Generic Issues and Environmental Projects Branch Division of Reactor Program Management Office of Nuclear Reactor Regulation

SUBJECT: SUMMARY OF THE DECEMBER 3, 1997, MEETING WITH NUCLEAR ENERGY INSTITUTE (NEI) REGARDING STEAM GENERATOR TUBE DATABASE FOR VOLTAGE-BASED ALTERNATE TUBE REPAIR CRITERIA

On December 3, 1997, representatives of the nuclear power industry met with members of the Nuclear Regulatory Commission (NRC) staff in Rockville, Maryland. The purpose of the meeting was to discuss issues related to the steam generator tube database for voltage-based alternate tube repair criteria for outside diameter stress corrosion cracking in Westinghouse plants with drilled hole tube support plates. The main topics of discussion were statistical techniques for simulation and treatment of steam generator tube data obtained from French nuclear plants. Meeting attendees are identified in Attachment 1. The agenda and staff's viewgraphs are included as Attachment 2.

The staff provided the following comments during the meeting:

With respect to statistical techniques for simulation, the staff commented that the currently adopted framework for performing conditional burst and leak calculations is Bayesian, which the staff and the industry both consider to be an appropriate model to address sampling uncertainty.

Any industry proposed modifications to the current statistical analysis framework need to be justified in terms of the goals of the analysis and the adopted analysis framework. In addition, the proposed modifications should be explicit with respect to the theoretical basis for the analysis framework; i.e., the formulation of the probabilistic problem and the model should be provided. This comment would also apply to the proposed alternative to the current probability of loak (POL) model or to the use of a Bootstrap approach. Calculations should be based on a consistent model and on applicable assumptions concerning data distributions and sampling assumptions made about the tail of the distributions should be used for all the calculations. The cannot be justified, by the data.

T. Essig

The staff commented that the proposed single sided p-test for the leak rate vs. voltage data correlation is acceptable. The industry representatives indicated that this approach results in a correlation and will be reflected in upcoming 90-day reports for plants with 7/8" tubing.

The staff commented that the industry proposed unbiased estimation for leak rate calculations as documented in section 6.3.2 of the EPRI report NP-7480-L is not acceptable for use in the current analysis framework because the approach has not demonstrated that the simulation will result in a conservative leak rate value at the 95% quantile.

With respect to the industry's proposal to modify the current statistical POL model, the staff believes that the industry needs to apply Goodness-of-Fit tests to the data to determine the applicability of the proposed model; and it needs to perform sensitivity studies to other statistical models to critically exarcise the proposed model.

With respect to the industry proposed exclusion of French data from the steam generator database, the staff noted that it is advantageous to include the French data in the database because the French data contain high voltage data points and have intergranular stress corrosion cracking (IGSCC) that has been in service for an extended time which is valuable for the future application to domestic plants. The staff commented that: (1) statistical tests cannot be used by themselves as a decision tool for excluding the data, (2) the primary bases for including or excluding the French data should rest on the experimental protocol, (3) the industry has not provided sufficient physical evidence to conclusively exclude the French data from the database, (4) the industry needs to perform a quality assurance review of the French data, (5) the quality assurance review will need to be performed expeditiously in order to satisfy the schedule requirement in the protocol for updating the database, and (6) any rules or criteria for including or excluding the French data should be applied consistently acries the database.

With respect to the protocol for updating the steam generator database, NEI submitted the final version of the industry proposal in a letter dated October 28, 1997. The staff finds the proposal acceptable and will forward a letter to NEI to bring this issue to a closure.

With respect to the proposed treatment of fractional tube indicatic. *s* in the tube integrity calculations, the staff commented that it will review the proposed method when it is submitted formally.

Project No. 689

Attachments: 1. List of Attendees

2. Agenda and Viewgraphs

cc w/att: See next page

T. Essig

The staff commented that the proposed single sided p-test for the leak rate vs. voltage data correlation is acceptable. The industry representatives indicated that this approach results in a correlation and will be reflected in upcoming 90-day reports for plants with 7/8" tubing.

The staff commented that the industry proposed unbiased estimation for leak rate calculations as documented in section 6.3.2 of the EPRI report NF-7480-L is not acceptable for use in the current analysis framework because the approach has not demonstrated that the simulation will result in a conservative leak rate value at the 95% quantile.

With respect to the industry's proposal to modify the current statistical POL model, the staff believes that the industry needs to apply Goodness-of-Fit tests to the data to determine the applicability of the proposed model; and it needs to perform sensitivity studies to other statistical models to critically examine the proposed model.

With respect to the industry proposed exclusion of French data from the steam generator database, the staff noted that it is advantageous to include the French data in the database because the French data contain high voltage data points and have intergranular stress corrosion cracking (IGSCC) that has been in service for an extended ... me which is valuable for the future application to domestic plants. The staff commented that: (1) statistical tests cannot be used by themselves as a decision tool for excluding the data, (2) the primary bases for including or excluding the French data should rest on the experimental protocol, (3) the industry has not provided sufficient physical evidence to conclusively exclude the French data from the database, (4) the industry needs to perform a quality assurance review of the French data, (5) the quality assurance review will need to be performed expeditiously in order to satisfy the schedule requirement in the protocol for updating the database, and (6) any rules or criteria for including or excluding the French data should be applied consistently across the database.

With respect to the protocol for updating the steam generator database, NEI submitted the final version of the industry proposal in a letter dated October 28, 1997. The staff finds the proposal acceptable and will forward a letter to NEI to bring this issue to a closure.

With respect to the proposed treatment of fractional tube indications in the tube integrity calculations, the staff commented that it will review the proposed method when it is submitted formally.

Project No. 689 Attachments: 1. List of Attendees 2. Agenda and Viewgraphs cc w/att: See next page DISTRIBUTION: See attach page

OFFICE	PM:PGEB	EMCB	SC:PGEB
NAME	SMagruder:sw5um	JTsao jet	FAkstulewicz
DATE	1/5/98	1/6/98	1/ 7/98

Distribution: Mtg. Summary w/ NEI Re SG Tube Database Dated January 7, 1998 Hard Copy Docket File PUBLIC PGEB R/F OGC ACRS SMagruder

JTsao

· · ·

.

EMail SCollins/FMiraglia BSheron RZimmerman GLainas/JStrosnider JRoe DMatthews FAkstulewicz SDembek ESullivan JDavis SCoffir LAbramson, RES JMuscara, RES

NRC-INDUSTRY MEETING REGARDING STEAM GENERATOR DATABASE FOR VOLTAGE-BASED ALTERNATE TUBE REPAIR CRITERIA DECEMBER 3, 1997

LIST OF ATTENDEES

NAME

ORGANIZATION

- 1. John Tsao
- 2. Rick Mullins
- 3. Steve Dembek
- 4. Stu Magruder
- 5. Brian Woodman
- 6. Ron Gamble
- 7. Ted Sullivan
- 8. Jim Davis
- 9. Lee Abramson
- 10. Joe Muscara
- 11. Christopher Begley
- 12. Robert Keating
- 13. Patrick Heasler
- 14. Stephanie Coffin

NRC/NRR Southern Company NRC/NRR NRC/NRR APTECH Engineering Sartrex NRC/NRR NRC/NRR NRC/RES NRC/RES APTECH Engineering Westinghouse Pacific Northwest National Lab. NRC/NRR

Attachment 1

AGENDA FOR NRC-INDUSTRY MEETING REGARDING STEAM GENERATOR DATABASE FOR VOLTAGE-BASED ALTERNATE TUBE REPAIR CRITERIA

DECEMBER 3, 1997 8:00 AM - 2:30 PM ONE WHITE FLINT NORTH ROOM O-10B13

1	STATISTICAL TECHNIQUES FOR SIMULATION	8:00 am
	A. TREATMENT OF UNCERTAINTIES IN PARAMETERSSTAFF B. DISTRIBUTION FOR LEAK RATESSTAFF C. UNBIASED ESTIMATIONSTAFF D. PROBABILITY OF LEAK DATAWESTINGHOUSE E. BOOTSTRAP APPROACHWESTINGHOUSE	
2.	TREATMENT OF FRENCH DATA IN 7/8 TUBE DATABASE	10:00 am
	A. STATISTICAL ANALYSIS OF BURST DATASTAFF B. IMPLICATION ON LEAK RATE DATASTAFF C. PHYSICAL EVIDENCEWESTINGHOUSE	
3.	CAUCUS	11:30 am
4.	TREATMENT OF FACTIONAL INDICATIONSWESTINGHOUSE	1:30 pm
5.	CAUCUS/SUMMARY	2:30 pm

1.1

SLB Leak Rate and Tube Burst Probability Models for ODSCC

Patrick G. Heasler PNNL

Dec. 1997

Problem Formulation

- Objective is to estimate the 95% quantile on *Total Leak Rate* for an inspected Steam Generator.
- Total leak rate is leak rate the steam generator would experience during a pressure transient.
- The Total Leak Rate Distribution depends upon the inspection results.

12/01/07 MON 10:28 FAX 1 509 375 3614

2400 STEVENS PNNL

Steam Gen

Problem Formulation

Simplified Leak Rate Model:

$$T = \sum_{k=1}^{N} R_k Q_k \tag{1}$$

• R_kQ_k is leak rate of tube k.

• Q_k is the conditional leak rate, with lognormal distribution $F_Q(q|\beta_3, \beta_4)$.

- R_k is binary variable with $Pr(R_k = 1) = logit(\beta_1 + \beta_2 V_k).$
- Want to Calculate U_{95} , where $Pr(T < U_{95}) = .95$.

٠.

Problem Formulation

If unknown parameters β (alternatively $F_Q()$ and $Pr(R_k = 1)$) are known, then problem has been solved:

- The distribution F_T() of T can be calculated numerically or by a Monte Carlo using the previous formulas.
- Result is $F_T(t|V,\beta) = Pr(T < t|V,\beta)$
- $F_T()$ can be used to find U_{95} .

Problem: We don't know β , but have data than can be used to estimate β . These estimates will contain substantial uncertainties. How can we modify the problem to account for this uncertainty?

Two solutions are available:

- Bayesian solution: Treat β as a random variable and describe uncertainty as a probability distribution.
- Frequentist solution: Put confidence bounds on U_{95} , which creates a tolerance bound or create a 95% prediction interval for T.

Bayesian Solution:

- Use leak rate data X to calculate $f(\beta|X)$, the posterior distribution of β given the data.
- Note: for this problem $f(\beta|X)$ can be expressed as $f(\beta|\hat{\beta})$.
- Solution is 95% quantile of $F_T(t|V, X)$, which is:

$$F_T(t|V,X) = \int F_T(t|V,\beta) f(\beta|X) d\beta \quad (2)$$

• \hat{U}_{95} satisifies:

$$F_T(\hat{U}_{95}|V,X) = .95$$
 (3)

Steam Gen

Parametric Uncertainty

Bayesian Posterior:

$$f(\beta|X) = \frac{f(X|\beta)f(\beta)}{f(X)}$$
(4)

Important Point: posterior $f(\beta|X)$ is completely determined by data distribution $f(X|\beta)$ and prior $f(\beta)$. If standard non-informative priors are chosen, then $f(\beta|X)$ is completely determined by $f(X|\beta)$.

Advantages of Bayesian Solution:

- Requires the least modification to present.
 M.C. code to implement.
- Provides a coherent framework for dealing with all parametric uncertainty.
- Gives results that are asymptotically similar to frequentist results.
- Is a well-documented methodology.

2400 STEVENS PNNL

Steam Gen

Unbiased Estimation

Given the problem formulation, we are interested in the properties of an estimator of U_{95} , call it $\hat{U}_{95} = h(X)$. The properties of other estimators (that are not even used to construct \hat{U}_{95}) are not relevant.

- Bayesian Property: $F_T(\hat{U}_{95}|V,X) = .95$.
- Tolerance Bound Property: $Pr(U_{95} < \hat{U}_{95}) = .95$
- Prediction Bound Property: $Pr(T < \hat{U}_{95}) = .95$

100

- An estimate of the mean of Q_k is not even used to construct the present \hat{U}_{95} .
- Even if the mean of Q_k were used to construct \hat{U}_{95} , its acceptability should be determined by one of the three properties above.

2400 STEVENS PNNL

Steam Gen

Unbiased Estimation

If we were interested in estimating μ_Q , the mean of Q_k , EPRI's observations are correct with the following qualifications.

 There seems to be an error in "unbiased" estimation formula. If natural logs are used the formula is,

$$\hat{\mu}_Q = \exp(M_{lnQ})g(\frac{1}{2}S_{lnQ}^2)$$
(7)

so the formula for base-10 logs is,

$$\hat{\mu}_Q = \exp(\ln(10)M_{\log Q})g(\frac{1}{2}\ln(10)^2 S_{\log Q}^2)$$
(8)

Using the formula

$$\hat{\mu}_Q = \exp(M_{lnQ} + \frac{1}{2}S_{lnQ}^2)$$
 (9)

is asymptotically correct.

2014

Steam Gen

Comments about log-normal distribution

- Fits existing data well (Fig. 6-8).
- Has a very heavy right-hand tail.
- Clearly is not bounded, as leak rate should be.
- Important information about right hand tail May exist.

12/01/01 MON 10:32 FAX 1 509 375 3614

2400 STEVENS PANL

Steam Gen



2017

12/01/97 MON 10:32 FAI 1 509 375 3614

2400 STEVENS PNNL

Steam Gen



2018

2/01/97 MON 10:34 FAX 1 809 378 3814

Statistical Analysis of French Data

- The GOF tests are performed correctly.
- The tests have NOT been interpreted correctly.
- From the results presented, I would favor retaining the French data, and it would be to industry's advantage to do this.

comparison	1	2	3	4	5	6	1,
null Hyp	model 4	model 4	model 6	model 4	model 11	model 14	
Alt Hyp	model 1	model 5	model 7	model 8	model 12	model 15	model 10
N-H SSE	66.94	66.94	52.12	66.94	52.118	20 83	54.36
N-H DOF	91	91	72	91	72	47	101
A-H SSE	62.47	65.96	52.11	60.203	49.849	19 971	50 596
A-H DOF	89	89	70	87	70	45	50
F Stats	3.183	0.662	0.00806	2.434	1.594	0.967	2.7
stats DOF	2. 89	2. 89	2. 70	4. 87	2.70	2 45	2.0
P value. 1	4.6	51.83	r9.2	5.32	21.1	38.8	12
comments	reject NH accept AH	accept NH	accept NH	need more	accept NH	accept NH	accept NH

model 1 US and MB data are from a different population than that of Edf data

model 4 All (US. MB & Edf) data are from the same population

model 5 All (US. MB. & Edf) data that are less than 3 polts and data upat are greater than 3 volts are from lifferant populations.

model 6 US+MB data less than 3 volts and greater than 3 volts are from the same population.

model 7 US+MB data less than 3 volts and greater than 3 volts are from different populations.

model 8 US data. MB data. and Edf data are from three separate populations.

model 11 US data and MB data are from the same population.

model 12 US data and MB data are from different populations.

model 14 MB data and EDF data are from the same population.

model 15 MB data and Edf data are from different populations.

model 16 Edf data and US data are from the same population.

model 17 Edf data and US data are from different populations.

1

Interpretation of Tests

- A significant F-test implies (1) the model does not fit, or (2) something is "wrong" with the data.
- Original reason for conducting such tests was to evaluate (1), because validity of model is very important.
- These tests can be used to prove (1), but not (2).
- (2) can only be concluded if compelling external proof can be found that the data is "in error."

12/01/97 BON 10:34 FAL 1 509 375 3614

2400 STEVENS PNNL

Steam Gen

Interpretation of Tests

If Tests are significant:

- 1. MODEL DOES NOT FIT RELEVANT DATA: ITS VALIDITY IS IN DOUET!!!!
- 2. Model can only be saved if we can PROVE that some of the data is not relevant.
- Must show that the "type" of ODSCC that occurs in French generators can't occur in US generators.

Nuclear Energy Institute

cc: Mr. Ralph Beedle Senior Vice President and Chief Nuclear Officer Nuclear Energy Institute Suite 400 1776 I Street, NW Washington, DC 20006-3708

> Mr. Alex Marion, Director Programs Nuclear Energy Institute Suite 400 1776 I Street, NW Washington, DC 20006-3708

> Mr. David Modeen, Director Engineering Nuclear Energy Institute Suite 400 1776 I Street, NW Washington, DC 20006-3708

Mr. Anthony Pietrangelo, Director Licensing Nuclear Energy Institute Suite 400 1776 I Street, NW Washington, DC 20006-3708

Mr. Nicholas J. Liparulo, Manager Nuclear Safety and Regulatory Activities Nuclear and Advanced Technology Division Westinghouse Electric Corporation P.O. Box 355 Pittsburgh, Pennsylvania 15230

Mr. Jim Davis, Director Operations Nuclear Energy Institute Suite 400 1776 I Street, NW Washington, DC 20006-3708 Ms. Lynnette Hendricks, Director Flant Support Nuclear Energy Institute Suite 400 1776 I Street, NW Washington, DC 20006-3708

Project No. 689