

Verified Revision ✓	
Initial <i>J</i>	Date <i>11/2/98</i>

CALCULATION TITLE PAGE

Total Number of Pages: 16

Seismic Capacity of the RBCCW Heat Exchangers

TITLE			
N/A	0	93C2799-C-018	
CALCULATION #	REVISION No #	VENDOR CALCULATION NUMBER	
CCR	2330A	CS	HXR
System Name	System Number	Structure	Component
NUCLEAR INDICATOR: ☒ CATI ☐ RWQA ☐ SBOQA ☐ FPQA ☐ ATWSQA ☐ NON-QA		Calc. Supports DCR/MMOD? ☐ Yes ☒ No	
Calc. Supports Licensing? ☐ Yes ☒ No		Calc. Supports Ind. Analysis? ☐ Yes ☒ No	
Chg. Doc. Ref.		DCR/MMOD No	
INCORPORATES: CCN NO: N/A AGAINST REV. N/A		Affects DBS? ☐ Yes ☒ No	
		Reference	
		Reference	

Executive Summary

(This NU Calculation is generated to enter the attached S&A calculation into NU's document control/tracking system, and to document the current NU technical review. This S&A calculation is part of NU's IPEEE program.)

This calculation evaluated the seismic capacity of the RBCCW Heat Exchangers (X18A, X18B & X18C). The result is a high-confidence of low probability of failure (HCLPF) capacity in terms of PGA. The HCLPF capacity of these heat exchanger is 0.29g PGA. This capacity is used in the seismic margin assessment.

Approvals (Print/Signature)	
Preparer: Apostolos Karavoussianis	Date: 12/20/97
Interdiscipline Reviewer: N/A	Discipline: N/A Date: N/A
Interdiscipline Reviewer: N/A	Discipline: N/A Date: N/A
Independent Reviewer: Nabil Juraydini	Date: 12/31/97
Supervisor: Steve Wainio	Date: 3/16/98
Installation Verification (Calculation accurately represents actual field conditions or does not affect plant configuration)	
Preparer/Designer Engineer: NABIL JURAYDINI	Date: 12/21/97

9901080227 981231
PDR ADOCK 05000336
PDR

3-15-98

3-26-98

3-27-98

4es 10



CTP/PassPort DATABASE INPUTs

Page 1A of 11Calculation Number: N/A
(prefix) (sequence no.) (suffix)Revision: N/AVendor Calculation Number/Other: 93C2799-C-018Revision: 0CCN # N/A QA ☒ Yes ☐ NoCalc Voided: ☐ Yes ☒ NoSuperseded By: N/ASupersedes Calc: N/ADiscipline (Up to 10) L, N, Q

Unit	Project Reference (EWA)	Component Id	Computer Code	Rev. No./ Level No.
02	M2-94223	X18A	N/A	N/A
		X18B		
		X18C		

PMMS CODES*

Structure	System	Component	Reference Calculation	Rev No.
CS-AB	CCR	HXR	93C2799-C-005	N/A

*The codes required must be alpha codes designed for structure, system and component.

Reference Drawing	Sheet	Rev. No.
25203-29004	20	N/A
25203-11090	N/A	N/A

Comments:
None

NORTHEAST UTILITIES SERVICE COMPANY

SUBJECT: Seismic Capacity of the RBCCW Heat Exchangers

By: A. Karavoussianis Date: 12/20/97

Chkd: N. Juraydini Date: 12/20/97

Calc. No. 93C2799-C-018 Rev.: 0

Sheet No. 1B of 11

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE No.</u>
NU Calculation Title Page	1
CTP Data Base Inputs	1A
NU Table of Contents	1B
Calculation Review Comment and Resolution Form	1C
S&A Calculation Cover Sheet	1D
S&A Calculation:	
1. Introduction & Summary	1E
2. References	1E
3. Configuration, Criteria and Assumptions	2
4. Calculation	2 - 11

Total Number of Pages	16 pages

Calculation Review Comment and Resolution Form

(Sheet 1 of 1)

Calculation Number: <u>93C2799-C-018</u>	Revision: <u>0</u>	Calculation Title: <u>Seismic Capacity of the RBCCW Heat Exchangers</u>
Calc. Originator: <u>Apostolos Karavoussianis</u>	Reviewer (PRINT): <u>Nabil Juraydini</u>	

This form is intended to document significant comments and their resolutions. Typographical errors and other editorial recommendations may be marked up in the calculation text and presented to the originator

Review Type ☐ ☐ Interdiscipline ☒ Independent

Reviewer (SIGN) <u>Nabil Juraydini</u>	Date: <u>12/31/97</u>
(signature signifies all comments have been resolved to your satisfaction)	

Item	Page/Section	Comments	Response
1 of 1	N/A	This NU Calculation is generated to enter the attached S&A calculation into NU's document control/tracking system, and to document the current NU technical review. This S&A calculation is part of NU's IPEEE program. There are no technical or significant review comments which need to be document here. Only S&A's calculation cover sheet is numbered as page 1D (this page was not numbered by S&A), and S&A calculation's first pages is re-numbered as 1E. These changes are for page numbering purposes only.	

Client: NU Calculation No. C018Title: Seismic Capacity of 4L RBCCW
Heat ExchangersProject: MP2 IPEEEMethod: See insideAcceptance Criteria: See inside

Remarks:

REVISIONS

No.	Description	By	Date	Chk.	Date	App.	Date
0	Initial Issue 11 pp.	gda	11/15/95	MSLi	11/16/95	(u)	11/16/95

CALCULATION
COVER
SHEET

FIGURE 1.3

CONTRACT NO.

93C2799

S&A	JOB NO. 93C2799 SUBJECT: C018	Sheet 1E Rev. 0
STEVENSON & ASSOCIATES a structural-mechanical consulting engineering firm	Seismic Capacity of the RBCCW Heat Exchangers	By <i>SAS</i> 11/15/95 Chk. <i>MSL</i> 11/16/95

1 Introduction & Summary

This calculation evaluates the seismic capacity of the Millstone Point Unit 2 Reactor Building Component Cooling Water Heat Exchangers, equipment IDs X18A, X18B, X18C. The result is a high-confidence of low probability of failure (HCLPF) capacity in terms of peak ground acceleration (PGA). The results are to be used in the seismic margin assessment of MP2. Refer to NP-6041 (reference 1) for a discussion of a seismic margin assessment and HCLPF.

Summary of Results

The capacity of each RBCCW Hx in terms of PGA is 0.29g. This value is a HCLPF capacity as defined in NP-6041. Capacity is controlled by anchorage shear.

2 References

1. A Methodology for Assessment of Nuclear Power Plant Seismic Margin, Electric Power Research Institute, prepared by Jack R. Benjamin and Associates, Inc., et al., August 1991. NP-6041-SL, Revision 1.
2. Generic Implementation Procedure for Seismic Verification of Nuclear Plant Equipment, Revision 2, Seismic Qualification Utility Group, February 1992.
3. NU drawings; 25203 series (individual drawings referenced by extension number in body of calculation).
4. "Code Requirements for Nuclear Safety Related Concrete Structures", ACI 349-90, American Concrete Institute.
5. "Building Code Requirements for Reinforced Concrete", ACI 318-89, American Concrete Institute.
6. "Manual of Steel Construction", 9th Edition, American Institute of Steel Construction.
7. S&A calculations for job 93C2799.
8. Seismic Verification of Nuclear Plant Equipment Anchorage (Revision 1) Volume 4, Electric Power Research Institute, prepared by URS/John Blume & Associates, June 1991. NP-5228-SL, Revision 1..
9. S&A document received 93C2799-DC-024.
10. Blevins, R., "Formulas for Natural Frequency and Mode Shape", 1979.

S&A STEVENSON & ASSOCIATES a structural-mechanical consulting engineering firm	JOB NO. 93C2799	Sheet 2
	SUBJECT: C018	Rev. 0
	Seismic Capacity of the RBCCW Heat Exchangers	By <i>SA</i> 11/14/95 Chk. <i>MS</i> 11/16/95

3 Configuration, Criteria and Assumptions

The configuration is shown in the following sheets and was obtained from referenced drawings. The evaluation is based on the guidance of NP-6041, as outlined in Section 6 of that document. Seismic demand is per S&A calculation 93C2799-C005.

Based on the IPLEE walkdown and A-46 walkdown and screening results, attached piping is well restrained [9]. Therefore no piping loads are included.

Assumptions

- Yield stress of saddle material is assumed to be 30 ksi
- Similar to other saddle plates, vertical transverse saddle plate is $\frac{3}{4}$ " thick.

4 Calculation

Capacity calculations are contained in the following pages.



Stevenson and Associates

A Structural-Mechanical
Consulting Engineering Firm

CLIENT

NU

JOB No.

92C2799

SHEET

OF

SUBJECT


COIB

XIBAB,C Seismic Capacity

REVISIONS

SW 11/18/95
MD: IVK/95

Configuration



NOTES:

1. MODELS UPON TO HAVE (1) 1/2" RT SCRD (L.S.) A
(2) 1" RT SCRD (R.S.) 60" AMPT 2" 1/2" RT SCRD (R.S.)
2. MODELS UPON TO HAVE (1) 1/2" SN COUP (L.S.) E
(2) 1/2" SN COUP (R.S.) 60" AMPT
3. RATING OF NAT RLT CWP & SN COUP
SHALL BE 80000
4. CONSTRUCTED TO ASME CODE SECT. VIII DIV. 2
STANDARD BRACKET CHANNEL TO TUBESHEET
& CHANNEL COVER GASKET JOINT
5. CHANNELS AND COVERS TO BE COATED
PER SPECIFICATION SP-46-76.

24" WIDE ANGLE IR	CHAM. OUTLET
24" WIDE ANGLE IR	CHAM. OUTLET
20" WIDE STUB	SHELL OUTLET
20" WIDE STUB	SHELL INLET
1" SN COUP	SHELL DRAIN
1/2" SN COUP	SHELL VENT
1" RT SCRD	SHELL RELIEF VALVE
1" RT SCRD	CHAM. DRAIN
1/2" RT SCRD	CHAM. RELIEF VALVE
1/2" RT SCRD	PLUGGED VENT "R.S."
1/2" RT SCRD	PLUGGED VENT "L.S."

CAPACITY:

SHELL SIDE
RIB SIDE


AT NO TIME SHALL TEST
WATER BE DELIVERED TO
USE UNMIXED WATER

	SHELL SIDE	RIB SIDE
DESIGN PRESS.	150"	125"
DESIGN TEMP.	250°	170°
TEST PRESS.	200"	160"
TEST TEMP.	250°	170°

DETAILS OF WELD STUBS (U1/U2)

WEIGHTS:
EMPTY
FLOODED
CHANNEL
CHANNEL COVER

CAST IRON
CHANNEL
CLAS
1.5% NI



DETAIL "A"
SHOWNING CHANNEL TO TUBESHEET
GASKET JOINT.
FOR GASKET JOINT AT
CHANNEL COVER.

25203-29004

SHEET 2

5	1/2" SN COUP
4	1/2" SN COUP
3	1/2" SN COUP
2	1/2" SN COUP
1	1/2" SN COUP

STRUTHER

SETTING
COOLING
ST. 1.5"

DESIGN	1/2"
DESIGN	1/2"
DESIGN	1/2"
DESIGN	1/2"

• See next sheet for modification to saddle



Stevenson and Associates

A Structural-Mechanical
Consulting Engineering Firm

CLIENT NU
SUBJECT COIB


JOB No. 93C2799

SHEET 4 OF

X1BA,B,C Seismic Capacity

REVISIONS

0 SA 11/14/95
AK: 11/15/95



FIXED END CRADLE

LOOKING WEST

[From 29004 sht 20]

PLA






Stevenson and Associates

A Structural-Mechanical
Consulting Engineering FirmCLIENT NU JOB No. 93C2799 SHEET 5 OF SUBJECT COBX18A,B,C Seismic Capacity

REVISIONS

GAS 11/14/95
MSL 11/16/95Longitudinal Frequency

Effective section @ webs



$$\bar{y} = \frac{(3/4) [(7.5) (3/4) + (85) (5.0)]}{(3/4) (7.5 + 8.5)}$$

$$\bar{y} = 2.832"$$

$$I = \frac{(8.5)^3 (3/4)}{12} + \frac{(3/4)^3 (7.5)}{12} + (2.457)^2 (5.43 \text{ in}^2) + (2.168)^2 (6.38 \text{ in}^2)$$

$$= 102.6 \text{ in}^4$$

$$A_s = (9.25) (3/4) = 6.94 \text{ in}^2 \text{ (shear area)}$$

Stiffness each element

$$K_1 = \frac{3EI}{l^3} = \frac{3 (29,000 \text{ ksi}) (102.6 \text{ in}^4)}{(13.2")^3}$$

$$= 3,881 \text{ k/in}$$

where

$$l = 13.2" = 8" + 24.5" (1 - \cos \theta)$$

$$\theta = \arcsin \left(\frac{15.125}{24.5} \right)$$

$$K_2 = \frac{GA}{l} = \frac{(11,150 \text{ ksi}) (6.94 \text{ in}^2)}{13.2"}$$

$$= 5,862 \text{ k/in}$$

Net stiffness each element

$$K_n = \frac{1}{1/K_1 + 1/K_2} = 2,335 \text{ k/in}$$



Stevenson and Associates

A Structural-Mechanical
Consulting Engineering FirmCLIENT NUJOB No. 932799SHEET 6 OF SUBJECT COBXIB A, B, C Seismic Capacity

REVISIONS

0 GM 11/14/95
MSL: 11/16/95

Longitudinal frequency, 2 elements effective @ fixed saddle

$$f_L = \frac{1}{2\pi} \left(\frac{2k_{\text{eff}}}{W} \right)^{1/2} = \frac{1}{2\pi} \left(\frac{2(2335)(386.4)}{49.5} \right)^{1/2} \text{ Hz}$$

$$= 25.6 \text{ Hz} \pm 15\%$$

Vertical Frequency per NP-5228 Vol 4, approximate

$$f_v = \frac{5.6}{2\pi} \left(\frac{EI}{g S^4} \right)^{1/2}$$

$$f_v = \frac{5.6}{2\pi} \left(\frac{(22,400)(22,400)(386.4)}{(0.112)(223.5)^4} \right)^{1/2} \text{ Hz}$$

$$= 21.6 \text{ Hz} \pm 15\%$$

$$I = \pi (24.25'')^3 (0.50'') = 22,400 \text{ in}^4$$

$$S = 223.5 \text{ in}$$

$$g = \frac{695 \text{ k}}{(403'')} = 0.172 \text{ k/in}$$

Actual $\gamma = 23.88''$ insignificant, O.K.
MSL:

Transverse Frequency

Since saddles are stiff in transverse

$$f_t \approx f_v = 21.6 \text{ Hz} \pm 15\%$$



Stevenson and Associates

A Structural-Mechanical
Consulting Engineering Firm

CLIENT NU JOB No. 93C2799 SHEET 7 OF
SUBJECT COIB

XIB A, B, C Seismic Capacity

REVISIONS
1 SA 11/16/95
2 MS 11/15/95

Seismic Demand

Elevation -255', demand is ground spectrum, per COOS

Mode	Freq.	Damping	S_a
Long	$25.6 \pm 15\%$	4%	0.39
Vert	$21.6 \pm 15\%$	4%	$\frac{2}{\sqrt{2}}(0.43) = 0.287$
Trans	$2.6 \pm 15\%$	4%	0.43

4% damping judged reasonable, same as GIP



Stevenson and Associates

A Structural-Mechanical
Consulting Engineering Firm

CLIENT NU JOB No. 93C2799 SHEET 8 OF

SUBJECT CXB

X1BA, B, C Seismic Capacity

REVISIONS	0	906 11/14/95
		MSI 11/16/95

Anchorage Capacity

1" Φ cast-in-place bolts per drawing 11090, estimated
embedment

$$l_e = 18" - 5" = 13"$$

Steel capacities

$$T_n = \pi (0.5")^2 (34 \text{ ksi}) = 26.7 \text{ k}$$

$$V_n = \pi (0.5")^2 (17 \text{ ksi}) = 13.35 \text{ k}$$

Check embedment per ACI-349, shear cone pullout

$$T = 4 (0.65) (3000)^{1/2} [\pi (13")^2] = 75,600 \text{ lb} \gg T_n$$

OK

Conclusion: allowables based on steel

$$T_n = 26.7 \text{ k} \quad V_n = 13.35 \text{ k}$$



Stevenson and Associates

A Structural Mechanical
Consulting Engineering Firm

CLIENT NU JOB No. 93C2799 SHEET 9 OF

SUBJECT COIB

XIB A,B,C Seismic Capacity

REVISIONS
0 JAS 11/14/95
MSL 11/16/95

Capacity Vs Demand

Check 2 cases

1.) 100% Long, 40% Trans, 40% Vertical

Check for tension, moment due to transverse about
edge of saddles

$$M_d = (0.40)(0.43)(69.5 \text{ k})(32.5") = 388.5 \text{ in-k}$$

Restoring moment from int vertical

$$M_R = (1 - 0.40(0.287))(69.5)(43"/2) = 1323 \text{ k-in}$$

Tension on an anchor, ignore longitudinal effect

$$T_d \approx (M_d - M_R) / 2(40") < 0 \quad \text{No tension.}$$

Shear on anchors to fixed saddle, vector sum

$$V_d = \left(\left(\frac{0.39}{2} \right)^2 + \left(\frac{0.40(0.43)}{4} \right)^2 \right)^{1/2} (69.5 \text{ k}) = 13.88 \text{ k}$$

HCLPF capacity

$$PGA_s = \left(\frac{13.35 \text{ k}}{13.88 \text{ k}} \right) (0.30g) = 0.289g$$



Stevenson and Associates

A Structural-Mechanical
Consulting Engineering Firm

CLIENT NU JOB No. 93C2799 SHEET 10 OF
SUBJECT COIB

XIBA, B, C Seismic Capacity

REVISIONS

0 SA 11/14/95
ASL 11/16/95

2) 100% Trans, 40% Long, 40% Vertical

Following previous

$$M_d = (0.43)(69.5 \text{ k})(32.5'') = 971 \text{ in-k}$$

$$M_R = 1323 \text{ in-k}$$

$$T_d < 2$$

$$V_d = \left(\left(\frac{0.156}{2} \right)^2 + \left(\frac{0.43}{4} \right)^2 \right)^{1/2} (69.5 \text{ k}) = 9.23 \text{ k} < V_a \text{ OK}$$

Conclusion: Case 1 controls, HCLPF capacity

$$PGA_a = 0.29g$$



Stevenson and Associates

A Structural-Mechanical
Consulting Engineering FirmCLIENT NU JOB No. 93C2799 SHEET 11 OF SUBJECT CQ/BXIBA, BIC Seismic Capacity

REVISIONS

Rev 11/15/95
MSL: 1/16/95Other Checks

Check saddle bending/shear for longitudinal load

$$M = (0.39)(69.5 \text{ k})(13.2") / 2 = 178.9 \text{ in-k}$$

$$f_b = \frac{M_y}{I} = \frac{(178.9 \text{ in-k})(6.418")}{102.6 \text{ in}^4} = 11.2 \text{ ksi} < 30.6 \text{ ksi}$$

← conservative since deeper @ top
↓
below

Check width/thickness for "stem of tree" per AISC

$$9.25 / 0.75 = 12.33 < 12.7 / \sqrt{30} = 23.2 \quad \text{OK}$$

Allowable stress per AISC, bending

$$F_{ab} = 1.7(0.60)F_y = (1.7)(0.60)(30 \text{ ksi}) = 30.6 \text{ ksi}$$

Shear stress, allowable $1.7(0.40)(30 \text{ ksi}) = 20.4 \text{ ksi}$ per AISC

$$f_v = (0.38)(69.5 \text{ k}) / \sqrt{2}(6.74 \text{ in}^2) = 1.90 \text{ ksi} < 20.4 \text{ ksi}$$

By inspection, other stresses are also OK. Note dominant anchorage load is shear.