



W. R. McCollum, Jr.
Vice President

Duke Power
Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679
(864) 885-3107 OFFICE
(864) 885-3564 FAX

November 12, 1997

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Licensee Event Report 269/97-03, Revision 1
Problem Investigation Process No.: 0-097-0279

Gentlemen:

Pursuant to 10 CFR 50.73 Sections (a) (1) and (d), attached is Licensee Event Report 269/97-03, concerning the post LOCA boron dilution design basis not being met.

This is a supplemental report to include updated information with respect to the past operability status of one of the post LOCA boron dilution flow paths which includes valves LP-1 and LP-2 on all three units. Also, a planned corrective action was revised. This report is being submitted in accordance with 10 CFR 50.73 (a) (2) (ii). This event is considered to be of no significance with respect to the health and safety of the public.

Very truly yours,



W. R. McCollum, Jr.

/fts

Attachment

9711170180 971112
PDR ADOCK 05000269
S PDR



Document Control Desk

November 12, 1997

Page 2

cc: Mr. Luis A. Reyes
Administrator, Region II
U.S. Nuclear Regulatory Commission
61 Forsyth Street, SW, Suite 23T85
Atlanta, GA 30303

Mr. D. E. LaBarge
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

INPO Records Center
700 Galleria Parkway, NW
Atlanta, GA 30339-5957

Mr. M. A. Scott
NRC Resident Inspector
Oconee Nuclear Station